

Weston & Sampson

westonandsampson.com

55 Walkers Brook Drive, Suite 100 Reading, MA 01867 tel: 978.532.1900

.....

STORMWATER MANAGEMENT

PLAN

MS4 GENERAL PERMIT COMPLIANCE



JUNE 2021

TOWN OF Hopedale MASSACHUSETTS



TABLE OF CONTENTS

Page

TABLE OF CONTENTS			
LIST OF TABLES			
LIST OF APPENDICESiv			
CERTIFICATION			
1.0INTRODUCTION / OVERVIEW.1-11.1Regulatory Summary and Purpose.1-11.2Town Governance and Structure.1-21.3Town Demographic Information.1-31.4Water Resources.1-31.5Interconnections.1-61.6Endangered Species and Historic Properties Determination.1-71.7Increased Discharges.1-71.8Surface Water Drinking Supplies.1-8			
2.0MINIMUM CONTROL MEASURES2-12.1Introduction2-12.2Permit Requirements and Implementation Timeframes2-12.2.1Public Education and Outreach2-12.2.2Public Involvement / Participation2-32.2.3Illicit Discharge Detection and Elimination2-42.2.4Construction of Site Stormwater Runoff Control2-82.2.5Post-Construction Stormwater Management2-92.2.6Pollution Prevention / Good Housekeeping.2-11			
3.0 REGULATORY STANDARDS. 3-1 3.1 Introduction 3-1 3.2 Existing Stormwater Regulatory Mechanisms. 3-1 3.2.1 Discharges to the Municipal Storm Drain System 3-1 3.2.2 Stormwater Management 3-2 3.3 Review of Regulatory Mechanisms for Compliance with the 2016 MS4 Permit. 3-2 3.3.1 Construction Site Stormwater Runoff Control 3-2 3.3.2 Post-Construction Stormwater Management 3-5			
4.0IDDE MONITORING AND PROGRESS4-14.1IDDE Plan4-14.1.1Mapping4-14.1.2Catchment Prioritization and Ranking4-24.1.3Field Investigation4-34.1.4Sanitary Sewer Overflows4-3			



STANDARD OPERATING PROCEDURES	5-1
MS4 Permit Requirement	5-1
Inventory of Municipal Facilities	5-1
Operation and Maintenance Procedures for Municipal Activities and Facilities	5-1
Catch Basin Cleaning and Optimization	5-2
TMDLS AND WATER OUALITY LIMITED WATERS	6-1
Discharges to Water Quality Limited Waters	6_1
Discridiges to water Quality Limited Waters	6 1
2.1 Total Maximum Daily Load for Nutrianta in the Upper/Middle Charles Diver	0-1
2.1 Total Maximum Daily Load for Nuthents in the Opper/Middle Charles River	0-2
2.2 Blackstone River Phosphorus Impairment	6-7
2.3 Public Education and Outreach	6-7
.2.4 Regulatory Updates	6-8
.2.5 Good Housekeeping and Pollution Prevention	6-8
.2.6 Phosphorus Source Identification	6-8
Bacteria Impairments	6-9
3.1 Public Education and Outreach	6-9
.3.2 Illicit Discharges	6-10
	7 4
MS4 Permit Reporting	
Evaluation of SWMP Success	7-1
Modifications to the SWMP or Notice of Intent	7-2
	 STANDARD OPERATING PROCEDURES. MS4 Permit Requirement

Weston & Sampson

LIST OF TABLES

Table 1.1	Parties Responsible for SWMP Implementation
Table 1.2	Receiving Waters and Impairments
Table 6.1	. Phosphorus Control Plan Phase 1 Components
Table 6.2	. Phosphorus Control Plan Phase 2 Components
Table 6.3	. Phosphorus Control Plan Phase 3 Components

westonandsampson.com

Weston & Sampson

.....

LIST OF APPENDICES

Appendix A	Definitions and Abbreviations
Appendix B	
Appendix C	
Appendix D	
Appendix E	
Appendix F	MS4 Checklists by Permit Year
Appendix G	Public Education Materials
Appendix H	Regulatory Mechanisms
Appendix I	Standard Operating Procedures
Appendix J	

Weston & Sampson

CERTIFICATION

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Printed Name CHRIS NADEAU Date 6-30-2021 Signature

westonandsampson.com

V

Weston & Sompson

1.0 INTRODUCTION / OVERVIEW

1.1 Regulatory Summary and Purpose

The Federal Water Pollution Control Act (WPCA), initially enacted in 1948, established ambient water quality standards to specify acceptable levels of pollution in lieu of preventing the causes of water pollution. The 1972 amendments to the WPCA, referred to as the Clean Water Act (CWA), implemented measures which were focused on establishing effluent limitations on point sources, or 'any discernable, confined, and discrete conveyance... from which pollutants are or may be discharged."

The 1972 CWA introduced the National Pollutant Discharge Elimination System (NPDES). The NPDES program was established as the fundamental regulatory mechanism of the CWA, requiring direct dischargers of pollutants into waters of the United States to obtain a NPDES permit. Between 1972 and 1987, the NPDES permit program focused on improving surface water quality by reducing pollutants of industrial process wastewater and municipal sewage. During this period, several nationwide studies on water quality, most notably the United States Environmental Protection Agency (EPA) National Urban Runoff Plan (NURP), identified stormwater discharges as a significant source of water pollution.

The results of the NURP and similar studies, resulted in the reauthorization of the CWA in 1987 with the passage of the Water Quality Act (WQA). The WQA established a legal framework and required EPA to develop a comprehensive phased program for regulating municipal and industrial stormwater discharges under the NPDES permit program.

The NPDES Phase 1 Rule, which was issued in November 1990, addressed stormwater dischargers from medium to large municipal separate storm sewer systems (MS4s), which were communities serving a population of at least 100,000 people, as well as stormwater discharges from 11 categories of industrial activity.

The NPDES Phase 2 Rule, which was promulgated in December 1999, addressed small MS4s serving a population of less than 100,000 people in urbanized areas. The Phase 2 Rule requires nationwide coverage of all operators of small MS4s that are located within the boundaries of the Bureau of the Census-defined "urbanized area" (UA) based on the latest decennial census. The Phase 2 rule requires that all MS4s located within "urbanized areas" automatically comply with the Phase 2 stormwater regulations. Appendix B of this report provides a map of the Phase II stormwater "permit compliance area" for Hopedale as determined by the USEPA using the latest decennial (year 2010) census. Since Hopedale is located within an urbanized area, the EPA has designated the Town of Hopedale as a Phase 2 Community, which must comply with the NPDES regulations. In the Commonwealth of Massachusetts, the EPA retains primacy as the Phase 2 permitting authority. On May 1, 2003, the EPA and the Massachusetts Department of Environmental Protection (MADEP) jointly issued the NPDES General Permit for Discharges from Small MS4s and in July 2003, Hopedale submitted the required Notice of Intent (NOI) for inclusion under this General Permit.

The 2003 NPDES Phase 2 MS4 General Permit (2003 MS4 Permit) required the Town of Hopedale to develop, implement, and enforce a Stormwater Management Program (SWMP). The objectives of the SWMP were to reduce the discharge of pollutants from the MS4 to the maximum extent practicable, to protect water quality, and to satisfy the appropriate water quality requirements of the CWA.

Weston & Sampson

TOWN OF HOPEDALE. MA

STORMWATER MANAGEMENT PLAN

This Stormwater Management Plan will specifically satisfy the requirements set forth by the NPDES Phase 2 regulations, which expanded Phase 1's efforts to preserve, protect, and improve the nation's water resources from polluted stormwater runoff to include additional operators of "traditional" (i.e. cities and towns) and "non-traditional" (i.e. Federal and state agencies) MS4s. The 2003 MS4 Permit expired on May 1, 2008 but was administratively continued for covered permittees until a new MS4 Permit was issued on April 4th, 2016 and became effective on July 1, 2018. A copy of the 2016 MS4 Permit is included in Appendix C. On May 3, 2019, the Town submitted a Notice of Intent to EPA to obtain coverage under the 2016 MS4 Permit. A copy of this Notice of Intent is included in Appendix D. EPA posted the Town's Notice of Intent for public comment on May 6, 2019 for a 30-day period. The Town received authorization from EPA to discharge under the 2016 MS4 Permit on May 24, 2019. A copy of the Town's Authorization to Discharge is included in Appendix D.

Since the Town of Hopedale was previously covered under the 2003 Small MS4 General Permit, the Town currently has many practices and programs in place related to stormwater management and pollution prevention. This plan coordinates and incorporates these programs, policies, guidelines and practices into one document and expands their reach to encompass the requirements and goals of the 2016 MS4 Permit. The objectives of the MS4 Permit are accomplished through the implementation of Best Management Practices (BMPs) for each of the following six minimum control measures.

- Public education and outreach
- Public involvement / participation
- Illicit discharge detection and elimination
- Construction site stormwater runoff control
- Post-construction stormwater management in new development or redevelopment
- Pollution prevention/good housekeeping

The Town's efforts to comply with these BMPs, as outlined in their Notice of Intent, are included in Section 2.0.

1.2 Town Governance and Structure

The Town of Hopedale has a Representative Town Meeting form of government. There is a Town Moderator who presides over the Town Meetings. The executive branch of the Government is led by a Board of Selectmen, who then appoint a Town Manager. The present-day duties of the Town Manager include proper administration of all town affairs. The Highway Department is responsible for maintaining town roads and drainage infrastructure.

Various entities within the Town have the responsibility for implementation of the MS4 Permit requirements as outlined in this plan and include the following:

- Highway Department
- Board of Health
- Planning Board
- Conservation Commission

Weston (&) Sampson

Specific representatives from each of these departments or committees that are responsible for implementation of the SWMP are outlined in the table below:

Table 1.1 PARTIES RESPONSIBLE FOR SWMP IMPLEMENTATION			
Name	Title	Affiliation	
Diana Schindler	Town Administrator	Selectmen	
Christopher Nadeau	Director	Highway Department	
Don Howes	Chair	Board of Health	
Stephen Chaplin	Vice Chair	Planning Board	
Becca Solomon	Chair	Conservation Commission	

1.3 Town Demographic Information

Hopedale is located in Worcester County and has a total area of 5.3 square miles (13.8 square kilometers). It is bordered by Milford to the northeast, Bellingham to the southeast, Mendon to the southwest, and Upton to the northwest. As of the 2010 census, the population was recorded at 5,852.

Territory comprised of densely settled tracts and adjacent urban developed areas that meet the minimum population requirements set forth by the EPA, according to the 2000 and 2010 census data, shall be referred to as urbanized area. Rural land uses and sparsely populated tracts shall be categorized as non-regulated for the purposes of the MS4 permit. Hopedale is entirely comprised of urbanized area (UA) as shown in the regulated area map in Appendix B and only 3.8% of the town is water.

No primary U.S. or state highways are located within the boundaries of Hopedale. There are secondary state highways within the Town of Hopedale, such as Route 16 running east to west, and Route 140, running north to south. There are approximately 2.8 miles of state-maintained roadways within town.

Climate within the Town of Hopedale ranges from January average minimum temperature of 13 degrees Fahrenheit (°F) to July average maximum temperature of 84°F. The average annual precipitation is 38.5 inches, distributed throughout the year. The rainiest month span is mid-May to mid-June, with approximately 3.6 inches of rain.

1.4 Water Resources

The majority of the Town is within the Blackstone River Watershed, although no outfalls discharge directly to the Blackstone River. A portion of Hopedale is located within the Charles River Watershed. There are the 4 main bodies of water in the Town of Hopedale. These include Hopedale Pond (MA51-35), Spindleville Pond (MA51158), Mill River (MA51-35) and the Charles River (MA72-07). The Charles River flows northwest along the south eastern side of town.

Weston (&) Sampson

Three of the four primary waters are impaired for several factors according to the Final 2014 303(d) list of Impaired Waters which include the Charles River (MA51-06), Hopedale Pond (MA51-35) and the Mille River (MA51-35). All impairments and outfalls discharging to these water bodies, and other receiving waters, are summarized in Table 1.2. Outfalls discharging to these waters of the United States are considered regulated under the MS4 Permit. When dry weather outfall screening is conducted, field verification will be used to confirm the regulated status of each outfall, and this table will be updated accordingly, as needed. Outfalls included in the table are believed to be under the Town's jurisdiction. However, if any of these outfalls are determined to be private or under the jurisdiction of another state entity in the future, they will be removed.

Table 1.2 RECEIVING WATERS AND IMPAIRMENTS			
Waterbody	Impairment	Number of Outfalls Discharging to Receiving Water	
Charles River (MA51-06)	DDT, Excess Algal Growth, Organic Enrichment (Sewage) Biological Indicators	3	
Hopedale Pond (Formally MA51065 now part of MA51- 35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue	16	
Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue	9	
Spindleville Pond (MA51158)		4	
Unnamed Stream near Cutler Street, Driftway Street, and Dutcher Street		4	
Unnamed Stream between Jones Road and Tammie Road		2	
Unnamed Stream off Steel Road		1	
Wetland off Centennial St		1	
Unnamed Stream off Briarcliff Road cul-de-sac		1	
Wetland area off of Oakview Lane and Greene Street		4	
Wetland area on Green St north of Birch Circle		1	
Wetland area off Haven Way		1	
Wetland area off Harmony Trail and Larkin Lane		2	
Wetland area between Larkin Lane, Harmony Trail and Liberty Circle		5	
Wetland area off Country		1	



Club Lane	
Unnamed Stream on Heron Lane	3
Unnamed Stream off Larkin Lane by Mill Street	1
Wetland area off Plain Street and Mill Street	1
Wetland area off Airport Road	1
Wetland off Plain Street near Mellen Street	1
Wetland off Thayer Street	1
Wetland areas around Anthony Road and Condon Way	3
Unnamed stream off Francis Road	1
Wetland area off of Richard Road	1
Wetland area off of Ben's Way	1
Wetland area off Greene Street and Hopedale Street	5
Wetland area off Patrick Road and Westcott Road	3
Wetland area off Hammond Road	2
Wetland area/unnamed stream between Gaskill Circle, Westcott Road, and Bancroft Park	2
Unnamed Steam off of Lampworth Circle	1
Wetland area between Tillotson Road and Moore Road	2
Unnamed stream off Whitney Road	1
Unnamed Stream at the end of Westcott Road	1
Unnamed Stream/Wetland area near Freedom Street	2
Mendon Street Interconnections	9

westonandsampson.com

Weston & Sampson

1.5 Interconnections

The Town of Hopedale has identified nine (9) locations where the Town's MS4 discharges to or receives flow from another MS4 under another entity's jurisdiction. The catchments associated with these junction points have been delineated. These interconnects are included on the town-wide drainage map located at the end of this section and summarized in Table 1.3.

Table 1.3 INTERCONNECTIONS			
Interconnection and/or Drainage Area ID	Connecting Municipality	Receiving Water	Impairment
IT001	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT002	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT003	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT004	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT005	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT006	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT007	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT008	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue
IT009	Interconnection with State Drainage	Mill River (MA51-35)	Non-Native Aquatic Plants, Macrophytes, Metal, PCB in Fish Tissue

Weston & Sampson

1.6 Endangered Species and Historic Properties Determination

The 2016 MS4 Permit requires that Hopedale demonstrate that all activities regulated under this permit will not adversely affect endangered and threatened species or critical habitat, or impact federal historic properties on the National Register of Historic Properties (NRHP). The Town must demonstrate that there is no critical habitat for any endangered species within its boundaries, and if such a habitat exists, that no best management practice shall interfere with that habitat. Hopedale must also certify that no discharge will affect a property that is listed or eligible for listing on the NRHP, that any such effects have written acknowledgements from the State Historic Preservation Officer (SHPO), Tribal Historic Preservation Officer (THPO), or other representative that such effects shall be mitigated, and written proof that any best management practices constructed under this permit will include measures to minimize harmful effects on these properties.

Through consultation with the US Fish & Wildlife Service (USFWS), it was determined that the only threatened species within Hopedale is the northern long-eared bat. Correspondence with USFWS is appended to the Town's Notice of Intent included in Appendix D. Actions currently included in this SWMP will not affect this species. Therefore, the Town has determined that it can certify eligibility under USFWS Criterion C for coverage under the permit. Prior to construction of any structural BMPs, the Town will consult with USFWS to confirm that the proposed project will not impact the northern long-eared bat or any other endangered or threatened species that may be identified in the future.

The Town has two federal historic properties, the Bancroft Memorial Library (99000188) and the Hopedale Village Historic District (02000635). Hopedale can certify eligibility under NHPA Criterion A on their Notice of Intent for coverage under the permit because the Town was previously covered under the 2003 MS4 Permit, and conditions have not changed since that determination. Prior to construction of any structural BMPs, the Town will consult with the State Historic Preservation Officer by submitting a completed Project Notification Form to confirm that the proposed project will not impact any federal historic properties.

1.7 Increased Discharges

Any increased discharges (including increased pollutant loadings) through the MS4 to waters of the United States are subject to the Massachusetts antidegradation regulations of 314 CMR 4.04. Section 2.1.2 of the 2016 MS4 Permit requires the Town of Hopedale comply with the provisions of 314 CMR 4.04 including information submittal requirements and obtaining authorization for increased discharges where appropriate. Any authorization by MassDEP for an increased discharge is required to be incorporated into this SWMP.

The Town understands that there shall be no increased discharges, including increased pollutant loadings from the MS4 to impaired waters listed in categories 5 or 4b on the most recent Massachusetts Integrated Report of Waters listed pursuant to Clean Water Act section 303(d) and 305(b) unless the Town demonstrates that there is no net increase in loading from the MS4 to the impaired water of the pollutant(s) for which the waterbody is impaired. If necessary, the Town of Hopedale will demonstrate compliance with this provision by either:

• Documenting that the pollutant(s) for which the waterbody is impaired is not present in the MS4's discharge and retaining documentation of this finding with the SWMP; or

Weston & Sampson

• Documenting that the total load of the pollutant(s) of concern from the MS4 to any impaired portion of the receiving water will not increase as a result of the activity and retain documentation of this finding in the SWMP. Unless otherwise determined by the Permittee, USEPA or by MADEP that additional demonstration is necessary, compliance with the requirements of Part 2.2.2 and Part 2.3.6 of this permit, including all reporting and documentation requirements, shall be considered as demonstrating no net increase as required by this part.

1.8 Surface Water Drinking Supplies

Section 3.0 of the MS4 Permit requires permittees to prioritize discharges to public drinking water supply sources in implementation of the SWMP. Hopedale does not have any surface drinking water supply sources. The closest surface drinking water supply is located in Milford's Echo Lake. There is a Zone A Protection Area located around this resource. Hopedale is southwest of Milford and Echo Lake is located in northeastern corner of Milford. The Town of Hopedale does not have any stormwater outfalls that discharge directly to Echo Lake within regulated areas.

2.0 MINIMUM CONTROL MEASURES

2.1 Introduction

This section of the report provides a summary of the regulatory requirements for each of the six minimum control measures as defined under the MS4 General Permit by the EPA. It also provides a summary of those stormwater management practices that the Town currently employs. As part of the requirements of the Notice of Intent submitted to EPA on May 3, 2019, as included in Appendix D, the Town has established a list of the Best Management Practices (BMPs) that it plans to implement in order to comply with each of the six minimum control measures. These BMPs will be implemented over the next five years (i.e. the permit term). However, the Town will have up to 20 years to implement some of the permit requirements as indicated. The Town's progress with respect to implementation of the BMPs, and other stormwater related activities, are summarized in annual reports submitted to EPA in accordance with the MS4 Permit. Under the 2003 MS4 Permit, the Town made progress in compliance with the requirements of the 2016 MS4 Permit. Links to annual reports submitted between 2004 and 2018 are included in Appendix E.

The BMPs selected for each minimum control measure are summarized and briefly described in this section. Specific details for each BMP including measurable goals, implementation dates and individuals responsible for implementation are stated in each of the respective sections for each control measure in this plan. The Town Administrator, Highway Department, Board of Health, Planning Department and Conservation Commission will be responsible for implementation and/or future enforcement of each of the BMPs for the six minimum control measures.

Compliance with requirements of the permit related to water quality limited waters and approved TMDLs is included in Section 6.

Checklists outlining requirements for Permit Years 1 through 5 are included in Appendix F.

2.2 Permit Requirements and Implementation Timeframes

2.2.1 Public Education and Outreach

The public education and outreach minimum control measure requires the Town to make educational information available to the public and other stakeholders as specified by the permit. Hopedale has been participating in public education and outreach activities since the 2003 MS4 Permit was enacted.

Regulatory Requirement:

Section 2.3.2 of the 2016 MS4 General Permit requires permittees to "implement an education program that includes educational goals based on stormwater issues of significance within the MS4 area. The ultimate objective of a public education program is to increase knowledge and change behavior of the public so that pollutants in stormwater are reduced."

Weston & Sampson

Existing Town Practices:

Since the 2003 MS4 Permit became effective, the Town of Hopedale has started to implement several public education initiatives. Hopedale is working to provide public outreach to targeted audiences throughout the Town. As required in the new iteration of the permit, two targeted messages must be provided to the following audiences within five years, spaced at least one year apart:

- 1. Residents
- 2. Businesses, Institutions and Commercial Facilities
- 3. Developers (Construction)
- 4. Industrial Facilities

In order to accomplish this, the Town will implement the following BMPs:

BMP: Newspaper Articles/Press Releases/Meetings

Description: Include information in the Town's newspaper regarding Hopedale's stormwater management program specifically targeting residents and how they can impact stormwater and receiving water quality.

Targeted Audience: Residents

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Submit article for publication in the Town newspaper on how residents can impact stormwater and receiving water quality.

Implementation Timeframe: Completed during Permit Year 2 (FY2020).

BMP: Newspaper Articles/Press Releases/Meetings

Description: Include information in the Town's newspaper regarding Hopedale's stormwater management program specifically targeting businesses, institutions and commercial facilities and how they can impact stormwater and receiving water quality.

Targeted Audiences: Businesses, Institutions, and Commercial Facilities

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Submit article for publication in the Town newspaper on how businesses, institutions and commercial facilities can impact stormwater and receiving water quality.

Implementation Timeframe: Completed during Permit Year 2 (FY2020).

BMP: Brochures/Pamphlets

Description: Distribute brochures to prospective developers and contractors providing general information on stormwater management on construction sites and the Town's erosion and sediment control rules and regulations.

Targeted Audiences: Developers (construction)

Responsible Department/Parties: Planning Board

<u>Measurable Goals</u>: Distribute brochures/make brochures available at Town Hall to all prospective developers and maintain a list of all recipients.

Implementation Timeframe: Completed during Permit Year 3 (FY2021).

BMP: Brochure/Pamphlets

Description: Distribute educational materials to industrial properties regarding stormwater best management practices, including equipment inspection, waste disposal, dumpster maintenance, use and storage of de-icing materials, and parking lot sweeping.



Targeted Audiences: Industrial Facilities.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Distribute brochure during Permit Year 3 and maintain a list of all recipients. <u>Implementation Timeframe</u>: Completed during Permit Year 3 (FY2021).

BMP: Brochure/Pamphlets

<u>Description</u>: Distribute a flyer about proper septic system maintenance to septic system owners. Targeted Audiences: Residents

Responsible Department/Parties: Board of Health

Measurable Goals: Maintain a list of all recipients of the flyer.

Implementation Timeframe: Completed during Permit Year 3 (FY2021).

BMP: Brochure/Pamphlets

Description: Distribute brochure about the benefits of adopting low impact development practices such as disconnecting impervious surfaces.

Targeted Audiences: Businesses, Institutions, and Commercial Facilities

Responsible Department/Parties: Highway Department, Conservation Commission

<u>Measurable Goals</u>: Have Chamber of Commerce distribute brochures. Track number of brochures distributed.

Implementation Timeframe: To be completed during Permit Year 4 (FY2022).

BMP: Brochures/Pamphlets

Description: Promote LID practices such as installation of vegetated filter strips to treat stormwater onsite and infiltrate to offset impervious area created through development.

Targeted Audiences: Developers (construction)

<u>Responsible Department/Parties</u>: Highway Department, Board of Health, Conservation Commission <u>Measurable Goals</u>: Distribute brochures at Town Hall. Track number of brochures distributed. <u>Implementation Timeframe</u>: To be completed during Permit Year 5 (FY2023).

BMP: Brochures/Pamphlets

Description: Promote LID practices such as installing on-site stormwater treatment systems and reducing impervious area footprint.

Targeted Audiences: Industrial Facilities

<u>Responsible Department/Parties</u>: Highway Department, Board of Health, Conservation Commission <u>Measurable Goals</u>: Distribute brochures at Town Hall. Track number of brochures distributed. <u>Implementation Timeframe</u>: To be completed during Permit Year 5 (FY2023).

Public education materials utilized in the implementation of the Town's SWMP are included in Appendix G.

2.2.2 Public Involvement / Participation

Regulatory Requirement:

Section 2.3.3 of the 2016 MS4 Permit requires the permittee to "provide opportunities to engage the public to participate in the review and implementation of the permittee's SWMP." Public participation

Weston (&) Sampson

benefits the program by increasing public support, including additional expertise and involving community groups/organizations.

Existing Town Practices:

The Town of Hopedale is starting to become more proactive in providing opportunities for public participation and involvement in stormwater management practices. For the last few years, the Board of Health provides a Hazardous Waste Collection Day at the Hopedale Recycling Center every fall. These efforts provide opportunities for safe disposal and the Town monitors the amount of material collected at these events.

In addition to continuing the above practices, it is recommended that the Town allow for public review of this stormwater management plan, by posting on the Town's website. These BMPs and others that the Town has committed to are detailed below.

BMP: SWMP Review

Description: Stormwater Management Plan Review

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Allow annual review of stormwater management plan and posting of stormwater management plan on Town website.

Beginning Year of BMP Implementation: Completed during Permit Year 2 (FY2020), and will be continued for the duration of the permit.

BMP: Public Participation

Description: Recycling Program

Responsible Department/Parties: Board of Health

<u>Measurable Goals</u>: The Town will continue to accept recyclable materials at the Hopedale Recycling Center and continue to track material collected.

<u>Beginning Year of BMP Implementation</u>: Implemented during Permit Year 1 (FY2019) and will be continued thereafter annually.

BMP: Public Participation

Description: Hazardous Waste Collection Day

Responsible Department/Parties: Board of Health

<u>Measurable Goals</u>: The Town will continue to work with the Town's contracted waste hauler and the Board of Health to continue to sponsor a Hazardous Waste Collection day.

<u>Beginning Year of BMP Implementation</u>: Implemented during Permit Year 1 (FY2019) and has continued each year since and plans to be continued for future years.

2.2.3 Illicit Discharge Detection and Elimination

Regulatory Requirement:

Section 2.3.4 of the 2016 MS4 General Permit requires the permittee to develop a written Illicit Discharge Detection and Elimination (IDDE) program. The IDDE program is designed to "systematically find and eliminate sources of non-stormwater discharges to its municipal separate storm sewer system and implement procedures to prevent such discharges."

Weston (&) Sampson

Existing Town Practices:

Under the 2003 MS4 Permit, the Town of Hopedale mapped its outfalls and receiving waters, and also mapped some of its other drainage infrastructure located within the town. The IDDE Plan was developed in FY2020 and illicit discharge detection and elimination by-laws were adopted on May 22, 2021.

The Town will continue their efforts to enhance their existing IDDE program to meet the requirements of the 2016 permit. The requirements of the new MS4 Permit can be achieved through implementation of the following BMPs:

BMP: SSO Inventory

Description: Develop an inventory of where Sanitary Sewer Overflows (SSOs) have discharged to the Town's MS4 within the 5 years prior to the permit effective date, and update this inventory annually going forward. The inventory must include the following: SSO location, whether the discharge entered the MS4 or a surface water directly, date and time that the SSO occurred, estimated discharge volume, known or suspected cause of the discharge, and mitigation or corrective measures completed or planned with implementation timeframes.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Develop and maintain a list of SSOs, including corrective measures taken.

<u>Implementation Timeframe</u>: Completed during Permit Year 1 and updated annually (FY2020). Hopedale has not had any SSOs reported during Permit Years 1, 2 or 3.

BMP: Storm Sewer System Map

Description: Update drainage map in accordance with permit conditions and update annually during IDDE program implementation.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Update the Town's existing drainage map to include a full inventory of the Town's storm drain system including the following within 2 years of the permit effective date:

- all outfalls and receiving waters,
- open channel conveyances,
- interconnections with other MS4s,
- municipally owned stormwater treatment structures,
- impaired waterbodies (already mapped),
- and initial catchment delineations

Within 10 years of the permit effective date, this map shall also include:

- location of outfalls with an accuracy of +/- 30 feet (already mapped),
- all pipes,
- manholes (already mapped),
- catch basins (already mapped),
- refined catchment delineations, and
- municipal sanitary sewer system (already mapped).



In addition, EPA suggests adding, but does not require, the following information:

- storm and sanitary sewer material, size and age (some data already mapped),
- privately-owned stormwater treatment structures (some already mapped),
- septic systems and areas likely to be affected by septic leaching (where applicable),
- seasonal high-water table elevations,
- topography,
- orthography,
- alignments, dates and representation of illicit discharge remediation and locations of suspected, confirmed and corrected illicit discharges

Implementation Timeframe: Begin to update the map during Permit Year 2 and complete full system map within 10 years of the permit effective date (FY2020) (FY2030). The Town has in place a comprehensive map of their drainage system which has been updated to meet Year 3 requirements outlined above.

BMP: Written IDDE Program

<u>Description:</u> Create a written IDDE plan that documents all elements of the Town's IDDE Program, including program responsibilities and procedures, and meets the conditions of the permit.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Completed within 1 year of the permit effective date and continue to update SSO inventory annually.

<u>Beginning Year of BMP Implementation</u>: Completed during Permit Year 2 and will be continued for the duration of the permit (FY2020). This plan is available at the Highway Department.

BMP: Implement IDDE Program

Description: Implement catchment investigations according to program and permit conditions, including TV inspection, smoke testing and dye testing as needed to isolate and identify illicit connections.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Implement and enforce practices set forth in written IDDE plan and IDDE bylaw to be adopted. Track the number of illicit connections that are identified and removed annually. <u>Implementation Timeframe</u>: Begin investigations of problem catchments, where applicable, in Year 4, after IDDE plan is written and continue annually until completion in Year 10 (FY2020, FY2028).

BMP: Employee Training

Description: Train employees on IDDE Plan components and program implementation.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Conduct annual training on the Town's IDDE Program. Track the number of employees that receive training annually and the dates on which training is held.

Implementation Timeframe: Employee training was conducted during FY2021 and will continue annually for the duration of the permit. Training during Permit Year 2 was delayed due to COVID-19. Training during Permit Year 3 was completed in June of 2021.

BMP: Conduct Dry Weather Screening

Description: Conduct dry weather screening and sampling in accordance with outfall screening procedures and permit conditions.

2-6



Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Complete all dry weather screening and sampling within 3 years of the permit effective date. Track number of outfalls that are screened and sampled annually. **Implementation Timeframe:** To be completed in permit year 4 (FY2022).

BMP: Conduct Wet Weather Screening

<u>Description:</u> Conduct wet weather screening and sampling at outfalls/interconnections in catchments where System Vulnerability Factors are present in accordance with permit conditions. **Responsible Department/Parties:** Highway Department

<u>Measurable Goals</u>: Complete all wet weather screening and sampling within 10 years of permit effective date. Track number of outfalls that are screened and sampled annually.

Implementation Timeframe: Begin wet weather screening and sampling after dry weather screening is complete, and complete sampling no later than 10 years from permit effective date (FY2028).

BMP: Ongoing Screening

Description: Conduct Dry and Wet weather screening (as necessary).

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Complete ongoing outfall screening every five years upon completion of IDDE program implementation.

<u>Beginning Year of BMP Implementation</u>: To be performed once initial screening of outfalls and IDDE investigations are complete (FY2029).

BMP: Priority Ranking

Description: Assess and rank the potential for all catchments to have illicit discharges. Identify catchments with System Vulnerability Factors that will necessitate wet weather sampling.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Complete within 2 years of permit effective date. Update catchment prioritization (FY2020).

Beginning Year of BMP Implementation: To be performed once initial screening of outfalls and IDDE investigations are complete (FY2022)

BMP: Follow-up Ranking

Description: Update catchment prioritization and ranking as dry weather screening information becomes available.

Responsible Department/Parties: Highway Department

Measurable Goals: Complete within 4 years of permit effective date.

<u>Beginning Year of BMP Implementation</u>: To be performed once initial screening of outfalls and IDDE investigations are complete (FY2023)

BMP: Catchment investigation Procedures

Description: Develop written catchment investigation procedures and incorporate into IDDE Plan. **Responsible Department/Parties:** Highway Department

Measurable Goals: Complete within 18 months of the permit effective date.

Implementation Timeframe: Completed in FY2021 and will be updated annually.



2.2.4 Construction of Site Stormwater Runoff Control

Regulatory Requirement:

Section 2.3.5 of the 2016 MS4 Permit requires the permittee to create a program to "minimize or eliminate erosion and maintain sediment on site so that it is not transported in stormwater and allowed to discharge to a water of the US through the permittee's MS4." The permittee will conduct site plan reviews, site inspections and include procedures for public involvement.

Existing Town Practices:

Sediment and erosion control requirements are included in the Town's Zoning By-Laws. Division 5506.0, Soil Erosion and Sediment Control provides language on when a control plan is needed/required as part of the definitive site plan review package. It outlines drainage design standards, as well as erosion and sediment control requirements to minimize surface runoff velocity, maximize protection of disturbed areas from stormwater runoff, and retain sedimentation within the development site as early as possible following disturbances.

On May 22, 2021, the Town adopted Stormwater Bylaws and associated Rules and Regulations. Within the Stormwater Management Rules and Regulations, there is criteria that lays out what erosion and sediment controls are needed for projects with stormwater management permits.

BMP: Site Inspection and Enforcement of Erosion and Sediment Control (ESC) Measures

Description: Develop written site inspection and enforcement procedures identifying who is responsible for site inspections as well as who has authority to implement enforcement procedures, including sanctions to ensure compliance.

Responsible Department/Parties: Highway Department, Planning Board

<u>Measurable Goals</u>: Develop written procedures and continue to enforce erosion and sediment control measures and report on the number of site plan reviews, inspections and enforcements that occur annually.

Implementation Timeframe: Completed within 3 years of the permit effective date (FY2021).

BMP: Site Plan Review

Description: Develop written procedures for conducting site plan reviews, inspection and enforcement.

Responsible Department/Parties: Highway Department, Planning Board

<u>Measurable Goals</u>: Create and implement site plan review procedures and report on the number of site plan reviews conducted, inspections conducted, and enforcement actions taken annually.

Implementation Timeframe: Completed within 3 years of the effective date of the permit (FY2021).

BMP: Erosion and Sediment Control

Description: Review and update existing stormwater regulations as needed to include language that requires construction operators to implement a sediment and erosion control program that includes BMPs that are appropriate for conditions at the construction site. **Responsible Department/Parties**: Highway Department, Planning Board

Weston (&) Sampson

<u>Measurable Goals</u>: Continue to enforce existing sediment and erosion control requirements, and update regulations as needed within one year of the permit effective date.

Implementation Timeframe: Complete within 3 years of the effective date of the permit (FY2021).

BMP: Waste Control

Description: Review and update, as needed, the Town's existing stormwater regulations to ensure the control of wastes at construction sites, including but not limited to, discarded building materials, concrete truck wash out, chemicals, litter, and sanitary wastes.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Review and update the Town's existing regulations as needed, and implement.

Implementation Timeframe: Complete within 3 years of the effective date of the permit (FY2021).

2.2.5 Post-Construction Stormwater Management

Regulatory Requirement:

Section 2.3.6 of the 2016 MS4 Permit requires the permittee to require developers to "reduce the discharge of pollutants found in stormwater through the retention or treatment of stormwater after construction on new or redeveloped sites."

In this case, a site is defined as the "area extent of construction activities which includes but is not limited to the creation of new impervious cover and improvement of existing impervious cover."

New Development is defined as construction activity that results in a total earth disturbance area equal to or greater than one acre on land that did not have any impervious area before work began.

Redevelopment is defined as any construction activity that disturbs greater than or equal to one acre and does not meet the requirements to be designated as new development.

Existing Town Practices and Amendments:

The Town established bylaws related to drainage ways in Division 5503.0 in the Zoning bylaws. No more than 50% of such areas shall be developed and the remaining 50% shall remain as permanent restricted open space. Division 5504 – Stormwater Runoff discusses detention for each development, limitations on stormwater runoff, storage capacity, and design regulations.

The Town established separate Rules and Regulations for Stormwater Management, which are referenced in the Town's Stormwater Management Bylaw. These were established in May 2021 and are provided in the Appendix H. For all new development and redevelopment projects, stormwater management systems must meet the Town's retention standard of two inches, and must remove 80% of the average annual load of Total Suspended Solids, and 50% of the average annual load of Total Phosphorus, generated from the total post-construction impervious area on the site. On redevelopment sites, stormwater management systems shall also improve existing conditions, and all projects must consider and, unless impracticable, propose and implement Low Impact Development

Weston & Sampson

(LID) Best Management Practices. The Regulations also require sediment and erosion controls at construction sites, as well as the long-term operation and maintenance of BMPs.

In order to comply with the requirements of the 2016 MS4 Permit, the Town shall implement the following BMPs:

BMP: As-Built plans for on-site stormwater control

Description: The procedures to require submission of as-built drawings and ensure long term operation and maintenance will be a part of the SWMP.

Responsible Department/Parties: Highway Department

Measurable Goals: Require submission of as-built plans for completed projects.

Implementation Timeframe: To be completed within 4 ears of the permit effective date (FY22).

BMP: Target properties to reduce impervious areas

Description: Identify at least 5 permittee-owned properties that could be modified or retrofitted with BMPs to reduce frequency, volume, and pollutant loads associated with stormwater discharges, and update annually.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: This goal can be achieved through disconnecting impervious surfaces, introducing low impact development and green infrastructure practices, or re-defining zoning regulations to change, for example, maximum sizes of parking lots and lane widths. Report annually on progress and retrofitted properties targeted by this effort.

Implementation Timeframe: Complete within 4 years of the permit effective date, and report annually regarding the number of retrofits identified thereafter, to maintain at least 5 retrofits for the duration of the permit (FY2022).

BMP: Allow for Green Infrastructure

Description: Develop a report assessing existing local regulations to determine the feasibility of making green infrastructure practices allowable when appropriate site conditions exist.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Complete assessment and implement recommendations of the report, where feasible.

Implementation Timeframe: Complete within 4 years of the permit effective date (FY2022).

BMP: Street Design and Parking Lot Guidelines

Description: Develop a report assessing requirements that affect the creation of impervious cover. The assessment will help determine if changes to design standards for streets and parking lots can be modified to support low impact design options.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Complete assessment and implement recommendations of the report, where feasible.

Implementation Timeframe: Complete within 4 years of the permit effective date (FY2022).

BMP: Ensure the Requirements of the MA Stormwater Handbook are met

Description: Ensure any stormwater controls or management practices for new development and redevelopment meet the retention or treatment requirements of the permit and all applicable requirements of the Massachusetts Stormwater Handbook.



<u>Description</u>: Adoption, amendment, or modification of a regulatory mechanism to meet permit requirements.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Review, and update as needed, existing regulatory mechanism that governs postconstruction stormwater management to meet the retention and treatment requirements of the permit. <u>Implementation Timeframe</u>: Completed within 3 years of the permit effective date (FY2021).

2.2.6 Pollution Prevention / Good Housekeeping

Regulatory Requirement:

Section 2.3.7 of the 2016 MS4 Permit requires the permittee to "implement an operations and maintenance program for permittee-owned operations that has a goal of preventing or reducing pollutant runoff and protecting water quality from all permittee-owned operations."

This minimum control measure includes a training component and has the ultimate goal of preventing or reducing stormwater pollution from municipal activities and facilities such as parks and open spaces, buildings and facilities, vehicles and equipment, and providing for the long-term operation and maintenance of MS4 infrastructure.

Existing Town Practices:

Hopedale has a list of currently employed good housekeeping measures adopted during the 2003 MS4 Permit. Catch basins are cleaned every year. All roads are swept at least three times per year. The Town has expressed interest in reviewing and identifying any gaps in the current Subdivision, Zoning, and Stormwater Management Bylaw as they pertain to stormwater management. To accomplish this and meet the requirements of the 2016 MS4 Permit, the Town shall implement the following BMPs:

BMP: O&M Procedures

Description: Create written O&M procedures including all requirements contained in 2.3.7.a.ii for parks and open spaces, buildings and facilities, and vehicles and equipment.

Responsible Department/Parties: Highway Department, Park Commission, Local Schools

<u>Measurable Goals:</u> Complete and implement within two years of permit effective date.

Implementation Timeframe: Completed during Permit Year 3 (FY2021). The final O&M Plan is included in Appendix I of the SWMP.

BMP: Inventory all permittee-owned parks and open spaces, buildings and facilities, and vehicles and equipment

Description: Create inventory

<u>Responsible Department/Parties</u>: Highway Department, Park Commission, Local Schools <u>Measurable Goals</u>: Complete within two years of permit effective date and implement annually. <u>Implementation Timeframe</u>: Completed during Permit Year 3 (FY2021).

BMP: Infrastructure O&M

<u>Description</u>: Establish and implement program for repair and rehabilitation of MS4 infrastructure. <u>Responsible Department/Parties</u>: Highway Department



<u>Measurable Goals</u>: Complete within two years of permit effective date (FY2020). <u>Implementation Timeframe</u>: Completed during Permit Year 3 (FY2021).

BMP: Stormwater Pollution Prevention Plan (SWPPP)

Description: Create SWPPPs for maintenance garages, transfer stations, and other waste-handling facilities.

Responsible Department/Parties: Highway Department

Measurable Goals: Complete and implement within two years of permit effective date.

Implementation Timeframe: Completed during Permit Year 3 (FY2021).

BMP: Street Sweeping Program

<u>Description</u>: Sweep all streets and permitee-owned parking lots in accordance with permit conditions. <u>Responsible Department/Parties</u>: Highway Department

<u>Measurable Goals</u>: Sweep all streets and permittee-owned parking lots once per year in the spring. <u>Implementation Timeframe</u>: Completed and implemented within year 2 (FY2020). The Town continued to sweep each street at least twice during Permit Year 2.

BMP: Road Salt Use Optimization Program

Description: Establish and implement a program to minimize the use of road salt.

Responsible Department/Parties: Highway Department

Measurable Goals: Implement salt use optimization during de-icing season.

Implementation Timeframe: Completed within 3 year of the permit effective date (FY2021). The Town developed a written Standard Operating Procedure for Winter Road Maintenance, which includes a Road Salt Use Optimization Program. This SOP is included in Appendix I.

BMP: Inspection and maintenance of stormwater treatment structures

Description: Establish and implement inspection and maintenance procedures and frequencies. **Responsible Department/Parties**: Highway Department

Measurable Goals: Inspect and maintain treatment structures at least annually.

<u>Implementation Timeframe</u>: Inspection and maintenance of treatment structures to begin in Year 1 and to be completed annually thereafter (FY2019). Written inspection and maintenance procedures to be developed in Year 3 (FY2021). All known stormwater treatment structures were inspected during Year 3.

BMP: Catch Basin Cleaning

Description: Establish schedule for catch basin cleaning such that each catch basin is no more than 50% full and clean catch basins on that schedule.

Responsible Department/Parties: Highway Department

<u>Measurable Goals</u>: Clean catch basins on established schedule and report number of catch basins cleaned and volume of material removed annually.

Implementation Timeframe: Completed and implemented catch basin optimization plan within three years of permit effective date or prepare a schedule outlining when information will be collected to develop the Catch Basin Optimization Plan (FY2021). The Town continued to collect data to develop their optimization plan during Permit Year 2 and Year 3. A schedule will be developed to collect data needed to further develop the plan in Permit Year 4 (FY2022).



3.0 REGULATORY STANDARDS

3.1 Introduction

In order to prevent pollutants from entering the drainage system and being discharged to the environment with stormwater, Hopedale will be implementing a wide variety of Best Management Practices (BMPs) categorized under the six minimum control measures as discussed earlier in this document. The control measures for Illicit Discharge Detection and Elimination, Construction Site Stormwater Runoff Control, and Post-Construction Stormwater Management are focused on improving stormwater pollution prevention into the future through implementation of the following:

- Regulatory mechanisms establishing legal authority, prohibitions and requirements
- Design and construction standards governing stormwater infrastructure
- Requirements for long-term Operation and Maintenance (O&M) of structural BMPs.

3.2 Existing Stormwater Regulatory Mechanisms

Under the 2003 MS4 Permit, the Town developed new rules and regulations to comply with the permit, and updated their existing regulations, as needed, to improve stormwater management town wide. The requirements adopted were progressive, and in some cases, exceeded the permit requirements.

3.2.1 Discharges to the Municipal Storm Drain System

Hopedale adopted their Illicit Discharge Detection and Elimination Bylaw on May 22, 2021. This Bylaw dictates what and who can discharge to the municipal drain system. The objectives of this bylaw are:

- 1. To prevent pollutants from entering the Town of Hopedale's municipal storm drain system;
- 2. To prohibit illicit connections and unauthorized discharges to the Town's municipal storm drain system;
- 3. To require the removal of all such illicit connections;
- 4. To comply with state and federal statutes and regulations relating to stormwater discharges; and
- 5. To establish the legal authority to ensure compliance with the provisions of this bylaw through inspection, monitoring, and enforcement.

This bylaw provides the legal authority to implement and enforce the IDDE Plan developed by the Town. A copy of this bylaw is included in Appendix H. Its main purpose is to prevent any introduction of pollutants to Hopedale's MS4 from stormwater discharges by any user, prohibit illicit connections to the MS4, and to allow the Town to monitor the system and remove any found illicit connections. The bylaw is adopted under the authority granted by the Home Rule Amendment of the Massachusetts Constitution and the Home Rule Procedures Act, and pursuant to the Clean Water Act. The Department of Public Works is responsible for enforcement and has the authority to investigate suspected illicit discharges. The Town has the authority to suspend or terminate the right to discharge to the MS4 of any discharger, including discharges associated with active construction sites. The ordinance mandates that in the case of a spill, that may result in the discharge of pollutants to the municipal drainage system or water of the Commonwealth, the person shall take all necessary steps

Weston & Sampson

to ensure containment, and cleanup of the release. In the event of a release of oil or hazardous materials, the person shall immediately notify the municipal fire and police departments.

3.2.2 Stormwater Management

Hopedale recently adopted their first iteration of the Stormwater Management By-law on May 22, 2021, and can be found in Appendix H of this SWMP. The Stormwater Management By-law is administered by the Planning Board, or its designated Stormwater Officer. This bylaw is applicable to any alteration, disturbance, development or redevelopment that will "disturb equal to or greater than three quarters (3/4) of an acre of land or will disturb less than three quarters (3/4) of an acre of land but is part of a larger common plan of development or sale that will ultimately disturb equal to or greater than three quarters (3/4) of an acre of land draining to the Town of Hopedale's municipal separate storm sewer system without a Stormwater Permit from the [Planning] Board. Construction activity does not include routine maintenance that is performed to maintain the original line and grade, hydraulic capacity, or the original purpose of the site."

3.2.3 Stormwater Management Rules and Regulations

The Town also established separate Rules and Regulations for Stormwater Management, which are referenced in the Stormwater Management By-law, which can also be found in Appendix H of this SWMP. For all new development and redevelopment projects, stormwater management systems must meet the Town's retention standard, and must retain two inches of runoff volume, remove 80% of the average annual load of Total Suspended Solids, and 50% of the average annual load of Total Phosphorus, generated from the total post-construction impervious area on the site. On redevelopment sites, stormwater management systems shall also improve existing conditions, and all projects must consider and, unless impracticable, propose and implement Low Impact Development (LID) Best Management Practices. The Regulations also require sediment and erosion controls at construction sites, as well as the long-term operation and maintenance of BMPs.

3.3 Review of Regulatory Mechanisms for Compliance with the 2016 MS4 Permit

A comprehensive review was conducted to evaluate what portions of the Town's existing regulatory mechanisms for construction and post-construction stormwater management comply with the 2016 MS4 Permit requirements, and identify what modifications are needed to bring the Town into compliance.

3.3.1 Construction Site Stormwater Runoff Control

The 2016 MS4 Permit builds on the requirements of the 2003 MS4 Permit for construction site runoff control and requires the following (Year 1 requirements):

Site Inspection & Enforcement

<u>Permit Requirement</u>: Development of written procedures for site inspections and enforcement of sediment and erosion control measures. These procedures shall clearly define who is responsible for site inspections as well as who has authority to implement enforcement procedures. The program shall



provide that the permittee may, to the extent authorized by law, impose sanctions to ensure compliance with the local program. These procedures and regulatory authorities shall be documented in the SWMP.

Hopedale's Regulations that Support Permit Requirement/Required Updates for Compliance:

As stated above, Hopedale recently adopted it's Stormwater Management Bylaws on May 22, 2021. Within this bylaw, Stormwater Management Rules and Regulations are referenced within. Under *Section 10, Inspections* in the Rules and Regulations, explicit language outlines the inspection and enforcement procedures for a Stormwater Management Permit and erosion and sediment controls during construction. During construction inspections the Planning Board's agent, designee, or professional engineer who has been approved by the Board shall conduct inspections. Section 10.B states "Inspection of the project site shall be at the following stages, at a minimum:

- A) Initial site inspection
- B) Stormwater Management System: The completed stormwater management system, or any component thereof, prior to backfilling of any underground drainage or stormwater conveyance structures.
- C) The physical markers showing the limits of land disturbance shall be inspected daily.
- D) Erosion and Sediment Control Plan: At least once every 7 calendar days and within 24 hours of the end of a storm event of 0.5 inches or greater, from the start of construction until the site is permanently stabilized. Inspection frequency may be reduced to at least once a month if the site is temporarily stabilized or runoff is unlikely due to winter conditions (e.g., site is covered with snow, ice, or the ground is frozen). The permittee is required to notify the Board of any change in inspection frequency, including termination of inspections due to site stabilization.
- E) If a project requires a Stormwater Pollution Prevention Plan (SWPPP) per the NPDES General Permit for Storm Water Discharges from Construction Activities (Construction General Permit), then the permittee is required to submit all Inspection Reports to the Board. If the Inspection Reports meet the requirements of the Construction General Permit, it will be considered equivalent to the Erosion and Sediment Control Inspection as described above."

Detailed language is provided in Section 10 of the Stormwater Rules and Regulations related to erosion and sediment control inspections and the inadequacy of Stormwater Management System and Erosion and Sediment Control Plan. There is a requirement in Section 7 of the Rules & Regulations that states that all projects shall comply with the Stormwater Management Handbook, with explicit reference to erosion and sedimentation control performance criteria. A copy of the Rules and Regulations are in Appendix H.

The Town plans to develop the Standard Operating Procedures (SOP) for inspection of construction sites, including sediment and erosion control measures in Permit Year 4 (FY2022).

Sediment and Erosion Control BMPs

<u>Permit Requirement</u>: Requirements for construction site operators performing land disturbance activities within the MS4 jurisdiction that result in stormwater discharges to the MS4 to implement a sediment and erosion control program that includes BMPs appropriate for the conditions at the construction site. The program may include references to BMP design standards in state manuals, such as the Massachusetts Stormwater Handbook or design standards developed by the MS4. EPA supports and encourages the use of design standards in local programs. Examples of appropriate sediment and erosion control measures for construction sites include local requirements to:

Weston & Sampson

TOWN OF HOPEDALE. MA

STORMWATER MANAGEMENT PLAN

- Minimize the amount of disturbed area and protect natural resources
- Stabilize sites when projects are complete, or operations have temporarily ceased
- Protect slopes on the construction site
- Protect all storm drain inlets and armor all newly constructed outlets
- Use perimeter controls at the site
- Stabilize construction site entrances and exists to prevent off-site tracking
- Inspect stormwater controls at consistent intervals

Excerpts from Hopedale's Regulations that Support Permit Requirement

Hopedale has language in their Zoning Bylaws which requires the development of a soil erosion and sedimentation control plan. This regulation is included in Appendix H. In Section 16 Division 5506.0.D the Town of Hopedale suggests that the Massachusetts Conservation Guide, Volume I – Erosion and Sediment Control in Site Development be used to comply with this requirement, provided that the zoning officer specifically determines that it complies with Division 5506.0 of the Zoning Bylaws.

Appendix B of Hopedale's Stormwater Management Rules and Regulations outline what is required of a Stormwater Management Permit. A project narrative with a description of how and where erosion and sedimentation controls will be implemented is required as well as a Proposed Conditions Plan which indicates proposed erosion controls and materials. Appendix C of Hopedale's Stormwater Management Rules and Regulations outline what is required in the Erosion and Sediment Control Plan. Included in this appendix is what the Erosion and Sediment Control Plan shall contain, what the design requirements are, and what content needs to be provided.

Control of Wastes

<u>Permit Requirement</u>: Requirements for construction site operators within the MS4 jurisdiction to control wastes, including but not limited to, discarded building materials, concrete truck wash out, chemicals, litter, and sanitary wastes. These wastes may not be discharged to the MS4.

Excerpts from Hopedale's Regulations that Support Permit Requirement:

Currently, no language to support this permit requirement exists. Language should be drafted to satisfy the requirements of the permit. Suggested language includes that "an applicant must develop a plan to control wastes that lists the construction and waste materials expected to be generated or stored on the construction site. These wastes include, but are not limited to discarded building materials, concrete truck washout, chemicals, litter, sanitary waste and material stockpiles. An applicant must also describe in narrative form the Best Management Practices that it will utilize to reduce pollutants from these materials including storage practices to minimize exposure of the materials to stormwater." The Town should add language to their Rules and Regulations to address the waste that construction operators must control on site.

Site Plan Review Inspection and Enforcement

<u>Permit Requirement</u>: Development of written procedures for site plan review, inspection and enforcement. The site plan review procedure shall include a pre-construction review by the permittee of the site design, the planned operations at the construction site, planned BMPs during the construction phase, and the planned BMPs to be used to manage runoff created after development. The review procedure shall incorporate procedures for the consideration of potential water quality impacts, and

procedures for the receipt and consideration of information submitted by the public. The site plan review procedure shall also include evaluation of opportunities for use of low impact design and green infrastructure. When the opportunity exists, the permittee shall encourage project proponents to incorporate these practices into the site design. The procedures for site inspection conducted by the permittee shall include the requirement that inspections occur during construction of BMPs as well as after construction of BMPs to ensure they are working as described in the approved plans, clearly defined procedures for inspections including qualifications necessary to perform the inspections, the use of mandated inspections forms if appropriate, and procedure for tracking the number of site reviews, inspections, and enforcement actions.

Excerpts from Hopedale's Regulations that Support Permit Requirements/Required Updates for Compliance

Currently, no language to support this permit requirement exists. Language should be drafted to satisfy the requirements of the permit, which includes the development of Standard Operating Procedures for site plan review, inspection and enforcement.

3.3.2 Post-Construction Stormwater Management

The 2016 MS4 Permit builds on the requirements of the 2003 MS4 Permit for post construction runoff from new development and redevelopment and requires the following (Year 2 requirements):

Low Impact Development

<u>Permit Requirement</u>: Low Impact Development (LID) site planning and design strategies must be used to the maximum extent feasible.

Hopedale's Regulations that Support Permit Requirement/Required Updates for Compliance:

Under Hopedale's Stormwater Management Rules & Regulations, projects needing Stormwater Management Permits must implement low-impact design (LID) practices to the maximum extent feasible. A list of LIP principles applicants must address in the project narrative are provided. Applicants not incorporating low-impact development practices into their plans must indicate why LID is not feasible for the site.

BMP Design Guidance

<u>Permit Requirement</u>: The design of treatment and infiltration practices should follow the guidance in Volume 2 of the Massachusetts Stormwater Handbook, as amended, or other federally or State approved BMP design guidance.

Excerpts from Hopedale's Regulations that Support Permit Requirement:

Under Hopedale's Stormwater Management Rules & Regulations, projects subject to Stormwater Management Permits must, at a minimum, "comply with the performance standards of the most recent version of the Massachusetts Stormwater Standards and accompanying Stormwater Management Handbook (Handbook)" (Section 7, p6). A few differences apply, but none that negate the intent of the Stormwater Management Handbook.

Weston (&) Sampson

Compliance with the Stormwater Management Standards for New Development

<u>Permit Requirement</u>: Stormwater Management systems on new development sites shall be designed to:

- Not allow new stormwater conveyances to discharge untreated stormwater in accordance with Massachusetts Stormwater Handbook Standard 1;
- Control peak runoff rates in accordance with Massachusetts Stormwater Handbook Standard 2;
- Recharge groundwater in accordance with Massachusetts Stormwater Handbook Standard 3;
- Eliminate or reduce the discharge of pollutants from land uses with higher pollutant loads as defined in the Massachusetts Stormwater Handbook in accordance with Massachusetts Stormwater Handbook Standard 5;
- Protect Zone 2 or Interim Wellhead Protection Areas of public water supplies in accordance with Massachusetts Stormwater Handbook Standard 6;
- Implement long term maintenance practices in accordance with Massachusetts Stormwater Handbook Standard 9;
- Require that all stormwater management systems be designed to:
 - 1. Retain the volume of runoff equivalent to, or greater than, one (1) inch multiplied by the total post-construction impervious surface area on the site;

AND/OR

2. Remove 90% of the average annual load of TSS generated from the total post-construction impervious surface area on the site AND 50 % of the average annual load of TP generated from the post-construction impervious surface area on the site. Pollutant removal shall be calculated consistent with EPA Region 1's Evaluation tool provided by EPA Region 1, where available. If EPA Region 1 tools do not address the planned or installed BMP performance any federally or State approved BMP design guidance or performance standards may be used to calculated BMP performance.

Excerpts from Hopedale's Regulations that Support Permit Requirement:

Section 7 of Hopedale's Stormwater Management Rules & Regulations outlines design standards, stating that projects "subject to a Stormwater Management Permit shall comply with the performance standards of the most recent version of the Massachusetts Stormwater Standards and accompanying Stormwater Management Handbook (Handbook), and the Town of Hopedale Drainage and Stormwater Design Standards" with three differences from the handbook. One of those differences states the following:

Stormwater Management Rules and Regulations, Appendix B.B: Design Standards Part 4.A "Stormwater management systems on new development and redevelopment sites shall be designed to:

- a) Retain the volume of runoff equivalent to, or greater than one (1) inch multiplied by the total post-construction impervious surface area on the site; and
- b) Remove 80% of the average annual load of Total Suspended Solids generated from the total post-construction impervious area on the site; and



c) Remove 50% if the average annual load of Total Phosphorus (TP) generated from he total post-construction impervious surface area on site.¹

Recommended Modification:

Footnote (1) meets the requirement that pollutant removal be calculated by EPA Region 1's Evaluation tool. If the Town wishes to continue to require the same standards for new and redevelopment, the requirement for TSS removal should be increased to 90%, though these standards are more stringent than what is required for redevelopment projects.

Compliance with the Stormwater Management Standards for Redevelopment

<u>Permit Requirement</u>: Stormwater management systems on redevelopment sites shall meet the following standards to the maximum extent feasible:

- Not allow new stormwater conveyances to discharge untreated stormwater in accordance with Massachusetts Stormwater Handbook Standard 1.
- Control peak runoff rates in accordance with Massachusetts Stormwater Handbook Standard 2;
- Recharge groundwater in accordance with Massachusetts Stormwater Handbook Standard 3;
- The pretreatment and structural best management practices requirements of Standards 5 (eliminate or reduce the discharge of pollutants from land uses with higher pollutant loads as defined in the Massachusetts Stormwater Handbook) and 6 (protect Zone 2 or Interim Wellhead Protection Areas of public water supplies in accordance with Massachusetts Stormwater Handbook Standard 6);
- Stormwater management systems on redevelopment sites shall also improve existing conditions by requiring that stormwater management systems be designed to:
- 1. Retain the volume of runoff equivalent to, or greater than 0.8 inch multiplied by the total postconstruction impervious surface area on the site;

AND/OR

2. Remove 80% of the average annual post-construction load of TSS generated from the total post-construction impervious area on the site AND 50% of the average annual load of TP generated from the total post-construction impervious surface area on the site. Pollutant removal shall be calculated consistent with EPA Region 1's Evaluation tool provided by EPA Region 1, where available. If EPA Region 1 tools do not address the planned or installed BMP performance any federally or State approved BMP design guidance or performance standards may be used to calculated BMP performance.

Weston (&) Sampson

¹ Per footnote (1) above, the required removal percentages are not required for each storm, it is the average removal over a year that is required. Pollutant removal shall be calculated consistent with the EPA's Region 1's BMP Performance Extrapolation Tool or other BMP performance evaluation tool provided by EPA Region 1, where available. If EPA Region 1 tools do not address the planned or installed BMP performance any federally or State approved BMP design guidance or performance standards (e.g. State stormwater handbooks and design guidance materials) may be used to calculate BMP Performance.

• Stormwater management systems on redevelopment sites may utilize offsite mitigation within the same USGS HUC10 as the redevelopment site to meet the equivalent retention or pollutant removal requirements indicated above.

Excerpts from Hopedale's Regulations that Support Permit Requirement:

Similar to the previously listed permit requirement, Hopedale's Stormwater Management Rules & Regulations do not distinguish between requirements for new development and redevelopment. If the Town wishes to continue to require the same standards for new and redevelopment, the requirement for TSS removal should be increased to 90%. If the Town's preference is to make a distinction between new and redevelopment, this section will need to be further modified.

Submission of As-Builts

<u>Permit Requirement</u>: The permittee shall require, at a minimum, the submission of as-built drawings no later than two (2) years after completion of construction projects. The as-built drawings must depict all on site controls, both structural and non-structural, designed to manage the stormwater associated with the completed site (post construction stormwater management).

Excerpts from Hopedale's Regulations that Support Permit Requirement:

Under Hopedale's Stormwater Rules and Regulations, as-builts shall be submitted no later than two (2) years from project completion and must be submitted prior to issuance of a Certificate of Completion. The as-built record drawings shall be submitted for all stormwater management facilities, practices and controls, and must be prepared and certified by a Professional Engineer.

Long-term Operation & Maintenance

<u>Permit Requirement</u>: The new development/redevelopment program shall have procedures to ensure adequate long-term operation and maintenance of stormwater management practices that are put in place after the completion of a construction project. These procedures may include the use of dedicated funds or escrow accounts for development projects or the acceptance of ownership by the permittee of all privately owned BMPs. These procedures may also include the development of maintenance contracts between the owner of the BMP and the permittee. Alternatively, these procedures may include the submission of an annual certification documenting the work that has been done over the last 12 months to properly operate and maintain the stormwater control measures. The procedures to require submission of as-built drawings and ensure long term operation and maintenances shall be a part of the SWMP.

Excerpts from Hopedale's Regulations that Support Permit Requirement:

Under Hopedale's Stormwater Management Rules & Regulations, Stormwater Management Permits must include an Operation and Maintenance Plan (O&M) to ensure compliance with the Stormwater Management Permit. Appendix D of the Stormwater Rules and Regulations provide the needed contents. Required components of the plan include the names and contact information of responsible parties, names responsible for financing maintenance and emergency repairs, maintenance schedule for all drainage structures, including swales and ponds, and a list of easements with the purpose and location of each. Additionally, the plan must be signed by the property owner and recorded with the Worcester County Registry of Deeds. The existing regulatory language meets this permit requirement as is.

Weston & Sampson

Phosphorous Impairment

<u>Permit Requirement</u>: For discharges to water quality limited water bodies and their tributaries where phosphorous is the cause of the impairment, the Town's regulatory mechanism for Stormwater Management in New Development and Redevelopment (Year 2 Permit Requirement), shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for phosphorus removal.

Recommended Modification:

There is currently no language in the Town's existing regulations that requires BMPs to be optimized for phosphorus removal. This language should be added and the Town should also have a methodology in place for evaluating BMP performance. The Town should consider adding the following statement, "To support compliance with the Town's MS4 Permit, all BMPs must be optimized for the removal of phosphorous. The justification and design of such BMPs must also include a methodology for assessing BMP performance. Pollutant removal shall be consistent with EPA Region 1's Evaluation tool."



4.0 IDDE MONITORING AND PROGRESS

4.1 IDDE Plan

Under the 2003 MS4 Permit, The Town of Hopedale established legal authority to prohibit illicit discharges, investigate suspected illicit discharges, eliminate illicit discharges, and implement enforcement procedures. Under the new MS4 Permit, the Town is required to implement their Illicit Discharge Detection and Elimination Investigation Program by presenting a defined approach to investigate, identify and remove illicit connections. The Town is required to develop the written plan in Year 1 and then continue to implement the plan throughout the permit term. The written plan was developed in Year 2 for the Town of Hopedale.

As part of Minimum Control Measure No. 3, Illicit Discharge Detection and Elimination (IDDE), the Town is required to implement an IDDE program to systematically find and eliminate sources of nonstormwater discharges to its MS4 and implement procedures to prevent such discharges. This includes, but is not limited to, the following measures:

- 1. Developing a comprehensive map of the Town's drainage system that builds upon the outfalls and receiving waters that were previously mapped under the 2003 MS4 Permit.
- 2. Ensuring that appropriate regulatory mechanisms and enforcement procedures, as required under the 2003 MS4 Permit, are in place to prohibit illicit discharges.
- 3. Developing and implementing a written plan to detect and eliminate illicit discharges, which references the Town's authority to implement all aspects of the IDDE program, clearly identifies responsibilities with regard to eliminating illicit discharges, and outlines written procedures for dry and wet weather outfall screening and sampling and catchment investigations.
- 4. Providing training annually to employees involved in the IDDE program about the program, including how to recognize illicit discharges and SSOs.

Such measures will be performed with the goal of finding and removing illicit discharges, which include fixed point source discharges such as illegal/improper sanitary or floor drain connections and cross connections between the sanitary and drainage infrastructure, in addition to all isolated or recurring discharges such as illegal dumping and improper disposal of waste from boats. Illicit Discharges could also be indirect sources that infiltrate into the drainage system through cracks/defects in infrastructure, such as sanitary wastes from failing sewer pipes. Exceptions do exist in the regulation for the discharge of clean water from sources such as water line flushing, fire-fighting operations, non-contact cooling waters, and for other discharges that have separately obtained a permit from the NPDES Program.

Hopedale has developed a comprehensive written IDDE Plan, under separate cover, to meet the requirements of the 2016 MS4 Permit.

4.1.1 Mapping

The Town has developed a comprehensive map of their drainage system, which include outfalls, pipes, manholes, catch basins, interconnections with other MS4s, municipally owned stormwater treatment structures and impaired water bodies. Outfalls and interconnections have been analyzed to create a defined catchment area that Includes surface runoff to catch basins tributary to the identified

4-1


outfall or interconnection. The catchment delineation process considers each catch basin upstream from the outfall or interconnection and the area that would conceivably drain to that catch basin based on topography and impervious cover. As drainage infrastructure mapping becomes more complete over the course of the investigations performed throughout the permit term, this exercise will be refined and updated.

Drainage Infrastructure under the Town's jurisdiction includes:

- 20.4 miles of gravity pipe/culverts ranging in size from 4-inches to 72-inches in diameter constructed of asbestos cement, brick, cast iron, corrugated metal, ductile iron, HDPE, PVC, vitrified clay, concrete, and reinforced concrete;
- 996 catch basins;
- 547 storm drain manholes;
- 163 municipal-owned outfalls;

Mapping has been in accordance with the 2016 MS4 Permit's accuracy guidelines and infrastructure has been recorded on a publicly available town map, the most recent version of which can be found in Appendix B.

Hopedale has reviewed drainage infrastructure within town boundaries to determine ownership. Private infrastructure or infrastructure owned and operated by another municipality or a state entity has been determined and designated in the Town's drainage GIS.

The mapping will serve as a planning tool for the implementation and phasing of the Town's IDDE Program and demonstration of the extent of complete and planned investigations and corrections. The Town will update their mapping as needed to reflect newly discovered information and required corrections or modifications. The Town will report annually on progress toward completion of the system map in their MS4 Annual Report.

4.1.2 Catchment Prioritization and Ranking

The Town will complete an initial inventory and priority ranking to assess the illicit discharge and SSO potential of each regulated catchment and the related public health significance. The ranking will determine the priority order for screening of outfalls and interconnections, catchment investigations for evidence of illicit discharges, and provide the basis for determining permit milestones. Major factors considered in the prioritization and ranking of catchments include:

- Past discharge complaints and reports
- Density of generating sites.
- Age of development and infrastructure
- Culverted streams
- Water body impairments

This inventory and ranking will be documented in the Town's IDDE Plan and will be updated annually throughout the permit term to reflect new findings from dry and wet-weather sampling and other IDDE program activities, and will be documented in the Town's MS4 Annual Reports.

westonandsampson.com

4-2



4.1.3 Field Investigation

The MS4 Permit requires the Town to develop a storm drain network investigation that involves systematically and progressively observing, sampling and evaluating key junction manholes in the MS4 to determine the approximate location of suspected illicit discharges or SSOs.

Once the source of an illicit discharge is approximated between two manholes, more detailed investigation techniques will be used to isolate and confirm the source of the illicit discharge. The following methods may be used in isolating and confirming the source of illicit discharges:

- <u>Sandbagging</u> If no flow is observed at a particular junction manhole or key junction manhole at the time of inspection, the drain segment in the area of concern can be isolated by placing sandbags within outlets to manholes to form a temporary dam that collects any intermittent flow for a 24 to 48-hour dry weather period to determine if any intermittent dry-weather flow is present. If intermittent flow is captured, grabs samples will be collected and analyzed at a minimum for ammonia, chlorine, and surfactants. If it is determined that no flow is captured behind the sandbag after a 24 to 48-hour period, the tributary drainage pipes can be excluded as the source of any intermittent discharge.
- <u>Dye Testing</u> dyed water is poured into plumbing fixtures and downstream drainage is observed to confirm connections.
- <u>ZoomCam Inspections</u> in selected tributary areas, or where indicated based on findings from other field investigation work, drainage structures will be inspected with a "zoom camera-on-a-stick" in an attempt to gather additional information and narrow the location of observed dryweather flow.
- <u>Smoke Testing</u> non-toxic smoke is introduced into drainage segments containing suspected illicit discharges and adjacent buildings are observed for signs of a connection, or smoke emanating from floor drains or sump pump connections.
- <u>CCTV/Video Inspections</u> drainage pipes are internally inspected to pinpoint and evaluate connections through the use of a closed-circuit television camera through all or a portion of the drain segment believed to contain the connection.

Upon location of an illicit discharge, the Town will work to eliminate the illicit discharge as expeditiously as possible. When the specific source of an illicit discharge is identified, the Town of Hopedale will exercise its authority as necessary to require its removal. The Town will notify all responsible parties of any such discharge and require immediate cessation of improper disposal practices in accordance with its legal authorities.

4.1.4 Sanitary Sewer Overflows

Sanitary Sewer Overflows (SSOs) are included in the MS4 Permit's definition of illicit discharges and can be defined as discharges of untreated sanitary wastewater from a municipal sanitary sewer that can contaminate surface waters, cause serious water quality problems and property damage, and threaten public health. SSOs can be caused by blockages, line breaks, power failures, vandalism, and sewer defects. This includes SSOs resulting during dry or wet weather, from inadequate conveyance capacities, or where interconnectivity of the storm and sanitary sewer infrastructure allows for communication of flow between the systems.

Weston (&) Sampson

Hopedale will maintain and update annually an inventory, that identifies all known locations where SSOs have discharged to the MS4 within the five (5) years prior to the effective date of the MS4 Permit (July 1, 2018), and any SSOs that have occurred thereafter. This includes SSOs resulting, during dry or wet weather, from inadequate conveyance capacities, or where interconnectivity of the storm and sanitary sewer infrastructure allows for transmission of flow between the systems. The inventory will include the following information, when available:

- Location (approximate street crossing/address and receiving water, if any);
- A clear statement of whether the discharge entered a surface water directly or entered the MS4
- Date(s) and time(s) of each known SSO occurrence (i.e., beginning and end of any known discharge);
- Estimated volume of the occurrence;
- Description of the occurrence indicating known or suspected cause(s);
- Mitigation and corrective measures completed with dates implemented; and
- Mitigation and corrective measures planned with implementation schedules.

Upon detection of an SSO, Hopedale will provide oral notice to EPA within 24 hours, a written notice to EPA within five (5) days and shall include the information in the updated inventory as identified above, and mitigate it as expeditiously as possible taking interim measures to minimize the discharge of pollutants to and from its MS4 until elimination is completed.

Hopedale has had three (3) SSO occurrence in the five years prior to the permit effective date and since the permit became effective. The first SSO occurred on March 22, 2014 at 14 Inman Street as a result of a sewer main that was clogged by an obstruction and there was a discharge to Hopedale Pond. The second SSO occurred on December 23, 2014 on Cutler Street due to a lift station power failure and there was a discharge to Hopedale Pond. The third SSO occurred on May 2, 2017 at 4 Cutler Street due to a hole in a 6-inch force main pipe at one of the Town's sewer lift stations and there was a discharge to Hopedale Pond.

The Town will maintain an SSO inventory as part of this plan and the Town's IDDE Plan. Information will also be included in the Town's MS4 Annual Reports, including the status of mitigation and corrective measures to address any identified SSOs, where applicable.

westonandsampson.com

Weston (&) Sampson

5.0 STANDARD OPERATING PROCEDURES

5.1 MS4 Permit Requirement

As part of the minimum control measure for Pollution Prevention/Good Housekeeping for Municipal Operations, the MS4 Permit requires permittees to implement an Operations and Maintenance (O&M) program for permittee-owned facilities and activities to prevent or reduce pollutant runoff and protect water quality. The O&M Program is required to include the following elements:

- 1) An inventory of all permittee-owned facilities.
- 2) Written O&M procedures for the following activities:
 - a. Parks and open space
 - b. Buildings and facilities where pollutants are exposed to runoff
 - c. Vehicles and equipment
- 3) A written program detailing the activities and procedures the permittee will implement so that MS4 infrastructure is maintained in a timely manner to reduce the discharge of pollutants from the MS4, to include:
 - a. Optimization of routine inspections, cleaning and maintenance of catch basins.
 - b. Implementation of procedures for sweeping and/or cleaning streets, and permitteeowned parking lots.
 - c. Proper storage and disposal of catch basin cleanings and street sweepings.
 - d. Implementation of procedures for winter road maintenance.
 - e. Implementation of inspection and maintenance frequencies and procedures for storm drain systems and stormwater treatment structures.
- 4) Written records for all maintenance activities, inspections and training.

5.2 Inventory of Municipal Facilities

Hopedale has developed a comprehensive Operation and Maintenance (O&M) Plan to meet permit requirements. The O&M Plan is included in Appendix I of the SWMP. The inventory of municipally owned facilities and property, including vehicles, equipment, and stormwater treatment structures is included as Appendix A of the O&M Plan.

5.3 Operation and Maintenance Procedures for Municipal Activities and Facilities

To address the MS4 Permit requirements, Standard Operating Procedures (SOPs) associated with the identified municipal activities and facilities are required to be developed within two years of the permit effective date, with the exception of procedures for winter road maintenance, which are required to be developed within one year of the permit effective date. The SOP for winter road maintenance, which includes snow removal and deicing, has been incorporated into Appendix I of this Stormwater Management Plan, as well as Appendix H of the Town's O&M Plan. All required SOPs mentioned above were developed during Year 3 and are appended to the Town's O&M Plan, which is included in Appendix I.

Weston (&) Sampson

5.4 Catch Basin Cleaning and Optimization

The Town currently has approximately 996 catch basins, which are cleaned on an annual basis. The Highway Department is responsible for the cleaning of all catch basins. A plan for proper disposal that is in accordance with state and local requirements is needed.

To meet anticipated requirements of the new MS4 Permit, the Town will need to optimize catch basin inspection, cleaning and maintenance such that the following conditions are met:

- Prioritization of inspection and maintenance of catch basins located near construction activities (roadway construction, residential, commercial, or industrial development or redevelopment). Catch basins in such areas must be cleaned more frequently if inspection and maintenance activities indicate excessive sediment or debris loading.
- A schedule must be established such that the frequency of routine cleaning ensures that no catch basin at any time will be more than 50 percent full. A catch basin sump is more than 50 percent full if the contents within the sump exceed one half the distance between the bottom interior of the catch basin to the invert of the deepest outlet of the catch basin.
- If a catch basin sump is more than 50 percent full during two consecutive routine inspections/cleaning events, the Town must document the finding, investigate the contributing drainage area for sources of excessive sediment loading, and to the extent practicable, abate contributing sources.
- The Town shall maintain documentation, including metrics and other information, used to reach the determination that the established plan for cleaning and maintenance is optimal and meets the requirements of the MS4 Permit, including a log of catch basins cleaned and inspected.
- The Town must continue to track and report the following information to EPA annually:
 - o Total number of catch basins town-wide
 - Number of catch basins inspected
 - o Number of catch basins cleaned
 - o Total volume or mass of material removed from all catch basins

The Town collected additional data during the 2020 cleaning season as part of their optimization plan to ensure that no catch basin is more than 50% full. Data collected includes depth from the catch basin rim to the top of water, to the top of sediment, to the bottom of the basin, and to the invert of the outlet pipe. Data was once again be collected during the 2021 catch basin cleaning season and included depth from the rim to the top of water and from the rim to the top of sediment. This data will be integrated into the Town's GIS and utilized to identify those catch basins that are filling up more frequently and will therefore need to be cleaned more than once annually to ensure that that catch basin sump is never more than 50% full .

The Town is working to collect sufficient data to include in the catch basin optimization plan. A schedule for collecting remaining data will be submitted with the Town's Year 3 Annual Report.



6.0 TMDLS AND WATER QUALITY LIMITED WATERS

6.1 Discharges to Water Quality Limited Waters

Under Massachusetts General Law (MGL) Chapter 21, MassDEP is responsible for monitoring the waters of the Commonwealth, identifying those waters that are impaired, and developing a plan to bring them back into compliance with Massachusetts Surface Water Quality Standards. The list of impaired waters, better known as the "303(d) list," identifies impaired surface waters and the reasons for impairment.

Once a waterbody is identified as impaired, MassDEP is required by the Federal Clean Water Act (CWA) to develop a strategy for restoring the health of the impaired waterbody. The process of developing this strategy, which is generally referred to as a Total Maximum Daily Load (TMDL) includes identifying the type of pollutant, and the potential sources of the pollutant, in addition to determining the maximum amount of pollutant that can be discharged to a specific surface water body in order to meet surface water quality standards. Part of the TMDL also includes the development of a plan to help in meeting the TMDL limits once they have been established. These impaired waters are listed under Category 4A in Part 2 of the Massachusetts Integrated List of Waters. There are currently two approved TMDLs that are applicable to Hopedale – all of which focus on bacteria and phosphorus impairments. These include the *Total Maximum Daily Load for Nutrients in the Upper/Middle Charles River and* the *Final Bacteria and Pathogen TMDL for the Upper/Middle Charles River.*

In addition to identifying water bodies for which a Total Maximum Daily Load has already been developed, the Integrated List of Waters also identifies the 303(d) List of Impaired Waters under Category 5. The 303(d) List identifies water bodies that are impaired for one or more designated uses and require the development of a TMDL.

6.2 Phosphorus Impairments

The 2016 MS4 Permit lists Hopedale as a municipality requiring compliance with an approved phosphorus TMDL for the Charles River and as having a phosphorus impairment without an approved TMDL. This phosphorus impairment without an approved TMDL refers to the Blackstone River (MA51-06). Hopedale is within the Blackstone River Watershed but does not have any direct discharges to the Blackstone River.

On June 10, 2011, EPA approved the *Total Maximum Daily Load for Nutrients in the Upper/Middle Charles River*. To address phosphorus in stormwater discharges and meet the waste load allocations outlined in these TMDLs, a Phosphorus Control Plan will need to be developed and implemented within 20 years of the permit effective date as outlined in Appendix F of the MS4 Permit. The permit indicates that Hopedale will have to reduce its phosphorus load by 35% to meet the established waste load allocation in these TMDLs. Hopedale's baseline phosphorus load is 107 kg/yr. The required phosphorus load reduction is 37 kg/yr to arrive at an allowable phosphorus load of 70 kg/yr. The waste load allocation is to be obtained through implementation of several structural and non-structural BMPs outlined in a three-phase Phosphorous Control Plan as detailed under Section 6.3.1.

westonandsampson.com

Weston & Sampson

6.2.1 Total Maximum Daily Load for Nutrients in the Upper/Middle Charles River

In order to comply with the TMDL for Nutrients in the Upper/Middles Charles River, the Town must create and implement a three-part Phosphorus Control Plan according to the schedule outlined below.

- Create a Phase 1 Phosphorus Control Plan within 5 years of the permit effective date.
- Implement the Phase 1 Phosphorous Control Plan and create a Phase 2 Phosphorous Control Plan within 5 years of the permit effective date.
- Implement the Phase 2 Phosphorus Control Plan and create a Phase 3 Phosphorus Control Plan within 15 years of the permit effective date.
- Implement the Phase 3 Phosphorous Control Plan within 20 years of the permit effective date.

Phase 1 of the Phosphorus Control Plan shall be drafted within 5 years of the permit effective date. It must include each of the following components to be completed by the dates associated with them:

Table 6-1: Phosphorus Control Plan Phase 1 Components

PCP Phase 1 Component	Completion Date
Legal Analysis – The Town must perform an assessment to ensure that the existing regulatory mechanisms of the Town support implementation of the PCP and update or create any bylaws and ordinances to effectively enact the entire plan.	2 years after the effective permit date - FY2020
<u>Funding Source Assessment</u> – The Town must describe all possible current and anticipated mechanisms that would be used to fund the PCP. The Town must describe in detail the steps taken to obtain such funding which may include conceptual development, outreach to affected parties, and development of legal authorities.	3 years after the effective permit date - FY2021
Define Scope of PCP – The Town must define the project area as either the entire area within the Town's jurisdiction or by all the urbanized area within the Town's jurisdiction that falls within the Charles River Watershed. In Hopedale's case, these are the same area. Within the PCP Area: The Baseline Phosphorus Load is 107 kg/yr The Stormwater Phosphorus Load Reduction Requirement is 37 kg/yr The Allowable Phosphorus Load is 70 kg/yr The Stormwater Percent Reduction in Phosphorus Load is 35%	4 years after the effective permit date - FY2022
<u>Describe Non-Structural Controls</u> – The Town must describe all non-structural controls to be implemented in the PCP. It must be detailed to include the planned measures, the area of implementation, and the annual	5 years after the effective permit date - FY2023



percent reduction expected from the BMP's effect. To calculate expected rate of phosphorus exported (P_{exp}), add the Allowable Phosphorus Load (P_{allow}) to the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.8 $P_{exp} \leq P_{allow} + (P_{RR} \times 0.8)$.	
<u>Describe Structural Controls</u> – The Town will perform a ranking assessment to determine priority areas to retrofit or develop structural BMPs to address phosphorus discharge. It must be detailed to include the planned measures, the area of implementation, and the annual percent reduction expected from the BMP's effect. To calculate expected rate of phosphorus exported (P_{exp}), add the Allowable Phosphorus Load (P_{allow}) to the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.75 $P_{exp} \leq P_{allow} + (P_{RR} \times 0.75)$. If the Town decides to hire a contractor to install the chosen BMP, that third party can be included in the plan as well.	5 years after the effective permit date - FY2023
<u>Describe Operation and Maintenance Programs</u> – The Town will detail an operation and maintenance plan for each of the structural BMPs including an inspection and maintenance schedule specific to the BMP design or manufacturer specification and the responsible party for carrying out the plan.	5 years after the effective permit date - FY2023
Phase 1 Implementation Schedule – A schedule for implementation of all planned Phase 1 BMPs including: obtaining funding, training, purchasing, construction, inspections, monitoring, operation and maintenance, and other assessment and evaluation components of implementation. All non-structural BMPs must be adopted 6 years after the effective date of the permit, all structural BMPs must be adopted to adhere to the phosphorus removal milestones in year 8 and 10, and the full plan must be implemented no later than 10 years after the effective date of the permit.	5 years after the effective permit date - FY2023
Estimated Cost -The Town must estimate the cost of implementing all aspects of the Phase 1 plan. This will confirm the validity the funding source assessment completed in year 3.	5 years after the effective permit date - FY2023
<u>Complete Written Phase</u> – The Town must complete the written Phase 1 plan no later than 5 years after the permit's effective date. The EPA encourages the Town to post the drafted plan online to allow for public involvement.	5 years after the effective permit date - FY2023

6-3

<u>Full Implementation of Non-Structural Controls</u> – The Town must have fully implemented and evaluated the effectiveness of all non-structural BMPs by 6 years after the permit effective date by the method described above. All performance evaluations for each BMP will be included as an appendix to this report.	6 years after the effective permit date - FY2024
<u>Performance Evaluation</u> – the Town will continue monitoring non-structural BMPs for their effectiveness at removing Phosphorus.	6 and 7 years after the effective permit date – FY2024-2025
Full Implementation of Structural Controls and Performance Evaluation - The Town must have fully implemented and evaluated the effectiveness of all - structural BMPs by 8 years after the permit effective date by the method described above. All performance evaluations for each BMP will be included as an appendix to this report.	8 years after the effective permit date - FY2026
<u>Performance Evaluation</u> - the Town will continue monitoring non-structural and structural BMPs for their effectiveness at removing Phosphorus.	9 years after the effective permit date - FY2027
Full Implementation of Structural Controls and Performance Evaluation - The Town must have fully implemented and evaluated the effectiveness of all BMPs by 10 years after the permit effective date by the method described above. All performance evaluations for each BMP will be included as an appendix to this report.	10 years after the effective permit date - FY2028

Phase 2 of the Phosphorus Control Plan shall be completed no later than 10 years after the effective permit date and contain all the following components:

Table 6-2: Phosphorus Control Plan Phase 2 Components

PCP Phase 2 Component	Completion Date	
Legal Analysis – Update any analysis performed for Phase 1 to include any new or augmented bylaws, ordinances, or funding mechanisms deemed necessary to enact in order to complete the PCP.	As necessary	
<u>Describe Planned Non-Structural Controls</u> - The Town must describe all new non-structural controls to be implemented in the PCP to reach the new reduction milestone set forth by the permit. It must be detailed to include the planned measures, the area of implementation, and the annual percent reduction expected from the BMP's effect. To calculate expected rate of phosphorus exported (P_{exp}), add the Allowable Phosphorus Load (P_{allow}) to the applicable Phosphorus	10 years after the effective permit date - FY2028	

Reduction Requirement (P_{RR}) multiplied by 0.65 $P_{exp} \leq$	
$P_{allow} + (P_{RR} \times 0.65).$	
<u>Describe Planned Structural Controls</u> - The Town must describe all new structural controls to be implemented in the PCP to reach the new reduction milestone set forth by the permit. It must be detailed to include the planned measures, the area of implementation, and the annual percent reduction expected from the BMP's effect. To calculate expected rate of phosphorus exported (P_{exp}), add the Allowable Phosphorus Load (P_{allow}) to the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.50 $P_{exp} \leq P_{allow} + (P_{RR} \times 0.50)$.	10 years after the effective permit date – FY2028
<u>Update Operation and Maintenance Plan</u> - The Town will detail an operation and maintenance plan for each of the structural BMPs including an inspection and maintenance schedule specific to the BMP design or manufacturer specification and the responsible party for carrying out the plan.	10 years after the effective permit date – FY2028
<u>Phase 2 Implementation Schedule</u> - A schedule for implementation of all planned Phase 2 BMPs including: obtaining funding, training, purchasing, construction, inspections, monitoring, operation and maintenance, and other assessment and evaluation components of implementation. All structural BMPs must be adopted to adhere to the phosphorus removal milestones in year 13 and 15, and the full plan must be implemented no later than 15 years after the effective date of the permit.	10 years after the effective permit date - FY2028
<u>Estimated Cost</u> - The Town must estimate the cost of implementing all aspects of the Phase 2 plan including installing any new BMPs and creating an ongoing operation and maintenance plan.	10 years after the effective permit date – FY2028
<u>Complete Written Phase</u> - The Town must complete the written Phase 2 plan no later than 10 years after the permit's effective date. The EPA encourages the Town to post the drafted plan online to allow for public involvement.	10 years after the effective permit date – FY2028
<u>Performance Evaluation</u> - The Town will continue monitoring non-structural BMPs for their effectiveness at removing Phosphorus.	11 and 12 years after the effective permit date – FY2029- 2030
Full Implementation of Non- Structural Controls and Performance Evaluation - The Town must have fully implemented and evaluated the effectiveness of all non- structural BMPs by 13 years after the permit effective date by the method described above. All performance evaluations for each BMP will be included as an appendix to this report.	13 years after the effective permit date – FY2031

6-5



TOWN OF HOPEDALE. MA

STORMWATER MANAGEMENT PLAN

Performance Evaluation - The Town will continue monitoring non-structural BMPs for their effectiveness at removing Phosphorus	14 years after the effective permit date - FY2032
Full Implementation of Structural Controls and Performance Evaluation - The Town must have fully implemented and evaluated the effectiveness of all BMPs by 15 years after the permit effective date by the method described above. All performance evaluations for each BMP will be included as an appendix to this report.	15 years after the effective permit date – FY2033

Phase 3 of the Phosphorus Control Plan shall be completed no later than 15 years after the permit effective date. It shall be fully implemented no later than 20 years after the permit effective date and contain the following components.

Table 6-3: Phosphorus Control Plan Phase 3 Components

PCP Phase 3 Components	Completion Date
<u>Legal Analysis</u> - Update any analysis performed for Phase 1 and 2 to include any new or augmented bylaws, ordinances, or funding mechanisms deemed necessary to enact in order to complete the PCP.	As necessary.
<u>Describe Planned Non-Structural Controls</u> - The Town must describe all new non-structural controls to be implemented in the PCP to reach the new reduction milestone set forth by the permit. It must be detailed to include the planned measures, the area of implementation, and the annual percent reduction expected from the BMP's effect. To calculate expected rate of phosphorus exported (P_{exp}), add the Allowable Phosphorus Load (P_{allow}) to the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.30: $P_{exp} \leq P_{allow} + (P_{RR} \times 0.30)$.	15 years after the effective permit date – FY2033
<u>Describe Planned Structural Controls</u> - The Town must describe all new structural controls to be implemented in the PCP to reach the new reduction milestone set forth by the permit. It must be detailed to include the planned measures, the area of implementation, and the annual percent reduction expected from the BMP's effect. To calculate expected rate of phosphorus exported (P_{exp}), add the Allowable Phosphorus Load (P_{allow}) to the applicable Phosphorus Reduction Requirement (P_{RR}): $P_{exp} \leq P_{allow} + P_{RR}$.	15 years after the effective permit date – FY2033
<u>Update Operation and Maintenance Plan</u> - The Town will detail an operation and maintenance plan for each of the structural BMPs including an inspection and maintenance schedule specific to the BMP design or manufacturer specification and the responsible party for carrying out the plan.	15 years after the effective permit date – FY2033
Phase 3 Implementation Schedule - A schedule for implementation of all planned Phase 3 BMPs including: obtaining funding, training, purchasing, construction, inspections, monitoring, operation and maintenance, and other assessment and evaluation components of implementation. All structural BMPs must be adopted to adhere to the	15 years after the effective permit date – FY2033

Weston & Sampson

phosphorus removal milestones in year 18 and 20, and the full plan must		
be implemented no later than 20 years after the effective date of the		
permit.		
Estimated Cost - The Town must estimate the cost of implementing all	15 years after the	
aspects of the Phase 2 plan including installing any new BMPs and	effective permit date -	
creating an ongoing operation and maintenance plan.	FY2033	
<u>Complete Written Phase</u> - The Town must complete the written Phase 3	15 years after the	
plan no later than 15 years after the permit's effective date. The EPA	effective permit date -	
encourages the Town to post the drafted plan online to allow for public	FY2033	
involvement.	1 12000	
Performance Evaluation - The Town will continue monitoring non-	16 and 17 years after the	
structural BMPs for their effectiveness at removing Phosphorus.	effective permit date -	
	FY2034-2035	
Full Implementation of Non- Structural Controls and Performance		
Evaluation - The Town must have fully implemented and evaluated the	18 years after the	
effectiveness of all non-structural BMPs by 18 years after the permit	effective permit date -	
effective date by the method described above. All performance FY2036		
evaluations for each BMP will be included as an appendix to this report.		
Performance Evaluation - The Town will continue monitoring non-	19 years after the	
structural BMPs for their effectiveness at removing Phosphorus.	effective permit date -	
	FY2037	
Full Implementation of Structural Controls and Performance Evaluation -		
The Town must have fully implemented and evaluated the effectiveness	20 years after the	
of all BMPs by 20 years after the permit effective date by the method	effective permit date –	
	-	
described above. All performance evaluations for each BMP will be	FY2038	

6.2.2 Blackstone River Phosphorus Impairment

The Blackstone River is impaired for phosphorus and requires the development of a TMDL. The Town has a few outfalls which discharge non-directly, to the Blackstone River and therefore, the Town is subject to the requirements of Appendix H of the MS4 Permit, which outlines requirements related to discharges to water quality limited water bodies and their tributaries where phosphorus is the cause of the impairment.

6.2.3 Public Education and Outreach

The Town must distribute additional educational messages to residential property owners, businesses, and commercial institutions about the proper use and disposal of grass clippings, and to encourage the use of slow release and phosphorous-free fertilizers annually in the spring, between March and April. An additional pet waste message must also be distributed to residents annually in the summer, between June and July, encouraging the proper management of pet waste and noting any existing bylaws where appropriate. In the Fall (August/September/October), an educational message detailing the proper disposal of leaf litter must be distributed to residential and commercial property owners. The Town has already begun posting information on fertilizer use and disposal of leaf litter on their website, on social media and at public events.

6.2.4 Regulatory Updates

The Town of Hopedale must also update their Rules and Regulations Regarding the Use of Public Sewers and Storm Drains to require that all new development and redevelopment stormwater management BMPs constructed within town be optimized for phosphorous removal. A comprehensive review of all existing rules and regulations must be performed within two years of the permit effective date to determine any updates that must be made to comply with this statute and any progress shall be reported here and in the Town's Annual Report.

In addition, as part of the assessment to identify permittee-owned property that can be retrofitted with BMPs, the incorporation of BMPs that infiltrate stormwater shall be prioritized where feasible to aid in phosphorus removal.

6.2.5 Good Housekeeping and Pollution Prevention

The Town shall develop and implement a program to manage grass clippings and leaf litter on all permittee-owned property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces, within 2 years of the permit effective date. That plan shall be appended here.

The Town shall increase street and municipal parking lot sweeping frequencies to a minimum of two times per year, in the spring after snowmelt and sanding practices have subsided, and in the fall after leaf fall events (September 1st to December 1st). A street sweeping schedule shall be included in this plan and in the Town's Annual Reports.

The Town has developed a SOP for the sweeping of streets and permittee-owned parking lots during Permit Year 3. That SOP is included in Appendix F of the Town's O&M Plan and in Appendix I of this SMWP.

6.2.6 Phosphorus Source Identification

The Town must develop a comprehensive Phosphorous Source Identification Report. This report must include the following elements:

- Calculation of the total MS4 regulated area draining directly to the Blackstone River. The analysis will reflect any updated MS4 mapping and catchment delineations.
- All screening and monitoring results for outfalls directly discharging to the Blackstone River will be tested for phosphorus during dry and wet weather sampling events, where flowing.
- Calculation of Impervious Area and Directly Connected Impervious Area for each catchment.
- Identification, delineation and prioritization of potential catchments with high phosphorous loading.
- Identification of potential retrofit opportunities or opportunities for the installation of structural BMPs during redevelopment, including the removal of impervious area to reduce phosphorous loadings.

This report must be appended to the Town's Year 4 Annual Report and to this SWMP upon completion. After the submission of the report, the Town must evaluate all permittee-owned properties within the drainage area that could be candidates for a BMP retrofit. This evaluation must include:



- The next planned infrastructure, resurfacing or redevelopment activity planned for the property or planned retrofit date;
- The estimated cost of redevelopment or retrofit BMPs; and
- The engineering and regulatory feasibility of redevelopment of retrofit BMPs.

This analysis must be complete within 5 years of the permit effective date, and a plan and schedule for implementation must be included in the Year 5 Annual Report. The Town must plan and install at least one structural BMP as a demonstration project within the drainage area of the Blackstone River within 6 years of the permit effective date. This BMP must target a catchment with high phosphorus load potential. Any other identified BMP retrofit projects must be installed according to the schedule outlined in the Year 5 Annual Report. For those structural BMPs installed, the Town must document the following in each MS4 Annual Report:

- BMP type
- Total area treated by the BMP
- Design storage volume of the BMP
- Estimated phosphorus removed in mass per year by the BMP

6.3 Bacteria Impairments

Since the Charles River Watershed is impaired for pathogens, the Town is subject to the requirements of Appendix H of the MS4 Permit, which outlines requirements related to discharges to water quality limited water bodies where bacteria or pathogens is the cause of the impairment.

6.3.1 Public Education and Outreach

The Town has a public education program and has been able to easily add in specific, targeted information regarding actions that can be taken to reduce sources of bacteria from outfalls tributary to the Charles River.

The Permit requires the Town to supplement its residential public education program by distributing information to pet owners within those catchments tributary to the Charles River about the proper management of pet waste, including noting any existing bylaws. This message must be disseminated to all residents annually and pet owners at the time of pet license issuance. This informational campaign can be combined with the phosphorus education requirements outlined in Section 6.2.2.1. The Town has already been distributing information on pet waste management on the Town's website under the Stormwater Management tab.

The Town has also distributed information targeted septic system owners about proper maintenance in those catchments tributary to the Charles River. This information can also be found on the Town's website under the Stormwater Management tab.

westonandsampson.com





6.3.2 Illicit Discharges

In implementing their Illicit Discharge Detection and Elimination Program, the Town has designated all catchments that are tributary to the Charles River as a problem or high priority under the catchment prioritization and ranking.

westonandsampson.com

6-10



7.0 REPORTING, EVALUATION AND MODIFICATION

7.1 MS4 Permit Reporting

The MS4 Permit requires submission of annual reports assessing the effectiveness of the proposed BMPs and reporting if the minimum control measures were met. The initial report is due 90 days from the close of the reporting period, or September 30, 2019, and annually thereafter. Reports are to be submitted to both EPA and MADEP. At a minimum, the report should include the following:

- The status of compliance with permit conditions, including an assessment of the appropriateness of the selected BMPs and progress toward achieving the selected measurable goals for each minimum control measure.
- Results of any information collected and analyzed, including monitoring data, if any. Outfall screening and monitoring data collected shall be submitted for both the reporting cycle and cumulative for the permit term.
- A summary of the stormwater activities planned for the next reporting cycle.
- A change in any identified best management practices or measurable goals for any minimum control measure.
- Notice of relying on another governmental entity to satisfy some of the permit obligations, if applicable.

As indicated in an earlier section, copies of past annual reports submitted by Hopedale are referenced in Appendix E of this SWMP. Hopedale will append future annual reports in compliance with the 2016 MS4 Permit as they are prepared in Appendix J.

7.2 Evaluation of SWMP Success

This SWMP should be considered a dynamic document that is modified as necessary to account for changes such as in drainage infrastructure, laws and regulations, and Town leadership and policy. The success of programs implemented by the SWMP – such as IDDE – should also be evaluated to ensure that they are accomplishing the goals for which they were intended and in a method and timetable that continues to be appropriate. In addition, the SWMP should be reviewed and revised as necessary to keep text and appendices current. For example:

- After each year of stormwater monitoring to update appended findings and priorities.
- As needed to keep appended IDDE investigation, identification and removal documentation current.
- After each NPDES stormwater permit renewal to incorporate new requirements, as well as append copies of new permits and associated Notices of Intent (NOIs).
- After adoption of any new or revised ordinances or other regulatory mechanisms related to stormwater or drainage infrastructure.

westonandsampson.com

7-1



Hopedale undertook this SWMP, in part, in order to ensure the protection of its water resources and the large investment in drainage infrastructure. Periodic review and revision of this written document will help achieve these goals on a perpetual basis.

7.3 Modifications to the SWMP or Notice of Intent

As discussed above, minor modifications to this SWMP should be made on a regular and frequent basis to keep it current. However, major changes to the SWMP or needed modifications to the NOI for inclusion under the NPDES Permit require an official process. In accordance with the MS4 Permit, modifications to the SWMP or NOI may be made under the following provisions:

- At any time, the Town may add (but not subtract or replace) components, controls or requirements to the SWMP.
- The Town may request to replace an ineffective or infeasible BMP specifically identified in the SWMP with an alternative BMP at any time as long as the basis for the change is documented in the SWMP by, at a minimum:
 - An analysis of why the BMP is ineffective or infeasible (or cost prohibitive).
 - o Expectations on the effectiveness of the replacement BMP.
 - An analysis of why the replacement BMP is expected to achieve the goals of the BMP to be replaced.
- The Town shall indicate BMP modifications along with a brief explanation of the modification in each Annual Report.

At this time, Hopedale does not anticipate any major modifications to the SWMP or NOI requiring official notification.

APPENDIX A

Abbreviations and Definitions



ABBREVIATIONS AND DEFINITIONS

Best Management Practices (BMPs) - schedules of activities, practices (and prohibitions of practices), structures, vegetation, maintenance procedures, and other management practices to prevent or reduce the discharge of pollutants to waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Common Plan of Development - A "larger common plan of development or sale" is a contiguous area where multiple separate and distinct construction activities may be taking place at different times different schedules under one plan. For example, if developer buys a 20-acre lot and builds roads, installs pipes, and runs electricity with the intention of constructing homes or other structures sometime in the future, this would be considered a larger common plan of development or sale. If the land is parceled off or sold, and construction occurs on plots that are less than one acre by separate, independent builders, this activity still would be subject to stormwater permitting requirements if the smaller plots were included on the original site plan.

Control Measure - refers to any BMP or other method (including effluent limitations) used to prevent or reduce the discharge of pollutants to waters of the United States.

Director - a Regional Administrator of the Environmental Protection Agency or an authorized representative.

Discharge - when used without qualification, means the "discharge of a pollutant."

Discharge of a pollutant - any addition of any "pollutant" or combination of pollutants to "waters of the United States" from any "point source," or any addition of any pollutant or combination of pollutants to the waters of the "contiguous zone" or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation. This includes additions of pollutants into waters of the United States from surface runoff which is collected or channeled by man; or discharges through pipes, sewers, or other conveyances, leading into privately owned treatment works.

Discharge-related activities - activities which cause, contribute to, or result in stormwater and allowable non-stormwater point source discharges, and measures such as the siting, construction and operation of BMPs to control, reduce, or prevent pollution in the discharges.

Disturbance - action to alter the existing vegetation and/or underlying soil of a site, such as clearing, grading, site preparation (e.g., excavating, cutting, and filling), soil compaction, and movement and stockpiling of top soils.

Existing Discharger – an operator applying for coverage under this permit for discharges covered previously under an NPDES general or individual permit.

Facility or Activity - any NPDES "point source" or any other facility or activity (including land or appurtenances thereto) that is subject to regulation under the NPDES program.

.....



Federal Facility – Any buildings, installations, structures, land, public works, equipment, aircraft, vessels, and other vehicles and property, owned by, or constructed or manufactured for the purpose of leasing to, the federal government.

Illicit Discharge - any discharge to a municipal separate storm sewer that is not composed entirely of stormwater except discharges pursuant to a NPDES permit (other than the NPDES permit for discharges from the municipal separate storm sewer) and discharges resulting from firefighting activities.

Impaired Water – A water is impaired if it does not meet one or more of its designated use(s). For purposes of this permit, "impaired" refers to categories 4 and 5 of the five-part categorization approach used for classifying the water quality standards attainment status for water segments under the TMDL program. Impaired waters compilations are also sometimes referred to as "303(d) lists." Category 5 waters are impaired because at least one designated use is not being supported or is threatened and a TMDL is needed. Category 4 waters indicate that at least one designated use is not being supported but a TMDL is not needed (4a indicates that a TMDL has been approved or established by EPA; 4b indicates other required control measures are expected in result in the attainment of water quality standards in a reasonable period of time; and 4c indicates that the nonattainment of the water quality standard is the result of pollution (e.g. habitat) and is not caused by a pollutant). See USEPA's 2006 Integrated Report Guidance, July 29, 2005 for more detail on the five-part categorization of waters [under EPA National TMDL Guidance]).

Impervious Surface- Any surface that prevents or significantly impedes the infiltration of water into the underlying soil. This can include but is not limited to roads, driveways, parking areas and other areas created using non porous material; buildings, rooftops, structures, artificial turf and compacted gravel or soil.

Industrial Activity - the ten categories of industrial activities included in the definition of "stormwater discharges associated with industrial activity," as defined in 40 CFR 122.26(b)(14)(i)-(ix) and (xi).

Industrial Stormwater - stormwater runoff associated with the definition of "stormwater discharges associated with industrial activity."

Interconnection – the point (excluding sheet flow over impervious surfaces) where the permittee's MS4 discharges to another MS4 or other storm sewer system, through which the discharge is eventually conveyed to a water of the United States. Interconnections shall be treated similarly to outfalls throughout the permit.

Junction Manhole - For the purposes of this permit, a junction manhole is a manhole or structure with two or more inlets accepting flow from two or more MS4 alignments. Manholes with inlets solely from private storm drains, individual catch basins, or both are not considered junction manholes for these purposes.

Key Junction Manhole - For the purposes of this permit, key junction manholes are those junction manholes that can represent one or more junction manholes without compromising adequate implementation of the illicit discharge program. Adequate implementation of the illicit discharge

.....



program would not be compromised if the exclusion of a junction manhole as a key junction manhole would not affect the permittee's ability to determine the possible presence of an upstream illicit discharge. A permittee may exclude a junction manhole located upstream from another located in the immediate vicinity or that is serving a drainage alignment with no potential for illicit connections.

Municipal Separate Storm Sewer - a conveyance or system of conveyances (including roads with drainage systems, municipal streets, catch basins, curbs, gutters, ditches, manmade channels, or storm drains):(i) Owned or operated by a State, city, town, borough, county, parish, district, association, or other public body (created by or pursuant to State law) having jurisdiction over disposal of sewage, industrial wastes, stormwater, or other wastes, including special districts under State law such as a sewer district, flood control district or drainage district, or similar entity, or an Indian tribe or an authorized Indian tribal organization, or a designated and approved management agency under section 208 of the CWA that discharges to waters of the United States; (ii) Designed or used for collecting or conveying stormwater; (iii) Which is not a combined sewer; and (iv) Which is not part of a Publicly Owned Treatment Works (POTW) as defined at 40 CFR 122.2.

Municipal Separate Storm Sewer System (MS4) - means all separate storm sewers that are defined as "large" or "medium" or "small" municipal storm sewer systems pursuant to paragraphs 40 CFR 122.26 (b)(4) and (b)(7) or designated under paragraph 40 126.26(a) (1)(v). For the purposes of this permit "MS4" may also refer to the permittee with jurisdiction over the sewer system.

New Development – any construction activities or land alteration resulting in total earth disturbances greater than 1 acre (or activities that are part of a larger common plan of development disturbing greater than 1 acre) on an area that has not previously been developed to include impervious cover. (see part 2.3.6. of the permit)

New Discharger – For the purposes of this permit, a new discharger is an entity that discharges stormwater from a new facility with an entirely new separate storm sewer system that is not physically located on the same or adjacent land as an existing facility and associated system operated by the same MS4.

New Source - any building, structure, facility, or installation from which there is or may be a "discharge of pollutants," the construction of which commenced:

- after promulgation of standards of performance under section 306 of the CWA which are applicable to such source, or
- after proposal of standards of performance in accordance with section 306 of the CWA which are applicable to such source, but only if the standards are promulgated in accordance with section 306 within 120 days of their proposal.

No exposure - all industrial materials or activities are protected by a storm-resistant shelter to prevent exposure to rain, snow, snowmelt, and/or runoff.

One Lane Width – The width of the travel lane for a roadway. Lane width does not include shoulders, curbs, and on-street parking areas.

.....



Outfall Catchment – The land area draining to a single outfall or interconnection. The extent of an outfall's catchment is determined not only by localized topography and impervious cover but also by the location of drainage structures and the connectivity of MS4 pipes.

Owner or operator - the owner or operator of any "facility or activity" subject to regulation under the NPDES program.

Person - an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

Point source - any discernible, confined, and discrete conveyance, including but not limited to any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel, or other floating craft from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural stormwater runoff.

Pollutant - dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, heat, wrecked or discarded equipment, rock, sand, cellar dirt, and industrial, municipal and agricultural waste discharged into water.

Pollutant of concern – A pollutant which causes or contributes to a violation of a water quality standard, including a pollutant which is identified as causing an impairment in a State's 303(d) list.

Redevelopment – for the purposes of part 2.3.6., any construction, land alteration, or improvement of impervious surfaces resulting in total earth disturbances greater than 1 acre (or activities that are part of a larger common plan of development disturbing greater than 1 acre) that does not meet the definition of new development (see above).

Runoff coefficient - the fraction of total rainfall that will appear at the conveyance as runoff.

Site – for the purposes of part 2.3.6., the area extent of construction activities, including but not limited to the creation of new impervious cover and improvement of existing impervious cover (e.g. repaving not covered by 2.3.6.a.ii.4.d.)

Small Municipal Separate Storm Sewer System – all separate storm sewer systems that are (i) owned or operated by the United States, a State, city, town, borough, county, parish, district, association, or other public body (created by or pursuant to State law) having jurisdiction over disposal of sewage, industrial wastes, storm water, or other wastes, including special districts under State law such as a sewer district, flood control district, or drainage district, or similar entity or an Indian tribe or an authorized Indian tribal organization or a designated and approved management agency under section 208 of the CWA that discharges to waters of the United States, and (ii) not defined as "large" or "medium" municipal separate storm sewer system pursuant to paragraphs 40 CFR 122.26 (b)(4) and (b)(7) or designated under paragraph 40 126.26(a) (1)(v). This term includes systems similar to separate storm sewer systems in municipalities, such as systems at military bases, large hospital or prison complexes, and highways and other thoroughfares. This term does not include separate storm sewers in very discrete areas, such as individual buildings.

.....

westonandsampson.com

Weston & Sampson

Small MS4 – means a small municipal separate storm sewer system.

Stormwater - stormwater runoff, snow melt runoff, and surface runoff and drainage.

Stormwater Discharges Associated with Construction Activity - a discharge of pollutants in stormwater runoff from areas where soil disturbing activities (e.g., clearing, grading, or excavating), construction materials, or equipment storage or maintenance (e.g., fill piles, borrow areas, concrete truck washout, fueling), or other industrial stormwater directly related to the construction process (e.g., concrete or asphalt batch plants) are located. (See 40 CFR 122.26(b)(14)(x) and 40 CFR 122.26(b)(15).

Stormwater Discharges Associated with Industrial Activity - the discharge from any conveyance that is used for collecting and conveying stormwater and that is directly related to manufacturing, processing or raw materials storage areas at an industrial plant. The term does not include discharges from facilities or activities excluded from the NPDES program under Part 122. For the categories of industries identified in this section, the term includes, but is not limited to, stormwater discharges from industrial plant yards; immediate access roads and rail lines used or traveled by carriers of raw materials, manufactured products, waste material, or by-products used or created by the facility; material handling sites; refuse sites; sites used for the application or disposal of process waste water (as defined at part 401 of this chapter); sites used for the storage and maintenance of material handling equipment; sites used for residual treatment, storage, or disposal; shipping and receiving areas; manufacturing buildings; storage areas (including tank farms) for raw materials, and intermediate and final products; and areas where industrial activity has taken place in the past and significant materials remain and are exposed to stormwater. For the purposes of this paragraph, material handling activities include storage, loading and unloading, transportation, or conveyance of any raw material, intermediate product, final product, by-product or waste product. The term excludes areas located on plant lands separate from the plant's industrial activities, such as office buildings and accompanying parking lots as long as the drainage from the excluded areas is not mixed with stormwater drained from the above described areas. Industrial facilities include those that are federally, State, or municipally owned or operated that meet the description of the facilities listed in Appendix D of this permit. The term also includes those facilities designated under the provisions of 40 CFR 122.26(a)(1)(v).

Total Maximum Daily Loads (TMDLs) - A TMDL is a calculation of the maximum amount of a pollutant that a waterbody can receive and still meet water quality standards, and an allocation of that amount to the pollutant's sources. A TMDL includes waste load allocations (WLAs) for point source discharges, load allocations (LAs) for nonpoint sources and/or natural background and must include a margin of safety (MOS) and account for seasonal variations. (See section 303(d) of the Clean Water Act and 40 CFR 130.2 and 130.7).

Urbanized Area – US Census designated area comprised of a densely settled core of census tracts and/or census blocks that meet minimum population density requirements, along with adjacent territory containing non-residential urban land uses as well as territory with low population density included to link outlying densely settled territory with the densely settled core. For the purposes of this permit, Urbanized Areas as defined by any Census since 2000 remain subject to stormwater regulation even if there is a change in the reach of the Urbanized Area because of a change in more recent Census data.

.....

westonandsampson.com

Weston & Sampson

Water Quality Limited Water – for the purposes of this permit, a water quality limited water is any waterbody that does not meet applicable water quality standards, including but not limited to waters listed in categories 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b).

Water Quality Standards - A water quality standard defines the water quality goals of a water body, or portion thereof, by designating the use or uses to be made of the water and by setting criteria necessary to protect the uses. States and EPA adopt WQS to protect public health or welfare, enhance the quality of water and serve the purposes of the Clean Water Act (See CWA sections 101(a)2 and 303(c)).

ABBREVIATIONS AND ACRONYMS

BMP – Best Management Practice

BPJ – Best Professional Judgment

- CGP Construction General Permit
- CWA Clean Water Act (or the Federal Water Pollution Control Act, 33 U.S.C. §1251 et seq)
- DCIA Directly Connected Impervious Area

EPA – U. S. Environmental Protection Agency

ESA – Endangered Species Act

USFWS – U. S. Fish and Wildlife Service

IA – Impervious Area

IDDE – Illicit Discharge Detection and Elimination

LA – Load Allocations

MS4 – Municipal Separate Storm Sewer System

MSGP – Multi-Sector General Permit

NHPA – National Historic Preservation Act

NMFS – U. S. National Marine Fisheries Service

NOI – Notice of Intent

NPDES – National Pollutant Discharge Elimination System

NRHP – National Register of Historic Places

NSPS – New Source Performance Standard

PCP – Phosphorus Control Plan

SHPO – State Historic Preservation Officer

SPCC – Spill Prevention, Control, and Countermeasure

SWMP – Stormwater Management Program

SWPPP - Stormwater Pollution Prevention Plan

TMDL – Total Maximum Daily Load

TSS – Total Suspended Solids

WLA – Waste load Allocation

WQS – Water Quality Standard

westonandsampson.com



APPENDIX B

Regulated Area Map





APPENDIX C

2016 MS4 Permit



Minor Permit Modification Summary

The following permit has been modified in accordance with 40 CFR §122.63:

Permit Name: GENERAL PERMITS FOR STORMWATER DISCHARGES FROM SMALL MUNICIPAL SEPARATE STORM SEWER SYSTEMS IN MASSACHUSETTS

Issue date: April 4, 2016

Effective Date: July 1, 2018

The following minor modifications were made on November 7, 2018:

Page	Modification
2	Table of Contents was updated to reflect the changes below
3	Table of Contents was updated to reflect the changes below
5	Line was added before first bullet point for consistency
6	Line was removed between parts for consistency
8	Lines were added and removed between parts for consistency
8	Typos were fixed
11	Extra word was removed
11	Extra spaces were removed between words for consistency
12	Extra spaces were removed between words for consistency
12	Extra words were removed
12	Text was moved to a bullet point in the last paragraph of part 1.10.2 instead of as
	part of the 1.10.3 title for consistency
12	Duplicate words and symbols were deleted
13	Bullets were moved to the correct subsection, consistent with other relevant
	sections of the permit
14	Typos were fixed
15	Extra spaces were removed between words for consistency
16	Extra spaces were removed between words for consistency
27	Extra spaces were removed between words for consistency
27	Duplicate character was removed
29	Typo was fixed
30	Duplicate character was removed
32	Lines were added before bullet points for consistency
33	Lines were added and removed between paragraphs for consistency
34	Line was added before bullet points for consistency
34	Typo was fixed
34	Duplicate spaces were removed
35	Typo was fixed
35	Line was added before bullet points for consistency
36	Lines were added before bullet points and in between parts for consistency
37	Lines were added before bullet points and in between parts for consistency
38	Line was added in between parts for consistency
38	Typos were fixed

39	Line was added in between paragraphs for consistency
39	Typos were fixed
41	Lines were added before bullets for consistency
42	Typos were fixed
43	Typo was fixed
44	Line was added for consistency
46	Typo was fixed
50	Typo was fixed
51	Typo was fixed
54	Line was added for consistency
55	Line was added for consistency
56	Typo was fixed
56	Line was added for consistency
57	Lines were added and removed for consistency

United States Environmental Protection Agency (EPA) National Pollutant Discharge Elimination System (NPDES)

GENERAL PERMITS FOR STORMWATER DISCHARGES FROM SMALL MUNICIPAL SEPARATE STORM SEWER SYSTEMS IN MASSACHUSETTS

AUTHORIZATION TO DISCHARGE UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act (CWA), as amended (33 U.S.C. §1251 *et seq.*), and the Massachusetts Clean Waters Act, as amended (M.G.L. Chap.21 §§ 26-53), any operator of a small municipal separate storm sewer system whose system:

- Is located in the areas described in part 1.1;
- Is eligible for coverage under part 1.2 and part 1.9; and
- Submits a complete and accurate Notice of Intent in accordance with part 1.7 of this permit and EPA issues a written authorization

is authorized to discharge in accordance with the conditions and the requirements set forth herein.

The following appendices are also included as part of these permits:

- Appendix A Definitions, Abbreviations, and Acronyms;
- Appendix B Standard permit conditions applicable to all authorized discharges;
- Appendix C Endangered Species Act Eligibility Guidance;
- Appendix D National Historic Preservation Act Eligibility Guidance;
- Appendix E Information required for the Notice of Intent (NOI);
- Appendix F Requirements for MA Small MS4s Subject to Approved TMDLs;
- Appendix G Impaired Waters Monitoring Parameter Requirements;
- Appendix H Requirements related to discharges to certain water quality limited waterbodies;

These permits become effective on July 1, 2017.

These permits and the authorization to discharge expire at midnight, June 30, 2022.

Signed this Yth day of April 2016

Ken Moraff, Director Office of Ecosystem Protection United States Environmental Protection Agency 5 Post Office Square – Suite 100 Boston, Massachusetts 02109-3912

Signed this 4th day of April 2016

Douglas E. Fine Assistant Commissioner for Water Resources Department of Environmental Protection One Winter Street Boston, Massachusetts 02108

TABLE OF CONTENTS

1.0.	INTRODUCTION	4
1.1.	AREAS OF COVERAGE	4
1.2.	ELIGIBILITY	4
1.2.1.	Small MS4s Covered	4
1.3.	LIMITATIONS ON COVERAGE	5
1.4.	NON-STORMWATER DISCHARGES	6
1.5.	Permit Compliance	6
1.6.	CONTINUATION OF THIS PERMIT	6
1.7.	OBTAINING AUTHORIZATION TO DISCHARGE	7
1.7.1.	How to Obtain Authorization to Discharge	7
1.7.2.	Notice of Intent	7
1.7.3.	Submission of Notice of Intent	7
1.7.4.	Public Notice of NOI and Effective Date of Coverage	8
1.8.	INDIVIDUAL PERMITS AND ALTERNATIVE GENERAL PERMITS	8
1.9.	SPECIAL ELIGIBILITY DETERMINATIONS	9
1.9.1.	Documentation Regarding Endangered Species	9
1.9.2.	Documentation Regarding Historic Properties	9
1.10.	STORMWATER MANAGEMENT PROGRAM (SWMP)	10
1.10.1.	Stormwater Management Program Availability	10
1.10.2.	Contents and Timelines of the Stormwater Management Program for 2003 permittees	10
1.10.3.	Contents and Timelines of the Stormwater Management Program for New Permittees	12
2.0.	NON-NUMERIC EFFLUENT LIMITATIONS	. 14
2.1.	WATER QUALITY BASED EFFLUENT LIMITATIONS	14
2.1.1.	Requirement to Meet Water Quality Standards	14
2.1.2.	Increased Discharges	15
2.2.	DISCHARGES TO CERTAIN IMPAIRED WATERS	16
2.2.1.	Discharges Subject to Requirements Related to an Approved TMDL	16
2.2.2.	Discharges to Certain Water Quality Limited Waters Subject to Additional Requirements	22
2.3.	REOUREMENTS TO REDUCE POLLUTANTS TO THE MAXIMUM EXTENT PRACTICABLE (MEP)	27
2.3.1.	Control Measures	27
2.3.2.	Public Education and Outreach	27
2.3.3.	Public Involvement and Participation	29
2.3.4.	Illicit Discharge Detection and Elimination (IDDE) Program	30
2.3.5.	Construction Site Stormwater Runoff Control	42
2.3.6.	Stormwater Management in New Development and Redevelopment (Post Construction	
	Stormwater Management)	43
2.3.7.	Good House Keeping and Pollution Prevention for Permittee Owned Operations	47
• •		
3.0.	ADDITIONAL REQUIREMENTS FOR DISCHARGES TO SURFACE	
DRINKING	WATER SUPPLIES AND THEIR TRIBUTARIES	54

4.0.	PROGRAM EVALUATION, RECORD KEEPING, AND	D REPORTING 54
4.1.	PROGRAM EVALUATION	
4.2.	RECORD KEEPING	
4.3.	OUTFALL MONITORING REPORTING	
4.4.	ANNUAL REPORTS	

5.0. NON-TRADITIONAL MS4S	58
---------------------------	----

5.1.	REQUIREMENTS FOR NON-TRADITIONAL MS4s	
5.1.1.	Public education	
5.1.2.	Ordinances and regulatory mechanisms	
5.1.3.	Assessment of Regulations	
5.1.4.	New Dischargers	

6.0 REQUIREMENTS FOR MS4S OWNED OR OPERATED BY TRANSPORTATION AGENCIES

6.1 PUBLIC EDUCATION	59
6.2 ORDINANCES AND REGULATORY MECHANISMS	59
6.3 ASSESSMENT OF REGULATIONS	59
6.4 NEW DISCHARGERS	59

1.0. Introduction

This document consists of three (3) general permits listed in part 1.1. Each general permit is applicable to a particular type of municipal system within Massachusetts. Many of the permit terms and conditions are applicable across all regulated entities, and therefore are presented just once in parts 1-2, part 4, and Appendices A through E. Other conditions are applicable to a particular set of authorized entities; these terms and conditions are included in parts 3, and 5 and Appendices F through H. Throughout the permit, the terms "this permit" or "the permit" will refer to the three general permits.

1.1. Areas of Coverage

This permit covers small municipal separate storm sewer systems (MS4s) located in the Commonwealth of Massachusetts:

- Traditional Cities and Towns (NPDES Permit No. MAR041000)
- State, federal, county and other publicly owned properties (Non-traditional) (MAR042000)
- State transportation agencies (except for MassDOT- Highway Division) (MAR043000)

1.2. Eligibility

The MS4 shall meet the eligibility provisions described in part 1.2.1 and part 1.9 to be eligible for authorization under this permit.

1.2.1. Small MS4s Covered

This permit authorizes the discharge of stormwater from small MS4s as defined at 40 CFR § 122.26(b) (16). This includes MS4s described in 40 CFR §122.32(a) (1) and (a) (2). An MS4 is eligible for coverage under this permit if it is:

- A small MS4 within the Commonwealth of Massachusetts;
- Not a large or medium MS4 as defined in 40 CFR §§122.26(b)(4) or (7);
- Located either fully or partially within an urbanized area as determined by the latest Decennial Census by the Bureau of Census as of the effective date of this permit (the 2010 Census); or
- Located in a geographic area designated by EPA as requiring a permit.

If the small MS4 is not located entirely within an urbanized area, only the portion of the MS4 that is located within the urbanized area is regulated under 40 CFR §122.32(a) (1).

A small municipal separate storm sewer system means all separate storm sewers that are:

- Owned or operated by the United States, a state, city, town, borough, county, parish, district, association, or other public body (created by or pursuant to state law) having jurisdiction over disposal of sewage, industrial wastes, stormwater, or other wastes, including special districts under state law such as a sewer district, flood control district or drainage district, or similar entity, or an Indian tribe or an authorized Indian tribal organization, or a designated and approved management agency under section 208 of the CWA that discharges to waters of the United States.
- Not defined as large or medium municipal separate storm sewer systems pursuant to 40 CFR § 122.26(b) (4) and (b) (7) or designated under 40 CFR § 122.26(a) (1) (v).
- This term includes systems similar to separate storm sewer systems in municipalities such as systems at military bases, large hospitals or prison complexes, and highways

and other thoroughfares. The term does not include separate storm sewers in very discrete areas, such as individual buildings.

1.3. Limitations on Coverage

This permit does not authorize the following:

- a. Stormwater discharges mixed with sources of non-stormwater unless such non-stormwater discharges are:
 - Authorized under a separate NPDES permit; or
 - A non-stormwater discharge as listed in part 1.4.
- b. Stormwater discharges associated with industrial activity as defined in 40 CFR §122.26 (b) (14) (i)-(ix) and (xi).
- c. Stormwater discharges associated with construction activity as defined in 40 CFR §122.26(b) (14) (x) or (b) (15).
- d. Stormwater discharges currently authorized under another NPDES permit, including discharges covered under other regionally issued general permits.
- e. Stormwater discharges or discharge related activities that are likely to adversely affect any species that are listed as endangered or threatened under the Endangered Species Act (ESA) or result in the adverse modification or destruction of habitat that is designated as critical under the ESA. The permittee shall follow the procedures detailed in Appendix C to make a determination regarding eligibility. The permittee shall certify compliance with this provision on the submitted NOI.
- f. Stormwater discharges whose direct or indirect impacts do not prevent or minimize adverse effects on any Essential Fish Habitat.
- g. Stormwater discharges, or implementation of a stormwater management program, which adversely affects properties listed or eligible to be listed on the National Register of Historic Places. The permittee shall follow the procedures detailed in Appendix D to make a determination regarding eligibility. The permittee shall certify compliance with this provision on the submitted NOI.
- h. Stormwater discharges prohibited under 40 CFR § 122.4.
- Stormwater discharges to the subsurface subject to state Underground Injection Control (UIC) regulations. Although the permit includes provisions related to infiltration and groundwater recharge, structural controls that dispose of stormwater into the ground may be subject to UIC regulation requirements. Authorization for such discharges shall be obtained from Massachusetts Department of Environmental Protection, Bureau of Resource Protection, Drinking Water Program, Underground Injection Control, One Winter Street, Boston, MA 02108 – phone 617-292-5859.
- j. Any non-traditional MS4 facility that is a "new discharger" as defined in part 5.1.4. and discharges to a waterbody listed in category 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b) due to nutrients (Total Nitrogen or (Total Phosphorus), metals (Cadmium, Copper, Iron, Lead or Zinc), solids (TSS or Turbidity), bacteria/pathogens (E. Coli, Enteroccus or Fecal Coliform), chloride (Chloride) or oil and grease

(Petroleum Hydrocarbons or Oil and Grease), or discharges to a waterbody with an approved TMDL for any of those pollutants.

1.4. Non-Stormwater Discharges

The following categories of non-stormwater discharges are allowed under this permit *unless* the permittee, EPA, or the MassDEP identifies any category or individual discharge of non-stormwater discharge in part 1.4.a-r as a significant contributor of pollutants to the MS4, then that category or individual discharge is not allowed under part 1.4, but rather shall be deemed an "illicit discharge" under part 2.3.4.1, and the permittee shall address that category or individual discharge as part of the Illicit Discharge Detection and Elimination (IDDE) Program described in part 2.3.4 of this permit.

- a. Water line flushing
- b. Landscape irrigation
- c. Diverted stream flows
- d. Rising ground water
- e. Uncontaminated ground water infiltration (as defined at 40 CFR § 35.2005(20))
- f. Uncontaminated pumped ground water
- g. Discharge from potable water sources
- h. Foundation drains
- i. Air conditioning condensation
- j. Irrigation water, springs
- k. Water from crawl space pumps
- 1. Footing drains
- m. Lawn watering
- n. Individual resident car washing
- o. Flows from riparian habitats and wetlands
- p. De-chlorinated swimming pool discharges
- q. Street wash waters
- r. Residential building wash waters without detergents

Discharges or flows from firefighting activities are allowed under this permit need only be addressed where they are identified as significant sources of pollutants to waters of the United States.

1.5. Permit Compliance

Non-compliance with any of the requirements of this permit constitutes a violation of the permit and the CWA and may be grounds for an enforcement action and may result in the imposition of injunctive relief and/or penalties.

1.6. Continuation of this Permit

If this permit is not reissued prior to the expiration date, it will be administratively continued in accordance with the Administrative Procedure Act and remain in force and effect for discharges that were authorized prior to expiration. If a small MS4 was granted permit authorization prior to the expiration date of this permit, it will automatically remain authorized by this permit until the earliest of:

- Authorization under a reissued general permit following timely and appropriate submittal of a complete and accurate NOI requesting authorization to discharge under the reissued permit; or
- Issuance or denial of an individual permit for the MS4's discharges; or

• Authorization or denial under an alternative general permit.

If the MS4 operator does not submit a timely, appropriate, complete, and accurate NOI requesting authorization to discharge under the reissued permit or a timely request for authorization under an individual or alternative general permit, authorization under this permit will terminate on the due date for the NOI under the reissued permit unless otherwise specified in the reissued permit.

1.7. Obtaining Authorization to Discharge

1.7.1. How to Obtain Authorization to Discharge

To obtain authorization under this permit, a small MS4 shall:

- Be located in the areas listed in part 1.1 of this permit;
- Meet the eligibility requirements in part 1.2 and part 1.9;
- Submit a complete and accurate Notice of Intent (NOI) in accordance with the requirements of part 1.7.2; and
- EPA issues a written authorization.

1.7.2. Notice of Intent

- a. Operators of Small MS4s seeking authorization to discharge under the terms and conditions of this permit shall submit a Notice of Intent that contains the information identified in Appendix E. This includes operators of small MS4s that were previously authorized under the May 1, 2003 small MS4 general permit (MS4-2003 permit).
- b. The NOI shall be signed by an appropriate official (see Appendix B, Subparagraph B.11, Standard Conditions).
- c. The NOI shall contain the following certification: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, I certify that the information submitted is, to best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Print the name and title of the official, followed by signature and date.

d. The NOI shall be submitted within 90 days of the effective date of the permit. If EPA notifies an MS4 that it is designated under 40 CFR § 122.32(a) (2) or (b), the NOI shall be submitted within 180 days of receipt of notice unless granted a longer period of time by EPA.

1.7.3. Submission of Notice of Intent

a. All small MS4s shall submit a complete and accurate Notice of Intent (suggested form in Appendix E) to EPA-Region 1 at the following address:

United States Environmental Protection Agency Stormwater and Construction Permits Section (OEP06-1) Five Post Office Square, Suite 100
Boston, MA 02109

Or submitted electronically to EPA at the following email address: stormwater.reports@epa.gov

b. All small MS4s shall also submit a copy of the NOI to the MassDEP at the following address:

Massachusetts Department of Environmental Protection One Winter Street -5th Floor Boston, Massachusetts 02108 ATTN: Frederick Civian, Stormwater Coordinator

c. Late notification: A small MS4 is not prohibited from submitting a NOI after the dates provided in part 1.7.2.d. However, if a late NOI is submitted, authorization is only for discharges that occur after permit authorization is granted. EPA and MassDEP reserve the right to take enforcement actions for any unpermitted discharges. All NOIs submitted after December 21, 2020 must be submitted electronically.

1.7.4. Public Notice of NOI and Effective Date of Coverage

- a. EPA will provide a public notice and opportunity for comment on the contents of the submitted NOIs. The public comment period will be a minimum of 30 calendar days.
- b. Based on a review of a small MS4's NOI or other information, EPA may grant authorization, extend the public comment period, or deny authorization under this permit and require submission of an application for an individual or alternative NPDES permit. (See part 1.8) A small MS4 will be authorized to discharge under the terms and conditions of this permit upon receipt of notice of authorization from EPA.
- c. Permittees whose authorization to discharge under the MS4-2003 permit, which expired on May 1, 2008, has been administratively continued in accordance with the Administrative Procedure Act 5 U.S.C. § 558(c) and 40 CFR § 122.6, who wish to obtain coverage under this permit, must submit a new NOI requesting permit coverage in accordance with the requirements of part 1.7 of this permit to EPA within 90 days after the effective date of this permit. Permittees whose authorization to discharge under the expired MS4-2003 permit was administratively continued, who fail to submit a timely, complete and accurate NOI or an application for an individual NPDES permit within 90 days after the effective date of this permit will be considered to be discharging without a permit (see 40 CFR § 122.28(b)(3)(iii)).

1.8. Individual Permits and Alternative General Permits

a. EPA may require a small MS4 to apply for and obtain authorization under either an individual NPDES permit or an alternative NPDES general permit. Any interested person may petition EPA in accordance with the provisions of 40 CFR § 122.26(f) to require a small MS4 to apply for and/or obtain authorization under either an individual NPDES permit or an alternative NPDES general permit. If EPA requires a small MS4 to apply for an individual or alternative NPDES permit, EPA will notify the small MS4 in writing that a permit application is required. This notification will include a brief statement of the reasons for this decision and will provide application information and an application deadline. If a small MS4 is authorized under the MS4-2003 permit or this permit application as required by EPA, then the authorization under the MS4-2003 permit or this permit to the small MS4 is automatically terminated at the end of the date specified by EPA as the deadline

for application submittal. EPA reserves the right to take enforcement action for any unpermitted discharge.

- b. A small MS4 may request to be excluded from this general permit by applying for an individual permit or authorization under an alternative general permit. In such a case, a small MS4 shall submit an individual permit application in accordance with the requirements of 40 CFR § 122.33(b) (2) (i) or § 122.33(b) (2) (ii), with reasons supporting the request, to EPA at the address listed in part 1.7.3 of this permit. The request may be granted by issuance of an individual permit or authorization under an alternative general permit if EPA determines that the reasons stated by the small MS4 are adequate to support the request. (See 40 CFR § 122.28(b) (3)).
- c. When an individual NPDES permit is issued, or a small MS4 is authorized to discharge under an alternative NPDES general permit, authorization under this permit automatically terminates on the effective date of the individual permit or the date of authorization of coverage under the alternative general permit.

1.9. Special Eligibility Determinations

1.9.1. Documentation Regarding Endangered Species

The small MS4 shall certify eligibility regarding endangered species in the NOI required by part 1.7.2. The Stormwater Management Program (SWMP) shall include documentation supporting the permittee's eligibility determination with regard to federal Endangered and Threatened Species and Critical Habitat Protection, including:

- Results of the Appendix C U.S. Fish and Wildlife Service endangered species screening determination; and
- If applicable, a description of the measures the small MS4 shall implement to protect federally listed endangered or threatened species, or critical habitat, including any conditions imposed by the U.S. Fish and Wildlife Service. If a permittee fails to document and implement such measures, the permittee's discharges are ineligible for coverage under this permit.

1.9.2. Documentation Regarding Historic Properties

The small MS4 shall certify eligibility regarding historic properties on the NOI required by part 1.7.2. The SWMP shall include documentation supporting the small MS4's eligibility determination with regard to Historic Properties Preservation, including:

- Information on whether the permittee's stormwater discharges, allowable nonstormwater discharges, or stormwater discharge-related activities would have an effect on a property that is listed or eligible for listing on the National Register of Historic Properties (NRHP);
- Where such effects may occur, any documents received by the permittee or any written agreements the permittee has made with the State Historic Preservation Officer (SHPO), Tribal Historic Preservation Officer (THPO), or other Tribal representative to mitigate those effects;
- Results of the Appendix D historic property screening investigations; and
- If applicable, a description of the measures the permittee shall implement to avoid or minimize adverse impacts on places listed, or eligible for listing, on the NRHP, including any conditions imposed by the SHPO or THPO. If the permittee fails to

document and implement such measures, those discharges are ineligible for coverage under this permit.

1.10. Stormwater Management Program (SWMP)

a. The permittee shall develop and implement a written (hardcopy or electronic) SWMP. The SWMP shall be signed in accordance with Appendix B, Subsection 11, including the date of signature. A signature and date is required for initial program preparation and for any significant revision to the program, which shall be in writing. The written SWMP shall be completed within one (1) year of the effective date of the permit.

The SWMP is the document used by the permittee to describe and detail the activities and measures that will be implemented to meet the terms and conditions of the permit. The SWMP shall accurately describe the permittees plans and activities. The document should be updated and/or modified during the permit term as the permittee's activities are modified, changed or updated to meet permit conditions during the permit term.

b. Permittees authorized by the MS4-2003 permit shall modify or update their existing Best Management Practices (BMPs) and measurable goals to meet the terms and conditions of part 2.3 of this permit within one (1) year of the effective date of the permit. These modifications and updates shall be reflected in the written (hardcopy or electronic) SWMP. Permittees authorized by the MS4-2003 permit shall continue to implement their existing SWMP until the program has been updated.

1.10.1. Stormwater Management Program Availability

- a. The permittee shall retain a copy of the current SWMP required by this permit at the office or facility of the person listed as the program contact on the submitted Notice of Intent (NOI). The SWMP shall be immediately available to representatives from EPA, MassDEP, U.S. Fish and Wildlife Service (USFWS) and the National Marine Fisheries Service (NMFS) at the time of an onsite inspection or upon request.
- b. The permittee shall make the SWMP available to the public during normal business hours. The permittee shall also post the SWMP online¹ if the permittee has a website on which to post the SWMP.

1.10.2. Contents and Timelines of the Stormwater Management Program for 2003 permittees

The following information must be included in the SWMP within one (1) year of the permit effective date and updated annually thereafter, as necessary:

- Identification of names and titles of people responsible for program implementation. If a position is currently unfilled, list the title of the position and modify the SWMP with the name once the position is filled;
- Documentation of compliance with part 1.9.1;
- Documentation of compliance with part 1.9.2;

¹ Should a permittee not wish to post mapping information included in the SWMP (see part 1.10.2) on their website for public safety reasons, they must state the reason either with or within the online SWMP and provide how the MS4 mapping information can be obtained. The permittee must retain the entire SWMP, including all completed mapping, at a location where it can be made available to the public during normal business hours.

- Documentation of authorization of all new or increased discharges granted by MassDEP in compliance with part 2.1.2;
- Listing of all discharges identified pursuant to part 2.1.1 and description of response;
- Description of practices to achieve compliance with part 2.3 (MEP requirements) identified in the permittee's NOI and any updates to those BMPs within the first year; For each permit condition in part 2.3 identify:
 - The person(s) or department responsible for the measure;
 - The BMPs for the control measure or permit requirement;
 - The measurable goal(s) for each BMP. Each measurable goal shall include milestones and timeframes for its implementation and have a quantity or quality associated with its endpoint. Each goal shall have a measure of assessment associated with it;
- Sanitary Sewer Overflow (SSO) inventory including all of the information required in part 2.3.4.4.b;
- Written IDDE Program pursuant to part 2.3.4.6;
- Written procedures for site inspections and enforcement of sediment and erosion control procedures in accordance with part 2.3.5;
- Description of measures to avoid or minimize impacts to surface public drinking water supply sources. The permittee is also encouraged to include provisions to notify public water supplies in the event of an emergency. Massachusetts Department of Environmental Protection, Bureau of Resource Protection, Drinking Water Program, One Winter Street, Boston, MA 02108 phone 617.292.5770.
- Description of activities to achieve compliance with part 3.0;
- Annual program evaluation (part 4.1). Update annually and maintain copies.

The following information must be included in the SWMP within two (2) years of the permit effective date and updated annually thereafter, as necessary:

- Listing of all receiving waterbody segments, their classification under the applicable state water quality standards, any impairment(s) and associated pollutant(s) of concern, applicable TMDLs and WLAs, and number of outfalls from the MS4 that discharge to each waterbody. In addition to the receiving water, the permittee shall document in the SWMP all surface public drinking water sources that may be impacted by MS4 discharges;
- Listing of all interconnected MS4s and other separate storm sewer systems receiving a discharge from the permitted MS4, the receiving waterbody segment(s) ultimately receiving the discharge, their classification under the applicable state water quality standards, any impairment(s) and associated pollutant(s) of concern, applicable TMDLs and WLAs, and the number of interconnections;
- Written procedures to require submission of as-built drawings and ensure long term operation and maintenance in accordance with part 2.3.6.a.iii;
- The map of the separate storm sewer system required by part 2.3.4.5.

The following information must be included in the SWMP within four (4) years of the permit effective date and updated annually thereafter, as necessary:

• Report(s) assessing current street design and parking lot guidelines and other local requirements within the municipality that affect the creation of impervious cover.

The following information must be included in the SWMP concurrent with the applicable

deadlines in Appendix F and H and updated annually thereafter, as necessary:

- Description of practices to achieve compliance with part 2.2.1 (TMDL requirements) including:
 - The person(s) or department responsible for the measure;
 - The BMPs for the control measure or permit requirement;
 - The measurable goal(s) for each BMP. Each measurable goal shall include milestones and timeframes for its implementation and have a quantity or quality associated with its endpoint. Each goal must have an associated measure of assessment.
- Description of practices to achieve compliance with part 2.2.2 (discharges to certain water quality limited waters subject to additional requirements) including:
 - The person(s) or department responsible for the measure;
 - The BMPs for the control measure or permit requirement;
 - The measurable goal(s) for each BMP. Each measurable goal shall include milestones and timeframes for its implementation and have a quantity or quality associated with its endpoint. Each goal must have an associated measure of assessment;
- Description of any other practices to achieve compliance with part 2.1 (water quality based requirements)

1.10.3. Contents and Timelines of the Stormwater Management Program for New Permittees

- a. Permittees seeking authorization for the first time shall meet all deadlines contained in this permit except the following:
 - Timelines for public education requirements in part 2.3.2.c shall be extended by one (1) year and need to include one (1) message to each audience over the permit term;
 - The ordinances, by-laws, or other regulatory mechanisms required by parts 2.3.4, 2.3.5 and 2.3.6 shall be completed as soon as possible, but no later than three (3) years from the permit effective date; and
 - All other deadlines in part 2.3.4 shall be extended by three (3) years.
 - All other deadlines in part 2.3.5, 2.3.6 and 2.3.7 shall be extended by two (2) years.
 - All deadlines for discharges to water quality limited waters without a TMDL under part 2.2.2 shall be extended by two (2) years.

b. Contents of the Stormwater Management Program for New Permittees

The following information must be included in the SWMP within one (1) year of the permit effective date and updated annually thereafter, as necessary:

- Identification of names and titles of people responsible for program implementation. If a position is currently unfilled, list the title of the position and modify the SWMP with the name once the position is filled;
- Documentation of compliance with part 1.9.1;
- Documentation of compliance with part 1.9.2;
- Documentation of authorization of all new or increased discharges granted by MassDEP in compliance with part 2.1.2;
- Listing of all discharges identified pursuant to part 2.1.1 and description of response;
- Description of practices to achieve compliance with part 2.3 (MEP requirements) identified in the permittee's NOI and any updates to those BMPs within the first year;

For each permit condition in part 2.3 identify:

- The person(s) or department responsible for the measure;
- The BMPs for the control measure or permit requirement;
- The measurable goal(s) for each BMP. Each measurable goal shall include milestones and timeframes for its implementation and have a quantity or quality associated with its endpoint. Each goal shall have a measure of assessment associated with it;
- Description of measures to avoid or minimize impacts to surface public drinking water supply sources. The permittee is also encouraged to include provisions to notify public water supplies in the event of an emergency. Massachusetts Department of Environmental Protection, Bureau of Resource Protection, Drinking Water Program, One Winter Street, Boston, MA 02108 phone 617.292.5770. Description of activities to achieve compliance with part 3.0;
- Annual program evaluation (part 4.1). Update annually and maintain copies.

The following information must be included in the SWMP within three (3) years of the permit effective date and updated annually thereafter, as necessary:

• Written procedures for site inspections and enforcement of sediment and erosion control procedures in accordance with part 2.3.5;

The following information must be included in the SWMP within four (4) years of the permit effective date and updated annually thereafter, as necessary:

- Outfall and interconnection inventory;
- Sanitary Sewer Overflow (SSO) inventory including all of the information required in part 2.3.4.4.b;
- Written IDDE Program pursuant to part 2.3.4.6.
- Written operation and maintenance procedures for municipal activities in part 2.3.7.a.ii;
- Written program detailing the activities and procedures the permittee will implement so that the MS4 infrastructure is maintained in a timely manner to reduce the discharge of pollutants from the MS4 in accordance with part 2.3.7.a.iii.1;
- Written procedures to require submission of as-built drawings and ensure long term operation and maintenance in accordance with part 2.3.6.a.iii;

The following information must be included in the SWMP within five (5) years of the permit effective date and updated annually thereafter, as necessary:

- Phase 1 of the map of the separate storm sewer system required by part 2.3.4.5;
- Listing of all receiving waterbody segments, their classification under the applicable state water quality standards, any impairment(s) and associated pollutant(s) of concern, applicable TMDLs and WLAs, and number of outfalls from the MS4 that discharge to each waterbody. In addition to the receiving water, the permittee shall document in the SWMP all surface public drinking water sources that may be impacted by MS4 discharges;
- Listing of all interconnected MS4s and other separate storm sewer systems receiving a discharge from the permitted MS4, the receiving waterbody segment(s) ultimately receiving the discharge, their classification under the applicable state water quality standards, any impairment(s) and associated pollutant(s) of concern, applicable TMDLs and WLAs, and the number of interconnections;

The following information must be included in the SWMP within six (6) years of the permit effective date and updated annually thereafter, as necessary:

• Report(s) assessing current street design and parking lot guidelines and other local requirements within the municipality that affect the creation of impervious cover.

The following information must be included in the SWMP concurrent with the applicable deadlines in Appendix F and H (extended by two (2) years) and updated annually thereafter, as necessary:

- Description of practices to achieve compliance with part 2.2.1 (discharges subject to requirements related to approved TMDLs)including:
 - The person(s) or department responsible for the measure;
 - The BMPs for the control measure or permit requirement;
 - The measurable goal(s) for each BMP. Each measurable goal shall include milestones and timeframes for its implementation and have a quantity or quality associated with its endpoint. Each goal must have an associated measure of assessment.
- Description of practices to achieve compliance with part 2.2.2 (discharges to certain water quality limited waters subject to additional requirements) including:
 - The person(s) or department responsible for the measure;
 - The BMPs for the control measure or permit requirement;
 - The measurable goal(s) for each BMP. Each measurable goal shall include milestones and timeframes for its implementation and have a quantity or quality associated with its endpoint. Each goal must have an associated measure of assessment;
- Description of any other practices to achieve compliance with part 2.1 (water quality based requirements).

2.0. Non-Numeric Effluent Limitations

The permittee shall develop, implement, and enforce a program to reduce the discharge of pollutants from the MS4 to the maximum extent practicable; to protect water quality and to satisfy the appropriate water quality requirements of the Clean Water Act and the Massachusetts Water Quality Standards.

2.1. Water Quality Based Effluent Limitations

Pursuant to Clean Water Act 402(p)(3)(B)(iii), this permit includes provisions to ensure that discharges from the permittee's small MS4 do not cause or contribute to an exceedance of water quality standards, in addition to requirements to reduce the discharge of pollutants to the maximum extent practicable. The requirements found in this part and part 2.2 constitute appropriate water quality based effluent limits of this permit. Requirements to reduce the discharge of pollutants to the maximum extent practicable are set forth in part 2.3.

2.1.1. Requirement to Meet Water Quality Standards

a. The permittee shall reduce the discharge of pollutants such that the discharges from the MS4 do not cause or contribute to an exceedance of water quality standards.

MA MS4 General Permit

- b. If there is a discharge from the MS4 to a waterbody (or its tributaries in some cases) that is subject to an approved TMDL identified in part 2.2.1, the permittee is subject to the requirements of part 2.2.1 and Appendix F of this permit and the permittee shall comply with all applicable schedules and requirements in Appendix F. A permittee's compliance with all applicable requirements and BMP implementation schedules in Appendix F applicable to it will constitute compliance with part 2.1.1.a. of the Permit.
- c. If there is a discharge from the MS4 to a waterbody (or its tributaries in some cases) that is water quality limited (see definition in Appendix A) due to nutrients (Total Nitrogen or Total Phosphorus), metals (Cadmium, Copper, Iron, Lead or Zinc), solids (TSS or Turbidity), bacteria/pathogens (E. Coli, Enterococcus or Fecal Coliform), chloride (Chloride) or oil and grease (Petroleum Hydrocarbons or Oil and Grease) and is not subject to an approved TMDL, or the MS4 is located within a municipality listed in part 2.2.2.a.-b., the permittee is subject to the requirements of part 2.2.2 and Appendix H of this permit and the permittee shall comply with all applicable schedules and requirements in Appendix H. A permittee's compliance with all applicable requirements and BMP implementation schedules in Appendix H applicable to it will constitute compliance with part 2.1.1.a. of the Permit.
- d. Except where a pollutant of concern in a discharge is subject to the requirements of part 2.2.1 and/or part 2.2.2 of this permit or is the result of an illicit discharge and subject to part 2.3.4 of this Permit, if a pollutant in a discharge from the MS4 is causing or contributing to a violation of applicable water quality criteria² for the receiving water, the permittee shall, as expeditiously as possible, but no later than 60 days of becoming aware of the situation, reduce or eliminate the pollutant in its discharge such that the discharge meets applicable water quality criteria.

2.1.2. Increased Discharges

- a. Any increased discharge, including increased pollutant loading(s) through the MS4 to waters of the United States is subject to Massachusetts antidegradation regulations at 314 CMR 4.04. The permittee shall comply with the provisions of 314 CMR 4.04 including information submittal requirements and obtaining authorization for increased discharges where appropriate³. Any authorization of an increased discharge by MassDEP shall be incorporated into the permittee's SWMP. If an applicable MassDEP approval specifies additional conditions or requirements, then those requirements are incorporated into this permit by reference. The permittee must comply with all such requirements.
- b. There shall be no increased discharges, including increased pollutant loading(s) from the MS4 to impaired waters listed in categories 5 or 4b on the most recent Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b) unless the permittee demonstrates that there is no net increase in loading from the MS4 to the impaired water of the pollutant(s) for which the waterbody is impaired. The permittee may demonstrate compliance with this provision by *either*:
 - i. Documenting that the pollutant(s) for which the waterbody is impaired is not present in the MS4's discharge and retaining documentation of this finding with the SWMP; or

² Applicable water quality criteria are part of the state standards that have been federally approved as of the effective date of this permit and are compiled by EPA at <u>http://www.epa.gov/waterscience/standards/wqslibrary/</u>

³ Contact MassDEP for guidance on compliance with 314 CMR 4.04

- ii. Documenting that the total load of the pollutant(s) of concern from the MS4 to any impaired portion of the receiving water will not increase as a result of the activity and retaining documentation of this finding in the SWMP. Unless otherwise determined by the Permittee, USEPA or by MassDEP that additional demonstration is necessary, compliance with the requirements of part 2.2.2 and part 2.3.6 of this Permit, including all reporting and documentation requirements, shall be considered as demonstrating no net increase as required by this part.
- c. The requirements of this part are independent of permit conditions requiring reduction in discharges of pollutants as set forth in parts 2.1.1 and 2.2 (water quality based requirements) and 2.3 (requirements to reduce discharge of pollutants to the maximum extent practicable). Permittees remain subject to requirements to reduce the discharge of pollutants from the MS4 as set forth in those parts.

2.2. Discharges to Certain Impaired Waters

The permittee shall identify in the SWMP and Annual Reports all MS4 discharges, including both outfalls and interconnections to other MS4s or other separate storm sewer systems, that:

- Are subject to Total Maximum Daily Load (TMDL) related requirements as identified in part 2.2.1.
- Are subject to additional requirements to protect water quality as identified in part 2.2.2.

The discharge location from an interconnection shall be determined based on the receiving water of the outfall from the interconnected system.

2.2.1. Discharges Subject to Requirements Related to an Approved TMDL

- a. "Approved TMDLs" are those that have been approved by EPA as of the date of issuance of this permit.
- b. The MS4s specified below discharge to waters within Massachusetts that are subject to TMDLs, or in some cases, to tributaries of such waters, and shall comply with the requirements of Appendix F, part A. Appendix F identifies, by section, the provisions the permittee shall implement to be consistent with the terms of the approved TMDL. Alternatively, EPA may notify the permittee that an individual permit application is necessary in accordance with part 1.8.a.
 - ArlingtonMendonAshlandMilfordBellinghamMillisBelmontNatickBrooklineNeedhamCambridgeNewtonDedhamNorfolk
 - i. The following is a list of municipalities in the Charles River Watershed:
 - 1.

Dover	Sherborn
Foxborough	Walpole
Franklin	Waltham
Holliston	Watertown
Hopedale	Wayland
Hopkinton	Wellesley
Lexington	Weston
Lincoln	Westwood
Medfield	Wrentham
Medway	

Permittees that operate regulated MS4s located in municipalities listed above that discharge to the Charles River or its Tributaries shall meet the requirements of Appendix F, part A.I with respect to the reduction of phosphorus discharges from their MS4.

ii. The following is a list of municipalities that contain a lake or pond subject to an approved lake or pond phosphorus TMDL in the Northern Blackstone Basin, Chicopee Basin, Connecticut Basin, French Basin, Millers Basin or in the watershed of Bare Hill Pond, Flint Pond, Indian Lake, Lake Boon, Lake Quinsigamond, Leesville Pond, Salisbury Pond, Quaboag Pond or Quacumquasit Pond.

Auburn	Millbury
Charlton	Oxford
Dudley	Shrewsbury
Gardner	Spencer
Grafton	Springfield
Granby	Stow
Hadley	Templeton
Harvard	Westminster
Hudson	Winchendon
Leicester	Wilbraham
Ludlow	

1.

Permittees that operate regulated MS4s in the above municipalities that discharge to waterbodies listed on Table F-6 in Appendix F or their tributaries, and any other MS4 that discharges to waterbodies listed on Table F-6 in Appendix F or their tributaries, shall meet the requirements of Appendix F, part A.II with respect to reduction of phosphorus discharges from their MS4.

iii. The following is a list of municipalities that contain waters subject to an approved TMDL for bacteria or pathogens.

1.

Abington	Marshfield
Acushnet	Mashpee
Andover	Mattapoisett
Avon	Medfield
Barnstable	Medway
Bedford	Melrose
Bellingham	Mendon
Belmont	Milford
Berkley	Millis
Beverly	Milton
Billerica	Nahant
Bourne	Natick
Brewster	Needham
Bridgewater	New Bedford
Brockton	Newton
Brookline	Norfolk
Burlington	North Andover
Cambridge	Norton
Canton	Norwell
Chatham	Norwood
Cohasset	Orleans
Concord	Peabody
Danvers	Pembroke
Dartmouth	Plymouth
Dedham	Raynham
Dennis	Rehoboth
Dighton	Revere
Dover	Rockland
Duxbury	Rockport
East Bridgewater	Salem
Eastham	Sandwich
Essex	Saugus
Everett	Scituate
Fairhaven	Seekonk
Fall River	Sharon
Falmouth	Sherborn
Foxborough	Somerset
Franklin	Stoughton

1.

Freetown	Swampscott
Gloucester	Swansea
Hanover	Taunton
Hanson	Tewksbury
Harwich	Wakefield
Holliston	Walpole
Hopedale	Waltham
Hopkinton	Wareham
Ipswich	Watertown
Kingston	Wellesley
Lawrence	Wellfleet
Lexington	West Bridgewater
Lincoln	Weston
Lynn	Westport
Lynnfield	Westwood
Malden	Whitman
Manchester	Wilmington
Mansfield	Winthrop
Marblehead	Yarmouth
Marion	

The operators of MS4s located in municipalities listed above that discharge to a waterbody segment listed on Table F-8 in Appendix F and any other MS4 that discharges directly to a waterbody segment listed on Table F-8 in Appendix F shall meet the requirements of Appendix F, part A.III with respect to reduction of bacteria/pathogens discharges from their MS4.

iv. The following is a list of municipalities located on Cape Cod that contain waters subject to an approved TMDL for nitrogen (Total Nitrogen).

Bourne
Barnstable
Chatham
Falmouth
Harwich
Mashpee
Orleans
Yarmouth

Permittees that operate regulated MS4s located in the municipalities above that discharge to waterbodies found on Table F-9 in Appendix F or their tributaries and any other MS4 that discharges to waterbodies found on Table F-9 in Appendix F or their

tributaries shall meet the requirements of Appendix F, part A.IV with respect to reduction of nitrogen discharges from their MS4.

v. The following is a list of municipalities located in the Assabet River Watershed:

Acton	Hudson
Berlin	Littleton
Bolton	Marlborough
Boxborough	Maynard
Boylston	Northborough
Ca rlisle	Shrewsbury
Clinton	Stow
Concord	Westborough
Grafton	Westford
Harvard	

1.

Permittees that operate regulated MS4s located in the municipalities above that discharge to the Assabet River or its tributaries shall meet the requirements of Appendix F part A.V with respect to reduction of phosphorus discharges from their MS4.

- c. The MS4s specified below discharge to waters, or tributaries of waters, that have been identified in an adjacent state's approved TMDL as being impaired due, in part, to MS4 stormwater discharges in Massachusetts, and shall comply with the requirements of Appendix F, part B. Appendix F identifies, by section, the provisions the permittee shall implement to be consistent with the reasonable assumptions related to Massachusetts MS4 discharges. Alternatively, EPA may notify the permittee that an individual permit application is necessary in accordance with part 1.8.a.
 - i. The following is a list of municipalities in Massachusetts located in the watershed of Long Island Sound, which has an approved TMDL for nitrogen (Total Nitrogen).

Adams	North Adams
Agawam	Northampton
Amherst	Oxford
Ashburnham	Palmer
Ashby	Paxton
Auburn	Pelham
Belchertown	Pittsfield
Charlton	Richmond
Cheshire	Russell
Chicopee	Rutland
Dalton	South Hadley
Douglas	Southampton

1.

Dudley	Southbridge
East Longmeadow	Southwick
Easthampton	Spencer
Gardner	Springfield
Granby	Sturbridge
Hadley	Sutton
Hampden	Templeton
Hatfield	Ware
Hinsdale	Webster
Holyoke	West Springfield
Lanesborough	Westfield
Leicester	Westhampton
Lenox	Westminster
Longmeadow	Wilbraham
Ludlow	Williamsburg
Millbury	Winchendon
Monson	

Permittees that operate regulated MS4s located in the municipalities above that discharge to a water within the Connecticut River Watershed, the Housatonic River Watershed, or the Thames River Watershed shall meet the requirements of Appendix F part B. I with respect to nitrogen discharges from their MS4.

ii. The following is a list of municipalities in Massachusetts identified in a TMDL as containing MS4s contributing phosphorus to waterbody segments that have out of state approved TMDLs for phosphorus:

At	tleboro
No	orth Attleborough
Pla	ainville
Re	hoboth
Se	ekonk
Sv	vansea

Permittees that operate regulated MS4s located in the municipalities above that discharge to a waterbody found on Table F-12 in Appendix F or its tributaries shall meet the requirements of Appendix F part B. II with respect to phosphorus discharges from their MS4.

iii. The following is a list of municipalities in Massachusetts identified in a TMDL as containing MS4s contributing bacteria/pathogens to waterbody segments that have out of state approved TMDLs for bacteria/pathogens:

1. Attleboro

1.

1.

North Attleborough	
Plainville	
Rehoboth	
Seekonk	

Permittees that operate regulated MS4s located in the municipalities above that discharge to a waterbody found on Table F-13 in Appendix F or its tributaries shall meet the requirements of Appendix F part B. III with respect to bacteria/pathogens discharges from their MS4.

iv. The following is a list of municipalities in Massachusetts identified in a TMDL as containing MS4s contributing metals (cadmium, lead, aluminum iron) to waterbody segments that have out of state approved TMDLs for metals (cadmium, lead, aluminum, iron):

Attleboro
North Attleborough
Plainville
Seekonk

Permittees that operate regulated MS4s located in the municipalities above that discharge to a waterbody found on Table F-14 in Appendix F or its tributaries shall meet the requirements of Appendix F part B. IV with respect to metals discharges from their MS4.

2.2.2. Discharges to Certain Water Quality Limited Waters Subject to Additional Requirements

For purposes of this permit, a 'water quality limited water body' is any water body that does not meet applicable water quality standards, including but not limited to waters listed in categories 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b).

If there is a discharge from the MS4 to a water quality limited waterbody where pollutants typically found in stormwater (specifically nutrients (Total Nitrogen or Total Phosphorus), solids (TSS or Turbidity), bacteria/pathogens (E. Coli, Enteroccus or Fecal Coliform), chloride (Chloride), metals (Cadmium, Copper, Iron, Lead or Zinc) and oil and grease (Petroleum Hydrocarbons or Oil and Grease)) are the cause of the impairment and there is not an approved TMDL, or the MS4 is located in a town listed in part 2.2.2.a.-b, the permittee shall comply with the provisions in Appendix H applicable to it.

In the absence of a defined pollutant reduction target and where no approved TMDL has been established, this permit part and Appendix H define an iterative approach addressing pollutant reductions to waterbodies where the permittee's discharge is causing or contributing to an excursion above water quality standards due to nutrients (Total Nitrogen Total Phosphorus), solids (TSS or Turbidity), bacteria/pathogens (E. Coli, Enteroccus or Fecal Coliform), chloride (Chloride), metals (Cadmium, Copper, Iron, Lead or Zinc) or oil and grease (Petroleum Hydrocarbons or Oil and Grease).

- a. Discharges to water quality limited waterbodies where nitrogen (Total Nitrogen) is the cause of the impairment, or their tributaries
 - i. The requirements of this part are applicable to:
 - 1. Permittees (including traditional and non-traditional MS4s) that own or operate an MS4 in the following municipalities. Discharges from MS4s within these municipalities are to waterbodies that are impaired due to nitrogen (Total Nitrogen), or their tributaries.

Abington	Mattapoisett
Acushnet	Middleborough
Attleboro	New Bedford
Avon	Norton
Barnstable	Peabody
Berkley	Pembroke
Bourne	Plainville
Bridgewater	Plymouth
Brockton	Plympton
Carver	Raynham
Dartmouth	Rehoboth
Dighton	Rochester
East Bridgewater	Salem
Easton	Seekonk
Fairhaven	Sharon
Fall River	Somerset
Foxborough	Stoughton
Freetown	Swansea
Halifax	Taunton
Hanson	Wakefield
Holbrook	Wareham
Kingston	West Bridgewater
Lakeville	Westport
Lynnfield	Whitman
Mansfield	Wrentham
Marion	Yarmouth

- 2. Any other permittee that, during the permit term, becomes aware that its discharge is to a waterbody that is water quality limited due to nitrogen (Total Nitrogen), or a tributary of such water.
- ii. Permittees subject to part 2.2.2.a.i above shall meet the requirements of Appendix H part I with respect to the control of nitrogen discharges from their MS4;

- iii. During development of their Notice of Intent, the permittee may determine that all discharges from the regulated area through their MS4 are outside of a watershed that contains a nitrogen (Total Nitrogen) impairment in a downstream segment. The permittee shall retain all documentation used in this determination as part of their NOI and are relieved from the requirements of part 2.2.2.a.i and Appendix H part I.
- b. Discharges to water quality limited waterbodies where phosphorus ("Total Phosphorus") is the cause of the impairment, or their tributaries
 - i. The requirements of this part are applicable to:
 - 1. Permittees (including traditional and non-traditional MS4s) that own or operate an MS4 in the following municipalities. Discharges from MS4s within these municipalities are to waterbodies that are impaired due to phosphorus (Total Phosphorus), or their tributaries.

Abington	Lynn
Acushnet	Lynnfield
Andover	Malden
Arlington	Mansfield
Ashburnham	Marlborough
Ashland	Mashpee
Auburn	Medfield
Avon	Medford
Ayer	Melrose
Barnstable	Mendon
Bedford	Methuen
Belchertown	Millbury
Belmont	Millville
Billerica	Milton
Blackstone	North Andover
Bolton	Northbridge
Brewster	Norton
Bridgewater	Norwood
Brockton	Oxford
Burlington	Peabody
Cambridge	Pembroke
Canton	Pepperell
Carlisle	Pittsfield
Carver	Quincy
Chelmsford	Randolph
Chelsea	Reading

Clinton	Revere
Concord	Rockland
Dalton	Salem
Dedham	Scituate
Douglas	Seekonk
Dover	Sharon
Dracut	Shirley
Dunstable	Shrewsbury
East Bridgewater	Somerville
Eastham	Southampton
Easthampton	Spencer
Everett	Springfield
Falmouth	Stoneham
Fitchburg	Stoughton
Foxborough	Sudbury
Framingham	Sutton
Gloucester	Taunton
Grafton	Tewksbury
Granby	Townsend
Groton	Tyngsborough
Halifax	Upton
Hanover	Uxbridge
Hanson	Wakefield
Harvard	Walpole
Haverhill	Wareham
Hinsdale	Watertown
Hopkinton	Wayland
Hudson	West Bridgewater
Lancaster	Westfield
Lawrence	Westminster
Leicester	Westwood
Lenox	Whitman
Leominster	Wilmington
Lexington	Winchendon
Littleton	Winchester
Lowell	Winthrop
Lunenburg	Woburn
Lynn	

- 2. Any other permittee that, during the permit term, becomes aware that its discharge is to a waterbody that is water quality limited due to phosphorus ("Total Phosphorus"), or to a tributary of such water.
- ii. The permittees subject to part 2.2.2.b.i. above shall meet all requirements of Appendix H part II with respect to the control of phosphorus discharges from the MS4.
- iii. During development of their Notice of Intent, the permittee may determine that all discharges from the regulated area through their MS4 are outside of a watershed that contains a phosphorus ("Total Phosphorus") impairment in a downstream segment. The permittee shall retain all documentation used in this determination as part of their NOI and are relieved from the requirements of part 2.2.2.b.i and Appendix H part II.
- c. Discharges to water quality limited waterbodies where bacteria or pathogens is the cause of the impairment
 - i. The requirements of this part are applicable to:
 - 1. Any MS4 discharge identified by the permittee on their Notice of Intent as discharging directly to an impaired waterbody on the most recent EPA approved Massachusetts 303(d) list where bacteria or pathogens (E. Coli, Enteroccus or Fecal Coliform) is the cause of the impairment.
 - 2. Any other MS4 that, during the permit term, becomes aware that its discharge is to a waterbody that is water quality limited due to bacteria or pathogens.
 - ii. The permittees subject to part 2.2.2.c.i. shall meet all requirements of Appendix H part III with respect to reduction of bacteria or pathogens discharges from the MS4.
- d. Discharges to water quality limited waterbodies where chloride (Chloride) is the cause of the impairment
 - i. The requirements of this part are applicable to:
 - 1. Any MS4 discharge identified by the permittee on their Notice of Intent as discharging directly to an impaired waterbody on the most recent EPA approved Massachusetts 303(d) list where chloride (Chloride) is the cause of the impairment.
 - 2. Any other MS4 that, during the permit term, becomes aware that its discharge is to a waterbody that is water quality limited due to chloride (Chloride).
 - ii. The permittees subject to part 2.2.2.d.i. shall meet all requirements of Appendix H part IV with respect to reduction of chloride discharges from the MS4.
- e. Discharges to water quality limited waterbodies where oil and grease (Petroleum Hydrocarbons or Oil and Grease), solids (TSS or Turbidity) or metals (Cadmium, Copper, Iron, Lead or Zinc) is the cause of the impairment
 - i. The requirements of this part are applicable to:
 - 1. Any MS4 discharge identified by the permittee on their Notice of Intent as discharging directly to an impaired waterbody on the most recent EPA

approved Massachusetts 303(d) list where oil and grease, solids or metals (Oil and Grease, Petroleum Hydrocarbons TSS, Turbidity, Cadmium, Copper, Iron, Lead or Zinc) is the cause of the impairment.

- 2. Any other MS4 that, during the permit term, becomes aware that its discharge is to a waterbody that is water quality limited due to oil and grease (Petroleum Hydrocarbons or Oil and Grease), solids (TSS or Turbidity) or metals (Cadmium, Copper, Iron, Lead or Zinc).
- ii. The permittees subject to part 2.2.2.d.i. shall meet all requirements of Appendix H part V with respect to reduction of solids, oil and grease or metals discharges from the MS4.

2.3. Requirements to Reduce Pollutants to the Maximum Extent Practicable (MEP)

The permittee shall reduce the discharge of pollutants from the MS4 to the maximum extent practicable (MEP) as detailed in parts 2.3.2 through 2.3.7.

2.3.1. Control Measures

- a. Permittees authorized under the MS4-2003 permit shall continue to implement their existing SWMPs while updating their SWMPs pursuant to this permit. This permit does not extend the compliance deadlines set forth in the MS4-2003 permit.
- b. Implementation of one or more of the minimum control measures described in parts 2.3.2- 2.3.7 or other permit requirements may be shared with another entity (including another interconnected MS4) or the other entity may fully implement the measure or requirement, if the following requirements are satisfied:
 - The other entity, in fact, implements the control measure.
 - The particular control measure or component thereof undertaken by the other entity is at least as stringent as the corresponding permit requirement.
 - The other entity agrees to implement the control measure on the permittee's behalf. The annual reports must specify that the permittee is relying on another entity to satisfy some of its permit obligations and specify what those obligations are.
 - If the permittee is relying on another governmental entity regulated under 40 CFR §122 to satisfy all of its permit obligations, including the obligation to file annual reports, the permittee shall note that fact in its NOI, but is not required to file annual reports.
 - The permittee remains responsible for compliance with all permit obligations if the other entity fails to implement the control measures (or component thereof). The permittee may enter into a legally binding agreement with the other entity regarding the other entity's performance of control measures, but the permittee remains ultimately responsible for permit compliance.

2.3.2. Public Education and Outreach

Objective: The permittee shall implement an education program that includes educational goals based on stormwater issues of significance within the MS4 area. The ultimate objective of a public education program is to increase knowledge and change behavior of the public so that pollutants in stormwater are reduced.

MA MS4 General Permit

- a. The permittee shall continue to implement the public education program required by the MS4-2003 permit by distributing educational material to the MS4 community. The educational program shall define educational goals, express specific messages, define the targeted audience for each message, and identify responsible parties for program implementation. If appropriate for the target audience, materials may be developed in a language other than English. At a minimum, the program shall provide information concerning the impact of stormwater discharges on water bodies within the community, especially those waters that are impaired or identified as priority waters. The program shall identify steps and/or activities that the public can take to reduce the pollutants in stormwater runoff and their impacts to the environment.
- b. The educational program shall include education and outreach efforts for the following four audiences: (1) residents, (2) businesses, institutions (churches, hospitals), and commercial facilities, (3) developers (construction), and (4) industrial facilities, unless one of these audiences is not present in the MS4 community. In such a situation, the MS4 must document in both the NOI and SWMP which audience is absent from the community and no educational messages are required to that audience.
- c. The permittee shall distribute a minimum of two (2) educational messages over the permit term to each audience identified in part 2.3.2.b. The distribution of materials to each audience shall be spaced at least a year apart. Educational messages may be printed materials such as brochures or newsletters; electronic materials such as websites; mass media such as newspaper articles or public service announcement (radio or cable); targeted workshops on stormwater management, or displays in a public area such as town/city hall. The permittee may use existing materials if they are appropriate for the message the permittee chooses to deliver or the permittee may develop its own educational materials. The permittee may partner with other MS4s, community groups or watershed associations to implement the education program to meet this permit requirement.

Some EPA educational materials are available at: <u>http://cfpub.epa.gov/npstbx/index.html</u>.

- d. The permittee shall, at a minimum, consider the topics listed in part 2.3.2.d.i. iv when developing the outreach/education program. The topics are not exclusive and the permittee shall focus on those topics most relevant to the community.
 - i. Residential program: effects of outdoor activities such as lawn care (use of pesticides, herbicides, and fertilizers and information on Massachusetts Regulation 331 CMR 31 pertaining to proper use of phosphorus containing fertilizers on turf grasses) on water quality; benefits of appropriate on-site infiltration of stormwater; effects of automotive work and car washing on water quality; proper disposal of swimming pool water; proper management of pet waste; maintenance of septic systems. If the small MS4 area has areas serviced by septic systems, the permittee shall consider information pertaining to maintenance of septic systems as part of its education program.
 - ii. Business/Commercial/Institution program: proper lawn maintenance (use of pesticides, herbicides and fertilizer, and information on Massachusetts Regulation 331 CMR 31 pertaining to proper use of phosphorus containing fertilizers on turf grasses); benefits of appropriate on-site infiltration of stormwater; building maintenance (use of detergents); use of salt or other de-icing and anti-icing materials (minimize their use); proper storage of salt or other de-icing/anti-icing materials (cover/prevent runoff to storm system and contamination to ground water); proper storage of materials (emphasize pollution prevention); proper management of waste materials and dumpsters (cover and pollution

prevention); proper management of parking lot surfaces (sweeping); proper car care activities (washing of vehicles and maintenance); and proper disposal of swimming pool water by entities such as motels, hotels, and health and country clubs (discharges must be dechlorinated and otherwise free from pollutants).

- iii. Developers and Construction: proper sediment and erosion control management practices; information about Low Impact Development (LID) principles and technologies; and information about EPA's construction general permit (CGP). This education can also be a part of the Construction Site Stormwater Runoff Control measure detailed in part 2.3.5.
- iv. Industrial program: equipment inspection and maintenance; proper storage of industrial materials (emphasize pollution prevention); proper management and disposal of wastes; proper management of dumpsters; minimization of use of salt or other de-icing/anti-icing materials; proper storage of salt or other de-icing/anti-icing materials (cover/prevent runoff to storm system and ground water contamination); benefits of appropriate on-site infiltration of stormwater runoff from areas with low exposure to industrial materials such as roofs or employee parking; proper maintenance of parking lot surfaces (sweeping); and requirements for coverage under EPA's Multi-Sector General Permit.
- e. The program shall show evidence of focused messages for specific audiences as well as evidence that progress toward the defined educational goals of the program has been achieved. The permittee shall identify methods that it will use to evaluate the effectiveness of the educational messages and the overall education program. Any methods used to evaluate the effectiveness of the program shall be tied to the defined goals of the program and the overall objective of changes in behavior and knowledge.
- f. The permittee shall modify any ineffective messages or distribution techniques for an audience prior to the next scheduled message delivery.
- g. The permittee shall document in each annual report the messages for each audience; the method of distribution; the measures/methods used to assess the effectiveness of the messages, and the method/measures used to assess the overall effectiveness of the education program.

2.3.3. Public Involvement and Participation

Objective: The permittee shall provide opportunities to engage the public to participate in the review and implementation of the permittee's SWMP.

- a. All public involvement activities shall comply with state public notice requirements (MGL Chapter 30A, Sections 18 25 effective 7/10/2010). The SWMP and all annual reports shall be available to the public.
- b. The permittee shall annually provide the public an opportunity to participate in the review and implementation of the SWMP.
- c. The permittee shall report on the activities undertaken to provide public participation opportunities including compliance with part 2.3.3.a. Public participation opportunities pursuant

to part 2.3.3.b may include, but are not limited to, websites; hotlines; clean-up teams; monitoring teams; or an advisory committee.

2.3.4. Illicit Discharge Detection and Elimination (IDDE) Program

Objective: The permittee shall implement an IDDE program to systematically find and eliminate sources of non-stormwater discharges to its municipal separate storm sewer system and implement procedures to prevent such discharges.

- a. <u>Legal Authority</u> The IDDE program shall include adequate legal authority to: prohibit illicit discharges; investigate suspected illicit discharges; eliminate illicit discharges, including discharges from properties not owned by or controlled by the MS4 that discharge into the MS4 system; and implement appropriate enforcement procedures and actions. Adequate legal authority consists of a currently effective ordinance, by-law, or other regulatory mechanism. For permittees authorized by the MS4-2003 permit, the ordinance, by-law, or other regulatory mechanism was a requirement of the MS4-2003 permit and was required to be effective by May 1, 2008. For new permittees the ordinance, by-law, or other regulatory mechanism shall be in place within 3 years of the permit effective date.
- b. During the development of the new components of the IDDE program required by this permit, permittees authorized by the MS4-2003 permit must continue to implement their existing IDDE program required by the MS4-2003 permit to detect and eliminate illicit discharges to their MS4.

2.3.4.1. Definitions and Prohibitions

The permittee shall prohibit illicit discharges and sanitary sewer overflows (SSOs) to its MS4 and require removal of such discharges consistent with parts 2.3.4.2 and 2.3.4.4 of this permit.

An SSO is a discharge of untreated sanitary wastewater from a municipal sanitary sewer.

An illicit discharge is any discharge to a municipal separate storm sewer that is not composed entirely of stormwater, except discharges pursuant to a NPDES permit (other than the NPDES permit for discharges from the municipal separate storm sewer) and discharges resulting from fire fighting activities.

2.3.4.2. Elimination of Illicit Discharges

- a. Upon detection of an illicit discharge, the permittee shall locate, identify and eliminate the illicit discharge as expeditiously as possible. Upon identification of the illicit source the MS4 notify all responsible parties for any such discharge and require immediate cessation of improper disposal practices in accordance with its legal authorities. Where elimination of an illicit discharge within 60 days of its identification as an illicit discharge is not possible, the permittee shall establish an expeditious schedule for its elimination and report the dates of identification and schedules for removal in the permittee's annual reports. The permittee shall immediately commence actions necessary for elimination. The permittee shall diligently pursue elimination of all illicit discharges. In the interim, the permittee shall take all reasonable and prudent measures to minimize the discharge of pollutants to and from its MS4.
 - b. The period between identification and elimination of an illicit discharge is not a grace period. Discharges from an MS4 that are mixed with an illicit discharge are not authorized by this Permit (part 1.3.a) and remain unlawful until eliminated.

2.3.4.3. Non-Stormwater Discharges

The permittee may presume that the sources of non-stormwater listed in part 1.4 of this permit need not be addressed. However, if the permittee identifies any of these sources as significant contributors of pollutants to the MS4, then the permittee shall implement measures to control these sources so they are no longer significant contributors of pollutants, and/or eliminate them entirely, consistent with part 2.3.4.

2.3.4.4. Sanitary Sewer Overflows

- a. Upon detection of an SSO the permittee shall eliminate it as expeditiously as possible and take interim mitigation measures to minimize the discharge of pollutants to and from its MS4 until elimination is completed.
- b. The permittee shall identify all known locations where SSOs have discharged to the MS4 within the previous five (5) years. This shall include SSOs resulting, during dry or wet weather, from inadequate conveyance capacities, or where interconnectivity of the storm and sanitary sewer infrastructure allows for communication of flow between the systems. Within one (1) year of the effective date of the permit, the permittee shall develop an inventory of all identified SSOs indicating the following information, if available:
 - 1. Location (approximate street crossing/address and receiving water, if any);
 - 2. A clear statement of whether the discharge entered a surface water directly or entered the MS4;
 - 3. Date(s) and time(s) of each known SSO occurrence (i.e., beginning and end of any known discharge);
 - 4. Estimated volume(s) of the occurrence;
 - 5. Description of the occurrence indicating known or suspected cause(s);
 - 6. Mitigation and corrective measures completed with dates implemented; and
 - 7. Mitigation and corrective measures planned with implementation schedules.

The permittee shall maintain the inventory as a part of the SWMP and update the inventory annually, all updates shall include the information in part 2.3.4.4.b.1-7.

- c. In accordance with Paragraph B.12 of Appendix B of this permit, upon becoming aware of an SSO to the MS4, the permittee shall provide oral notice to EPA within 24 hours. Additionally, the permittee shall provide written notice to EPA and MassDEP within five (5) days of becoming aware of the SSO occurrence and shall include the information in the updated inventory. The notice shall contain all of the information listed in part 2.3.4.4.b. Where common notification requirements for SSOs are included in multiple NPDES permits issued to a permittee, a single notification may be made to EPA as directed in the permittee's wastewater or CSO NPDES permit and constitutes compliance with this part.
- d. The permittee shall include and update the SSO inventory in its annual report, including the status of mitigation and corrective measures implemented by the permittee to address each SSO identified pursuant to this part.
- e. The period between detection and elimination of a discharge from the SSO to the MS4 is not a grace period. Discharges from an MS4 that are mixed with an SSO are not authorized by this Permit (part 1.3.a) and remain unlawful until eliminated.

2.3.4.5. System mapping

The permittee shall develop a revised and more detailed map than was required by the MS4-2003 permit. This revised map of the MS4 shall be completed in two phases as outlined below. The mapping shall include a depiction of the permittee's separate storm sewer system in the permit area. The mapping is intended to facilitate the identification of key infrastructure and factors influencing proper system operation, and the potential for illicit sanitary sewer discharges.

- a. Phase I: The system map shall be updated within two (2) years of the permit effective date to include the following information:
 - Outfalls and receiving waters (required by MS4-2003 permit)
 - Open channel conveyances (swales, ditches, etc.)
 - Interconnections with other MS4s and other storm sewer systems
 - Municipally-owned stormwater treatment structures (e.g., detention and retention basins, infiltration systems, bioretention areas, water quality swales, gross particle separators, oil/water separators, or other proprietary systems)
 - Waterbodies identified by name and indication of all use impairments as identified on the most recent EPA approved Massachusetts Integrated List of waters report pursuant to Clean Water Act section 303(d) and 305(b)
 - Initial catchment delineations. Any available system data and topographic information may be used to produce initial catchment delineations. For the purpose of this permit, a catchment is the area that drains to an individual outfall or interconnection.
- b. Phase II: The system map shall be updated annually as the following information becomes available during implementation of catchment investigation procedures in part 2.3.4.8. This information must be included in the map for all outfalls within ten (10) years of the permit effective date:
 - Outfall spatial location (latitude and longitude with a minimum accuracy of +/-30 feet)
 - Pipes
 - Manholes
 - Catch basins
 - Refined catchment delineations. Catchment delineations shall be updated to reflect information collected during catchment investigations
 - Municipal sanitary sewer system (if available)
 - Municipal combined sewer system (if applicable).
- c. Recommended elements to be included in the system map as information becomes available:
 - Storm sewer material, size (pipe diameter) and age
 - Sanitary sewer system material, size (pipe diameter) and age
 - Privately-owned stormwater treatment structures
 - Where a municipal sanitary sewer system exists, properties known or suspected to be served by a septic system, especially in high-density urban areas
 - Area where the permittee's MS4 has received or could receive flow from septic system discharges (e.g., areas with poor soils, or high ground water elevations unsuitable for conventional subsurface disposal systems)
 - Seasonal high water table elevations impacting sanitary alignments
 - Topography
 - Orthophotography

- Alignments, dates and representation of work completed (with legend) of past illicit discharge investigations (e.g., flow isolation, dye testing, CCTV)
- Locations of suspected, confirmed and corrected illicit discharges (with dates and flow estimates).
- d. The mapping may be produced by hand or through computer-aided methods (e.g. GIS). The required scale and detail of the map shall be appropriate to facilitate a rapid understanding of the system by the permittee, EPA and the state. In addition, the mapping shall serve as a planning tool for the implementation and phasing of the IDDE program and demonstration of the extent of complete and planned investigations and corrections. The permittee shall update the mapping as necessary to reflect newly discovered information and required corrections or modifications.
- e. The permittee shall report on the progress towards the completion of the system map in each annual report.

2.3.4.6. Written Illicit Discharge Detection and Elimination Program

The IDDE program shall be recorded in a written (hardcopy or electronic) document. The IDDE program shall include each of the elements described in parts 2.3.4.7 and part 2.3.4.8, unless the permittee provides a written explanation within the IDDE program as to why a particular element is not applicable to the permittee.

Notwithstanding the permittee's explanation, EPA may at any time determine that a particular element is in fact applicable to the permittee and require the permittee to add it to the IDDE program. The written (hardcopy or electronic) IDDE program shall be completed within one (1) year of the effective date of the permit and updated in accordance with the milestones of this part. The permittee shall implement the IDDE program in accordance with the goals and milestones contained in this part.

- a. The written (hardcopy or electronic) IDDE program shall include a reference or citation of the authority the permittee will use to implement all aspects of the IDDE program.
- b. <u>Statement of IDDE Program Responsibilities</u> The permittee shall establish a written (hardcopy or electronic) statement that clearly identifies responsibilities with regard to eliminating illicit discharges. The statement shall identify the lead municipal agency(ies) or department(s) responsible for implementing the IDDE Program as well as any other agencies or departments that may have responsibilities for aspects of the program (e.g., board of health responsibilities for overseeing septic system construction; sanitary sewer system staff; inspectional services for enforcing plumbing codes; town counsel responsibilities in enforcement actions, etc.). Where multiple departments and agencies have responsibilities with respect to the IDDE program specific areas of responsibility shall be defined and processes for coordination and data sharing shall be established and documented.
- c. <u>Program Procedures</u> The permittee shall include in the written IDDE program all written procedures developed in accordance with the requirements and timelines in parts 2.3.4.7 and 2.3.4.8 below. At a minimum this shall include the written procedures for dry weather outfall screening and sampling and for catchment investigations.

2.3.4.7. Assessment and Priority Ranking of Outfalls/Interconnections

The permittee shall assess and priority rank the outfalls in terms of their potential to have illicit discharges and SSOs and the related public health significance. This ranking will determine the priority order for

screening of outfalls and interconnections pursuant to part 2.3.4.7.b, catchment investigations for evidence of illicit discharges and SSOs pursuant to part 2.3.4.8, and provides the basis for determining permit milestones of this part.

a. <u>Outfall/Interconnection Inventory and Initial Ranking:</u>

An initial outfall and interconnection inventory and priority ranking to assess illicit discharge potential based on existing information shall be completed within one (1) year from the effective date of the permit; an updated inventory and ranking will be provided in each annual report thereafter. The inventory shall be updated annually to include data collected in connection with the dry weather screening and other relevant inspections conducted by the permittee.

- i. The outfall and interconnection inventory will identify each outfall and interconnection discharging from the MS4, record its location and condition, and provide a framework for tracking inspections, screenings and other activities under the permittee's IDDE program.
 - An outfall means a point source as defined by 40 CFR § 122.2 as the point where the municipal separate storm sewer discharges to waters of the United States. An outfall does not include open conveyances connecting two municipal separate storm sewers or pipes, tunnels or other conveyances that connect segments of the same stream or other waters of the United States and that are used to convey waters of the United States. (40 CFR § 122.26(b)(9)). However, it is strongly recommended that a permittee inspect all accessible portions of the system as part of this process. Culverts longer than a simple road crossing shall be included in the inventory unless the permittee can confirm that they are free of any connections and simply convey waters of the United States.
 - An interconnection means the point (excluding sheet flow over impervious surfaces) where the permittee's MS4 discharges to another MS4 or other storm sewer system, through which the discharge is conveyed to waters of the United States or to another storm sewer system and eventually to a water of the United States.
- ii. The permittee shall classify each of the permittee's outfalls and interconnections into one of the following categories:
 - <u>Problem Outfalls:</u> Outfalls/interconnections with known or suspected contributions of illicit discharges based on existing information shall be designated as Problem Outfalls. This shall include any outfalls/interconnections where previous screening indicates likely sewer input.⁴ Problem Outfalls need not be screened pursuant to part 2.3.4.7.b.
 - <u>High Priority Outfalls</u>: Outfalls/interconnections that have not been classified as Problem Outfalls and that are:
 - discharging to an area of concern to public health due to proximity of public beaches, recreational areas, drinking water supplies or shellfish beds;
 - determined by the permittee as high priority based on the characteristics listed below or other available information;
 - <u>Low Priority Outfalls</u>: Outfalls/interconnections determined by the permittee as low priority based on the characteristics listed below or other available information.
 - <u>Excluded outfalls</u>: Outfalls/interconnections with no potential for illicit discharges may be

⁴ Likely sewer input indicators are any of the following:

- Olfactory or visual evidence of sewage,
- Ammonia ≥ 0.5 mg/L, surfactants ≥ 0.25 mg/L, and bacteria levels greater than the water quality criteria applicable to the receiving water, or
- Ammonia ≥ 0.5 mg/L, surfactants ≥ 0.25 mg/L, and detectable levels of chlorine.

excluded from the IDDE program. This category is limited to roadway drainage in undeveloped areas with no dwellings and no sanitary sewers; drainage for athletic fields, parks or undeveloped green space and associated parking without services; cross-country drainage alignments (that neither cross nor are in proximity to sanitary sewer alignments) through undeveloped land.

- iii. The permittee shall priority rank outfalls into the categories above (except for excluded outfalls), based on the following characteristics of the defined initial catchment area where information is available:
 - Past discharge complaints and reports.
 - Poor receiving water quality- the following guidelines are recommended to identify waters as having a high illicit discharge potential: exceeding water quality standards for bacteria; ammonia levels above 0.5 mg/l; surfactants levels greater than or equal to 0.25 mg/l.
 - Density of generating sites- Generating sites are those places, including institutional, municipal, commercial, or industrial sites, with a potential to generate pollutants that could contribute to illicit discharges. Examples of these sites include, but are not limited to, car dealers; car washes; gas stations; garden centers; and industrial manufacturing areas.
 - Age of development and infrastructure Industrial areas greater than 40 years old and areas where the sanitary sewer system is more than 40 years old will probably have a high illicit discharge potential. Developments 20 years or younger will probably have a low illicit discharge potential.
 - Sewer conversion contributing catchment areas that were once serviced by septic systems, but have been converted to sewer connections may have a high illicit discharge potential.
 - Historic combined sewer systems contributing areas that were once serviced by a combined sewer system, but have been separated may have a high illicit discharge potential.
 - Surrounding density of aging septic systems Septic systems thirty years or older in residential land use areas are prone to have failures and may have a high illicit discharge potential.
 - Culverted streams any river or stream that is culverted for distances greater than a simple roadway crossing may have a high illicit discharge potential.
 - Water quality limited waterbodies that receive a discharge from the MS4 or waters with approved TMDLs applicable to the permittee, where illicit discharges have the potential to contain the pollutant identified as the cause of the water quality impairment.
 - The permittee may also consider additional relevant characteristics, including location-specific characteristics; if so, the permittee shall include the additional characteristics in its written (hardcopy or electronic) IDDE program.

b. Dry Weather Outfall and Interconnection Screening and Sampling

All outfalls/interconnections (excluding Problem and excluded Outfalls) shall be inspected for the presence of dry weather flow within three (3) years of the permit effective date. The permittee shall screen all High and Low Priority Outfalls in accordance with their initial ranking developed at part 2.3.4.7.a.

- i. <u>Written procedure</u>: The permittee shall develop an outfall and interconnection screening and sampling procedure to be included in the IDDE program within one (1) year of the permit effective date. This procedure shall include the following procedures for:
 - sample collection,
 - use of field kits,

- storage and conveyance of samples (including relevant hold times), and
- field data collection and storage.

An example screening and sampling protocol (*EPA New England Bacterial Source Tracking Protocol*) can be found on EPA's website.

- ii. <u>Weather conditions:</u> Dry weather screening and sampling shall proceed only when no more than 0.1 inches of rainfall has occurred in the previous 24-hour period and no significant snow melt is occurring.
- iii. <u>Screening requirements</u>: For each outfall/interconnection:
 - 1. The permittee shall record all of the following information and include it in the outfall/interconnection inventory and priority ranking:
 - unique identifier,
 - receiving water,
 - date of most recent inspection,
 - dimensions,
 - shape,
 - material (concrete, PVC),
 - spatial location (latitude and longitude with a minimum accuracy of +/-30 feet,
 - physical condition,
 - indicators of potential non-stormwater discharges (including presence or evidence of suspect flow and sensory observations such as odor, color, turbidity, floatables, or oil sheen).
 - 2. If an outfall/interconnection is inaccessible or submerged, the permittee shall proceed to the first accessible upstream manhole or structure for the observation and sampling and report the location with the screening results.
 - 3. If no flow is observed, but evidence of illicit flow exists, the permittee shall revisit the outfall during dry weather within one week of the initial observation, if practicable, to perform a second dry weather screening and sample any observed flow (proceed as in iv. below).
 - 4. Where dry weather flow is found at an outfall/interconnection, at least one (1) sample shall be collected, and:
 - a) Samples shall be analyzed at a minimum for:
 - ammonia,
 - chlorine,
 - conductivity,
 - salinity,
 - *E. coli* (freshwater receiving water) or enterococcus (saline or brackish receiving water),
 - surfactants (such as MBAS),
 - temperature, and

- pollutants of concern⁵
- b) All analyses with the exception of indicator bacteria and pollutants of concern can be performed with field test kits or field instrumentation and are not subject to 40 CFR part 136 requirements. Sampling for bacteria and pollutants of concern shall be conducted using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136. Sampling for ammonia and surfactants must use sufficiently sensitive methods to detect those parameters at or below the threshold indicator concentrations of 0.5 mg/L for ammonia and 0.25 mg/L for surfactants. Sampling for residual chlorine must use a method with a detection limit of 0.02 mg/L or 20 ug/L.
- iv. The permittee may rely on screening conducted under the MS4-2003 permit, pursuant to an EPA enforcement action, or by the state or EPA to the extent that it meets the requirements of part 2.3.4.7.b.iii.4. All data shall be reported in each annual report. Permittees that have conducted substantially equivalent monitoring to that required by part 2.3.4.7.b as part of an EPA enforcement action can request an exemption from the requirements of part 2.3.4.7.b by submitting a written request to EPA and retaining exemption approval from EPA as part of the SWMP. Until the permittee receives formal written approval of the exemption from part 2.3.4.7.b from EPA the permittee remains subject to all requirements of part 2.3.4.7.b.
- v. The permittee shall submit all screening data used in compliance with this part in its Annual Report.
- c. Follow-up ranking of outfalls and interconnections:
 - i. The permittee's outfall and interconnection ranking (2.3.4.7.a) shall be updated to reprioritize outfalls and interconnections based on information gathered during dry weather screening (part 2.3.4.7.b).
 - ii. Outfalls/interconnections where relevant information was found indicating sewer input to the MS4 or sampling results indicating sewer input⁶ shall be considered highly likely to contain illicit discharges from sanitary sources, and such outfalls/interconnections shall be ranked at the top of the High Priority Outfalls category for investigation. At this time, permittees may choose to rank other outfalls and interconnections based on any new information from the dry weather screening.
- iii. The ranking can be updated continuously as dry weather screening information becomes available, but shall be completed within three (3) years of the effective date of the permit.

2.3.4.8. Catchment Investigations

The permittee shall develop a systematic procedure to investigate each catchment associated with an

- Olfactory or visual evidence of sewage,
- Ammonia ≥ 0.5 mg/L, surfactants ≥ 0.25 mg/L, and bacteria levels greater than the water quality criteria applicable to the receiving water, or
- Ammonia ≥ 0.5 mg/L, surfactants ≥ 0.25 mg/L, and detectable levels of chlorine.

⁵ Where the discharge is directly into a water quality limited water or a water subject to an approved TMDL as indicated in Appendix F; the sample shall be analyzed for the pollutant(s) of concern identified as the cause of the impairment as specified in Appendix G

⁶ Likely sewer input indicators are any of the following:

outfall or interconnection within their MS4 system.

- a. <u>Timelines:</u>
 - A written catchment investigation procedure shall be developed within 18 months of the permit effective date in accordance with the requirements of part 2.3.4.8.b below.
 - Investigations of catchments associated with Problem Outfalls shall begin no later than two (2) years from the permit effective date.
 - Investigations of catchments associated with High and Low Priority Outfalls shall follow the ranking of outfalls updated in part 2.3.4.7.c.
 - Investigations of catchments associated with Problem Outfalls shall be completed within seven (7) years of the permit effective date
 - Investigations of catchments where any information gathered on the outfall/interconnection identifies sewer input⁷ shall be completed within seven (7) years of the permit effective date.
 - Investigations of catchments associated with all High- and Low-Priority Outfalls shall be completed within ten (10) years of the permit effective date.

*For the purposes of these milestones, an individual catchment investigation will be considered complete if all relevant procedures in part 2.3.4.8.c. and 2.3.4.8.d. below have been completed.

- b. <u>A written catchment investigation procedure</u> shall be developed that:
 - i. **Identifies maps, historic plans and records, and other sources of data**, including but not limited to plans related to the construction of the storm drain and of sanitary sewers, prior work performed on the storm drains or sanitary sewers, board of health or other municipal data on septic system failures or required upgrades, and complaint records related to SSOs, sanitary sewer surcharges, and septic system breakouts. These data sources will be used in identifying system vulnerability factors within each catchment.
 - ii. Includes a manhole inspection methodology that shall describe a storm drain network investigation that involves systematically and progressively observing, sampling (as required below) and evaluating key junction manholes (see definition in Appendix A) in the MS4 to determine the approximate location of suspected illicit discharges or SSOs. The manhole inspection methodology may either start from the outfall and work up the system or start from the upper parts of the catchment and work down the system or be a combination of both practices. Either method must, at a minimum, include an investigation of each key junction manhole within the MS4, even where no evidence of an illicit discharge is observed at the outfall. The manhole inspection methodology must describe the method the permittee will use. The manhole inspection methodology shall include procedures for dry and wet weather investigations.
- iii. **Establishes procedures to isolate and confirm sources of illicit discharges** where manhole investigations or other physical evidence or screening has identified that MS4 alignments are influenced by illicit discharges or SSOs. These shall include isolation of the drainage area for implementation of more detailed investigations, inspection of additional manholes along the alignment to refine the location of potential contaminant sources, and methods such as sandbagging key junction manhole inlets, targeted internal plumbing inspections, dye testing,

⁷ Likely sewer input indicators are any of the following:

[•] Olfactory or visual evidence of sewage,

[•] Ammonia ≥ 0.5 mg/L, surfactants ≥ 0.25 mg/L, and bacteria levels greater than the water quality criteria applicable to the receiving water, or

[•] Ammonia ≥ 0.5 mg/L, surfactants ≥ 0.25 mg/L, and detectable levels of chlorine.

MA MS4 General Permit

video inspections, or smoke testing to isolate and confirm the sources.

- c. <u>Requirements for each catchment investigation associated with an outfall/interconnection:</u>
 - i. For each catchment being investigated, the permittee shall review relevant mapping and historic plans and records gathered in accordance with Part 2.3.4.8.b.i. This review shall be used to identify areas within the catchment with higher potential for illicit connections. The permittee shall identify and record the presence of any of the following specific **System Vulnerability Factors (SVFs)**:
 - History of SSOs, including, but not limited to, those resulting from wet weather, high water table, or fat/oil/grease blockages;
 - Common or twin-invert manholes serving storm and sanitary sewer alignments;
 - Common trench construction serving both storm and sanitary sewer alignments;
 - Crossings of storm and sanitary sewer alignments where the sanitary system is shallower than the storm drain system;
 - Sanitary sewer alignments known or suspected to have been constructed with an underdrain system;
 - Inadequate sanitary sewer level of service (LOS) resulting in regular surcharging, customer back-ups, or frequent customer complaints;
 - Areas formerly served by combined sewer systems;
 - Sanitary sewer infrastructure defects such as leaking service laterals, cracked, broken, or offset sanitary infrastructure, directly piped connections between storm drain and sanitary sewer infrastructure, or other vulnerability factors identified through Inflow/Infiltration Analyses, Sanitary Sewer Evaluation Surveys, or other infrastructure investigations.

EPA recommends the permittee include the following in their consideration of System Vulnerability Factors:

- Sewer pump/lift stations, siphons, or known sanitary sewer restrictions where power/equipment failures or blockages could readily result in SSOs;
- Any sanitary sewer and storm drain infrastructure greater than 40 years old;
- Widespread code-required septic system upgrades required at property transfers (indicative of inadequate soils, water table separation, or other physical constraints of the area rather than poor owner maintenance);
- History of multiple Board of Health actions addressing widespread septic system failures (indicative of inadequate soils, water table separation, or other physical constraints of the area rather than poor owner maintenance);

The permittee shall document the presence or absence of System Vulnerability Factors for each catchment, retain this documentation as part of its IDDE program, and report this information in Annual Reports. Catchments with a minimum of one (1) System Vulnerability Factor are subject to wet weather sampling requirements of part 2.3.4.8.c.ii.2.

- ii. For each catchment, the permittee must inspect key junction manholes and gather catchment information on the locations of MS4 pipes, manholes, and the extent of the contributing catchment.
 - 1. For all catchments
 - a) Infrastructure information shall be incorporated into the permittee's mapping required at part 2.3.4.5; the permittee will refine their catchment delineation based on the field investigation where appropriate.

- b) The SVF inventory for the catchment will be updated based on information obtained during the inspection, including common (twin invert) manholes, directly piped connections between storm drains and sanitary sewer infrastructure, common weir walls, sanitary sewer underdrain connections and other structural vulnerabilities where sanitary discharges could enter the storm drain system during wet weather.
 - 1) Where a minimum of one (1) SVF is identified based on previous information or the investigation, a wet weather investigation must be conducted at the associated outfall (see below).
- c) During dry weather, key junction manholes⁸ shall be opened and inspected systematically for visual and olfactory evidence of illicit connections (e.g., excrement, toilet paper, gray filamentous bacterial growth, or sanitary products present).
 - 1) If flow is observed, the permittee shall sample the flow at a minimum for ammonia, chlorine and surfactants and can use field kits for these analyses.
 - 2) Where sampling results or visual or olfactory evidence indicate potential illicit discharges or SSOs, the area draining to the junction manhole shall be flagged for further upstream investigation.
- d) Key junction and subsequent manhole investigations will proceed until the location of suspected illicit discharges or SSOs can be isolated to a pipe segment between two manholes. If no evidence of an illicit discharge is found, catchment investigations will be considered complete upon completion of key junction manhole sampling.
- 2. For all catchments with a minimum of one (1) SVF identified
 - a) The permittee shall meet the requirements above for dry weather screening
 - b) The permittee shall inspect and sample under wet weather conditions to the extent necessary to determine whether wet weather-induced high flows in sanitary sewers or high groundwater in areas served by septic systems result in discharges of sanitary flow to the MS4.
 - 1) The permittee shall conduct at least one wet weather screening and sampling at the outfall that includes the same parameters required during dry weather screening, part 2.3.4.7.b.iii.4.
 - 2) Wet weather sampling and screening shall proceed during or after a storm event of sufficient depth or intensity to produce a stormwater discharge. EPA strongly recommends sampling during the spring (March through June) when groundwater levels are relatively high.
 - 3) The permit does not require a minimum rainfall event prior to wet weather screening. However, permittees may incorporate provisions that assist in targeting such discharges, including avoiding sampling during the initial period of discharge ("first flush") and/or identifying minimum storm event intensities likely to trigger sanitary sewer interconnections.
 - c) This sampling can be done upon completion of any dry weather investigation but must be completed before the catchment investigation is marked as complete.
- iii. All data collected as part of the dry and wet weather catchment investigations shall be recorded and reported in each annual report.

⁸ Where catchments do not contain junction manholes, the dry weather screening and sampling shall be considered as meeting the manhole inspection requirement. In these catchments, dry weather screenings that indicate potential presence of illicit discharges shall be further investigated pursuant to part 2.3.4.8.d. Investigations in these catchments may be considered complete where dry weather screening reveals no flow; no evidence of illicit discharges or SSOs is indicated through sampling results or visual or olfactory means; and no wet weather System Vulnerability Factors are identified.

MA MS4 General Permit

d. Identification/Confirmation of illicit source

Where the source of an illicit discharge has been approximated between two manholes in the permittee's MS4, the permittee shall isolate and identify/confirm the source of the illicit discharge using more detailed methods identified in their written procedure (2.3.4.8.b.iii). For outfalls that contained evidence of an illicit discharge, catchment investigations will be considered complete upon confirmation of all illicit sources.

e. <u>Illicit discharge removal</u>

When the specific source of an illicit discharge is identified, the permittee shall exercise its authority as necessary to require its removal pursuant to part 2.3.4.2 or 2.3.4.3.

- i. For each confirmed source the permittee shall include in the annual report the following information:
 - the location of the discharge and its source(s);
 - a description of the discharge;
 - the method of discovery;
 - date of discovery;
 - date of elimination, mitigation or enforcement action OR planned corrective measures and a schedule for completing the illicit discharge removal; and
 - estimate of the volume of flow removed.
- ii. Within one year of removal of all identified illicit discharges within a catchment area, confirmatory outfall or interconnection screening shall be conducted. The confirmatory screening shall be conducted in dry weather unless System Vulnerability Factors have been identified, in which case both dry weather and wet weather confirmatory screening shall be conducted. If confirmatory screening indicates evidence of additional illicit discharges, the catchment shall be scheduled for additional investigation.

2.3.4.9. Indicators of IDDE Program Progress

The permittee shall define or describe indicators for tracking program success and evaluate and report on the overall effectiveness of the IDDE program in each annual report. At a minimum the permittee shall document in each annual report:

- the number of SSOs and illicit discharges identified and removed,
- the number and percent of total outfall catchments served by the MS4 evaluated using the catchment investigation procedure,
- all dry weather and wet weather screening and sampling results and
- the volume of sewage removed

2.3.4.10 Ongoing Screening

Upon completion of all catchment investigations pursuant to part 2.3.4.8.c and illicit discharge removal and confirmation (if necessary) pursuant to paragraph 2.3.4.8.e, each outfall or interconnection shall be reprioritized for screening in accordance with part 2.3.4.7.a and scheduled for ongoing screening once every five years. Ongoing screening shall consist of dry weather screening and sampling consistent with part 2.3.4.7.b; wet weather screening and sampling shall also be required at outfalls where wet weather screening was required due to SVFs and shall be conducted in accordance with part 2.3.4.8.c.ii. All sampling results shall be reported in the permittee's annual report.

2.3.4.11 Training

The permittee shall, at a minimum, annually provide training to employees involved in IDDE program about the program, including how to recognize illicit discharges and SSOs. The permittee shall report on the frequency and type of employee training in the annual report.

2.3.5. Construction Site Stormwater Runoff Control

Objective: The objective of an effective construction stormwater runoff control program is to minimize or eliminate erosion and maintain sediment on site so that it is not transported in stormwater and allowed to discharge to a water of the U.S through the permittee's MS4. The construction site stormwater runoff control program required by this permit is a separate and distinct program from EPA's stormwater construction permit program. (http://cfpub1.epa.gov/npdes/stormwater/cgp.cfm)

- a. Permittees shall implement and enforce a program to reduce pollutants in any stormwater runoff discharged to the MS4 from all construction activities that result in a land disturbance of greater than or equal to one acre within the regulated area. The permittee's program shall include disturbances less than one acre if that disturbance is part of a larger common plan of development or sale that would disturb one or more acres. Permittees authorized under the MS4-2003 permit shall continue to implement and enforce their existing program and modify as necessary to meet the requirements of this part.
- b. The permittee does not need to apply its construction program requirements to projects that receive a waiver from EPA under the provisions of 40 CFR § 122.26(b) (15) (i).
- c. The permittee shall develop and implement a construction site runoff control program that includes the elements in Paragraphs i. through v. of this part:
 - i. An ordinance or regulatory mechanism that requires the use of sediment and erosion control practices at construction sites. In addition to addressing sediment and erosion control, the ordinance must include controls for other wastes on construction sites such as demolition debris, litter and sanitary wastes. Development of an ordinance or other regulatory mechanism was a requirement of the MS4-2003 permit (See part II.B.4 and part IV.B.4). The ordinance or other regulatory mechanism required by the MS4-2003 permit shall have been effective by May 1, 2008.
 - ii. Written (hardcopy or electronic) procedures for site inspections and enforcement of sediment and erosion control measures. If not already existing, these procedures shall be completed within one (1) year from the effective date of the permit. The procedures shall clearly define who is responsible for site inspections as well as who has authority to implement enforcement procedures. The program shall provide that the permittee may, to the extent authorized by law, impose sanctions to ensure compliance with the local program. These procedures and regulatory authorities shall be documented in the SWMP.
 - iii. Requirements for construction site operators performing land disturbance activities within the MS4 jurisdiction that result in stormwater discharges to the MS4 to implement a sediment and erosion control program that includes BMPs appropriate for the conditions at the construction site. The program may include references to BMP

design standards in state manuals, such as the Massachusetts Stormwater Handbook⁹, or design standards developed by the MS4. EPA supports and encourages the use of design standards in local programs. Examples of appropriate sediment and erosion control measures for construction sites include local requirements to:

- 1. Minimize the amount of disturbed area and protect natural resources;
- 2. Stabilize sites when projects are complete or operations have temporarily ceased;
- 3. Protect slopes on the construction site;
- 4. Protect all storm drain inlets and armor all newly constructed outlets;
- 5. Use perimeter controls at the site;
- 6. Stabilize construction site entrances and exits to prevent off-site tracking;
- 7. Inspect stormwater controls at consistent intervals.
- iv. Requirements for construction site operators within the MS4 jurisdiction to control wastes, including but not limited to, discarded building materials, concrete truck wash out, chemicals, litter, and sanitary wastes. These wastes may not be discharged to the MS4.
- v. Written procedures for site plan review and inspection and enforcement. If not already existing, the procedures for site plan review and inspection and enforcement shall be completed within one (1) year from the effective date of the permit. The site plan review procedure shall include a pre-construction review by the permittee of the site design, the planned operations at the construction site, planned BMPs during the construction phase, and the planned BMPs to be used to manage runoff created after development. The review procedure shall incorporate procedures for the consideration of potential water quality impacts, and procedures for the receipt and consideration of information submitted by the public. The site plan review procedure shall also include evaluation of opportunities for use of low impact design and green infrastructure. When the opportunity exists, the permittee shall encourage project proponents to incorporate these practices into the site design. The procedures for site inspections conducted by the permittee shall include the requirement that inspections occur during construction of BMPs as well as after construction of BMPs to ensure they are working as described in the approved plans, clearly defined procedures for inspections including qualifications necessary to perform the inspections, the use of mandated inspection forms if appropriate, and procedure for tracking the number of site reviews, inspections, and enforcement actions. This tracking information shall be included as part of each annual report required by part 4.4.

2.3.6. Stormwater Management in New Development and Redevelopment (Post Construction Stormwater Management)

Objective: The objective of this control measure is to reduce the discharge of pollutants found in stormwater through the retention or treatment of stormwater after construction on new or redeveloped sites. For the purposes of this part (2.3.6.), the following definitions apply:

site is defined as the area extent of construction activities, including but not limited to the creation of new impervious cover and improvement of existing impervious cover (e.g. repaving not covered by 2.3.6.a.ii.4.d.)

⁹ The handbook is available at: http://www.mass.gov/dep/water/laws/policies.htm#storm
new development is defined as any construction activities or land alteration resulting in total earth disturbances equal to or greater than 1 acre (or activities that are part of a larger common plan of development disturbing greater than 1 acre) on an area that has not previously been developed to include impervious cover.

redevelopment is defined as any construction, land alteration, or improvement of impervious surfaces resulting in total earth disturbances equal to or greater than 1 acre (or activities that are part of a larger common plan of development disturbing greater than 1 acre) that does not meet the definition of new development (see above).

- a. Permittees shall develop, implement, and enforce a program to address post-construction stormwater runoff from all new development and redevelopment sites that disturb one or more acres and discharge into the permittees MS4 at a minimum. Permittees authorized under the MS4-2003 permit shall continue to implement and enforce their program and modify as necessary to meet the requirements of this part.
 - i. The permittee's new development/ redevelopment program shall include sites less than one acre if the site is part of a larger common plan of development or redevelopment which disturbs one or more acre.
 - ii. The permittee shall develop or modify, as appropriate, an ordinance or other regulatory mechanism within two (2) years of the effective date of the permit to contain provisions that are at least as stringent as the following:
 - 1. Low Impact Development (LID) site planning and design strategies must be used to the maximum extent feasible.
 - 2. The design of treatment and infiltration practices should follow the guidance in Volume 2 of the Massachusetts Stormwater Handbook, as amended, or other federally or State approved¹⁰ BMP design guidance.
 - 3. Stormwater management systems on new development sites shall be designed to:
 - a) Not allow new stormwater conveyances to discharge untreated stormwater in accordance with Massachusetts Stormwater Handbook Standard 1;
 - b) Control peak runoff rates in accordance with Massachusetts Stormwater Handbook Standard 2¹¹;
 - c) Recharge groundwater in accordance with Massachusetts Stormwater Handbook Standard 3¹²;
 - d) Eliminate or reduce the discharge of pollutants from land uses with higher pollutant loads as defined in the Massachusetts Stormwater Handbook in accordance with Massachusetts Stormwater Handbook Standard 5;
 - e) Protect Zone II or Interim Wellhead Protection Areas of public water supplies in accordance with Massachusetts Stormwater Handbook Standard 6¹³;

¹⁰ State approved includes any state in the United States, including, but not limited to, approved guidance by the Commonwealth of Massachusetts

¹¹ Requirement necessary for Section 401 water quality certification by Massachusetts

¹² Requirement necessary for Section 401 water quality certification by Massachusetts

¹³ Requirement necessary for Section 401 water quality certification by Massachusetts

- f) Implement long term maintenance practices in accordance with Massachusetts Stormwater Handbook Standard 9; and
- g) Require that all stormwater management systems be designed to:
 - 1) Retain the volume of runoff equivalent to, or greater than, one (1.0) inch multiplied by the total post-construction impervious surface area on the site AND/OR
 - 2) Remove 90% of the average annual load of Total Suspended Solids (TSS) generated from the total post-construction impervious area on the site¹⁴ AND 60% of the average annual load of Total Phosphorus (TP) generated from the total post-construction impervious surface area on the site¹⁴. Pollutant removal shall be calculated consistent with EPA Region 1's BMP Performance Extrapolation Tool or other BMP performance evaluation tool provided by EPA Region 1, where available. If EPA Region 1 tools do not address the planned or installed BMP performance any federally or State approved¹⁵ BMP design guidance or performance standards (e.g. State stormwater handbooks and design guidance manuals) may be used to calculate BMP performance.
- 4. Redevelopment Requirements
 - a) Stormwater management systems on Redevelopment sites shall meet the following sections of part 2.3.6.a.ii.3 to the maximum extent feasible:
 - 1) Part 2.3.6.a.ii.3(a) (Massachusetts Stormwater Standard 1);
 - 2) Part 2.3.6.a.ii.3(b) (Massachusetts Stormwater Standard 2);
 - 3) Part 2.3.6.a.ii.3(c) (Massachusetts Stormwater Standard 3); and
 - 4) The pretreatment and structural best management practices requirements of 2.3.6.a.ii.3(d) and 2.3.6.a.ii.3(e) (Massachusetts Stormwater Standards 5 and 6).
 - b) Stormwater management systems on Redevelopment sites shall also improve existing conditions by requiring that stormwater management systems be designed to:
 - 1) Retain the volume of runoff equivalent to, or greater than, 0.80 inch multiplied by the total post-construction impervious surface area on the site AND/OR
 - 2) Remove 80% of the average annual post-construction load of Total Suspended Solids (TSS) generated from the total post-construction impervious area on the site AND 50% of the average annual load of Total Phosphorus (TP) generated from the total postconstruction impervious surface area on the site. Pollutant removal shall be calculated consistent with EPA Region 1's BMP Performance Extrapolation Tool or other BMP performance evaluation tool provided by EPA Region 1 where available. If EPA Region 1 tools do not address the planned or installed BMP performance any federally or State approved BMP design guidance or performance standards (e.g. State stormwater handbooks and design guidance manuals) may be used to calculate BMP performance.
 - c) Stormwater management systems on redevelopment sites may utilize offsite mitigation within the same USGS HUC10 as the redevelopment site

¹⁴ The required removal percentage is not required for each storm, it is the average removal over a year that is required ¹⁵ See footnote 14

to meet the equivalent retention or pollutant removal requirements in part 2.3.6.a.ii.4(b).

- d) Redevelopment activities that are exclusively limited to maintenance and improvement of existing roadways, (including widening less than a single lane, adding shoulders, correcting substandard intersections, improving existing drainage systems, and repaving projects) shall improve existing conditions where feasible and are exempt from part 2.3.6.a.ii.4(a), part 2.3.6.a.ii.4(b) and part 2.3.6.a.ii.4(c). Roadway widening or improvements that increase the amount of impervious area on the redevelopment site by greater than or equal to a single lane width shall meet the requirements of part 2.3.6.a.ii.4(a) (c)fully.
- iii. The permittee shall require, at a minimum, the submission of as-built drawings no later than two (2) years after completion of construction projects. The as-built drawings must depict all on site controls, both structural and non-structural, designed to manage the stormwater associated with the completed site (post construction stormwater management). The new development/redevelopment program shall have procedures to ensure adequate long-term operation and maintenance of stormwater management practices that are put in place after the completion of a construction project. These procedures may include the use of dedicated funds or escrow accounts for development projects or the acceptance of ownership by the permittee of all privately owned BMPs. These procedures may also include the development of maintenance contracts between the owner of the BMP and the permittee. Alternatively, these procedures may include the submission of an annual certification documenting the work that has been done over the last 12 months to properly operate and maintain the stormwater control measures. The procedures to require submission of as-built drawings and ensure long term operation and maintenance shall be a part of the SWMP. The permittee shall report in the annual report on the measures that the permittee has utilized to meet this requirement.
- b. Within four (4) years of the effective date of this permit, the permittee shall develop a report assessing current street design and parking lot guidelines and other local requirements that affect the creation of impervious cover. This assessment shall be used to provide information to allow the permittee to determine if changes to design standards for streets and parking lots can be made to support low impact design options. If the assessment indicates that changes can be made, the assessment shall include recommendations and proposed schedules to incorporate policies and standards into relevant documents and procedures to minimize impervious cover attributable to parking areas and street designs. The permittee shall implement all recommendations, in accordance with the schedules, contained in the assessment. The local planning board and local transportation board should be involved in this assessment. This assessment shall be part of the SWMP. The permittee shall report in each annual report on the status of this assessment including any planned or completed changes to local regulations and guidelines.
- c. Within four (4) years from the effective date of the permit, the permittee shall develop a report assessing existing local regulations to determine the feasibility of making, at a minimum, the following practices allowable when appropriate site conditions exist:
 - i. Green roofs;
 - ii. Infiltration practices such as rain gardens, curb extensions, planter gardens, porous and pervious pavements, and other designs to manage stormwater using landscaping and structured or augmented soils; and

iii. Water harvesting devices such as rain barrels and cisterns, and the use of stormwater for non-potable uses.

The assessment should indicate if the practices are allowed in the MS4 jurisdiction and under what circumstances are they allowed. If the practices are not allowed, the permittee shall determine what hinders the use of these practices, what changes in local regulations may be made to make them allowable, and provide a schedule for implementation of recommendations. The permittee shall implement all recommendations, in accordance with the schedules, contained in the assessment. The permittee shall report in each annual report on its findings and progress towards making the practices allowable.(Information available at:

http://www.epa.gov/region1/npdes/stormwater/assets/pdf/AddressingBarrier2LID.pdf and http://www.mapc.org/resources/low-impact-dev-toolkit/local-codes-lid)

d. Four (4) years from the effective date of this permit, the permittee shall identify a minimum of 5 permittee-owned properties that could potentially be modified or retrofitted with BMPs designed to reduce the frequency, volume, and pollutant loads of stormwater discharges to and from its MS4 through the reduction of impervious area. Properties and infrastructure for consideration shall include those with the potential for reduction of on-site impervious area (IA) as well as those that could provide reduction of off-site IA. At a minimum, the permittee shall consider municipal properties with significant impervious cover (including parking lots, buildings, and maintenance yards) that could be modified or retrofitted. MS4 infrastructure to be considered includes existing street right-of-ways, outfalls and conventional stormwater conveyances and controls (including swales and detention practices) that could be readily modified or retrofitted to provide reduction in frequency, volume or pollutant loads of such discharges through reduction of impervious cover.

In determining the potential for modifying or retrofitting particular properties, the permittee shall consider factors such as access for maintenance purposes; subsurface geology; depth to water table; proximity to aquifers and subsurface infrastructure including sanitary sewers and septic systems; and opportunities for public use and education. In determining its priority ranking, the permittee shall consider factors such as schedules for planned capital improvements to storm and sanitary sewer infrastructure and paving projects; current storm sewer level of service; and control of discharges to water quality limited waters, first or second order streams, public swimming beaches, drinking water supply sources and shellfish growing areas.

Beginning with the fifth year annual report and in each subsequent annual report, the permittee shall identify additional permittee owned sites and infrastructure that could be retrofitted such that the permittee maintains a minimum of 5 sites in their inventory, until such a time as when the permittee has less than 5 sites remaining. In addition, the permittee shall report on all properties that have been modified or retrofitted with BMPs to mitigate IA that were inventoried in accordance with this part. The permittee may also include in its annual report non-MS4 owned property that has been modified or retrofitted with BMPs to mitigate IA.

2.3.7. Good House Keeping and Pollution Prevention for Permittee Owned Operations

Objective: The permittee shall implement an operations and maintenance program for permittee-owned operations that has a goal of preventing or reducing pollutant runoff and protecting water quality from all permittee-owned operations.

a. Operations and Maintenance Programs

i. Within two (2) years from the effective date of the permit, the permittee shall develop, if not already developed, written (hardcopy or electronic) operations and maintenance

procedures for the municipal activities listed below in part 2.3.7.a.ii. These written procedures shall be included as part of the SWMP.

- ii. Within two (2) year of the effective date of this permit, the permittee shall develop an inventory of all permittee owned facilities within the categories listed below. The permittee shall review this inventory annually and update as necessary.
 - Parks and open space: Establish procedures to address the proper use, storage, and disposal of pesticides, herbicides, and fertilizers including minimizing the use of these products and using only in accordance manufacturer's instruction. Evaluate lawn maintenance and landscaping activities to ensure practices are protective of water quality. Protective practices include reduced mowing frequencies, proper disposal of lawn clippings, and use of alternative landscaping materials (e.g., drought resistant planting). Establish pet waste handling collection and disposal locations at all parks and open space where pets are permitted, including the placing of proper signage concerning the proper collection and disposal of pet waste. Establish procedures to address waterfowl congregation areas where appropriate to reduce waterfowl droppings from entering the MS4. Establish procedures for management of trash containers at parks and open space (scheduled cleanings; sufficient number). Establish procedures to address erosion or poor vegetative cover when the permittee becomes aware of it; especially if the erosion is within 50 feet of a surface water.
 - 2. Buildings and facilities where pollutants are exposed to stormwater runoff: This includes schools (to the extent they are permittee-owned or operated), town offices, police, and fire stations, municipal pools and parking garages and other permittee-owned or operated buildings or facilities. Evaluate the use, storage, and disposal of petroleum products and other potential stormwater pollutants. Provide employee training as necessary so that those responsible for handling these products know proper procedures. Ensure that Spill Prevention Plans are in place, if applicable, and coordinate with the fire department as necessary. Develop management procedures for dumpsters and other waste management equipment. Sweep parking lots and keep areas surrounding the facilities clean to reduce runoff of pollutants.
 - 3. Vehicles and Equipment: Establish procedures for the storage of permittee vehicles. Vehicles with fluid leaks shall be stored indoors or containment shall be provided until repaired. Evaluate fueling areas owned or operated by the permittee. If possible, place fueling areas under cover in order to minimize exposure. Establish procedures to ensure that vehicle wash waters are not discharged to the municipal storm sewer system or to surface waters. This permit does not authorize such discharges.
- iii. Infrastructure Operations and Maintenance
 - 1. The permittee shall establish within two (2) year of the effective date of the permit a written (hardcopy or electronic) program detailing the activities and procedures the permittee will implement so that the MS4 infrastructure is maintained in a timely manner to reduce the discharge of pollutants from the MS4. If the permittee has an existing program to maintain its MS4 infrastructure

in a timely manner to reduce or eliminate the discharge of pollutants from the MS4, the permittee shall document the program in the SWMP.

- 2. The permittee shall optimize routine inspections, cleaning and maintenance of catch basins such that the following conditions are met:
 - Prioritize inspection and maintenance for catch basins located near construction activities (roadway construction, residential, commercial, or industrial development or redevelopment). Clean catch basins in such areas more frequently if inspection and maintenance activities indicate excessive sediment or debris loadings.
 - Establish a schedule with a goal that the frequency of routine cleaning will ensure that no catch basin at anytime will be more than 50 percent full.
 - If a catch basin sump is more than 50 percent full during two consecutive routine inspections/cleaning events, the permittee shall document that finding, investigate the contributing drainage area for sources of excessive sediment loading, and to the extent practicable, abate contributing sources. The permittee shall describe any actions taken in its annual report.
 - For the purposes of this part, an excessive sediment or debris loading is a catch basin sump more than 50 percent full. A catch basin sump is more than 50 percent full if the contents within the sump exceed one half the distance between the bottom interior of the catch basin to the invert of the deepest outlet of the catch basin.
 - The permittee shall document in the SWMP and in the first annual report its plan for optimizing catch basin cleaning, inspection plans, or its schedule for gathering information to develop the optimization plan. Documentation shall include metrics and other information used to reach the determination that the established plan for cleaning and maintenance is optimal for the MS4. The permittee shall keep a log of catch basins cleaned or inspected.
 - The permittee shall report in each annual report the total number of catch basins, number inspected, number cleaned, and the total volume or mass of material removed from all catch basins.
- 3. The permittee shall establish and implement procedures for sweeping and/or cleaning streets, and permittee-owned parking lots. All streets with the exception of rural uncurbed roads with no catch basins or high speed limited access highways shall be swept and/or cleaned a minimum of once per year in the spring (following winter activities such as sanding). The procedures shall also include more frequent sweeping of targeted areas determined by the permittee on the basis of pollutant load reduction potential, based on inspections, pollutant loads, catch basin cleaning or inspection results, land use, water quality limited or TMDL waters or other relevant factors as determined by the permittee. The permittee shall report in each annual report the number of miles cleaned or the volume or mass of material removed.

For rural uncurbed roadways with no catch basins and limited access highways, the permittee shall either meet the minimum frequencies above, or develop and implement an inspection, documentation and targeted sweeping plan within two (2) years of the effective date of the permit, and submit such plan with its year one annual report.

- 4. The permittee shall ensure proper storage of catch basin cleanings and street sweepings prior to disposal or reuse such that they do not discharge to receiving waters. These materials should be managed in compliance with current MassDEP policies:
 - For catch basins cleanings: http://www.mass.gov/eea/agencies/massdep/recycle/regulations/manageme nt-of-catch-basin-cleanings.html
 - For street sweepings: <u>http://www.mass.gov/eea/docs/dep/recycle/laws/stsweep.pdf</u>.
- 5. The permittee shall establish and implement procedures for winter road maintenance including the use and storage of salt and sand; minimize the use of sodium chloride and other salts, and evaluate opportunities for use of alternative materials; and ensure that snow disposal activities do not result in disposal of snow into waters of the United States. For purposes of this MS4 Permit, salt shall mean any chloride-containing material used to treat paved surfaces for deicing, including sodium chloride, calcium chloride, magnesium chloride, and brine solutions.
- 6. The permittee shall establish and implement inspection and maintenance frequencies and procedures for all stormwater treatment structures such as water quality swales, retention/detention basins, infiltration structures, proprietary treatment devices or other similar structures. All permittee-owned stormwater treatment structures (excluding catch basins) shall be inspected annually at a minimum.
- iv. The permittee shall report in the annual report on the status of the inventory required by this part and any subsequent updates; the status of the O&M programs for the permitteeowned facilities and activities in part 2.3.7.a.ii; and the maintenance activities associated with each.
- v. The permittee shall keep a written (hardcopy or electronic) record of all required activities including but not limited to maintenance activities, inspections and training required by part 2.3.7.a. The permittee shall maintain, consistent with part 4.2.a, all records associated with maintenance and inspection activities required by part 2.3.7.a.

b. Stormwater Pollution Prevention Plan (SWPPP)

The permittee shall develop and fully implement a SWPPP for each of the following permittee-owned or operated facilities: maintenance garages, public works yards, transfer stations, and other waste handling facilities where pollutants are exposed to stormwater as determined by the permittee. If facilities are located at the same property, the permittee may develop one SWPPP for the entire property. The SWPPP is a separate and different document from the SWMP required in part 1.10. A SWPPP does not need to be developed for a facility if the permittee has either developed a SWPPP or received a no exposure certification for the discharge under the Multi-Sector General Permit or the discharge is authorized under another NPDES permit.

i. No later than two (2) years from the effective date of the permit, the permittee shall develop and implement a written (hardcopy or electronic) SWPPP for the facilities

described above. The SWPPP shall be signed in accordance with the signatory requirements of Appendix B – Subparagraph 11.

- ii. The SWPPP shall contain the following elements:
 - 1. Pollution Prevention Team

Identify the staff on the team, by name and title. If the position is unstaffed, the title of the position should be included and the SWPPP updated when the position is filled. The role of the team is to develop, implement, maintain, and revise, as necessary, the SWPPP for the facility.

- 2. Description of the facility and identification of potential pollutant sources The SWPPP shall include a map of the facility and a description of the activities that occur at the facility. The map shall show the location of the stormwater outfalls, receiving waters, and any structural controls. Identify all activities that occur at the facility and the potential pollutants associated with each activity including the location of any floor drains. These may be included as part of the inventory required by part 2.3.7.a.
- 3. Identification of stormwater controls The permittee shall select, design, install, and implement the control measures detailed in paragraph 4 below to prevent or reduce the discharge of pollutants from the permittee owned facility.

The selection, design, installation, and implementation of the control measures shall be in accordance with good engineering practices and manufacturer's specifications. The permittee shall also take all reasonable steps to control or address the quality of discharges from the site that may not originate at the facility.

If the discharge from the facility is to a water quality limited water and the facility has the potential to discharge the pollutant identified as causing the water quality limitation, the permittee shall identify the control measures that will be used to address this pollutant at the facility so that the discharge does not cause or contribute to a violation of a water quality standard.

- 4. The SWPPP shall include the following management practices:
 - a) <u>Minimize or Prevent Exposure</u>: The permittee shall to the extent practicable either locate materials and activities inside, or protect them with storm-resistant coverings in order to prevent exposure to rain, snow, snowmelt and runoff (although significant enlargement of impervious surface area is not recommended). Materials do not need to be enclosed or covered if stormwater runoff from affected areas will not be discharged directly or indirectly to surface waters or to the MS4 or if discharges are authorized under another NPDES permit.
 - b) <u>Good Housekeeping</u>: The permittee shall keep clean all exposed areas that are potential sources of pollutants, using such measures as sweeping at regular intervals. Ensure that trash containers are closed when not in use, keep storage areas well swept and free from leaking or damaged containers; and store leaking vehicles needing repair indoors.

- c) <u>Preventative Maintenance</u>: The permittee shall regularly inspect, test, maintain, and repair all equipment and systems to avoid situations that may result in leaks, spills, and other releases of pollutants in stormwater to receiving waters. Inspections shall occur at a minimum once per quarter.
- d) <u>Spill Prevention and Response</u>: The permittee shall minimize the potential for leaks, spills, and other releases that may be exposed to stormwater and develop plans for effective response to such spills if or when they occur. At a minimum, the permittee shall have procedures that include:
 - Preventive measures such as barriers between material storage and traffic areas, secondary containment provisions, and procedures for material storage and handling.
 - Response procedures that include notification of appropriate facility personnel, emergency agencies, and regulatory agencies, and procedures for stopping, containing, and cleaning up leaks, spills and other releases. Measures for cleaning up hazardous material spills or leaks shall be consistent with applicable Resource Conservation and Recovery Act (RCRA) regulations at 40 CFR section 264 and 40 CFR section 265. Employees who may cause, detect, or respond to a spill or leak shall be trained in these procedures and have necessary spill response equipment available. If possible, one of these individuals should be a member of the Pollution Prevention Team; and
 - Contact information for individuals and agencies that shall be • notified in the event of a leak, spill, or other release. Where a leak, spill, or other release containing a hazardous substance or oil in an amount equal to or in excess of a reportable quantity established under 40 CFR section 110, 40 CFR section 117, or 40 CFR section 302, occurs during a 24-hour period, the permittee shall notify the National Response Center (NRC) at (800) 424-8802 in accordance with the requirements of 40 CFR section 110, 40 CFR section 117, and 40 CFR section 302 as soon as the permittee has knowledge of the discharge. State or local requirements may necessitate reporting spills or discharges to local emergency, public health or drinking water supply agencies, and owners of public drinking water supplies. Contact information shall be in locations that are readily accessible and available.
- e) <u>Erosion and Sediment Control</u>: The permittee shall use structural and non-structural control measures at the facility to stabilize and contain runoff from exposed areas and to minimize or eliminate onsite erosion and sedimentation. Efforts to achieve this may include the use of flow velocity dissipation devices at discharge locations and within outfall channels where necessary to reduce erosion.

- f) <u>Management of Runoff</u>: The permittee shall manage stormwater runoff from the facility to prevent or reduce the discharge of pollutants. This may include management practices which divert runoff from areas that are potential sources of pollutants, contain runoff in such areas, or reuse, infiltrate or treat stormwater to reduce the discharge of pollutants.
- g) <u>Salt Storage Piles or Piles Containing Salt</u>: For storage piles of salt or piles containing salt used for deicing or other purposes (including maintenance of paved surfaces) for which the discharge during precipitation events discharges to the permittee's MS4, any other storm sewer system, or to a Water of the US, the permittee shall prevent exposure of the storage pile to precipitation by enclosing or covering the storage piles. Such piles shall be enclosed or covered within two (2) years of the permit effective date. The permittee shall implement appropriate measures (e.g., good housekeeping, diversions, containment) to minimize exposure resulting from adding to or removing materials from the pile. The permittee is encouraged to store piles in such a manner as not to impact surface water resources, ground water resources, recharge areas, and wells.
- h) Employee Training: The permittee shall regularly train employees who work in areas where materials or activities are exposed to stormwater, or who are responsible for implementing activities identified in the SWPPP (e.g., inspectors, maintenance personnel), including all members of the Pollution Prevention Team. Training shall cover both the specific components and scope of the SWPPP and the control measures required under this part, including spill response, good housekeeping, material management practices, any best management practice operation and maintenance, etc. EPA recommends annual training.

The permittee shall document the following information for each training:

- The training date, title and training duration;
- List of municipal attendees;
- Subjects covered during training
- i) <u>Maintenance of Control Measures</u>: The permittee shall maintain all control measures, required by this permit in effective operating condition. The permittee shall keep documentation onsite that describes procedures and a regular schedule for preventative maintenance of all control measures and discussions of back-up practices in place should a runoff event occur while a control measure is off-line. Nonstructural control measures shall also be diligently maintained (e.g., spill response supplies available, personnel trained).

iii. The permittee shall conduct the following inspections:

1. Site Inspections: Inspect all areas that are exposed to stormwater and all stormwater control measures. Inspections shall be conducted at least once each calendar quarter. More frequent inspections may be required if significant activities are exposed to stormwater. Inspections shall be performed when the

facility is in operation. At least one of the quarterly inspections shall occur during a period when a stormwater discharge is occurring.

The permittee shall document the following information for each facility inspection:

- The inspection date and time;
- The name of the inspector;
- Weather information and a description of any discharge occurring at the time of the inspection;
- Identification of any previously unidentified discharges from the site;
- Any control measures needing maintenance or repair;
- Any failed control measures that need replacement.
- Any SWPPP changes required as a result of the inspection.

If during the inspections, or any other time, the permittee identifies control measures that need repair or are not operating effectively, the permittee shall repair or replace them before the next anticipated storm event if possible, or as soon as practicable following that storm event. In the interim, the permittee shall have back-up measures in place.

The permittee shall report the findings from the Site Inspections in the annual report.

iv. The permittee must keep a written (hardcopy or electronic) record of all required activities including but not limited to maintenance, inspections, and training required by part 2.3.7.b.The permittee shall maintain all records associated with the development and implementation of the SWPPP required by this part consistent with the requirements of part 4.2.

3.0. Additional Requirements for Discharges to Surface Drinking Water Supplies and Their Tributaries

- a. Permittees which discharge to public surface drinking water supply sources (Class A and Class B surface waters used for drinking water) or their tributaries should consider these waters a priority in the implementation of the SWMP.
- b. Permittees should provide pretreatment and spill control measures to stormwater discharges to public drinking water supply sources or their tributaries to the extent feasible.
- c. Direct discharges to Class A waters should be avoided to the extent feasible.

4.0. Program Evaluation, Record Keeping, and Reporting

4.1. Program Evaluation

a. The permittee shall annually self-evaluate its compliance with the terms and conditions of this permit and submit each self-evaluation in the Annual Report. The permittee shall also maintain the annual evaluation documentation as part of the SWMP.

MA MS4 General Permit

- b. The permittee shall evaluate the appropriateness of the selected BMPs in achieving the objectives of each control measure and the defined measurable goals. Where a BMP is found to be ineffective the permittee shall change BMPs in accordance with the provisions below. In addition, permittees may augment or change BMPs at any time following the provisions below:
 - Changes adding (but not subtracting or replacing) components or controls may be made at any time.
 - Changes replacing an ineffective or infeasible BMP specifically identified in the SWMP with an alternative BMP may be made as long as the basis for the changes is documented in the SWMP by, at a minimum:
 - An analysis of why the BMP is ineffective or infeasible;
 - Expectations on the effectiveness of the replacement BMP; and
 - An analysis of why the replacement BMP is expected to achieve the defined goals of the BMP to be replaced.

The permittee shall indicate BMP modifications along with a brief explanation of the modification in each Annual Report.

- c. EPA or MassDEP may require the permittee to add, modify, repair, replace or change BMPs or other measures described in the annual reports as needed:
 - To address impacts to receiving water quality caused or contributed to by discharges from the MS4; or
 - To satisfy conditions of this permit

Any changes requested by EPA or MassDEP will be in writing and will set forth the schedule for the permittee to develop the changes and will offer the permittee the opportunity to propose alternative program changes to meet the objective of the requested modification.

4.2. Record Keeping

- a. The permittee shall keep all records required by this permit for a period of at least five years. EPA may extend this period at any time. Records include information used in the development of any written (hardcopy or electronic) program required by this permit, any monitoring results, copies of reports, records of screening, follow-up and elimination of illicit discharges; maintenance records; inspection records; and data used in the development of the notice of intent, SWMP, SWPPP, and annual reports. This list provides examples of records that should be maintained, but is not all inclusive.
- b. Records other than those required to be included in the annual report, part 4.4, shall be submitted only when requested by the EPA or the MassDEP.
- c. The permittee shall make the records relating to this permit, including the written (hardcopy or electronic) stormwater management program, available to the public. The public may view the records during normal business hours. The permittee may charge a reasonable fee for copying requests. The permittee is encouraged to satisfy this requirement by posting records online.

4.3. Outfall Monitoring Reporting

- a. The permittee shall monitor and sample its outfalls at a minimum through sampling and testing at the frequency and locations required in connection with IDDE screening under part 2.3.4.7.b. and 2.3.4.8.c.ii.2. The monitoring program may also include additional outfall and interconnection monitoring as determined by the permittee in connection with assessment of SWMP effectiveness pursuant to part 4.1; evaluation of discharges to water quality limited waters pursuant to part 2.2; assessment of BMP effectiveness pursuant to part 2.2 or 2.3; or otherwise.
- b. The permittee shall document all monitoring results each year in the annual report. The report shall include the date, outfall or interconnection identifier, location, weather conditions at time of sampling, precipitation in previous 48 hours, field screening parameter results, and results of all analyses. The annual report shall include all of this information and data for the current reporting period and for the entire permit period.
- c. The permittee shall also include in the annual report results from any other stormwater or receiving water quality monitoring or studies conducted during the reporting period where that data is being used by the permittee to inform permit compliance or program effectiveness. If such monitoring or studies were conducted on behalf of the permittee, or if monitoring or studies conducted by other entities were reported to the permittee, a brief description of the type of information gathered or received shall be included in the annual report(s) covering the time period(s) the information was received.

4.4. Annual Reports

- a. The permittee shall submit annual reports each year of the permit term. The reporting period will be a one year period commencing on the permit effective date, and subsequent anniversaries thereof, except that the first annual report under this permit shall also cover the period from May 1, [year of final permit effective date] to the permit effective date. The annual report is due ninety days from the close of each reporting period.
- b. The annual reports shall contain the following information:
 - i. A self-assessment review of compliance with the permit terms and conditions.
 - ii. An assessment of the appropriateness of the selected BMPs.
 - iii. The status of any plans or activities required by part 2.1 and/ or part 2.2, including:
 - Identification of all discharges determined to be causing or contributing to an exceedance of water quality standards and description of response including all items required by part 2.1.1;
 - For discharges subject to TMDL related requirements, identification of specific BMPs used to address the pollutant identified as the cause of impairment and assessment of the BMPs effectiveness at controlling the pollutant (part 2.2.1. and Appendix F) and any deliverables required by Appendix F;
 - For discharges to water quality limited waters a description of each BMP required by Appendix H and any deliverables required by Appendix H.
 - iv. An assessment of the progress towards achieving the measurable goals and objectives of each control measure in part 2.3 including:

- Evaluation of the public education program including a description of the targeted messages for each audience; method of distribution and dates of distribution; methods used to evaluate the program; and any changes to the program.
- Description of the activities used to promote public participation including documentation of compliance with state public notice regulations.
- Description of the activities related to implementation of the IDDE program including: status of the map; status and results of the illicit discharge potential ranking and assessment; identification of problem catchments; status of all protocols described in part 2.3.4.(program responsibilities and systematic procedure); number and identifier of catchments evaluated; number and identifier of outfalls screened; number of illicit discharges located; number of illicit discharges removed; gallons of flow removed; identification of tracking indicators and measures of progress based on those indicators; and employee training.
- Evaluation of the construction runoff management including number of project plans reviewed; number of inspections; and number of enforcement actions.
- Evaluation of stormwater management for new development and redevelopment including status of ordinance development (2.3.6.a.ii.), review and status of the street design assessment(2.3.6.b.), assessments to barriers to green infrastructure (2.3.6.c), and retrofit inventory status (2.3.6.d.)
- Status of the O&M Programs required by part 2.3.7.a.
- Status of SWPPP required by part 2.3.7.b. including inspection results.
- Any additional reporting requirements in part 3.0.
- v. All outfall screening and monitoring data collected by or on behalf of the permittee during the reporting period and cumulative for the permit term, including but not limited to all data collected pursuant to part 2.3.4. The permittee shall also provide a description of any additional monitoring data received by the permittee during the reporting period.
- vi. Description of activities for the next reporting cycle.
- vii. Description of any changes in identified BMPs or measurable goals.
- viii. Description of activities undertaken by any entity contracted for achieving any measurable goal or implementing any control measure.
- c. Reports shall be submitted to EPA at the following address:

United State Environmental Protection Agency Stormwater and Construction Permits Section (OEP06-1) Five Post Office Square, Suite 100 Boston, MA 02109

Massachusetts Department of Environmental Protection One Winter Street – 5th Floor Boston, MA 02108 ATTN: Frederick Civian Or submitted electronically to EPA at the following email address: <u>stormwater.reports@epa.gov</u>. After December 21, 2020 all Annual Reports must be submitted electronically.

5.0. Non-Traditional MS4s

Non-traditional MS4s are MS4s owned and operated by the Commonwealth of Massachusetts, counties or other public agencies within the Commonwealth of Massachusetts, and properties owned and operated by the United States (Federal Facilities) within the Commonwealth of Massachusetts. This part addresses all non-traditional MS4s except MS4s that are owned or operated by transportation agencies, which are addressed in part 6.0 below.

5.1. Requirements for Non-Traditional MS4s

All requirements and conditions of parts 1 - 4 above apply to all Non-traditional MS4s, except as specifically provided below:

5.1.1. Public education

For the purpose of this permit, the audiences for a Non-traditional MS4 include the employees, clients and customers (including students at education MS4s), visitors to the property, tenants, long term contractors and any other contractors working at the facility where the MS4 is located. The permittee may use some of the educational topics included in part 2.3.2.d. as appropriate, or may focus on topics specific to the MS4. The permittee shall document the educational topics for each target audience in the SWMP and annual reports.

5.1.2. Ordinances and regulatory mechanisms

Some Non-traditional MS4s may not have authority to enact an ordinance, by-law, or other regulatory mechanisms. MS4s without the authority to enact an ordinance shall ensure that written policies or procedures are in place to address the requirements of part 2.3.4.5., part 2.3.4.6 and part 2.3.6.a.

5.1.3. Assessment of Regulations

Non-traditional MS4s do not need to meet the requirements of part 2.3.6.c.

5.1.4. New Dischargers

New MS4 facilities are subject to additional water quality-based requirements if they fall within the definition of "new discharger" under 40 CFR § 122.2: "A new discharger is any building, structure, facility or installation (a) from which there is or may be a 'discharge of pollutants' (b) that did not commence the 'discharge of pollutants' at a particular 'site' prior to August 13, 1979; (c) which is not a 'new source'; and (d) which never received a finally effective NPDES permit for discharges at that 'site.' The term "site" is defined in § 122.2 to mean "the land or water area where any 'facility or activity' is physically located or conducted including adjacent land used in connection with the facility or activity."

Consistent with these definitions, a Non-traditional MS4 is a "new discharger" if it discharges stormwater from a new facility with an entirely new separate storm sewer system that is not

physically located on the same or adjacent land as an existing facility and associated system operated by the same MS4.

Any Non-traditional MS4 facility that is a "new discharger" and discharges to a waterbody listed in category 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b) due to nutrients (Total Nitrogen or Total Phosphorus), metals (Cadmium, Copper, Iron, Lead or Zinc), solids (TSS or Turbidity), bacteria/pathogens (E. Coli, Enteroccus or Fecal Coliform), chloride (Chloride) or oil and grease (Petroleum Hydrocarbons or Oil and Grease), or discharges to a waterbody with an approved TMDL for any of those pollutants, is not eligible for coverage under this permit and shall apply for an individual permit.

Any Non-traditional MS4 facility that is a "new discharger" and discharges to a waterbody that is in attainment is subject to Massachusetts antidegradation regulations at 314 CMR 4.04. The permittee shall comply with the provisions of 314 CMR 4.04 including information submittal requirements and obtaining authorization for new discharges where appropriate¹⁶. Any authorization of new discharges by MassDEP shall be incorporated into the permittee's SWMP. If an applicable MassDEP approval specifies additional conditions or requirements, then those requirements are incorporated into this permit by reference. The permittee must comply with all such requirements.

6.0 Requirements for MS4s Owned or Operated by Transportation Agencies

This part applies to all MS4s owned or operated by any state or federal transportation agency (except Massachusetts Department of Transportation –MassDOT- Highway Division, which is subject to a separate individual permit). All requirements and conditions of this permit apply with the following exceptions:

6.1 Public education

For the purpose of this permit, the audiences for a transportation agency education program include the general public (users of the roadways), employees, and any contractors working at the location. The permittee may use some of the educational topics included in part 2.3.2.d. as appropriate, or may focus on topics specific to the agency. The permittee shall document the educational topics for each target audience.

6.2 Ordinances and regulatory mechanisms

The transportation agency may not have authority to enact an ordinance, by-law or other regulatory mechanisms. The agency shall ensure that written agency policies or procedures are in place to address the requirements of part 2.3.4.5., part 2.3.4.6 and part 2.3.6.a.

6.3 Assessment of regulations

Non-traditional MS4s do not need to meet the requirements of part 2.3.6.c.

6.4 New Dischargers

New MS4 facilities are subject to additional water quality-based requirements if they fall within the definition of "new dischargers" under 40 CFR § 122.2: "A new discharger is any building, structure, facility or installation (a) from which there is or may be a 'discharge of pollutants' (b) that did not commence the 'discharge of pollutants' at a particular 'site' prior to August 13, 1979; (c) which is not a 'new source'; and (d) which never received a finally effective NPDES permit for discharges at that 'site.' The term "site" is defined

¹⁶ Contact MassDEP for guidance on compliance with 314 CMR 4.04

in § 122.2 to mean "the land or water area where any 'facility or activity' is physically located or conducted including adjacent land used in connection with the facility or activity."

Consistent with these definitions, a new transportation MS4 is a "new discharger" if it discharges stormwater from a new facility with an entirely new separate storm sewer system that is not physically located on the same or adjacent land as an existing facility and associated system operated by the same MS4.

Any transportation MS4 facility that is a "new discharger" and discharges to a waterbody listed as impaired in category 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b) due to nutrients (Total Nitrogen or Total Phosphorus), metals (Cadmium, Copper, Iron, Lead or Zinc), solids (TSS or Turbidity), bacteria/pathogens (E. Coli, Enteroccus or Fecal Coliform), chloride (Chloride) or oil and grease (Petroleum Hydrocarbons or Oil and Grease), or discharges to a waterbody with an approved TMDL for any of those pollutants, is not eligible for coverage under this permit and shall apply for an individual permit.

Any transportation MS4 facility that is a "new discharger" and discharges to a waterbody that is in attainment is subject to Massachusetts antidegradation regulations at 314 CMR 4.04. The permittee shall comply with the provisions of 314 CMR 4.04 including information submittal requirements and obtaining authorization for new discharges where appropriate¹⁷. Any authorization of new discharges by MassDEP shall be incorporated into the permittee's SWMP. If an applicable MassDEP approval specifies additional conditions or requirements, then those requirements are incorporated into this permit by reference. The permittee must comply with all such requirements.

¹⁷ Contact MassDEP for guidance on compliance with 314 CMR 4.04

Appendix A Definitions, Abbreviations and Acronyms

Definitions

Best Management Practices (BMPs) - schedules of activities, practices (and prohibitions of practices), structures, vegetation, maintenance procedures, and other management practices to prevent or reduce the discharge of pollutants to waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Common Plan of Development - A "larger common plan of development or sale" is a contiguous area where multiple separate and distinct construction activities may be taking place at different times on different schedules under one plan. For example, if a developer buys a 20-acre lot and builds roads, installs pipes, and runs electricity with the intention of constructing homes or other structures sometime in the future, this would be considered a larger common plan of development or sale. If the land is parceled off or sold, and construction occurs on plots that are less than one acre by separate, independent builders, this activity still would be subject to stormwater permitting requirements if the smaller plots were included on the original site plan.

Control Measure - refers to any BMP or other method (including effluent limitations) used to prevent or reduce the discharge of pollutants to waters of the United States.

Director - a Regional Administrator of the Environmental Protection Agency or an authorized representative.

Discharge - when used without qualification, means the "discharge of a pollutant."

Discharge of a pollutant - any addition of any "pollutant" or combination of pollutants to "waters of the United States" from any "point source," or any addition of any pollutant or combination of pollutants to the waters of the "contiguous zone" or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation. This includes additions of pollutants into waters of the United States from surface runoff which is collected or channeled by man; or discharges through pipes, sewers, or other conveyances, leading into privately owned treatment works.

Discharge-related activities - activities which cause, contribute to, or result in stormwater and allowable non-stormwater point source discharges, and measures such as the siting, construction and operation of BMPs to control, reduce, or prevent pollution in the discharges.

Disturbance - action to alter the existing vegetation and/or underlying soil of a site, such as clearing, grading, site preparation (e.g., excavating, cutting, and filling), soil compaction, and movement and stockpiling of top soils.

Existing Discharger – an operator applying for coverage under this permit for discharges covered previously under an NPDES general or individual permit.

Facility or Activity - any NPDES "point source" or any other facility or activity (including land or appurtenances thereto) that is subject to regulation under the NPDES program.

Federal Facility – Any buildings, installations, structures, land, public works, equipment, aircraft, vessels, and other vehicles and property, owned by, or constructed or manufactured for the purpose of leasing to, the federal government.

Illicit Discharge - any discharge to a municipal separate storm sewer that is not composed entirely of stormwater except discharges pursuant to a NPDES permit (other than the NPDES permit for discharges from the municipal separate storm sewer) and discharges resulting from fire fighting activities.

Impaired Water – A water is impaired if it does not meet one or more of its designated use(s). For purposes of this permit, "impaired" refers to categories 4 and 5 of the fivepart categorization approach used for classifying the water quality standards attainment status for water segments under the TMDL program. Impaired waters compilations are also sometimes referred to as "303(d) lists." Category 5 waters are impaired because at least one designated use is not being supported or is threatened and a TMDL is needed. Category 4 waters indicate that at least one designated use is not being supported or established by EPA; 4b indicates other required control measures are expected in result in the attainment of water quality standards in a reasonable period of time; and 4c indicates that the non-attainment of the water quality standard is the result of pollution (e.g. habitat) and is not caused by a pollutant). See *USEPA's 2006 Integrated Report Guidance, July 29, 2005* for more detail on the five part categorization of waters [under EPA National TMDL Guidance <u>http://www.epa.gov/owow/tmdl/policy.html]</u>).

Impervious Surface- Any surface that prevents or significantly impedes the infiltration of water into the underlying soil. This can include but is not limited to: roads, driveways, parking areas and other areas created using non porous material; buildings, rooftops, structures, artificial turf and compacted gravel or soil.

Industrial Activity - the ten categories of industrial activities included in the definition of "stormwater discharges associated with industrial activity," as defined in 40 CFR 122.26(b)(14)(i)-(ix) and (xi).

Industrial Stormwater - stormwater runoff associated with the definition of "stormwater discharges associated with industrial activity."

Interconnection – the point (excluding sheet flow over impervious surfaces) where the permittee's MS4 discharges to another MS4 or other storm sewer system, through which the discharge is eventually conveyed to a water of the United States. Interconnections shall be treated similarly to outfalls throughout the permit.

Junction Manhole - For the purposes of this permit, a junction manhole is a manhole or structure with two or more inlets accepting flow from two or more MS4 alignments. Manholes with inlets solely from private storm drains, individual catch basins, or both are not considered junction manholes for these purposes.

Key Junction Manhole - For the purposes of this permit, key junction manholes are those junction manholes that can represent one or more junction manholes without compromising adequate implementation of the illicit discharge program. Adequate implementation of the illicit discharge program would not be compromised if the exclusion of a particular junction manhole as a key junction manhole would not affect the permittee's ability to determine the possible presence of an upstream illicit discharge. A permittee may exclude a junction manhole located upstream from another located in the immediate vicinity or that is serving a drainage alignment with no potential for illicit connections.

Municipal Separate Storm Sewer - a conveyance or system of conveyances (including roads with drainage systems, municipal streets, catch basins, curbs, gutters, ditches, manmade channels, or storm drains):

- (i) Owned or operated by a State, city, town, borough, county, parish, district, association, or other public body (created by or pursuant to State law) having jurisdiction over disposal of sewage, industrial wastes, stormwater, or other wastes, including special districts under State law such as a sewer district, flood control district or drainage district, or similar entity, or an Indian tribe or an authorized Indian tribal organization, or a designated and approved management agency under section 208 of the CWA that discharges to waters of the United States;
- (ii) Designed or used for collecting or conveying stormwater;
- (iii) Which is not a combined sewer; and
- (iv) Which is not part of a Publicly Owned Treatment Works (POTW) as defined at 40 CFR 122.2.

Municipal Separate Storm Sewer System (MS4) - means all separate storm sewers that are defined as "large" or "medium" or "small" municipal storm sewer systems pursuant to paragraphs 40 CFR 122.26 (b)(4) and (b)(7), or designated under paragraph 40 126.26(a) (1)(v). For the purposes of this permit "MS4" may also refer to the permittee with jurisdiction over the sewer system.

New Development – any construction activities or land alteration resulting in total earth disturbances greater than 1 acre (or activities that are part of a larger common plan of development disturbing greater than 1 acre) on an area that has not previously been developed to include impervious cover. (see part 2.3.6. of the permit)

New Discharger – For the purposes of this permit, a new discharger is an entity that discharges stormwater from a new facility with an entirely new separate storm sewer system that is not physically located on the same or adjacent land as an existing facility and associated system operated by the same MS4.

New Source - any building, structure, facility, or installation from which there is or may be a "discharge of pollutants," the construction of which commenced:

- S after promulgation of standards of performance under section 306 of the CWA which are applicable to such source, or
- S after proposal of standards of performance in accordance with section 306 of the CWA which are applicable to such source, but only if the standards are promulgated in accordance with section 306 within 120 days of their proposal.

New Source Performance Standards (NSPS) – Technology-based standards for facilities that qualify as new sources under 40 CFR 122.2 and 40 CFR 122.29.

No exposure - all industrial materials or activities are protected by a storm-resistant shelter to prevent exposure to rain, snow, snowmelt, and/or runoff.

One Lane Width – The width of the travel lane for a roadway. Lane width does not include shoulders, curbs, and on-street parking areas.

Outfall Catchment – The land area draining to a single outfall or interconnection. The extent of an outfall's catchment is determined not only by localized topography and impervious cover but also by the location of drainage structures and the connectivity of MS4 pipes.

Owner or operator - the owner or operator of any "facility or activity" subject to regulation under the NPDES program.

Person - an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

Point source - any discernible, confined, and discrete conveyance, including but not limited to any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel, or other floating craft from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural stormwater runoff.

Pollutant - dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, heat, wrecked or discarded equipment, rock, sand, cellar dirt, and industrial, municipal and agricultural waste discharged into water.

Pollutant of concern – A pollutant which causes or contributes to a violation of a water quality standard, including a pollutant which is identified as causing an impairment in a State's 303(d) list.

Redevelopment – for the purposes of part 2.3.6., any construction, land alteration, or improvement of impervious surfaces resulting in total earth disturbances greater than 1

acre (or activities that are part of a larger common plan of development disturbing greater than 1 acre) that does not meet the definition of new development (see above).

Reportable Quantity Release – a release of a hazardous substance at or above the established legal threshold that requires emergency notification. Refer to 40 CFR Parts 110, 177, and 302 for complete definitions and reportable quantities for which notification is required.

Runoff coefficient - the fraction of total rainfall that will appear at the conveyance as runoff.

Significant materials - includes, but is not limited to: raw materials; fuels; materials such as solvents, detergents, and plastic pellets; finished materials such as metallic products; raw materials used in food processing or production; hazardous substances designated under section 101(14) of CERCLA; any chemical the facility is required to report pursuant to section 313 of Title III of SARA; fertilizers; pesticides; and waste products such as ashes, slag and sludge that have the potential to be released with stormwater discharges.

Site – for the purposes of part 2.3.6., the area extent of construction activities, including but not limited to the creation of new impervious cover and improvement of existing impervious cover (e.g. repaying not covered by 2.3.6.a.ii.4.d.)

Small Municipal Separate Storm Sewer System – all separate storm sewer systems that are (i) owned or operated by the United States, a State, city, town, borough, county, parish, district, association, or other public body (created by or pursuant to State law) having jurisdiction over disposal of sewage, industrial wastes, storm water, or other wastes, including special districts under State law such as a sewer district, flood control district, or drainage district, or similar entity or an Indian tribe or an authorized Indian tribal organization or a designated and approved management agency under section 208 of the CWA that discharges to waters of the United States, and (ii) not defined as "large" or "medium" municipal separate storm sewer system pursuant to paragraphs 40 CFR 122.26 (b)(4) and (b)(7), or designated under paragraph 40 126.26(a) (1)(v). This term includes systems similar to separate storm sewer systems in municipalities, such as systems at military bases, large hospital or prison complexes, and highways and other thoroughfares. This term does not include separate storm sewers in very discrete areas, such as individual buildings.

Small MS4 – means a small municipal separate storm sewer system.

Stormwater - stormwater runoff, snow melt runoff, and surface runoff and drainage.

Stormwater Discharges Associated with Construction Activity - a discharge of pollutants in stormwater runoff from areas where soil disturbing activities (e.g., clearing, grading, or excavating), construction materials, or equipment storage or maintenance (e.g., fill piles, borrow areas, concrete truck washout, fueling), or other industrial

stormwater directly related to the construction process (e.g., concrete or asphalt batch plants) are located. (See 40 CFR 122.26(b)(14)(x) and 40 CFR 122.26(b)(15).

Stormwater Discharges Associated with Industrial Activity - the discharge from any conveyance that is used for collecting and conveying stormwater and that is directly related to manufacturing, processing or raw materials storage areas at an industrial plant. The term does not include discharges from facilities or activities excluded from the NPDES program under Part 122. For the categories of industries identified in this section, the term includes, but is not limited to, stormwater discharges from industrial plant yards; immediate access roads and rail lines used or traveled by carriers of raw materials, manufactured products, waste material, or by-products used or created by the facility; material handling sites; refuse sites; sites used for the application or disposal of process waste waters (as defined at part 401 of this chapter); sites used for the storage and maintenance of material handling equipment; sites used for residual treatment, storage, or disposal; shipping and receiving areas; manufacturing buildings; storage areas (including tank farms) for raw materials, and intermediate and final products; and areas where industrial activity has taken place in the past and significant materials remain and are exposed to stormwater. For the purposes of this paragraph, material handling activities include storage, loading and unloading, transportation, or conveyance of any raw material, intermediate product, final product, by-product or waste product. The term excludes areas located on plant lands separate from the plant's industrial activities, such as office buildings and accompanying parking lots as long as the drainage from the excluded areas is not mixed with stormwater drained from the above described areas. Industrial facilities include those that are federally, State, or municipally owned or operated that meet the description of the facilities listed in Appendix D of this permit. The term also includes those facilities designated under the provisions of 40 CFR 122.26(a)(1)(v).

Total Maximum Daily Loads (TMDLs) - A TMDL is a calculation of the maximum amount of a pollutant that a waterbody can receive and still meet water quality standards, and an allocation of that amount to the pollutant's sources. A TMDL includes wasteload allocations (WLAs) for point source discharges, load allocations (LAs) for nonpoint sources and/or natural background, and must include a margin of safety (MOS) and account for seasonal variations. (See section 303(d) of the Clean Water Act and 40 CFR 130.2 and 130.7).

Urbanized Area – US Census designated area comprised of a densely settled core of census tracts and/or census blocks that meet minimum population density requirements, along with adjacent territory containing non-residential urban land uses as well as territory with low population density included to link outlying densely settled territory with the densely settled core. For the purposes of this permit, Urbanized Areas as defined by any Census since 2000 remain subject to stormwater regulation even if there is a change in the reach of the Urbanized Area because of a change in more recent Census data.

Water Quality Limited Water – for the purposes of this permit, a water quality limited water is any waterbody that does not meet applicable water quality standards, including but not limited to waters listed in categories 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act section 303(d) and 305(b).

Water Quality Standards - A water quality standard defines the water quality goals of a water body, or portion thereof, by designating the use or uses to be made of the water and by setting criteria necessary to protect the uses. States and EPA adopt WQS to protect public health or welfare, enhance the quality of water and serve the purposes of the Clean Water Act (See CWA sections 101(a)2 and 303(c)).

ABBREVIATIONS AND ACRONYMS

BMP – Best Management Practice

BPJ – Best Professional Judgment

CGP – Construction General Permit

CWA – Clean Water Act (or the Federal Water Pollution Control Act, 33 U.S.C. §1251 *et seq*)

DCIA – Directly Connected Impervious Area

EPA – U. S. Environmental Protection Agency

ESA - Endangered Species Act

USFWS – U. S. Fish and Wildlife Service

IA – Impervious Area

IDDE – Illicit Discharge Detection and Elimination

LA – Load Allocations

MOS – Margin of Safety

MS4 – Municipal Separate Storm Sewer System

MSGP - Multi-Sector General Permit

NHPA – National Historic Preservation Act

NMFS – U. S. National Marine Fisheries Service

NOI – Notice of Intent

NPDES – National Pollutant Discharge Elimination System

NRHP - National Register of Historic Places

NSPS – New Source Performance Standard

NTU – Nephelometric Turbidity Unit

PCP – Phosphorus Control Plan (pertaining to Charles River Watershed phosphorus

TMDL requirements only – Appendix F Part A.I)

LPCP – Lake Phosphorus Control Plan (pertaining to Lake or pond phosphorus TMDL

requirements only – Appendix F Part A.II)

POTW – Publicly Owned Treatment Works

RCRA – Resource Conservation and Recovery Act

SHPO - State Historic Preservation Officer

SIC – Standard Industrial Classification

SPCC – Spill Prevention, Control, and Countermeasure

SWMP – Stormwater Management Program

SWPPP – Stormwater Pollution Prevention Plan

TMDL – Total Maximum Daily Load

TSS – Total Suspended Solids

USGS – United States Geological Survey WLA – Wasteload Allocation

WQS - Water Quality Standard

Appendix B

Standard Permit Conditions

Standard Permit Conditions

Standard permit conditions in Appendix B are consistent with the general permit provisions required under 40 CFR 122.41.

B.1. Duty To Comply

You must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

- A. You must comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- B. Penalties for Violations of Permit Conditions: The Director will adjust the civil and administrative penalties listed below in accordance with the Civil Monetary Penalty Inflation Adjustment Rule (61 FR 252, December 31, 1996, pp. 69359-69366, as corrected in 62 FR 54, March 20, 1997, pp.13514-13517) as mandated by the Debt Collection Improvement Act of 1996 for inflation on a periodic basis. This rule allows EPA's penalties to keep pace with inflation. The Agency is required to review its penalties at least once every 4 years thereafter and to adjust them as necessary for inflation according to a specified formula. The civil and administrative penalties following were adjusted for inflation starting in 1996.
 - 1. Criminal Penalties.
 - a. *Negligent Violations*. The CWA provides that any person who negligently violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation or by imprisonment of not more than two years, or both.
 - *Knowing Violations*. The CWA provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than 3 years, or both. In the case of a

second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.

- c. Knowing Endangerment. The CWA provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act and who knows at that time that he or she is placing another person in imminent danger of death or serious bodily injury shall upon conviction be subject to a fine of not more than \$250,000 or by imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision be subject to a fine of not more than \$1,000,000 and can fined up to \$2,000,000 for second or subsequent convictions.
- False Statement. The CWA provides that any person who falsifies, d. tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.
- 2. *Civil Penalties.* The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a civil penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$32,500 per day for each violation).
- 3. *Administrative Penalties.* The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to an administrative penalty, as follows:

- 3.1. Class I Penalty. Not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$11,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$32,500).
- 3.2. *Class II Penalty*. Not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$11,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$157,500).

B.2. Duty to Reapply

If you wish to continue an activity regulated by this permit after the expiration date of this permit, you must apply for and obtain a new permit.

B.3. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for you in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

B.4. Duty to Mitigate

You must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

B.5. Proper Operation and Maintenance

You must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by you to achieve compliance with the conditions of this permit, including the requirements of your SWPPP. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by you only when the operation is necessary to achieve compliance with the conditions of this permit.

B.6. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. Your filing of a request for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

B.7. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privileges.

B.8. Duty to Provide Information

You must furnish to EPA or an authorized representative (including an authorized contractor acting as a representative of EPA), within a reasonable time, any information which EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. You must also furnish to EPA upon request, copies of records required to be kept by this permit.

B.9. Inspection and Entry

You must allow EPA or an authorized representative (including an authorized contractor acting as a representative of EPA), upon presentation of credentials and other documents as may be required by law, to:

- A. Enter upon your premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- D. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

B.10. Monitoring and Records

- A. Samples and measurements taken for the purpose of monitoring must be representative of the volume and nature of the monitored activity.
- B. You must retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three years from the date of the sample, measurement, report or application. This period may be extended by request of EPA at any time.
- C. Records of monitoring information must include:
 - 1. The date, exact place, and time of sampling or measurements;
 - 2. The individual(s) who performed the sampling or measurements;
 - 3. The date(s) analyses were performed

- 4. The individual(s) who performed the analyses;
- 5. The analytical techniques or methods used; and
- 6. The results of such analyses.
- Monitoring results must be conducted according to test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, unless other test procedures have been specified in the permit.
- E. The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.

B.11. Signatory Requirements

- A. All applications, including NOIs, must be signed as follows:
 - 1. For a corporation: By a responsible corporate officer. For the purpose of this subsection, a responsible corporate officer means: (i) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
 - 2. For a partnership or sole proprietorship: By a general partner or the proprietor, respectively; or
 - 3. For a municipality, state, federal, or other public agency: By either a principal executive officer or ranking elected official. For purposes of this subsection, a principal executive officer of a federal agency includes (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrator of EPA).

- B. All reports, including SWPPPs, inspection reports, annual reports, monitoring reports, reports on training and other information required by this permit must be signed by a person described in Appendix B, Subsection 11.A above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by a person described in Appendix B, Subsection 11.A;
 - 2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
 - 3. The signed and dated written authorization is included in the SWPPP. A copy must be submitted to EPA, if requested.
- C. Changes to Authorization. If an authorization under Appendix B, Subsection 11.B is no longer accurate because a different operator has responsibility for the overall operation of the industrial facility, a new NOI satisfying the requirements of Subsection 11.B must be submitted to EPA prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Any person signing documents required under the terms of this permit must include the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

E. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

B.12. Reporting Requirements

- A. Planned changes. You must give notice to EPA as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - 1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR §122.29(b); or
 - 2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR §122.42(a)(1).
- B. Anticipated noncompliance. You must give advance notice to EPA of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- C. Transfers. This permit is not transferable to any person except after notice to EPA. EPA may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Clean Water Act. (See 40 CFR §122.61; in some cases, modification or revocation and reissuance is mandatory.)
- D. Monitoring reports. Monitoring results must be reported at the intervals specified elsewhere in this permit.
 - 1. Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms (paper or electronic) provided or specified by EPA for reporting results of monitoring of sludge use or disposal practices.
 - 2. If you monitor any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or, in the case of sludge use or disposal, approved under 40 CFR Part 136 unless otherwise specified in 40 CFR Part 503, or as specified in the permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by EPA.
 - 3. Calculations for all limitations which require averaging of measurements must use an arithmetic mean and non-detected results must be incorporated in calculations as the limit of quantitation for the analysis.
- E. Compliance schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date.
- F. Twenty-four hour reporting.
 - 1. You must report any noncompliance which may endanger health or the environment. Any information must be provided orally within 24 hours

from the time you become aware of the circumstances. A written submission must also be provided within five days of the time you become aware of the circumstances. The written submission must contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- 2. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - a. Any unanticipated bypass which exceeds any effluent limitation in the permit. (See 40 CFR §122.41(g).)
 - b. Any upset which exceeds any effluent limitation in the permit
 - c. Violation of a maximum daily discharge limitation for any of the pollutants listed by EPA in the permit to be reported within 24 hours. (See 40 CFR §122.44(g).)
- 3. EPA may waive the written report on a case-by-case basis for reports under Appendix B, Subsection 12.F.2 if the oral report has been received within 24 hours.
- G. Other noncompliance. You must report all instances of noncompliance not reported under Appendix B, Subsections 12.D, 12.E, and 12.F, at the time monitoring reports are submitted. The reports must contain the information listed in Appendix B, Subsection 12.F.
- H. Other information. Where you become aware that you failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Permitting Authority, you must promptly submit such facts or information.

B.13. Bypass

- A. Definitions.
 - 1. Bypass means the intentional diversion of waste streams from any portion of a treatment facility
 - 2. Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- B. Bypass not exceeding limitations. You may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential

maintenance to assure efficient operation. These bypasses are not subject to the provisions of Appendix B, Subsections 13.C and 13.D.

- C. Notice.
 - 1. Anticipated bypass. If you know in advance of the need for a bypass, you must submit prior notice, if possible at least ten days before the date of the bypass.
 - 2. Unanticipated bypass. You must submit notice of an unanticipated bypass as required in Appendix B, Subsection 12.F (24-hour notice).
- D. Prohibition of bypass.
 - 1. Bypass is prohibited, and EPA may take enforcement action against you for bypass, unless:
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - c. You submitted notices as required under Appendix B, Subsection 13.C.
 - 2. EPA may approve an anticipated bypass, after considering its adverse effects, if EPA determines that it will meet the three conditions listed above in Appendix B, Subsection 13.D.1.

B.14. Upset

- A. Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond your reasonable control. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- B. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Appendix B, Subsection 14.C are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

- C. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - 1. An upset occurred and that you can identify the cause(s) of the upset;
 - 2. The permitted facility was at the time being properly operated; and
 - 3. You submitted notice of the upset as required in Appendix B, Subsection 12.F.2.b (24 hour notice).
 - 4. You complied with any remedial measures required under Appendix B, Subsection 4.

D. Burden of proof. In any enforcement proceeding, you, as the one seeking to establish the occurrence of an upset, has the burden of proof.

APPENDIX C ENDANGERED SPECIES GUIDANCE

A. Background

In order to meet its obligations under the Clean Water Act and the Endangered Species Act (ESA), and to promote the goals of those Acts, the Environmental Protection Agency (EPA) is seeking to ensure the activities regulated by this general permit do not adversely affect endangered and threatened species or critical habitat. Applicants applying for permit coverage must assess the impacts of their stormwater discharges and discharge-related activities on federally listed endangered and threatened species ("listed species") and designated critical habitat ("critical habitat") to ensure that those goals are met. Prior to obtaining general permit coverage, applicants must meet the ESA eligibility provisions of this permit by following the steps in this Appendix¹.

Applicants also have an independent ESA obligation to ensure that their activities do not result in any prohibited "take" of listed species¹². The term "Take" is used in the ESA to include harass, harm, pursue, hunt, shoot, wound, kill, trap, capture, collect, or attempt to engage in any such conduct. "Harm" is further defined to include significant habitat modification or degradation that results in death or injury to listed species by significantly impairing essential behavioral patterns including breeding, feeding, or sheltering. "Harass" is defined as intentional or negligent actions that create the likelihood of injury to listed species to such an extent as to significantly disrupt normal behavior patterns which include, but are not limited to, breeding, feeding, or sheltering. Many of the measures required in this general permit and in these instructions to protect species may also assist in ensuring that the applicant's activities do not result in a prohibited take of species in violation of section 9 of the ESA. If the applicant has plans or activities in an area where endangered and threatened species are located, they may wish to ensure that they are protected from potential take liability under ESA section 9 by obtaining an ESA section 10 permit or by requesting formal consultation under ESA section 7. Applicants that are unsure whether to pursue a section 10 permit or a section 7 consultation for takings protection should confer with the appropriate United States Fish and Wildlife Service (USFWS) office or the National Marine Fisheries Service (NMFS), (jointly the Services).

Currently, there are 20 species of concern for applicants applying for permit coverage, namely the Dwarf wedgemussel (*Alasmidonta heterodon*), Northeastern bulrush (*Scirpus ancistrochaetus*), Sandplain gerardia (*Agalinis acuta*), Piping Plover (*Charadrius melodus*), Roseate Tern (*Sterna dougallii*), Northern Red-bellied cooter (*Pseudemys rubriventis*), Bog Turtle (*Glyptemys muhlenbergii*), Small whorled Pogonia (*Isotria medeoloides*), Puritan tiger beetle (*Cicindela puritana*), American burying beetle (*Nicrophorus americanus*), Northeastern beach tiger beetle (*Cicindela dorsalis*), Northern Long-eared Bat (*Myotis septentriolis*)Atlantic Sturgeon (*Acipenser oxyrinchus*), Shortnose Sturgeon (*Acipenser brevirostrum*), North Atlantic Right Whale (*Eubalaena glacialis*) Humpback Whale (*Megaptera novaengliae*), Fin Whale (*Balaenoptera physalus*), Kemp's Ridley Sea Turtle (*Lepidochelys kempii*), Loggerhead Sea Turtle (*Caretta caretta*), Leatherback Sea Turtle (*Dermochelys coriacea*), and the Green Turtle (*Chelonia*)

¹ EPA strongly encourages applicants to begin this process at the earliest possible stage to ensure the notification requirements for general permit coverage are complete upon Notice of Intent (NOI) submission.

² Section 9 of the ESA prohibits any person from "taking" a listed species (e.g. harassing or harming it) unless: (1) the taking is authorized through an "incidental take statement" as part of completion of formal consultation according to ESA section 7; (2) where an incidental take permit is obtained under ESA section 10 (which requires the development of a habitat conversion plan; or (3) where otherwise authorized or exempted under the ESA. This prohibition applies to all entities including private individuals, businesses, and governments.
mydas). The Atlantic Sturgeon, Shortnose Sturgeon, North Atlantic Right Whale, Humpback Whale, Fin Whale, Loggerhead Sea Turtle, Kemp's Ridley Sea Turtle, Leatherback Sea Turtle and Green Turtle are listed under the jurisdiction of NMFS. The Dwarf wedgemussel, Northeastern bulrush, Sandplain gerardia, Piping Plover, Northern Red-bellied cooter, Bog Turtle, Small whorled Pogonia, Roseate Tern, Puritan tiger beetle, Northeastern beach tiger beetle, Northern Long-eared Bat and American burying beetle are listed under the jurisdiction of the U.S. Fish and Wildlife Service.

Any applicant seeking coverage under this general permit, must consult with the Services where appropriate. When listed species are present, permit coverage is only available if EPA determines, or the applicant determines and EPA concurs, that the discharge or discharge related activities will have "no affect" on the listed species or critical habitat, or the applicant or EPA determines that the discharge or discharge related activities are "not likely to adversely affect" listed species or critical habitat and formal or informal consultation with the Services has been concluded and results in written concurrence by the Services that the discharge is "not likely to adversely affect" an endangered or threatened species or critical habitat.

EPA may designate the applicants as non-Federal representatives for the general permit for the purpose of carrying out formal or informal consultation with the Services (See 50 CFR §402.08 and §402.13). By terms of this permit, EPA has automatically designated operators as non-Federal representatives for the purpose of conducting formal or informal consultation with the U.S. Fish and Wildlife Service. EPA has not designated operators as non-Federal representatives for the purpose of conducting formal consultation with the National Marine Fisheries Service. EPA has determined that discharges from MS4s are not likely to adversely affect listed species or critical habitat under the jurisdiction of the National Marine Fisheries Service. EPA has initiated informal consultation with the National Marine Fisheries Service on behalf of all permittees and no further action is required by permittees in order to fulfill ESA requirements of this permit related to species under the jurisdiction of NMFS

B. The U.S. Fish and Wildlife Service ESA Eligibility Process

Before submitting a notice of intent (NOI) for coverage by this permit, applicants must determine whether they meet the ESA eligibility criteria by following the steps in Section B of this Appendix. Applicants that cannot meet the eligibility criteria in Section B must apply for an individual permit.

The USFWS ESA eligibility requirements of this permit relating to the Dwarf wedgemussel, Northeastern bulrush, Sandplain gerardia, Piping Plover, Northern Red-bellied cooter, Bog Turtle, Small whorled Pogonia, Roseate Tern, Puritan tiger beetle, Northeastern beach tiger beetle, Northern Long-eared Bat and American burying beetle may be satisfied by documenting that one of the following criteria has been met:

USFWS Criterion A:	No endangered or threatened species or critical habitat are in proximity to the stormwater discharges or discharge related activities.
USFWS Criterion B:	In the course of formal or informal consultation with the Fish and Wildlife Service, under section 7 of the ESA, the consultation resulted in either a no jeopardy opinion (formal consultation) or a written concurrence by USFWS on a finding that the stormwater discharges and

discharge related activities are "not likely to adversely affect" listed species or critical habitat (informal consultation).

USFWS Criterion C: Using the best scientific and commercial data available, the effect of the stormwater discharge and discharge related activities on listed species and critical habitat have been evaluated. Based on those evaluations, a determination is made by EPA, or by the applicant and affirmed by EPA, that the stormwater discharges and discharge related activities will have "no affect" on any federally threatened or endangered listed species or designated critical habitat under the jurisdiction of the USFWS.

1. The Steps to Determine if the USFWS ESA Eligibility Criteria Can Be Met

To determine eligibility, you must assess the potential effects of your known stormwater discharges and discharge related activities on listed species or critical habitat, PRIOR to completing and submitting a Notice of Intent (NOI). You must follow the steps outlined below and document the results of your eligibility determination.

Step 1 – Determine if you can meet USFWS Criterion A

USFWS Criterion A: You can certify eligibility, according to USFWS Criterion A, for coverage by this permit if, upon completing the Information, Planning, and Conservation (IPaC) online system process, you printed and saved the preliminary determination which indicated that federally listed species or designated critical habitats are not present in the action area. See Attachment 1 to Appendix C for instructions on how to use IPaC.

If you have met USFWS Criterion A skip to Step # 4.

If you have not met USFWS Criterion A, go to Step # 2.

Step 2 – Determine if You Can Meet Eligibility USFWS Criteria B

USFWS Criterion B: You can certify eligibility according to USFWS Criteria B for coverage by this permit if you answer "Yes" to **all** of the following questions:

- Does your action area contain one or more of the following species: Sandplain gerardia, Small whorled Pogonia, American burying beetle, Dwarf wedgemussel, Northeastern bulrush, Piping Plover, Northern Red-bellied cooter, Bog Turtle, Roseate Tern, Puritan tiger beetle, and Northeastern beach tiger beetle? AND
- 2) Did your assessment of the discharge and discharge related activities indicate that the discharge or discharge related activities "may affect" or are "not likely to adversely affect" listed species or critical habitat? AND
- 3) Did you contact the USFWS and did the formal or informal consultation result in either a "no jeopardy" opinion by the USFWS (for formal consultation) or concurrence by the

USFWS that your activities would be "not likely to adversely affect" listed species or critical habitat (for informal consultation)? AND

- 4) Do you agree to implement all measures upon which the consultation was conditioned?
- 5) Do you agree that if, during the course of the permit term, you plan to install a structural BMP not identified in the NOI that you will re-initiate informal or formal consultation with USFWS as necessary?

Use the guidance below Step 3 to understand effects determination and to answer these questions.

If you answered "Yes" to all four questions above, you have met eligibility USFWS Criteria B. Skip to Step 4.

If you answered "No" to any of the four questions above, go to Step 3.

Step 3 – Determine if You Can Meet Eligibility USFWS Criterion C

USFWS Criterion C: You can certify eligibility according to USFWS Criterion C for coverage by this permit if you answer "Yes" to both of the following question:

- Does your action area contain one or more of the following species: Northern Longeared Bat, Sandplain gerardia, Small whorled Pogonia and/or American burying beetle and **does not** contain one any following species: Dwarf wedgemussel, Northeastern bulrush, Piping Plover, Northern Red-bellied cooter, Bog Turtle, Roseate Tern, Puritan tiger beetle, and Northeastern beach tiger beetle?³ OR
- 2) Did the assessment of your discharge and discharge related activities and indicate that there would be "no affect" on listed species or critical habitat and EPA provided concurrence with your determination?
- 3) Do you agree that if, during the course of the permit term, you plan to install a structural BMP not identified in the NOI that you will to conduct an endangered species screening for the proposed site and contact the USFWS if you determine that the new activity "may affect" or is "not likely to adversely affect" listed species or critical habitat under the jurisdiction of the USFWS.

Use the guidance below to understand effects determination and to answer these questions.

If you answered "Yes" to both the question above, you have met eligibility USFWS Criterion C. Go to Step 4.

If you answered "No" to either of the questions above, you are not eligible for coverage by this permit. You must submit an application for an individual permit for your stormwater discharges. (See 40 CFR 122.21).

USFWS Effects Determination Guidance:

If you are unable to certify eligibility under USFWS Criterion A, you must assess whether your stormwater discharges and discharge-related activities "may affect", will have "no affect" or are "not likely to adversely affect" listed species or critical habitat. "Discharge-related activities" include: activities which cause, contribute to, or result in point source stormwater pollutant discharges; and measures to provide treatment for stormwater discharges including the siting, construction and operational procedures to control, reduce or prevent water pollution. Please be aware that no protection from incidental take liability is provided under this criterion.

The scope of effects to consider will vary with each system. If you are having difficulty in determining whether your system is likely to cause adverse effects to a listed species or critical habitat, you should contact the USFWS for assistance. In order to complete the determination of effects it may be necessary to follow the formal or informal consultation procedures in section 7 of the ESA.

Upon completion of your assessment, document the results of your effects determination. If your results indicate that stormwater discharges or discharge related activities will have "no affect" on threatened or endangered species or critical habitat and EPA concurs with your determination, you are eligible under USFWS Criterion C of this Appendix. Your determination may be based on measures that you implement to avoid, eliminate, or minimized adverse effects.

If the determination is "May affect" or "not likely to adversely affect" you must contact the USFWS to discuss your findings and measures you could implement to avoid, eliminate, or minimize adverse effects. If you and the USFWS reach agreement on measures to avoid adverse effects, you are eligible under USFWS Criterion B. Any terms and/or conditions to protect listed species and critical habitat that you relied on in order to complete an adverse effects determination, must be incorporated into your Storm Water Management Program (required by this permit) and implemented in order to maintain permit eligibility.

If endangered species issues cannot be resolved: If you cannot reach agreement with the USFWS on measures to avoid or eliminate adverse effects then you are not eligible for coverage under this permit. You must seek coverage under an individual permit.

Effects from stormwater discharges and discharge-related activities which could pose an adverse effect include:

- *Hydrological:* Stormwater discharges may cause siltation, sedimentation, or induce other changes in receiving waters such as temperature, salinity or pH. These effects will vary with the amount of stormwater discharged and the volume and condition of the receiving water. Where a discharge constitutes a minute portion of the total volume of the receiving water, adverse hydrological effects are less likely.
- *Habitat:* Excavation, site development, grading and other surface disturbance activities, including the installation or placement of treatment equipment may adversely affect listed species or their habitat. Stormwater from the small MS4 may inundate a listed species habitat.

• *Toxicity:* In some cases, pollutants in the stormwater may have toxic effects on listed species.

Step 4 - Document Results of the Eligibility Determination

Once the USFWS ESA eligibility requirements have been met, you shall include documentation of USFWS ESA eligibility in the Storm Water Management Program required by the permit. Documentation for the various eligibility criteria are as follows:

- USFWS Criterion A: A copy of the IPaC generated preliminary determination letter indicating that no listed species or critical habitat is present within your action area. You shall also include a statement on how you determined that no listed species or critical habitat are in proximity to your stormwater system or discharges.
- USFWS Criterion B: A dated copy of the USFWS letter of concurrence on a finding of "no jeopardy" (for formal consultation) or "not likely to adversely affect" (for informal consultation) regarding the ESA section 7 consultation.
- USFWS Criterion C: A dated copy of the EPA concurrence with the operator's determination that the stormwater discharges and discharge-related activities will have "no affect" on listed species or critical habitat.

C. Submittal of Notice of Intent

Once the ESA eligibility requirements of Part C of this Appendix have been metyoumay submit the Notice of Intent indicating which Criterion you have met to be eligible for permit coverage. Signature and submittal of the NOI constitutes your certification, under penalty of law, of eligibility for permit coverage under 40 CFR 122.21.

D. Duty to Implement Terms and Conditions upon which Eligibility was Determined

You must comply with any terms and conditions imposed under the ESA eligibility requirements to ensure that your stormwater discharges and discharge related activities do not pose adverse effects or jeopardy to listed species and/or critical habitat. You must incorporate such terms and conditions into your Storm Water Management Program as required by this permit. If the ESA eligibility requirements of this permit cannot be met, then you may not receive coverage under this permit and must apply for an individual permit.

E. Services Information

United States Fish and Wildlife Service Office

National websites for Endangered Species Information: Endangered Species home page: <u>http://endangered.fws.gov</u> ESA Section 7 Consultations: <u>http://endangered.fws.gov/consultation/index.html</u> Information, Planning, and Conservation System (IPAC): <u>http://ecos.fws.gov/ipac/</u>

U.S. FWS – Region 5 Supervisor New England Field Office U.S. Fish and Wildlife Services 70 Commercial Street, Suite 300 Concord, NH 03301

Natural Heritage Network

The Natural Heritage Network comprises 75 independent heritage program organizations located in all 50 states, 10 Canadian provinces, and 12 countries and territories located throughout Latin America and the Caribbean. These programs gather, manage, and distribute detailed information about the biological diversity found within their jurisdictions. Developers, businesses, and public agencies use natural heritage information to comply with environmental laws and to improve the environmental sensitivity of economic development projects. Local governments use the information to aid in land use planning.

The Natural Heritage Network is overseen by NatureServe, the Network's parent organization, and is accessible on-line at:

<u>http://www.natureserve.org/nhp/us_programs.htm</u>, which provides websites and other access to a large number of specific biodiversity centers.

U.S. Fish and Wildlife IPaC system instructions

Use the following protocol to determine if any federally listed species or designated critical habitats under USFWS jurisdiction exist in your action area:

Enter your project specific information into the "Initial Project Scoping" feature of the Information, Planning, and Conservation (IPaC) system mapping tool, which can be found at the following location:

http://ecos.fws.gov/ipac/

- a. Indicate the action area¹ for the MS4 by either:
 a. Drawing the boundary on the map or by uploading a shapefile. Select "Continue"
- c. Click on the "SEE RESOURCE LIST" button and on the next screen you can export a trust resources list. This will provided a list of natural resources of concern, which will include an Endangered Species Act Species list. You may also request an official species list under "REGULATORY DOCUMENTS" Save copies and retain for your records

For storm water discharges or discharge related activities, the action area should encompass the following:

¹ The action area is defined by regulation as all areas to be affected directly or indirectly by the action and not merely the immediate area involved in the action (50 CFR §402.02). This analysis is not limited to the "footprint" of the action nor is it limited by the Federal agency's authority. Rather, it is a biological determination of the reach of the proposed action on listed species. Subsequent analyses of the environmental baseline, effects of the action, and levels of incidental take are based upon the action area.

The documentation used by a Federal action agency to initiate consultation should contain a description of the action area as defined in the Services' regulations and explained in the Services' consultation handbook. If the Services determine that the action area as defined by the action agency is incorrect, the Services should discuss their rationale with the agency or applicant, as appropriate. Reaching agreement on the description of the action area is desirable but ultimately the Services can only consult when an action area is defined properly under the regulations.

[•] The immediate vicinity of, or nearby, the point of discharge into receiving waters.

[•] The path or immediate area through which or over which storm water flows from the municipality to the point of discharge into the receiving water. This includes areas in the receiving water downstream from the point of discharge.

[•] Areas that may be impacted by construction or repair activities. This extends as far as effects related to noise (from construction equipment, power tools, etc.) and light (if work is performed at night) may reach.

The action area will vary with the size and location of the outfall pipe, the nature and quantity of the storm water discharges, and the type of receiving waters, among other factors.

Appendix D National Historic Preservation Act Guidance

Background

Section 106 of the National Historic Preservation Act (NHPA) requires federal agencies to take into account the effects of Federal "undertakings" on historic properties that are either listed on, or eligible for listing on, the National Register of Historic Places. The term federal "undertaking" is defined in the NHPA regulations to include a project, activity, or program of a federal agency including those carried out by or on behalf of a federal agency, those carried out with federal financial assistance, and those requiring a federal permit, license or approval. See 36 CFR 800.16(y). Historic properties are defined in the NHPA regulations to include prehistoric or historic districts, sites, buildings, structures, or objects that are included in, or are eligible for inclusion in, the National Register of Historic Places. This term includes artifacts, records, and remains that are related to and located within such properties. See 36 CFR 800.16(1).

EPA's issuance of a National Pollutant Discharge Elimination System (NPDES) General Permit is a federal undertaking within the meaning of the NHPA regulations and EPA has determined that the activities to be carried out under the general permit require review and consideration, in order to be in compliance with the federal historic preservation laws and regulations. Although individual submissions for authorization under the general permit do not constitute separate federal undertakings, the screening processes provides an appropriate site-specific means of addressing historic property issues in connection with EPA's issuance of the permit. To address any issues relating to historic properties in connection with the issuance of this permit, EPA has included a screening process for applicants to identify whether properties listed or eligible for listing on the National Register of Historic Places are within the path of their discharges or discharge-related activities (including treatment systems or any BMPs relating to the discharge or treatment process) covered by this permit.

Applicants seeking authorization under this general permit must comply with applicable, State, Tribal, and local laws concerning the protection of historic properties and places and may be required to coordinate with the State Historic Preservation Officer (SHPO) and/or Tribal Historic Preservation Officer (THPO) and others regarding effects of their discharges on historic properties.

Activities with No Potential to Have an Effect on Historic Properties

A determination that a federal undertaking has no potential to have an effect on historic properties fulfills an agency's obligations under NHPA. EPA has reason to believe that the vast majority of activities authorized under this general permit will have no potential effects on historic properties. This permit typically authorizes discharges from existing facilities and requires control of the pollutants discharged from the facility. EPA does not anticipate effects on historic properties from the pollutants in the authorized discharges. Thus, to the extent EPA's issuance of this general permit authorizes discharges of such constituents, confined to existing channels, outfalls or natural drainage areas, the permitting action does not have the potential to cause effects on historical properties.

In addition, the overwhelming majority of sources covered under this permit will be facilities that are seeking renewal of previous permit authorization. These existing dischargers should have already addressed NHPA issues in the previous general permit as they were required to certify that they were either not affecting historic properties or they had obtained written agreement from

the applicable SHPO or THPO regarding methods of mitigating potential impacts. To the extent this permit authorizes renewal of prior coverage without relevant changes in operations the discharge has no potential to have an effect on historic properties.

Activities with Potential to Have an Effect on Historic Properties

EPA believes this permit may have some potential to have an effect on historic properties the applicant undertakes the construction and/or installation of control measures that involve subsurface disturbance that involves less than 1 acre of land. (Ground disturbances of 1 acre or more require coverage under the Construction General Permit.) Where there is disturbance of land through the construction and/or installation of control measures, there is a possibility that artifacts, records, or remains associated with historic properties could be impacted. Therefore, if the applicant is establishing new or altering existing control measures to manage their discharge that will involve subsurface ground disturbance of less than 1 acre, they will need to ensure (1) that historic properties will not be impacted by their activities or (2) that they are in compliance with a written agreement with the SHPO, THPO, or other tribal representative that outlines all measures the applicant will carry out to mitigate or prevent any adverse effects on historic properties.

Examples of Control Measures Which Involve Subsurface Disturbance

The type of control measures that are presumptively expected to cause subsurface ground disturbance include:

- Dikes
- Berms
- Catch basins, drainage inlets
- Ponds, bioretention areas
- Ditches, trenches, channels, swales
- Culverts, pipes
- Land manipulation; contouring, sloping, and grading
- Perimeter Drains
- Installation of manufactured treatment devices

EPA cautions applicants that this list is non-inclusive. Other control measures that involve earth disturbing activities that are not on this list must also be examined for the potential to affect historic properties.

Certification

Upon completion of this screening process the applicant shall certify eligibility for this permit using one of the following criteria on their Notice of Intent for permit coverage:

Criterion A: The discharges do not have the potential to cause effects on historic properties.

Criterion B: A historic survey was conducted. The survey concluded that no historic properties are present. Discharges do not have the potential to cause effects on historic properties.

Criterion C: The discharges and discharge related activities have the potential to have an effect on historic properties, and the applicant has obtained and is in compliance with a written agreement with the State Historic Preservation Officer (SHPO), Tribal Historic Preservation Officer (TPHO), or other tribal representative that outlines measures the applicant will carry out to mitigate or prevent any adverse effects on historic properties.

Authorization under the general permit is available only if the applicant certifies and documents permit eligibility using one of the eligibility criteria listed above. Small MS4s that cannot meet any of the eligibility criteria in above must apply for an individual permit.

Screening Process

Applicants or their consultant need to answer the questions and follow the appropriate procedures below to assist EPA in compliance with 36 CFR 800.

Question 1: Is the facility an existing facility authorized by the previous permit or a new facility and the applicant is not undertaking any activity involving subsurface land disturbance less than an acre?

YES - The applicant should certify that fact in writing and file the statement with the EPA. This certification must be maintained as part of the records associated with the permit.

The applicant should certify eligibility for this permit using Criterion A on their Notice of Intent for permit coverage. The applicant does not need to contact the state Historic Commission. Based on that statement, EPA will document that the project has "no potential to cause effects" (36 CFR 800.3(a)(1)). There are no further obligations under the Section 106 regulations.

NO- Go to Question 2.

Question 2: Is the property listed in the National Register of Historic Places or have prior surveys or disturbances revealed the existence of a historic property or artifacts?

NO - The applicant should certify that fact in writing and file the statement with the EPA. This certification must be maintained as part of the records associated with the permit. **The applicant should certify eligibility for this permit using Criterion B on their Notice of Intent for permit coverage.** The applicant does not need to contact the state Historic Commission. Based on that statement, EPA will document that the project has "no potential to cause effects" (36 CFR 800.3(a)(1)). There are no further obligations under the Section 106 regulations.

YES - The applicant or their consultant should prepare a complete information submittal to the SHPO. The submittal consists of:

•Completed Project Notification Form- forms available at http://www.sec.state.ma.us/mhc/mhcform/formidx.htm;

•USGS map section with the actual project boundaries clearly indicated; and •Scaled project plans showing existing and proposed conditions.

(1) Please note that the SHPO does not accept email for review. Please mail a paper copy of your submittal (Certified Mail, Return Receipt Requested) or deliver a paper copy of your submittal (and obtain a receipt) to:

State Historic Preservation Officer Massachusetts Historical Commission 220 Morrissey Blvd. Boston MA 02125.

(2) Provide a copy of your submittal and the proof of MHC delivery showing the date MHC received your submittal to:

NPDES Permit Branch Chief US EPA Region 1 (OEP06-1) 5 Post Office Square, Suite 100 Boston MA 02109-3912.

The SHPO will comment within thirty (30) days of receipt of complete submittals, and may ask for additional information. Consultation, as appropriate, will include EPA, the SHPO and other consulting parties (which includes the applicant). The steps in the federal regulations (36 CFR 800.2 to 800.6, etc.) will proceed as necessary to conclude the Section 106 review for the undertaking. **The applicant should certify eligibility for this permit using Criterion C on their Notice of Intent for permit coverage.**

Notice of Intent (NOI) for coverage under Small MS4 General Permit Page # of

Part I: General Conditions

General Information

Name of Municipality or Organization:					State	•
EPA NPDES Permit Number:					-	
Primary MS4 Program Manager Contac	ct Informatio	n				
Name:	Title:					
Street Address Line 1						
Street Address Line 2						
City		State		Zip Code	12345-6789	
Email:	Phone N	umber: (12	23) 456-7890			
Fax Number:						
Other Information						
Check the box if your municipality or organ	ization was cove	ered under t	he 2003 MS4	General Permit	t	
Stormwater Management Program (SWMP) Loca (web address or physical location):	tion					
Eligibility Determination						
Endangered Species Act (ESA) Determination Co	mplete?	• I	Eligibility Crite	eria apply): 🗌 A	В С	D E F
National Historic Preservation Act (NHPA) Deterr	nination Comple	ete?	E (c	ligibility Criteri heck all that ap	ia oply): 🗌 A	B C D
MS4 Infrastructure (if covered under the 2003 per	rmit)					
Estimated Percent of Outfall Map Complete? (Part II,III,IV or V, Subpart B.3.(a.) of 2003 permit)	•	lf 100% of 2 estimated c	003 requirem late of comple	ents not met, e etion (MM/DD/	enter an YY):	
Web address where MS4 map is published:					L	
If outfall map is unavailable on the internet an elect for submission options)	ronic or paper co	py of the ou	tfall map must	be included wi	th NOI submissi	on (see section V
Regulatory Authorities (if covered under the 20	03 permit)					
Illicit Discharge Detection and Elimination (ID (Part II,III,IV or V, Subpart B.3.(b.) of 2003 permit)	DE) Authority A	dopted?:	E	ffective Date o vate of Adoptio	r Estimated on (MM/DD/YY)	:
Construction/Erosion and Sediment Control (E (Part II,III,IV or V, Subpart B.4.(a.) of 2003 permit)	ESC) Authority A	\dopted?:	•	Effective Date Date of Adopt	e or Estimated tion (MM/DD/Y	Υ):

		_	
Post- Construction Stormwater Management Adopted?: (Part II,III,IV or V, Subpart B.5.(a.) of 2003 permit)	•	Effective Date or Estimated Date of Adoption (MM/DD/YY):	

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part II: Summary of Receiving Waters

Please list the waterbody segments to which your MS4 discharges. For each waterbody segment, please report the number of outfalls discharging into it and, if applicable, any impairments.

For Massachusetts list of impaired waters click here: <u>Massachusetts 2010 List of Impaired: Waters http://www.mass.gov/dep/water/resources/10list6.pdf</u>

For New Hampshire list of impaired waters click here: <u>New Hampshire Final 303(d) Materials: http://des.nh.gov/organization/divisions/water/wmb/swqa/2010/index.htm</u>

Source of pollutants column should be completed with a preliminary source evaluation of pollutants for discharges to impaired waterbodies (see above 303(d) lists) without an approved TMDL in accordance with Section 2.2.2a of the permit

Waterbody segment that receives flow from the MS4	Number of outfalls into receiving water segment	Pollutant list (select one at a time to add)	Click impairment at left to add, or at right to remove	Pollutant(s) causing impairment, if applicable (select one at a time to remove)
		Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
		Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
		Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
		Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	

	[Pa	ge # of ##
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove		
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove		
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove		
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove		
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove		
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total)	Add/Remove		

	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	
	Chlorophyll-a Dissolved oxygen saturation Escherichia coli Mercury Nitrogen (Total) Oxygen, Dissolved	Add/Remove	

Click to lengthen table

Page # of ## Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Identify the Best Management Practices (BMPs) that will be employed to address each of the six Minimum Control Measures (MCMs). For municipalities/organizations whose MS4 discharges into a receiving water with an approved Total Maximum Daily Load (TMDL) and applicable waste lod allocation (WLA), identify any additional BMPs employed to specifically support the achievement of the WLA in the TMDL section at the end of Part III.

For each MCM list each existing or proposed BMP by category and provide a brief description, responsible parties/departments, measurable goals and the year the BMP will be employed (Public education and outreach BMPs also requires a target audience). **Use the drop-down menus in each table or enter your own text to override the drop down menu**

MCM 1: Public Education and Outreach

BMP Media/Category (enter your own text to override the drop down menu)	BMP Description	Targeted Audience	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goal	Beginning Year of BMP implemen tation
-		Residents	-		•
-		Businesses, Institutions and Commercial Facilities	•		•
•		Developers (construction)	•		•
-		Industrial Facilities	•		•
•		Residents	•		•
•		Businesses, Institutions and Commercial Facilities	•		•
•		Developers (construction)	-		•
		Industrial Facilities	-		•
			-		•
		•	-		•
		•	-		•
		•	-		•
		•			•
		•	-		•
-		•			•
		•	-		•
·			·		-
			-		•

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part III: Stormwater Management Program Summary

MCM 2: Public Involvement and Participation

BMP Categorization	Brief BMP Description (enter your own text to override the drop down menu)	Responsible Department/ Parties	Additional Description/ Measurable Goal	Beginning Year of BMP implement ation
Public Review	SWMP Review	-		•
Public Participation	·	·		•
•	·	· ·		•
•	·	·		•
•	·	·		•
•	·	·		•
•		·		•
•	·	·		•
•	·	_		•
	·	·		·
•		·		•
•	·	·		•
•	·	·		•
•	·	·		•
•	·			•
•	•			•
•	·	·		•
•		·		•
•	-	-		-
_	·			•

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part III: Stormwater Management Program Summary

MCM 3: Illicit Discharge Detection and Elimination (IDDE)

BMP Categorization (enter your own text to override the drop down menu)	BMP Description	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)
SSO inventory		-	Develop SSO inventory within 1 year of effective date
Storm sewer system map			Update map within 2 years of effective date of permit and complete full system map 10 years after effective date of permit
Written IDDE program development		·	Complete within 1.5 years of the effective date of permit
Implement IDDE Program		·	Implement catchment investigations according to program and permit conditions
Employee Training			Train annually
Conduct dry weather screening		·	Conduct in accordance with outfall screening procedure and permit conditions
Conduct wet weather screening			Conduct in accordance with outfall screening procedure and permit conditions
		·	
		·	
·			
-		-	
		·	
·		·	
		·	
		·	
		·	
·		•	
		·	

Page # of ## Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part III: Stormwater Management Program Summary

MCM 4: Construction Site Stormwater Runoff Control

BMP Categorization (enter your own text to override the drop down menu or entered text)	BMP Description	Responsible Department/ Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)	Beginning Year of BMP implemen tation
Site inspection and enforcement of Erosion and Sediment Control (ESC) measures	Complete written procedures of site inspections and enforcement procedures	-	Complete by the end of Year 1	•
Site plan review	Complete written procedures of site plan review and begin implementation	-	Complete by the end of Year 1	•
Erosion and Sediment Control	Adoption of requirements for construction operators to implement a sediment and erosion control program	•		•
Waste Control	Adoption of requirements to control wastes, including but not limited to, discarded building materials, concrete truck wash out, chemicals, litter, and sanitary wastes.	-		•
-		-		•
-		-		•
]	•		•
]	·		•
]	·		•
]	·		•
		·		•
		·		•
		·		•
				-
		·		•
-		•		•

Page # of ##

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part III: Stormwater Management Program Summary

MCM 5: Post-Construction Stormwater Management in New Development and Redevelopment

BMP Categorization (enter your own text to override the drop down menu or entered text)	BMP Description	Responsible Department/ Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)	Beginning Year of BMP implemen tation
As-built plans for on-site stormwater control	The procedures to require submission of as- built drawings and ensure long term operation and maintenance will be a part of the SWMP.	-	Require submission of as-built plans for completed projects	•
Inventory and priority ranking of MS4- owned properties that may be retrofitted with BMPs	Conduct detailed inventory of MS4 owned properties and rank for retrofit potential	•	Complete 4 years after permit effective date	·
Allow green infrastructure	Develop a report assessing existing local regulations to determine the feasibility of making green infrastructure practices allowable when appropriate site conditions exist	•	Complete 4 years after permit effective date	•
Street design and parking lot guidelines	Develop a report assessing requirements that affect the creation of impervious cover. The assessment will help determine if changes to design standards for streets and parking lots can be modified to support low impact design options.		Complete 4 years after permit effective date	•
Ensure any stormwater controls or management practices for new development and redevelopment will prevent or minimize impacts to water quality.	Adoption, amendment or modification of a regulatory mechanism to meet permit requirements	×	Complete 2 years after permit effective date	-
•		•		•
		-		
				
·				
•		•		•

Page # of ##

	•	-
-	-	-
-	•	•
·	•	•
·	•	•
·	•	•
·	•	•
·	•	•
-	•	•
	•	•
	•	•
·	•	•
-	•	•
	Ľ	•

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part III: Stormwater Management Program Summary

MCM 6: Municipal Good Housekeeping and Pollution Prevention

BMP Categorization (enter your own text to override the drop down menu or entered text)	BMP Description	Responsible Department/ Parties (enter your own text to override the drop down menu)	Measurable Goal (a ll text can be overwritten)	Beginning Year of BMP implemen tation
Create written O&M procedures for parks and open spaces, buildings and facilities, and vehicles and equipment		•	Complete 2 years after permit effective date	Ţ
Inventory all permittee-owned parks and open spaces, buildings and facilities (including their storm drains), and vehicles and equipment		•	Complete 2 years after permit effective date	·
Establish and implement program for repair and rehabilitation of MS4 infrastructure		•	Complete 2 years after permit effective date	•
Stormwater Pollution Prevention Plan (SWPPP) for maintenance garages, transfer stations and other waste- handling facilities		•	Complete 2 years after permit effective date	•
Catch Basin Cleaning		·		•
Street Sweeping Program		·		•
Road Salt use optimization program		·		•
		·		•
-		·		•
		·		•
		•		•
		•		•
·				
		·		
		·		-

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part III: Stormwater Management Program Summary

Actions for meeting Total Maximum Daily Load (TMDL) Requirements

Use the drop-down menus to select the best categorization of your BMP and responsible party. If no options are applicable, or more than one, **enter your own text to override drop-down menus.**

Applicable TMDL	Action Description	Responsible Department/ Parties (enter your own text to override the drop down menu)
·		×
-	•	×
-	•	×
-	•	•
-	•	•
-	•	•
-	•	×
-	•	×
-	•	·
		T
•		
·		
·		
•		
•		×
		· · · · · · · · · · · · · · · · · · ·
·		· ·
·	×	T
	▼	
·	×	T

Use the drop-down menus to select the Pollutant causing the water quality limitation and enter the waterbody ID(s) experiencing excursions above water quality standards for that pollutant. Choose the action description from the dropdown menu and indicate the responsible party. If no options are applicable, or more than one, **enter your own text to override drop-down menus.**

Actions for meeting Requirements Related to water Quality Limited Waters

Part III: Stormwater Management Program Summary

Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Pollutant	Waterbody ID(s)	Action Description	Responsible Department/Parties (enter your own text to override the drop down menu)
•		•	•
•		▼	•
•		▼	•
×		▼	T
×		▼	•
×		▼	-
•		▼	-
•		▼	-
•		~	•
•		•	•
•		•	
•		•	•
•		•	-
•		•	•
•		•	•
•		•	
•		•	_
•		•	
•		▼	_
•			

Page # of ## Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part IV: Notes and additional information

Use the space below to provide any additional information about your MS4 program

Click to add text

Page # of ## Notice of Intent (NOI) for coverage under Small MS4 General Permit (continued)

Part V: Certification

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, I certify that the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name:	Title:	
Signature Field	Date:	

NOI Submission

Please submit the form electronically via email using the "submit by Email" button below or send in a CD with your completed NOI. You may also print and submit via mail at the address below if you choose not to submit electronically. Outfall map required in Part I of the NOI (if applicable) can be submitted electronically as an email attachment OR as a paper copy.

Permittees that choose to submit their NOI electronically by email or by mailing a CD with the completed NOI form to EPA, will be able to download a partially filled Year 1 Annual Report at a later date from EPA.

Submit by Email Submit by email using this button. Or, send an email with attachments to: <u>stormwater.reports@epa.gov</u>

Save

Save NOI for your records

EPA Submittal Address:

United States Environmental Protection Agency 5 Post Office Square - Suite 100 Mail Code - OEP06-1 Boston, Massachusetts 02109-3912 ATTN: Newton Tedder

State Submittal Address

Massachusetts Department of Environmental Protection One Winter Street - 5th Floor Boston, MA 02108 ATTN: Fred Civian

APPENDIX F

Requirements for Discharges to Impaired Waters with an Approved TMDL

Table of Contents

A. Requirements for Discharges to Impaired Waters with an Approved MassDEP In S TMDL	tate
I. Charles River Watershed Phosphorus TMDL Requirements	2
II. Lake and Pond Phosphorus TMDL Requirements	18
III. Bacteria and Pathogen TMDL Requirements	27
IV. Cape Cod Nitrogen TMDL Requirements	40
V. Assabet River Phosphorus TMDL Requirements	44
B. Requirements for Discharges to Impaired Waters with an Approved Out of State TMDL	47
I. Nitrogen TMDL Requirements	47
II. Phosphorus TMDL Requirements	51
III. Bacteria and Pathogen TMDL Requirements	55
IV. Metals TMDL Requirements	58
C. Requirements for Discharges to Impaired Waters with a Regional TMDL	61
I. The "Northeast Regional Mercury TMDL (2007)"	61

Attachment 1 – Method To Calculate Baseline Watershed Phosphorus Load For Lake And Pond Phosphorus TMDLs (Applicable To part II Of Appendix F Only) And Method To Calculate Increases in Phosphorus Load due to Development

Attachment 2 – Phosphorus Reduction Credits For Selected Enhanced Non-Structural BMPs

Attachment 3 - Phosphorus Reduction Credits For Selected Structural BMPs

<u>A. Requirements for Discharges to Impaired Waters with an Approved MassDEP In State</u> <u>TMDL</u>

I. Charles River Watershed Phosphorus TMDL Requirements

On October 17, 2007, EPA approved the *Final TMDL for Nutrients in the Lower Charles River Basin* (Lower Charles TMDL)¹ and on June 10, 2011 EPA approved the *Total Maximum Daily Load for Nutrients in the Upper/Middle Charles River* (Upper/Middle Charles TMDL)². The following phosphorus reduction requirements address phosphorus in MS4 discharges.

 To address the discharge of phosphorus from its MS4, the permittee shall develop a Phosphorus Control Plan (PCP) designed to reduce the amount of phosphorus in stormwater (SW) discharges from its MS4 to the Charles River and its tributaries. The PCP shall be completed in phases and the permittee shall add it as an attachment to its written SWMP upon completion and report in annual reports pursuant to part 4.4 of the Permit on its progress toward achieving its Phosphorus Reduction Requirement. The PCP shall be developed and fully implemented as soon as possible but no later than 20 years after the permit effective date in accordance with the phases and schedule outlined below. Each Phase shall contain the elements required of each phase as described in parts a.through c below. The timing of each phase over 20 years from the permit effective date is:

1-5 years after	5-10 years after	10-15 years after	15-20 years after
permit effective	permit effective	permit effective	permit effective
date	date	date	date
Create Phase 1	Implement Phase 1		
Plan	Plan		
	Create Phase 2	Implement Phase 2	
	Plan	Plan	
		Create Phase 3	Implement Phase
		Plan	3 Plan

a. Phase 1

- 1) The permittee shall complete a written Phase 1 plan of the PCP five years after the permit effective date and fully implement the Phase 1 plan of the PCP as soon as possible but no longer than 10 years after the permit effective date.
- 2) The Phase 1 plan of the PCP shall contain the following elements and has the following required milestones:

Item	Phase 1 of the PCP Component and	Completion
Number	Milestones	Date
1-1	Legal analysis	2 years after permit effective date

¹ Massachusetts Department of Environmental Protection. 2007. *Final TMDL for Nutrients in the Lower Charles River Basin*. CN 301.1

² Massachusetts Department of Environmental Protection. 2011. *Total Maximum Daily Load for Nutrients in the Upper/Middle Charles River Basin, Massachusetts*. CN 272.0

1-2	Funding source assessment.	3 years after
		permit
		effective date
1-3	Define scope of PCP (PCP Area) Baseline	4 years after
	Phosphorus Load and Phosphorus Reduction	permit
	Requirement and Allowable Phosphorus Load	effective date
1-4	Description of Phase 1 planned nonstructural	5 years after
	controls	permit
		effective date
1-5	Description of Phase 1 planned structural	5 years after
	controls	permit
		effective date
1-6	Description of Operation and Maintenance	5 years after
	program for structural controls	permit
		effective date
1-7/	Phase I implementation schedule	5 years after
		permit
1.0		effective date
1-8	Estimated cost for implementing Phase 1 of the	5 years after
	PCP	permit
1.0	Complete Written Dhese 1 DCD	5 viscous often
1-9	Complete written Phase I PCP	5 years after
		offective date
1 10	Full implementation of nonstructural controls	6 years after
1-10	Full implementation of nonstructural controls	o years arter
		effective date
1-11	Performance Evaluation	6 and 7 years
1 11		after permit
		effective date
1-12	1. Performance Evaluation.	8 years after
	2. Full implementation of all structural controls	permit
	used to demonstrate that the total phosphorus	effective date
	export rate (P_{exp}) from the PCP Area in	
	mass/yr is equal to or less than the applicable	
	Allowable Phosphorus Load(Pallow) plus the	
	applicable Phosphorus Reduction	
	Requirement (P_{RR}) multiplied by 0.80	
	$P_{exp} \le P_{allow} + (P_{RR} X \ 0.80)$	
1-13	Performance Evaluation	9 years after
		permit
		effective date
1-14	1. Performance Evaluation.	10 years after
	2. Full implementation of all structural controls	permit
	used to demonstrate that the total phosphorus	effective date
	export rate (P_{exp}) from the PCP Area in	
	mass/yr is equal to or less than the applicable	
	Allowable Phosphorus Load(P _{allow}) plus the	
	applicable Phosphorus Reduction	
	Kequirement (P_{RR}) multiplied by 0./5	

	$P_{exp} \le P_{allow} + (P_{RR} X \ 0.75)$	
Table F-1:	Phase 1 of the PCP components and Milestones	

3) Description of Phase 1 PCP Components

<u>Legal Analysis</u>- The permittee shall develop and implement an analysis that identifies existing regulatory mechanisms available to the MS4 such as bylaws and ordinances, and describes any changes to regulatory mechanisms that may be necessary to effectively implement the entire PCP. This may include the creation or amendment of financial and regulatory authorities. The permittee shall adopt necessary regulatory changes by the end of the permit term.

<u>Funding source assessment</u> – The permittee shall describe known and anticipated funding mechanisms (e.g. general funding, enterprise funding, stormwater utilities) that will be used to fund PCP implementation. The permittee shall describe the steps it will take to implement its funding plan. This may include but is not limited to conceptual development, outreach to affected parties, and development of legal authorities.

Scope of the PCP, Baseline Phosphorus Load (Pbase), Phosphorus Reduction Requirement (P_{RR}) and Allowable Phosphorus Load (P_{allow}) - The permittee shall indicate the area in which it plans to implement the PCP. The permittee must choose one of the following: (1) to implement its PCP in the entire area within its jurisdiction (for municipalities this would be the municipal boundary) within the Charles River Watershed; or (2) to implement its PCP only in the urbanized area portion of the permittee's jurisdiction within the Charles River Watershed. The implementation area selected by the permittee is known as the "PCP Area" for that permittee. Table $F-2^3$ and Table $F-3^4$ list the permittees subject to phosphorus reduction requirements along with the estimated Baseline Phosphorous Loads in mass/yr, the calculated Allowable Stormwater Phosphorus Load in mass/yr, the Stormwater Phosphorus Reduction Requirement in mass/yr and the respective percent reductions necessary. The two tables contain different reduction requirements for each permittee based on the PCP Area they choose (see above). If the permittee chooses to implement the PCP in its entire jurisdiction, the permittee may demonstrate compliance with the Phosphorus Reduction Requirement and Allowable Phosphorus Load requirements applicable to it through structural and non-structural controls on discharges that occur outside the regulated area. If the permittee chooses to implement the PCP in its regulated area only, the permittee must demonstrate compliance with the Phosphorus Reduction Requirement and Allowable Phosphorus Load requirements applicable to it through structural

³ The estimated Baseline Phosphorus Load, Allowable Phosphorus Load, Phosphorus Reduction Requirement and percent reductions presented in Table F-2 apply to the entire watershed land area that drains to the Charles River and its tributaries within the permittee's jurisdiction.

⁴ The estimated Baseline Phosphorus Load, Allowable Phosphorus Load, Phosphorus Reduction Requirement and percent reductions presented in Table F-3 apply only to the urbanized area portion of the permittee's jurisdiction that drains to the Charles River or its tributaries.

and non-structural controls on discharges that occur within the regulated area only.

The permittee shall select the Baseline Phosphorus Load, Stormwater Phosphorus Reduction Requirement and Allowable Phosphorus Load that corresponds to the PCP Area selected. The selected Stormwater Phosphorus Reduction Requirement and Allowable Phosphorus Load will be used to determine compliance with PCP milestones of this Phase and Phase 2 and Phase 3. If the permittee chooses to implement its PCP in all areas within its jurisdiction within the Charles River Watershed, then the permittee shall use Table F-2 to determine the Baseline Phosphorus Load, Stormwater Phosphorus Reduction Requirement and Allowable Phosphorus Load for its PCP Area. If the permittee chooses to implement its PCP only within the regulated area within the Charles River Watershed, then the permittee shall use Table F-3 to determine the Baseline Phosphorus Load, Stormwater Phosphorus Reduction Requirement and Allowable Phosphorus Load for its PCP Area. If the permittee chooses to implement its PCP only within the regulated area within the Charles River Watershed, then the permittee shall use Table F-3 to determine the Baseline Phosphorus Load, Stormwater Phosphorus Reduction Requirement and Allowable Phosphorus Load for its PCP Area.

The Permittee may submit more accurate land use data from 2005, which is the year chosen as the baseline land use for the purposes of permit compliance, for EPA to recalculate baseline phosphorus stormwater loads for use in future permit reissuances. Updated land use maps, land areas, characteristics, and MS4 area and catchment delineations shall be submitted to EPA along with the year 4 annual report in electronic GIS data layer form for consideration for future permit requirements⁵. Until such a time as future permit requirements reflect information submitted in the year 4 annual report, the permittee shall use the Baseline Phosphorus Load, Stormwater Phosphorus Reduction Requirement and Allowable Phosphorus Load Table F-2 (if its PCP Area is the permittee's entire jurisdiction) or Table F-3 (if its PCP Area is the regulated area only) to calculate compliance with milestones for Phase 1, 2, and 3 of the PCP.

<u>Description of Phase 1 planned non-structural controls</u> – The permittee shall describe the non-structural stormwater control measures necessary to support achievement of the phosphorus export milestones in Table F-1. The description of non-structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions that are expected to result from their implementation in units of mass/yr. Annual phosphorus reduction from non-structural BMPs shall be calculated consistent with Attachment 2 to Appendix F.

<u>Description of Phase 1 planned structural controls</u> – The permittee shall develop a priority ranking of areas and infrastructure within the municipality for potential implementation of structural phosphorus controls during Phase 1. The ranking shall be developed through the use of available

⁵ This submission is optional and needs only be done if the permittee has more accurate land use information from 2005 than information provided by MassGIS (<u>http://www.mass.gov/anf/research-and-tech/it-serv-and-support/application-serv/office-of-geographic-information-massgis/datalayers/lus2005.html</u>, retrieved 10/1/2013) or the permittee has updated MS4 drainage area characteristics and the permittee would like to update the Baseline Phosphorus Load.

screening and monitoring results collected during the permit term either by the permittee or another entity and the mapping required pursuant to part 2.3.4.6 of the Permit. The permittee shall also include in this priority ranking a detailed assessment of site suitability for potential phosphorus control measures based on soil types and other factors. The permittee shall coordinate this activity with the requirements of part 2.3.6.8.b of the Permit. A description and the results of this priority ranking shall be included in Phase 1 of the PCP. The permittee shall describe the structural stormwater control measures necessary to support achievement of the phosphorus export milestones in Table F-1. The description of structural controls shall include the planned and existing measures, the areas where the measures will be implemented or are currently implemented, and the annual phosphorus reductions in units of mass/yr that are expected to result from their implementation. Structural measures to be implemented by a third party may be included in a municipal PCP. Annual phosphorus reductions from structural BMPs shall be calculated consistent with Attachment 3 to Appendix F.

<u>Description of Operation and Maintenance (O&M) Program for all planned</u> <u>and existing structural BMPs</u> – The permittee shall establish an Operation and Maintenance Program for all structural BMPs being claimed for phosphorus reduction credit as part of Phase 1 of the PCP. This includes BMPs implemented to date as well as BMPs to be implemented during Phase 1 of the PCP. The Operation and Maintenance Program shall become part of the PCP and include: (1) inspection and maintenance schedule for each BMP according to BMP design or manufacturer specification and (2) program or department responsible for BMP maintenance.

<u>Phase 1 Implementation Schedule</u> – A schedule for implementation of all planned Phase 1 BMPs, including, as appropriate: obtaining funding, training, purchasing, construction, inspections, monitoring, operation and maintenance activities, and other assessment and evaluation components of implementation. Implementation of planned BMPs must begin upon completion of the Phase 1 Plan, and all non-structural BMPs shall be fully implemented within six years of the permit effective date. Structural BMPs shall be designed and constructed to ensure the permittee will comply with the 8 and 10 year phosphorus load milestones established in Table F-1. The Phase 1 plan shall be fully implemented as soon as possible, but no later than 10 years after the effective date of permit.

<u>Estimated cost for implementing Phase 1 of the PCP –</u> The permittee shall estimate the cost of implementing the Phase 1 non-structural and structural controls and associated Operation and Maintenance Program. This cost estimate can be used to assess the validity of the funding source assessment completed by year 3 after the permit effective date and to update funding sources as necessary to complete Phase 1.

<u>Complete written Phase 1 Plan</u> – The permittee must complete the written Phase 1 Plan of the PCP no later than 5 years after the permit effective date. The complete Phase 1 Plan shall include Phase 1 PCP item numbers 1-1 through 1-7 in Table F-1. The permittee shall make the Phase 1 Plan available to the public for public comment during Phase 1 Plan development. EPA encourages the permittee to post the Phase I Plan online to facilitate public involvement.

Performance Evaluation - The permittee shall evaluate the effectiveness of the PCP by tracking the phosphorus reductions achieved through implementation of structural and non-structural BMPs⁶ and tracking increases resulting from development. Phosphorus reductions shall be calculated consistent with Attachment 2 to Appendix F (non-structural BMP performance) and Attachment 3 to Appendix F (structural BMP performance) for all BMPs implemented to date. Phosphorus export increases since 2005 due to development shall be calculated consistent with Attachment 1 to Appendix F. Phosphorus loading increases and reductions in unit of mass/yr shall be added or subtracted from the applicable Baseline Phosphorus Load given in Table F-2 or Table F-3 depending on the Scope of PCP chosen to estimate the yearly phosphorous export rate from the PCP Area. The permittee shall also include all information required in part I.2 of this Appendix in each performance evaluation. Performance evaluations will be included as part of each permittee's annual report as required by part 4.4 of the Permit.

River Watershed				
Community	Baseline Phosphorus Load, kg/yr	Stormwater Phosphorus Load Reduction Requirement kg/yr	Allowable Phosphorus Load, kg/yr	Stormwater Percent Reduction in Phosphorus Load (%)
Arlington	106	57	49	53%
Ashland	67	23	44	34%
Bellingham	947	331	616	35%
Belmont	202	86	116	42%
Brookline	1,635	789	846	48 %
Cambridge	512	263	249	51%
Dedham	805	325	480	40%
Dover	831	137	694	17%
Foxborough	2	0	2	0%
Franklin	2,344	818	1,526	35%

⁶ In meeting its phosphorus reduction requirements a permittee may quantify phosphorus reductions by actions undertaken by another entity, except where those actions are credited to MassDOT or another permittee identified in Appendix F Table F-2 or F-3.

Γ

Community Annual Stormwater Phosphorus Load Reduction by Permittee, Charles River Watershed				
Community	Baseline Phosphorus Load, kg/yr	Stormwater Phosphorus Load Reduction Requirement kg/yr	Allowable Phosphorus Load, kg/yr	Stormwater Percent Reduction in Phosphorus Load (%)
Holliston	1,543	395	1,148	26%
Hopedale	107	37	70	35%
Hopkinton	292	66	226	22%
Lexington	530	194	336	37%
Lincoln	593	101	492	17%
Medfield	955	277	678	29%
Medway	1,063	314	749	30%
Mendon	29	9	20	31%
Milford	1,611	663	948	41%
Millis	969	248	721	26%
Natick	1,108	385	723	35%
Needham	1,772	796	976	45%
Newton	3,884	1,941	1,943	50%
Norfolk	1,004	232	772	23%
Somerville	646	331	315	51%
Sherborn	846	131	715	16%
Walpole	159	28	131	18%
Waltham	2,901	1,461	1,400	50%
Watertown	1,127	582	545	52%
Wayland	46	15	31	33%
Wellesley	1,431	661	770	46%
Weston	1,174	281	893	24%
Westwood	376	114	262	30%
Wrentham	618	171	447	28%
Mass-DCR	421	91	330	22%

Table F-2: Baseline Phosphorus Load, Phosphorus Reduction Requirement,Allowable Phosphorus Load and Percent Reduction in Phosphorus Loadfrom Charles River Watershed. For use when PCP Area is chosen to bethe entire community within the Charles River Watershed.

Urbanized Area Annual Stormwater Phosphorus Load Reduction by Permittee, Charles River Watershed				
Community	Baseline Watershed Phosphorus Load, kg/yr	Stormwater Phosphorus Load Reduction Requirement, kg/yr	Allowable Phosphorus Load, kg/yr	Stormwater Percent Reduction in Phosphorus Load (%)
Arlington	106	57	49	53%
Ashland	67	23	44	34%
Bellingham	801	291	510	36%
Belmont	202	86	116	42%
Brookline	1,635	789	846	48 %
Cambridge	512	263	249	51%
Dedham	805	325	480	40%
Dover	282	54	228	19%
Foxborough	2	0	2	0%
Franklin	2,312	813	1,499	35%
Holliston	1,359	369	990	27%
Hopedale	107	37	70	35%
Hopkinton	280	65	215	23%
Lexington	525	193	332	37%
Lincoln	366	63	303	17%
Medfield	827	267	560	33%
Medway	1,037	305	732	29%
Mendon	10	5	5	50%
Milford	1,486	653	833	44%
Millis	501	159	342	32%
Natick	994	359	635	36%
Needham	1,771	795	976	45%
Newton	3,884	1,941	1,943	50%
Norfolk	1,001	231	770	23%
Somerville	646	331	315	51%
Sherborn	203	38	165	19%
Walpole	159	28	131	18%
Waltham	2,901	1,461	1,440	50%
Watertown	1,127	582	545	52%
Wayland	46	15	31	33%
Wellesley	1,431	661	770	46%

Urbanized Area Annual Stormwater Phosphorus Load Reduction by Permittee, Charles River Watershed					
Community	Baseline Watershed Phosphorus Load, kg/yr	Stormwater Phosphorus Load Reduction Requirement, kg/yr	Allowable Phosphorus Load, kg/yr	Stormwater Percent Reduction in Phosphorus Load (%)	
Weston	1,174	281	893	24%	
Westwood	346	108	238	31%	
Wrentham	556	159	397	29%	
Mass DCR	396	89	307	22%	

Table F-3: Baseline Phosphorus Load, Phosphorus Reduction Requirement,Allowable Phosphorus Load and Percent Reduction in Phosphorus Loadfrom Charles River Watershed. For use when PCP Area is chosen to beonly the urbanized area portion of a permittee's jurisdiction within theCharles River Watershed.

b. Phase 2

- 1) The permittee shall complete the Phase 2 Plan of the PCP 10 years after the permit effective date and fully implement the Phase 2 plan of the PCP as soon as possible but no longer than 15 years after the permit effective date.
- 2) The Phase 2 plan of the PCP shall be added to the Phase 1 Plan and contain the following elements and has the following required milestones:

Item	Phase 2 of the PCP Component and	Completion Date
Number	Milestones	
2-1	Update Legal analysis	As necessary
2-2	Description of Phase 2 planned nonstructural controls	10 years after permit effective date
2-3	Description of Phase 2 planned structural controls	10 years after permit effective date
2-4	Updated description of Operation and Maintenance Program	10 years after permit effective date
2-5	Phase 2 implementation schedule	10 years after permit effective date
2-6	Estimated cost for implementing Phase 2 of the PCP	10 years after permit effective date
2-7	Complete written Phase 2 Plan	10 years after permit effective date
------	--	--
2-8	Performance Evaluation.	11, and 12 years after permit effective date
2-9	 Performance Evaluation. Full implementation of all structural controls used to demonstrate that the total phosphorus export rate (P_{exp}) from the PCP Area in mass/yr is equal to or less than the applicable Allowable Phosphorus Load(P_{allow}) plus the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.65 P_{exp} ≤ P_{allow} + (P_{RR} X 0.65) 	13 years after permit effective date
2-10	Performance Evaluation	14 years after permit effective date
2-11	1. Performance Evaluation. 2. Full implementation of all structural controls used to demonstrate that the total phosphorus export rate (P_{exp}) from the PCP Area in mass/yr is equal to or less than the applicable Allowable Phosphorus Load(P_{allow}) plus the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.50 $P_{exp} \leq P_{allow} + (P_{RR} X 0.50)$	15 years after permit effective date

Table F-4: Phase 2 of the PCP components and Milestones

3) Description of Phase 2 PCP Components

<u>Updated Legal Analysis</u>- The permittee shall update the legal analysis completed during Phase 1 of the PCP as necessary to include any new or augmented bylaws, ordinances or funding mechanisms the permittee has deemed necessary to implement the PCP. The permittee shall use experience gained during Phase 1 to inform the updated legal analysis. The permittee shall adopt necessary regulatory changes as soon as possible to implement the Phase 2 Plan.

<u>Description of Phase 2 planned non-structural controls</u> – The permittee shall describe the non-structural stormwater control measures necessary to support achievement of the phosphorus export milestones in Table F-4. The description of non-structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions that are expected to result from their implementation in units of mass/yr. Annual phosphorus reduction from non-structural BMPs shall be calculated consistent with Attachment 2 to Appendix F.

Description of planned Phase 2 structural controls – The permittee shall develop a priority ranking of areas and infrastructure within the municipality for potential implementation of phosphorus control practices during Phase 2. The ranking shall build upon the ranking developed for Phase 1. The permittee shall describe the structural stormwater control measures necessary to support achievement of the phosphorus export milestones in Table F-4. The description of structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions in units of mass/yr that are expected to result from their implementation. Structural measures to be implemented by a third party⁷ may be included in a municipal PCP. Annual phosphorus reductions from structural BMPs shall be calculated consistent with Attachment 3 to Appendix F.

<u>Updated description of Operation and Maintenance (O&M) Program for all</u> <u>planned and existing structural BMPs</u> – The permittee shall establish an Operation and Maintenance Program for all structural BMPs being claimed for phosphorus reduction credit as part of Phase 1 and 2 of the PCP. This includes BMPs implemented to date as well as BMPs to be implemented during Phase 2 of the PCP. The Operation and Maintenance Program shall become part of the PCP and include: (1) inspection and maintenance schedule for each BMP according to BMP design or manufacturer specification and (2) program or department responsible for BMP maintenance.

<u>Phase 2 Implementation Schedule</u> – A schedule for implementation of all planned Phase 2 BMPs, including, as appropriate: funding, training, purchasing, construction, inspections, monitoring, O&M activities and other assessment and evaluation components of implementation. Implementation of planned BMPs must begin upon completion of the Phase 2 Plan. Structural BMPs shall be designed and constructed to ensure the permittee will comply with the 13 and 15 year milestones established in Table F-4. The Phase 2 plan shall be fully implemented as soon as possible, but no later than 15 years after the effective date of permit.

<u>Estimated cost for implementing Phase 2 of the PCP –</u> The permittee shall estimate the cost of implementing the Phase 2 non-structural and structural controls and associated Operation and Maintenance Program. This cost estimate can be used to plan for the full implementation of Phase 2.

<u>Complete written Phase 2 Plan</u> – The permittee must complete a written Phase 2 Plan of the PCP no later than 10 years after the permit effective date. The complete Phase 2 Plan shall include Phase 2 PCP item numbers 2-1 through 2-6 in Table F-4. The permittee shall make the Phase 2 Plan available to the public for public comment during Phase 2 plan development. EPA encourages the permittee to post the Phase 2 Plan online to facilitate public involvement.

⁷ See footnote 6

Performance Evaluation – The permittee shall evaluate the effectiveness of the PCP by tracking the phosphorus reductions achieved through implementation of structural and non-structural BMPs⁸ and tracking increases resulting from development. Phosphorus reductions shall be calculated consistent with Attachment 2 to Appendix F (non-structural BMP performance) and Attachment 3 to Appendix F (structural BMP performance) for all BMPs implemented to date. Phosphorus export increases due to development shall be calculated consistent with Attachment 1 to Appendix F. Phosphorus loading increases and reductions in unit of mass/yr shall be added or subtracted from the applicable Baseline Phosphorus Load given in Table F-2 or Table F-3 depending on the Scope of PCP chosen to estimate the yearly phosphorous export rate from the PCP Area. The permittee shall also include all information required in part I.2 of this Appendix in each performance evaluation. Performance evaluations will be included as part of each permittee's annual report as required by part 4.4 of the Permit.

c. Phase 3

- 1) The permittee shall complete the Phase 3 Plan of the PCP 15 years after the permit effective date and fully implement the Phase 3 plan of the PCP as soon as possible but no longer than 20 years after the permit effective date.
- 2) The Phase 3 plan of the PCP shall be added to the Phase 1 Plan and the Phase 2 Plan to create the comprehensive PCP and contain the following elements and has the following required milestones:

Item	Phase 3 of the PCP Component and	Completion
Number	Milestones	Date
3-1	Update Legal analysis	As necessary
3-2	Description of Phase 3 planned nonstructural controls	15 years after permit effective date
3-3	Description of Phase 3 planned structural controls	15 years after permit effective date
3-4	Updated description of Operation and Maintenance (O&M) Program	15 years after permit effective date
3-5	Phase 3 implementation schedule	15 years after permit effective date
3-6	Estimated cost for implementing Phase 3 of the PCP	15 years after permit effective date
3-7	Complete written Phase 3 Plan	15 years after permit effective date

⁸ See footnote 9

3-8	Performance Evaluation.	16, and 17 years
		after permit
		effective date
3-9	1. Performance Evaluation.	18 years after
	2. Full implementation of all structural	permit effective
	controls used to demonstrate that the	date
	total phosphorus export rate (P _{exp})	
	from the PCP Area in mass/yr is equal	
	to or less than the applicable	
	Allowable Phosphorus Load(P _{allow})	
	plus the applicable Phosphorus	
	Reduction Requirement (P_{RR})	
	multiplied by 0.30	
	$P_{exp} \le P_{allow} + (P_{RR} X \ 0.30)$	
3-10	Performance Evaluation	19 years after
		permit effective
		date
3-11	1. Performance Evaluation.	20 years after
	2. Full implementation of all structural	permit effective
	controls used to demonstrate that the	date
	total phosphorus export rate (P _{exp})	
	from the PCP Area in mass/yr is equal	
	to or less than the applicable	
	Allowable Phosphorus Load (Pallow)	
	$P_{exp} \le P_{allow}$	

 Table F-5:Phase 3 of the PCP components and Milestones

3) Description of Phase 3 PCP Components

<u>Updated Legal Analysis</u>- The permittee shall update the legal analysis completed during Phase 1 and Phase 2 of the PCP as necessary to include any new or augmented bylaws, ordinances or funding mechanisms the permittee has deemed necessary to implement the PCP. The permittee shall use experience gained during Phase 1 and Phase 2 to inform the updated legal analysis. The permittee shall adopt necessary regulatory changes as soon as possible to implement the Phase 3 Plan.

<u>Description of Phase 3 planned non-structural controls</u> – The permittee shall describe the non-structural stormwater control measures necessary to support achievement of the phosphorus export milestones in Table F-5. The description of non-structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions that are expected to result from their implementation in units of mass/yr. Annual phosphorus reduction from non-structural BMPs shall be calculated consistent with Attachment 2 to Appendix F.

<u>Description of planned Phase 3 structural controls</u> – The permittee shall develop a priority ranking of areas and infrastructure within the municipality for potential implementation of phosphorus control practices during Phase 3. The ranking shall build upon the ranking developed for

Phase 1 and 2. The permittee shall describe the structural stormwater control measures necessary to support achievement of the phosphorus export milestones in Table F-5. The description of structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions in units of mass/yr that are expected to result from their implementation. Structural measures to be implemented by a third party may be included in a municipal PCP. Annual phosphorus reduction from structural BMPs shall be calculated consistent with Attachment 3 to Appendix F.

<u>Updated description of Operation and Maintenance (O&M) Program for all</u> <u>planned and existing structural BMPs</u> – The permittee shall establish an Operation and Maintenance Program for all structural BMPs being claimed for phosphorus reduction credit as part of Phase 1, 2 and 3 of the PCP. This includes BMPs implemented to date as well as BMPs to be implemented during Phase 3 of the PCP. The Operation and Maintenance Program shall become part of the PCP and include: (1) inspection and maintenance schedule for each BMP according to BMP design or manufacturer specification and (2) program or department responsible for BMP maintenance.

<u>Phase 3 Implementation Schedule</u> – A schedule for implementation of all planned Phase 3 BMPs, including, as appropriate: funding, training, purchasing, construction, inspections, monitoring, O&M activities and other assessment and evaluation components of implementation. Implementation of planned BMPs must begin upon completion of the Phase 3 Plan. Structural BMPs shall be designed and constructed to ensure the permittee will comply with the 18 and 20 year milestones established in Table F-5. The Phase 3 plan shall be fully implemented as soon as possible, but no later than 20 years after the effective date of permit.

<u>Estimated cost for implementing Phase 3 of the PCP</u> – The permittee shall estimate the cost of implementing the Phase 3 non-structural and structural controls and associated Operation and Maintenance Program. This cost estimate can be used to plan for the full implementation of Phase 3.

<u>Complete written Phase 3 Plan</u> – The permittee must complete the written Phase 3 Plan of the PCP no later than 15 years after the permit effective date. The complete Phase 3 Plan shall include Phase 3 PCP item numbers 3-1 through 3-6 in Table F-5. The permittee shall make the Phase 3 Plan available to the public for public comment during Phase 3 Plan development. EPA encourages the permittee to post the Phase 3 Plan online to facilitate public involvement.

<u>Performance Evaluation</u> – The permittee shall evaluate the effectiveness of the PCP by tracking the phosphorus reductions achieved through implementation of structural and non-structural BMPs⁹ and tracking increases resulting from development. Phosphorus reductions shall be calculated consistent with Attachment 2 to Appendix F (non-structural BMP

⁹ See footnote 9

performance) and Attachment 3 to Appendix F (structural BMP performance) for all BMPs implemented to date. Phosphorus export increases due to development shall be calculated consistent with Attachment 1 to Appendix F. Phosphorus loading increases and reductions in unit of mass/yr shall be added or subtracted from the applicable Baseline Phosphorus Load given in Table F-2 or Table F-3 depending on the Scope of PCP chosen to estimate the yearly phosphorous export rate from the PCP Area. The permittee shall also include all information required in part I.2 of this Appendix in each performance evaluation. Performance evaluations will be included as part of each permittee's annual report as required by part 4.4 of the Permit.

2. Reporting

Beginning 1 year after the permit effective date, the permittee shall include a progress report in each annual report on the planning and implementation of the PCP.

Beginning five (5) years after the permit effective date, the permittee shall include the following in each annual report submitted pursuant to part 4.4 of the Permit:

- a. All non-structural control measures implemented during the reporting year along with the phosphorus reduction in mass/yr (P_{NSred}) calculated consistent with Attachment 2 to Appendix F
- b. Structural controls implemented during the reporting year and all previous years including:
 - a. Location information of structural BMPs (GPS coordinates or street address)
 - b. Phosphorus reduction from all structural BMPs implemented to date in mass/yr (P_{Sred}) calculated consistent with Attachment 3 to Appendix F
 - c. Date of last completed maintenance and inspection for each Structural control
- c. Phosphorus load increases due to development over the previous reporting period and incurred since 2005 (P_{DEVinc}) calculated consistent with Attachment 1 to Appendix F.
- d. Estimated yearly phosphorus export rate (P_{exp}) from the PCP Area calculated using Equation 2. Equation 2 calculates the yearly phosphorus export rate by subtracting yearly phosphorus reductions through implemented nonstructural controls and structural controls to date from the Baseline Phosphorus Load and adding loading increases incurred through development to date. This equation shall be used to demonstrate compliance with the phosphorus reduction milestones required as part of each phase of the PCP.

$$P_{exp}\left(\frac{mass}{yr}\right) = P_{base}\left(\frac{mass}{yr}\right) - \left(P_{Sred}\left(\frac{mass}{yr}\right) + P_{NSred}\left(\frac{mass}{yr}\right)\right) + P_{DEVinc}\left(\frac{mass}{yr}\right)$$

Equation 1. Equation used to calculate yearly phosphorus export rate from the chosen PCP Area. P_{exp} =Current phosphorus export rate from the PCP Area in mass/year. P_{base} =baseline phosphorus export rate from LPCP Area in mass/year. P_{Sred} = yearly phosphorus reduction from implemented structural controls in the PCP Area in mass/year. P_{NSred} = yearly phosphorus reduction from implemented non-structural controls in the PCP Area in mass/year. P_{DEVinc} = yearly phosphorus increase resulting from development since 2005 in the PCP Area in mass/year.

e. Certification that all structural BMPs are being inspected and maintained according to the O&M program specified as part of the PCP. The certification statement shall be:

I certify under penalty of law that all source control and treatment Best Management Practices being claimed for phosphorus reduction credit have been inspected, maintained and repaired in accordance with manufacturer or design specification. I certify that, to the best of my knowledge, all Best Management Practices being claimed for a phosphorus reduction credit are performing as originally designed.

- f. Certification that all municipally owned and maintained turf grass areas are being managed in accordance with Massachusetts Regulation 331 CMR 31 pertaining to proper use of fertilizers on turf grasses (see http://www.mass.gov/courts/docs/lawlib/300-399cmr/330cmr31.pdf).
- 3. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part A.I.1. as follows.
 - a. The permittee is relieved of its additional requirements as of the date when the following conditions are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of phosphorus are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. When the criteria in Appendix F part A.I.3.a. are met, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part A.I.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part A.I.1 to date to reduce phosphorus in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part A.I.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation of identified nonstructural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications, and the reporting requirements of Appendix F part I.2. remain in place.

II. Lake and Pond Phosphorus TMDL Requirements

Between 1999 and 2010 EPA has approved 13 Lake TMDLs¹⁰ completed by MassDEP covering 78 lakes and ponds within the Commonwealth of Massachusetts. Any permittee (traditional or non-traditional) that discharges to a waterbody segment in Table F-6 is subject to the requirements of this part.

 Permittees that operate regulated MS4s (traditional and non-traditional) that discharge to the identified impaired waters or their tributaries must reduce phosphorus discharges to support achievement of phosphorus load reductions identified in the TMDLs. To address phosphorus, all permittees with a phosphorus reduction requirement greater than 0% shall develop a Lake Phosphorus Control Plan (LPCP) designed to reduce the amount of phosphorus in stormwater discharges from its MS4 to the impaired waterbody or its tributaries in accordance with the phosphorus load reduction requirements set forth in Table F-6 below. Permittees discharging to waterbodies in Table F-6 with an associated 0% Phosphorus Required Percent Reduction are subject to Appendix F part II.2.f and are relieved of the requirements of Appendix F part II.1.i through Appendix F part II.2.e Table F-6 identifies the primary municipalities¹¹ located within the watershed of the respective lake or pond and the percent phosphorus reductions necessary from urban stormwater sources. Any permittee (traditional or non-traditional) that discharges to a lake or pond listed in Table F-6 or its tributaries is subject to the same phosphorus percent reduction requirements associated with that lake or pond.

Primary Municipality	Waterbody Name	Required Percent Reduction	
	Leesville Pond	31%	
	Auburn Pond	24%	
Auburn	Eddy Pond	0%	
	Pondville Pond	8%	
	Stoneville Pond	3%	
	Buffumville Lake	28%	
	Dresser Hill Pond	17%	
	Gore Pond	14%	
Charlton	Granite Reservoir	11%	
	Jones Pond	13%	
	Pierpoint Meadow Pond	27%	
	Pikes Pond	38%	
Dudley	Gore Pond	14%	

¹⁰ Final TMDLs for lakes and ponds in the Northern Blackstone River Watershed, Chicopee Basin, Connecticut Basin, French Basin, Millers Basin and Bare Hill Pond, Flint Pond, Indian Lake, Lake Boon, Leesville Pond, Salisbury Pond, White Island Pond, Quaboag Pond and Quacumquasit Pond can be found here: <u>http://www.mass.gov/eea/agencies/massde//water/watersheds/total-maximum-daily-loads-tmdls.html</u>

¹¹ Primary municipalities indicate the municipality in which the majority of the lake or pond is located but does not necessarily indicate each municipality that has urbanized area that discharges to the lake or pond or its tributaries.

Primary Municipality	Primary Municipality Waterbody Name	
	Larner Pond	55%
	New Pond	56%
	Pierpoint Meadow Pond	27%
	Shepherd Pond	25%
	Tobins Pond	62%
	Wallis Pond	54%
	Hilchey Pond	27%
Canduan	Parker Pond	47%
Gardner	Bents Pond	52%
	Ramsdall Pond	49%
Grafton	Flint Pond/Lake Quinsigamond	59%
Granby	Aldrich Lake East	0%
Hadley	Lake Warner	24%
Harvard	Bare Hill Pond	2%
Hudson	Lake Boon	28%
	Smiths Pond	30%
	Southwick Pond	64%
Laisastan	Cedar Meadow Pond	17%
Leicester	Dutton Pond	23%
	Greenville Pond	14%
	Rochdale Pond	8%
Ludlow	Minechoag Pond	48%
	Brierly Pond	14%
Millbury	Dorothy Pond	1%
	Howe Reservoir	48%
	Buffumville Lake	28%
	Hudson Pond	37%
Orafa ad	Lowes Pond	51%
Oxford	McKinstry Pond	79%
	Robinson Pond	8%
	Texas Pond	21%
	Flint Pond/Lake Quinsigamond	49%
	Jordan Pond	60%
Shrewsbury	Mill Pond	43%
	Newton Pond	19%
	Shirley Street Pond	30%
Spencer	Quaboag Pond	29%

Primary Municipality	Waterbody Name	Required Percent Reduction
	Quacumquasit Pond	2%
	Jones Pond	13%
	Sugden Reservoir	31%
	Loon Pond	10%
Springfield	Long Pond	56%
	Mona Lake	57%
Stow	Lake Boon	28%
	Brazell Pond	62%
Tomulaton	Depot Pond	50%
rempieton	Bourn-Hadley Pond	49%
	Greenwood Pond 2	56%
Wilbraham	Spectacle Pond	45%
	Lake Denison	22%
Winchandon	Stoddard Pond	24%
winchendon	Whitney Pond	16%
	Whites Mill Pond	21%

Table F-6: Phosphorus impaired Lakes or Ponds subject to a TMDLalong with primary municipality and required percent reduction ofphosphorus from urban stormwater sources

- i. The LPCP shall be implemented in accordance with the following schedule and contain the following elements:
 - a. LPCP Implementation Schedule The permittee shall complete its LPCP and fully implement all of the control measures in its LPCP as soon as possible but no later than 15 years after the effective date of the permit.
 - b. The LPCP shall be implemented in accordance with the following schedule and contain the following elements:

Number	LPCP Component and Milestones	Completion Date
1	Legal Analysis	2 years after permit
		effective date
2	Funding source assessment	3 years after permit
		effective date
3	Define LPCP scope (LPCP Area)	4 years after permit
		effective date
4	Calculate Baseline Phosphorus, Allowable	4 years after permit
	Phosphorus Load and Phosphorus Reduction	effective date
	Requirement	

5	Description of planned nonstructural and	5 years after permit
	structural controls	effective date
6	Description of Operation and Maintenance	5 years after permit
	(O&M) Program	effective date
7	Implementation schedule	5 years after permit
		effective date
8	Cost and Funding Source Assessment	5 years after permit
		effective date
9	Complete written LPCP	5 years after permit
		effective date
10	Full implementation of nonstructural	6 years after permit
	controls.	effective date
11	Performance Evaluation.	6 and 7 years after
		permit effective date
12	1. Performance Evaluation.	8 years after permit
	2. Full implementation of all structural	effective date
	controls used to demonstrate that the	
	total phosphorus export rate (P_{exp}) from	
	the LPCP Area in mass/yr is equal to or	
	less than the applicable Allowable	
	Phosphorus Load(P _{allow}) plus the	
	applicable Phosphorus Reduction	
	Requirement (P_{RR}) multiplied by 0.80	
	$P_{exp} \le P_{allow} + (P_{RR} X \ 0.80)$	
13	Performance Evaluation	9 years after permit
1.4		effective date
14	1. Performance Evaluation.	10years after permit
	2. Update LPCP	effective date
	3. Full implementation of all structural	
	total phosphorus opport rate (D) from	
	the LPCP Area in mage/unic equal to an	
	lass than the applicable Allowable	
	Phosphorus L ord(P) plus the	
	applicable Phosphorus Reduction	
	$\mathbf{R}_{\text{acuirement}}(\mathbf{P}_{\text{acu}})$ multiplied by 0.60	
	$P \leq P_{xx} \pm (P \times Q + G)$	
	$\frac{1}{exp} \leq 1_{allow} + (1_{RR} \times 0.00)$	
	nhosphorus export rate by 20kg/year	
	(which over is greater, uplace full	
	Whichever is greater, unless full Phosphorus Paduction Paguirement has	
	heen met)	
15	Performance Evaluation	11 and 12 years after
1.5		nermit effective date
16		permit encetive auto
	1 Performance Evaluation	13 years after permit
10	 Performance Evaluation. Full implementation of all structural 	13 years after permit effective date
10	 Performance Evaluation. Full implementation of all structural controls used to demonstrate that the 	13years after permit effective date
	 Performance Evaluation. Full implementation of all structural controls used to demonstrate that the total phosphorus export rate (Para) from 	13years after permit effective date
	 Performance Evaluation. Full implementation of all structural controls used to demonstrate that the total phosphorus export rate (P_{exp}) from the LPCP Area in mass/vr is equal to or 	13years after permit effective date

	Phosphorus Load(P_{allow}) plus the applicable Phosphorus Reduction Requirement (P_{RR}) multiplied by 0.30 $P_{exp} \le P_{allow} + (P_{RR} X 0.30)$	
17	Performance Evaluation	14 years after permit effective date
18	 Performance Evaluation. Full implementation of all structural controls used to demonstrate that the total phosphorus export rate (P_{exp}) from the LPCP Area in mass/yr is equal to or less than the applicable Allowable Phosphorus Load(P_{allow}) P_{exp} ≤ P_{allow} 	15years after permit effective date

Table F-7: LPCP components and milestones

c. Description of LPCP Components:

<u>Legal Analysis</u>- The permittee shall develop and implement an analysis that identifies existing regulatory mechanisms available to the MS4 such as by-laws and ordinances and describes any changes to these regulatory mechanisms that may be necessary to effectively implement the LPCP. This may include the creation or amendment of financial and regulatory authorities. The permittee shall adopt necessary regulatory changes by the end of the permit term.

Scope of the LPCP (LPCP Area) - The permittee shall indicate the area in which the permittee plans to implement the LPCP, this area is known as the "LPCP Area". The permittee must choose one of the following: 1) to implement its LPCP in the entire area within its jurisdiction discharging to the impaired waterbody (for a municipality this would be the municipal boundary) or 2) to implement its LPCP in only the urbanized area portion of its jurisdiction discharging to the impaired waterbody. If the permittee chooses to implement the LPCP in its entire jurisdiction discharging to the impaired waterbody, the permittee may demonstrate compliance with the Phosphorus Reduction Requirement and Allowable Phosphorus Load requirements applicable to it through structural and nonstructural controls on discharges that occur both inside and outside the urbanized area. If the permittee chooses to implement the LPCP in its urbanized area only discharging to the impaired waterbody, the permittee must demonstrate compliance with the Phosphorus Reduction Requirement and Allowable Phosphorus Load requirements applicable to it through structural and non-structural controls on discharges that occur within the urbanized area only.

<u>Calculate Baseline Phosphorus Load (P_{base}), Phosphorus Reduction Requirement</u> ($\underline{P_{RR}}$) and Allowable Phosphorus Load (\underline{P}_{allow}) –Permittees shall calculate their numerical Allowable Phosphorus Load and Phosphorus Reduction Requirement in mass/yr by first estimating their Baseline Phosphorus Load in mass/yr from its LPCP Area consistent with the methodology in Attachment 1 to Appendix F, the baseline shall only be estimated using land use phosphorus export coefficients in Attachment 1 to Appendix F and not account for phosphorus reductions resulting from implemented structural BMPs completed to date. Table F-6 contains the percent phosphorus reduction required from urban stormwater consistent with the TMDL of each impaired waterbody. The permittee shall apply the applicable required percent reduction in Table F-6 to the calculated Baseline Phosphorus Load to obtain the permittee specific Allowable Phosphorus Load. The Allowable Phosphorus Load shall then be subtracted from the Baseline Phosphorus Load to obtain the permittee specific Phosphorus Reduction Requirement in mass/yr.

<u>Description of planned non-structural controls</u> – The permittee shall describe the non-structural stormwater control measures to be implemented to support the achievement of the milestones in Table F-7. The description of non-structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions that are expected to result from their implementation. Annual phosphorus reduction from non-structural BMPs shall be calculated consistent with Attachment 2 to Appendix F. The permittee shall update the description of planned non-structural controls as needed to support the achievement of the milestones in Table F-7, including an update in the updated written LPCP 10 years after the permit effective date.

Description of planned structural controls – The permittee shall develop a priority ranking of areas and infrastructure within the municipality for potential implementation of phosphorus control practices. The ranking shall be developed through the use of available screening and monitoring results collected during the permit term either by the permittee or another entity and the mapping required pursuant to part 2.3.4.6 of the Permit. The permittee shall also include in this prioritization a detailed assessment of site suitability for potential phosphorus control measures based on soil types and other factors. The permittee shall coordinate this activity with the requirements of part 2.3.6.8.b of the Permit. A description and the result of this priority ranking shall be included in the LPCP. The permittee shall describe the structural stormwater control measures necessary to support achievement of the milestones in Table F-7. The description of structural controls shall include the planned measures, the areas where the measures will be implemented, and the annual phosphorus reductions in units of mass/yr that are expected to result from their implementation. Structural measures to be implemented by a third party may be included in the LPCP. Annual phosphorus reduction from structural BMPs shall be calculated consistent with Attachment 3 to Appendix F. The permittee shall update the description of planned structural controls as needed to support the achievement of the milestones in Table F-7, including an update in the updated written LPCP 10 years after the permit effective date.

Description of Operation and Maintenance (O&M) Program for all planned and existing structural BMPs – The permittee shall establish an Operation and Maintenance Program for all structural BMPs being claimed for phosphorus reduction credit as part of Phase 1 and 2 of the PCP. This includes BMPs implemented to date as well as BMPs to be implemented during Phase 2 of the PCP. The Operation and Maintenance Program shall become part of the PCP and include: (1) inspection and maintenance schedule for each BMP according to BMP design or manufacturer specification and (2) program or department responsible for BMP maintenance. <u>Implementation Schedule</u> – An initial schedule for implementing the BMPs, including, as appropriate: funding, training, purchasing, construction, inspections, monitoring, O&M and other assessment and evaluation components of implementation. Implementation of planned BMPs must begin upon completion of the LPCP, and all non-structural BMPs shall be fully implemented within six years of the permit effective date. Where planned structural BMP retrofits or major drainage infrastructure projects are expected to take additional time to construct, the permittee shall within four years of the effective date of the permit have a schedule for completion of construction consistent with the reduction requirements in Table F-7. The permittee shall complete the implementation of its LPCP as soon as possible or at a minimum in accordance with the milestones set forth in Table F-7. The implementation schedule shall be updated as needed to support the achievement of the milestones in Table F-7, including an update in the updated written LPCP 10 years after the permit effective date.

<u>Cost and funding source assessment</u> – The permittee shall estimate the cost for implementing its LPCP and describe known and anticipated funding mechanisms. The permittee shall describe the steps it will take to implement its funding plan. This may include but is not limited to conceptual development, outreach to affected parties, and development of legal authorities.

<u>Complete written LPCP</u> – The permittee must complete the written LPCP 5 years after permit effective date. The complete LPCP shall include item numbers 1-8 in Table F-7. The permittee shall make the LPCP available to the public for public comment during the LPCP development. EPA encourages the permittee to post the LPCP online to facilitate public involvement. The LPCP shall be updated as needed with an update 10 years after the permit effective date at a minimum to reflect changes in BMP implementation to support achievement of the phosphorus export milestones in Table F-7. The updated LPCP shall build upon the original LPCP and include additional or new BMPs the permittee will use to support the achievement of the milestones in Table F-7.

<u>Performance Evaluation</u> – The permittee shall evaluate the effectiveness of the LPCP by tracking the phosphorus reductions achieved through implementation of structural and non-structural BMPs¹² and tracking increases in phosphorus loading from the LPCP Area beginning six years after the effective date of the permit. Phosphorus reductions shall be calculated consistent with Attachment 2 (non-structural BMP performance), Attachment 3 (structural BMP performance) and Attachment 1 (reductions through land use change), to Appendix F for all BMPs implemented to date¹³. Phosphorus load increases resulting from development shall be calculated consistent with Attachment 1 to Appendix F. Phosphorus

¹² In meeting its phosphorus reduction requirements a permittee may quantify phosphorus reductions by actions undertaken by another entity, except where those actions are credited to MassDOT or another permittee identified in Appendix F Table F-7

¹³ Annual phosphorus reductions from structural BMPs installed in the LPCP Area prior to the effective date of this permit shall be calculated consistent with Attachment 3 to Appendix F. Phosphorus Reduction Credit for previously installed BMPs will only be given if the Permittee demonstrates that the BMP is performing up to design specifications and certifies that the BMP is properly maintained and inspected according to manufacturer design or specifications. This certification shall be part of the annual performance evaluation during the year credit is claimed for the previously installed BMP.

loading increases and reductions in units of mass/yr shall be added or subtracted from the calculated Baseline Phosphorus Load to estimate the yearly phosphorous export rate from the LPCP Area in mass/yr. The permittee shall also include all information required in part II.2 of this Appendix in each performance evaluation.

2. Reporting

Beginning 1 year after the permit effective date, the permittee shall include a progress report in each annual report on the planning and implementation of the LPCP.

Beginning five (5) years after the permit effective date, the permittee shall include the following in each annual report submitted pursuant to part 4.4 of the Permit:

- a. All non-structural control measures implemented during the reporting year along with the phosphorus reduction in mass/yr (P_{NSred}) calculated consistent with Attachment 2 to Appendix F
- b. Structural controls implemented during the reporting year and all previous years including:
 - a. Location information of structural BMPs (GPS coordinates or street address)
 - b. Phosphorus reduction from all structural BMPs implemented to date in mass/yr (P_{Sred}) calculated consistent with Attachment 3 to Appendix F
 - c. Date of last completed maintenance for each Structural control
- c. Phosphorus load increases due to development over the previous reporting period and incurred to date (P_{DEVinc}) calculated consistent with Attachment 1 to Appendix F.
- d. Estimated yearly phosphorus export rate (P_{exp}) from the LPCP Area calculated using Equation 2. Equation2 calculates the yearly phosphorus export rate by subtracting yearly phosphorus reductions through implemented nonstructural controls and structural controls to date from the Baseline Phosphorus Load and adding loading increases incurred through development to date. This equation shall be used to demonstrate compliance with the phosphorus reduction milestones required as part of each phase of the LPCP.

$$P_{exp\left(\frac{mass}{yr}\right)} = P_{base\left(\frac{mass}{yr}\right)} - \left(P_{Sred\left(\frac{mass}{yr}\right)} + P_{NSred\left(\frac{mass}{yr}\right)}\right) + P_{DEVinc\left(\frac{mass}{yr}\right)}$$

Equation 2. Equation used to calculate yearly phosphorus export rate from the chosen LPCP Area. P_{exp} =Current phosphorus export rate from the LPCP Area in mass/year. P_{base} =baseline phosphorus export rate from LPCP Area in mass/year. P_{Sred} = yearly phosphorus reduction from implemented structural controls in the LPCP Area in mass/year. P_{NSred} = yearly phosphorus reduction from implemented non-structural controls in the LPCP Area in mass/year. Area in mass/year. P_{DEVinc} = yearly phosphorus increase resulting from development since the year baseline loading was calculated in the LPCP Area in mass/year.

e. Certification that all structural BMPs are being inspected and maintained according to the O&M program specified as part of the PCP. The certification statement shall be:

I certify under penalty of law that all source control and treatment Best Management Practices being claimed for phosphorus reduction credit have been inspected, maintained and repaired in accordance with manufacturer or design specification. I certify that, to the best of my knowledge, all Best Management *Practices being claimed for a phosphorus reduction credit are performing as originally designed.*

- f. Certification that all municipally owned and maintained turf grass areas are being managed in accordance with Massachusetts Regulation 331 CMR 31 pertaining to proper use of fertilizers on turf grasses (see <u>http://www.mass.gov/courts/docs/lawlib/300-399cmr/330cmr31.pdf</u>).
- 3. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part A.II.1. as follows:
 - a. The permittee is relieved of its additional requirements as of the date when the following conditions are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of phosphorus are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any additional remaining requirements of Appendix F part A.II.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part A.II.1 to date to reduce phosphorus in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part A.I.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications, and the reporting requirements of Appendix F part A.II.2. remain in place.

III. Bacteria and Pathogen TMDL Requirements

There are currently approved 16 approved bacteria (fecal coliform bacteria) or mixed pathogen (fecal coliform, E. coli, and/or enterococcus bacteria) TMDLs for certain waterbodies in Massachusetts.¹⁴ Any permittee (traditional or non-traditional) that discharges to a waterbody segment in Table F-8 is subject to the requirements of this part.

- 1. Traditional and non-traditional MS4s operating in the municipalities listed in Table F-8 and/or that discharge to a waterbody listed on Table F-8 shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below:
 - a. Enhanced BMPs
 - i. Enhancement of BMPs required by part 2.3 of the permit that shall be implemented during this permit term:
 - part 2.3.3. Public Education: The permittee shall supplement its Residential program with an annual message encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee or its agents shall disseminate educational materials to dog owners at the time of issuance or renewal of a dog license, or other appropriate time. Education materials shall describe the detrimental impacts of improper management of pet waste, requirements for waste collection and disposal, and penalties for non-compliance. The permittee shall also provide information to owners of septic systems about proper maintenance in any catchment that discharges to a water body impaired for bacteria or pathogens. All public education messages can be combined with requirements of Appendix H part I, II and III as well as Appendix F part A.IV, A.V, B.I, B.II and B.III where appropriate.
 - 2. part 2.3.4 Illicit Discharge: Catchments draining to any waterbody impaired for bacteria or pathogens shall be designated either Problem Catchments or HIGH priority in implementation of the IDDE program.

Primary Municipality	Segment ID	Waterbody Name	Indicator Organism
Abington	MA62-09	Beaver Brook	Escherichia Coli (E. Coli)
Abington	MA62-33	Shumatuscacant River	Escherichia Coli (E. Coli)
Acushnet	MA95-31	Acushnet River	Escherichia Coli (E. Coli)
Acushnet	MA95-32	Acushnet River	Escherichia Coli (E. Coli)
Acushnet	MA95-33	Acushnet River	Fecal Coliform

¹⁴ Final bacteria or pathogen TMDLs can be found here:

http://www.mass.gov/eea/agencies/massdep/water/watersheds/total-maximum-daily-loads-tmdls.html

Andover	MA83-04	Rogers Brook	Fecal Coliform
Andover	MA83-15	Unnamed Tributary	Fecal Coliform
Andover	MA83-18	Shawsheen River	Fecal Coliform
Andover	MA83-19	Shawsheen River	Fecal Coliform
Avon	MA62-07	Trout Brook	Escherichia Coli (E. Coli)
Barnstable	MA96-01	Barnstable Harbor	Fecal Coliform
Barnstable	MA96-02	Bumps River	Fecal Coliform
Barnstable	MA96-04	Centerville River	Fecal Coliform
Barnstable	MA96-05	Hyannis Harbor	Fecal Coliform
Barnstable	MA96-06	Maraspin Creek	Fecal Coliform
Barnstable	MA96-07	Prince Cove	Fecal Coliform
Barnstable	MA96-08	Shoestring Bay	Fecal Coliform
Barnstable	MA96-36	Lewis Bay	Fecal Coliform
Barnstable	MA96-37	Mill Creek	Fecal Coliform
Barnstable	MA96-63	Cotuit Bay	Fecal Coliform
Barnstable	MA96-64	Seapuit River	Fecal Coliform
Barnstable	MA96-66	North Bay	Fecal Coliform
Barnstable	MA96-81	Snows Creek	Fecal Coliform
Barnstable	MA96-82	Hyannis Inner Harbor	Fecal Coliform
Barnstable	MA96-92	Santuit River	Fecal Coliform
Barnstable	MA96-93	Halls Creek	Fecal Coliform
Barnstable	MA96-94	Stewarts Creek	Fecal Coliform
Bedford	MA83-01	Shawsheen River	Fecal Coliform
Bedford	MA83-05	Elm Brook	Fecal Coliform
Bedford	MA83-06	Vine Brook	Fecal Coliform
Bedford	MA83-08	Shawsheen River	Fecal Coliform
Bedford	MA83-10	Kiln Brook	Fecal Coliform
Bedford	MA83-14	Spring Brook	Fecal Coliform
Bedford	MA83-17	Shawsheen River	Fecal Coliform
Bellingham	MA72-03	Charles River	Pathogens
Bellingham	MA72-04	Charles River	Pathogens
Belmont	MA72-28	Beaver Brook	Pathogens
Berkley	MA62-02	Taunton River	Fecal Coliform
Berkley	MA62-03	Taunton River	Fecal Coliform
Berkley	MA62-20	Assonet River	Fecal Coliform
Beverly	MA93-08	Bass River	Fecal Coliform
Beverly	MA93-09	Danvers River	Fecal Coliform
Beverly	MA93-20	Beverly Harbor	Fecal Coliform
Beverly	MA93-25	Salem Sound	Fecal Coliform
Billerica	MA83-14	Spring Brook	Fecal Coliform
Billerica	MA83-17	Shawsheen River	Fecal Coliform

Billerica	MA83-18	Shawsheen River	Fecal Coliform
Bourne	MA95-01	Buttermilk Bay	Fecal Coliform
Bourne	MA95-14	Cape Cod Canal	Fecal Coliform
Bourne	MA95-15	Phinneys Harbor	Fecal Coliform
Bourne	MA95-16	Pocasset River	Fecal Coliform
Bourne	MA95-17	Pocasset Harbor	Fecal Coliform
Bourne	MA95-18	Red Brook Harbor	Fecal Coliform
Bourne	MA95-47	Back River	Fecal Coliform
Bourne	MA95-48	Eel Pond	Fecal Coliform
Brewster	MA96-09	Quivett Creek	Fecal Coliform
Brewster	MA96-27	Namskaket Creek	Fecal Coliform
Bridgewater	MA62-32	Matfield River	Escherichia Coli (E. Coli)
Brockton	MA62-05	Salisbury Plain River	Escherichia Coli (E. Coli)
Brockton	MA62-06	Salisbury Plain River	Escherichia Coli (E. Coli)
Brockton	MA62-07	Trout Brook	Escherichia Coli (E. Coli)
Brockton	MA62-08	Salisbury Brook	Escherichia Coli (E. Coli)
Brockton	MA62-09	Beaver Brook	Escherichia Coli (E. Coli)
Brookline	MA72-11	Muddy River	Pathogens
Burlington	MA83-06	Vine Brook	Fecal Coliform
Burlington	MA83-11	Long Meadow Brook	Fecal Coliform
Burlington	MA83-13	Sandy Brook	Fecal Coliform
Cambridge	MA72-36	Charles River	Pathogens
Cambridge	MA72-38	Charles River	Pathogens
Canton	MA73-01	Neponset River	Fecal Coliform
Canton	MA73-01	Neponset River	Escherichia Coli (E. Coli)
Canton	MA73-02	Neponset River	Fecal Coliform
Canton	MA73-05	East Branch	Fecal Coliform
Canton	MA73-20	Beaver Meadow Brook	Fecal Coliform
Canton	MA73-22	Pequid Brook	Fecal Coliform
Canton	MA73-25	Pecunit Brook	Escherichia Coli (E. Coli)
Canton	MA73-27	Ponkapog Brook	Fecal Coliform
Chatham	MA96-11	Stage Harbor	Fecal Coliform
Chatham	MA96-41	Mill Creek	Fecal Coliform
Chatham	MA96-42	Taylors Pond	Fecal Coliform
Chatham	MA96-43	Harding Beach Pond	Fecal Coliform
Chatham	MA96-44	Bucks Creek	Fecal Coliform
Chatham	MA96-45	Oyster Pond	Fecal Coliform
Chatham	MA96-46	Oyster Pond River	Fecal Coliform
Chatham	MA96-49	Frost Fish Creek	Pathogens
Chatham	MA96-50	Ryder Cove	Fecal Coliform
Chatham	MA96-51	Muddy Creek	Pathogens

Chatham	MA96-79	Cockle Cove Creek	Fecal Coliform
Chatham	MA96-79	Cockle Cove Creek	Enterococcus Bacteria
Cohasset	MA94-01	Cohasset Harbor	Fecal Coliform
Cohasset	MA94-19	The Gulf	Fecal Coliform
Cohasset	MA94-20	Little Harbor	Fecal Coliform
Cohasset	MA94-32	Cohasset Cove	Fecal Coliform
Concord	MA83-05	Elm Brook	Fecal Coliform
Danvers	MA93-01	Waters River	Fecal Coliform
Danvers	MA93-02	Crane Brook	Escherichia Coli (E. Coli)
Danvers	MA93-04	Porter River	Fecal Coliform
Danvers	MA93-09	Danvers River	Fecal Coliform
Danvers	MA93-36	Frost Fish Brook	Escherichia Coli (E. Coli)
Danvers	MA93-41	Crane River	Fecal Coliform
Dartmouth	MA95-13	Buttonwood Brook	Escherichia Coli (E. Coli)
Dartmouth	MA95-34	Slocums River	Fecal Coliform
Dartmouth	MA95-38	Clarks Cove	Fecal Coliform
Dartmouth	MA95-39	Apponagansett Bay	Fecal Coliform
Dartmouth	MA95-40	East Branch Westport River	Escherichia Coli (E. Coli)
Dartmouth	MA95-62	Buzzards Bay	Fecal Coliform
Dedham	MA72-07	Charles River	Pathogens
Dedham	MA72-21	Rock Meadow Brook	Pathogens
Dedham	MA73-02	Neponset River	Fecal Coliform
Dennis	MA96-09	Quivett Creek	Fecal Coliform
Dennis	MA96-12	Bass River	Fecal Coliform
Dennis	MA96-13	Sesuit Creek	Fecal Coliform
Dennis	MA96-14	Swan Pond River	Fecal Coliform
Dennis	MA96-35	Chase Garden Creek	Fecal Coliform
Dighton	MA62-02	Taunton River	Fecal Coliform
Dighton	MA62-03	Taunton River	Fecal Coliform
Dighton	MA62-50	Broad Cove	Fecal Coliform
Dighton	MA62-51	Muddy Cove Brook	Fecal Coliform
Dighton	MA62-55	Segreganset River	Fecal Coliform
Dighton	MA62-56	Three Mile River	Escherichia Coli (E. Coli)
Dighton	MA62-57	Three Mile River	Fecal Coliform
Dover	MA72-05	Charles River	Pathogens
Dover	MA72-06	Charles River	Pathogens
Duxbury	MA94-15	Duxbury Bay	Fecal Coliform
Duxbury	MA94-30	Bluefish River	Fecal Coliform
East Bridgewater	MA62-06	Salisbury Plain River	Escherichia Coli (E. Coli)
East Bridgewater	MA62-09	Beaver Brook	Escherichia Coli (E. Coli)
East Bridgewater	MA62-32	Matfield River	Escherichia Coli (E. Coli)

East Bridgewater	MA62-33	Shumatuscacant River	Escherichia Coli (E. Coli)
East Bridgewater	MA62-38	Meadow Brook	Escherichia Coli (E. Coli)
Eastham	MA96-15	Boat Meadow River	Fecal Coliform
Eastham	MA96-16	Rock Harbor Creek	Fecal Coliform
Eastham	MA96-34	Wellfleet Harbor	Fecal Coliform
Eastham	MA96-68	Town Cove	Fecal Coliform
Essex	MA93-11	Essex River	Fecal Coliform
Essex	MA93-16	Essex Bay	Fecal Coliform
Essex	MA93-45	Alewife Brook	Escherichia Coli (E. Coli)
Essex	MA93-46	Alewife Brook	Fecal Coliform
Everett	MA93-51	Unnamed Tributary	Enterococcus Bacteria
Fairhaven	MA95-33	Acushnet River	Fecal Coliform
Fairhaven	MA95-42	New Bedford Inner Harbor	Fecal Coliform
Fairhaven	MA95-62	Buzzards Bay	Fecal Coliform
Fairhaven	MA95-63	Outer New Bedford Harbor	Fecal Coliform
Fairhaven	MA95-64	Little Bay	Fecal Coliform
Fairhaven	MA95-65	Nasketucket Bay	Fecal Coliform
Fall River	MA61-06	Mount Hope Bay	Fecal Coliform
Fall River	MA62-04	Taunton River	Fecal Coliform
Falmouth	MA95-20	Wild Harbor	Fecal Coliform
Falmouth	MA95-21	Herring Brook	Fecal Coliform
Falmouth	MA95-22	West Falmouth Harbor	Fecal Coliform
Falmouth	MA95-23	Great Sippewisset Creek	Fecal Coliform
Falmouth	MA95-24	Little Sippewisset Marsh	Fecal Coliform
Falmouth	MA95-25	Quissett Harbor	Fecal Coliform
Falmouth	MA95-46	Harbor Head	Fecal Coliform
Falmouth	MA96-17	Falmouth Inner Harbor	Fecal Coliform
Falmouth	MA96-18	Great Harbor	Fecal Coliform
Falmouth	MA96-19	Little Harbor	Fecal Coliform
Falmouth	MA96-20	Quashnet River	Fecal Coliform
Falmouth	MA96-21	Waquoit Bay	Fecal Coliform
Falmouth	MA96-53	Perch Pond	Fecal Coliform
Falmouth	MA96-54	Great Pond	Fecal Coliform
Falmouth	MA96-55	Green Pond	Fecal Coliform
Falmouth	MA96-56	Little Pond	Fecal Coliform
Falmouth	MA96-57	Bournes Pond	Fecal Coliform
Falmouth	MA96-58	Hamblin Pond	Fecal Coliform
Falmouth	MA96-62	Oyster Pond	Fecal Coliform
Foxborough	MA62-39	Rumford River	Escherichia Coli (E. Coli)
Foxborough	MA62-47	Wading River	Escherichia Coli (E. Coli)
Foxborough	MA73-01	Neponset River	Fecal Coliform

Foxborough	MA73-01	Neponset River	Escherichia Coli (E. Coli)
Franklin	MA72-04	Charles River	Pathogens
Freetown	MA62-04	Taunton River	Fecal Coliform
Freetown	MA62-20	Assonet River	Fecal Coliform
Gloucester	MA93-12	Annisquam River	Fecal Coliform
Gloucester	MA93-16	Essex Bay	Fecal Coliform
Gloucester	MA93-18	Gloucester Harbor	Fecal Coliform
Gloucester	MA93-28	Mill River	Fecal Coliform
Hanover	MA94-05	North River	Fecal Coliform
Hanover	MA94-21	Drinkwater River	Escherichia Coli (E. Coli)
Hanover	MA94-24	Iron Mine Brook	Escherichia Coli (E. Coli)
Hanover	MA94-27	Third Herring Brook	Escherichia Coli (E. Coli)
Hanson	MA62-33	Shumatuscacant River	Escherichia Coli (E. Coli)
Harwich	MA96-22	Herring River	Fecal Coliform
Harwich	MA96-23	Saquatucket Harbor	Fecal Coliform
Harwich	MA96-51	Muddy Creek	Pathogens
Holliston	MA72-16	Bogastow Brook	Pathogens
Hopedale	MA72-03	Charles River	Pathogens
Hopkinton	MA72-01	Charles River	Pathogens
Ipswich	MA93-16	Essex Bay	Fecal Coliform
Kingston	MA94-14	Jones River	Fecal Coliform
Kingston	MA94-15	Duxbury Bay	Fecal Coliform
Lawrence	MA83-19	Shawsheen River	Fecal Coliform
Lexington	MA72-28	Beaver Brook	Pathogens
Lexington	MA83-06	Vine Brook	Fecal Coliform
Lexington	MA83-10	Kiln Brook	Fecal Coliform
Lincoln	MA83-05	Elm Brook	Fecal Coliform
Lincoln	MA83-08	Shawsheen River	Fecal Coliform
Lynn	MA93-24	Nahant Bay	Fecal Coliform
Lynn	MA93-44	Saugus River	Fecal Coliform
Lynn	MA93-52	Lynn Harbor	Fecal Coliform
Lynnfield	MA93-30	Beaverdam Brook	Escherichia Coli (E. Coli)
Lynnfield	MA93-32	Hawkes Brook	Escherichia Coli (E. Coli)
Lynnfield	MA93-34	Saugus River	Escherichia Coli (E. Coli)
Lynnfield	MA93-35	Saugus River	Escherichia Coli (E. Coli)
Malden	MA93-51	Unnamed Tributary	Enterococcus Bacteria
Manchester	MA93-19	Manchester Harbor	Fecal Coliform
Manchester	MA93-25	Salem Sound	Fecal Coliform
Manchester	MA93-29	Cat Brook	Escherichia Coli (E. Coli)
Manchester	MA93-47	Causeway Brook	Escherichia Coli (E. Coli)
Mansfield	MA62-39	Rumford River	Escherichia Coli (E. Coli)

Mansfield	MA62-47	Wading River	Escherichia Coli (E. Coli)
Mansfield	MA62-49	Wading River	Escherichia Coli (E. Coli)
Marblehead	MA93-21	Salem Harbor	Fecal Coliform
Marblehead	MA93-22	Marblehead Harbor	Fecal Coliform
Marblehead	MA93-25	Salem Sound	Fecal Coliform
Marion	MA95-05	Weweantic River	Fecal Coliform
Marion	MA95-07	Sippican River	Fecal Coliform
Marion	MA95-08	Sippican Harbor	Fecal Coliform
Marion	MA95-09	Aucoot Cove	Fecal Coliform
Marion	MA95-56	Hammett Cove	Fecal Coliform
Marshfield	MA94-05	North River	Fecal Coliform
Marshfield	MA94-06	North River	Fecal Coliform
Marshfield	MA94-09	South River	Fecal Coliform
Marshfield	MA94-11	Green Harbor	Fecal Coliform
Mashpee	MA96-08	Shoestring Bay	Fecal Coliform
Mashpee	MA96-21	Waquoit Bay	Fecal Coliform
Mashpee	MA96-24	Mashpee River	Fecal Coliform
Mashpee	MA96-39	Popponesset Creek	Fecal Coliform
Mashpee	MA96-58	Hamblin Pond	Fecal Coliform
Mashpee	MA96-61	Little River	Fecal Coliform
Mashpee	MA96-92	Santuit River	Fecal Coliform
Mattapoisett	MA95-09	Aucoot Cove	Fecal Coliform
Mattapoisett	MA95-10	Hiller Cove	Fecal Coliform
Mattapoisett	MA95-35	Mattapoisett Harbor	Fecal Coliform
Mattapoisett	MA95-60	Mattapoisett River	Fecal Coliform
Mattapoisett	MA95-61	Eel Pond	Fecal Coliform
Mattapoisett	MA95-65	Nasketucket Bay	Fecal Coliform
Medfield	MA72-05	Charles River	Pathogens
Medfield	MA72-10	Stop River	Pathogens
Medfield	MA73-09	Mine Brook	Fecal Coliform
Medway	MA72-04	Charles River	Pathogens
Medway	MA72-05	Charles River	Pathogens
Melrose	MA93-48	Bennetts Pond Brook	Escherichia Coli (E. Coli)
Mendon	MA72-03	Charles River	Pathogens
Milford	MA72-01	Charles River	Pathogens
Millis	MA72-05	Charles River	Pathogens
Millis	MA72-16	Bogastow Brook	Pathogens
Milton	MA73-02	Neponset River	Fecal Coliform
Milton	MA73-03	Neponset River	Fecal Coliform
Milton	MA73-04	Neponset River	Fecal Coliform
Milton	MA73-26	Unquity Brook	Fecal Coliform

Milton	MA73-29	Pine Tree Brook	Fecal Coliform
Milton	MA73-30	Gulliver Creek	Fecal Coliform
Nahant	MA93-24	Nahant Bay	Fecal Coliform
Nahant	MA93-52	Lynn Harbor	Fecal Coliform
Nahant	MA93-53	Lynn Harbor	Fecal Coliform
Natick	MA72-05	Charles River	Pathogens
Natick	MA72-06	Charles River	Pathogens
Needham	MA72-06	Charles River	Pathogens
Needham	MA72-07	Charles River	Pathogens
Needham	MA72-18	Fuller Brook	Pathogens
Needham	MA72-21	Rock Meadow Brook	Pathogens
Needham	MA72-25	Rosemary Brook	Pathogens
New Bedford	MA95-13	Buttonwood Brook	Escherichia Coli (E. Coli)
New Bedford	MA95-33	Acushnet River	Fecal Coliform
New Bedford	MA95-38	Clarks Cove	Fecal Coliform
New Bedford	MA95-42	New Bedford Inner Harbor	Fecal Coliform
New Bedford	MA95-63	Outer New Bedford Harbor	Fecal Coliform
Newton	MA72-07	Charles River	Pathogens
Newton	MA72-23	Sawmill Brook	Pathogens
Newton	MA72-24	South Meadow Brook	Pathogens
Newton	MA72-29	Cheese Cake Brook	Pathogens
Newton	MA72-36	Charles River	Pathogens
Norfolk	MA72-05	Charles River	Pathogens
Norfolk	MA72-10	Stop River	Pathogens
North Andover	MA83-19	Shawsheen River	Fecal Coliform
Norton	MA62-49	Wading River	Escherichia Coli (E. Coli)
Norton	MA62-56	Three Mile River	Escherichia Coli (E. Coli)
Norwell	MA94-05	North River	Fecal Coliform
Norwell	MA94-27	Third Herring Brook	Escherichia Coli (E. Coli)
Norwell	MA94-31	Second Herring Brook	Fecal Coliform
Norwood	MA73-01	Neponset River	Fecal Coliform
Norwood	MA73-01	Neponset River	Escherichia Coli (E. Coli)
Norwood	MA73-02	Neponset River	Fecal Coliform
Norwood	MA73-15	Germany Brook	Fecal Coliform
Norwood	MA73-16	Hawes Brook	Fecal Coliform
Norwood	MA73-17	Traphole Brook	Fecal Coliform
Norwood	MA73-24	Purgatory Brook	Fecal Coliform
Norwood	MA73-33	Unnamed Tributary	Escherichia Coli (E. Coli)
Orleans	MA96-16	Rock Harbor Creek	Fecal Coliform
Orleans	MA96-26	Little Namskaket Creek	Fecal Coliform
Orleans	MA96-27	Namskaket Creek	Fecal Coliform

	i i	i .	i la
Orleans	MA96-68	Town Cove	Fecal Coliform
Orleans	MA96-72	Paw Wah Pond	Fecal Coliform
Orleans	MA96-73	Pochet Neck	Fecal Coliform
Orleans	MA96-76	The River	Fecal Coliform
Orleans	MA96-78	Little Pleasant Bay	Fecal Coliform
Peabody	MA93-01	Waters River	Fecal Coliform
Peabody	MA93-05	Goldthwait Brook	Escherichia Coli (E. Coli)
Peabody	MA93-39	Proctor Brook	Escherichia Coli (E. Coli)
Pembroke	MA94-05	North River	Fecal Coliform
Plymouth	MA94-15	Duxbury Bay	Fecal Coliform
Plymouth	MA94-16	Plymouth Harbor	Fecal Coliform
Plymouth	MA94-34	Ellisville Harbor	Fecal Coliform
Raynham	MA62-02	Taunton River	Fecal Coliform
Rehoboth	MA53-03	Palmer River	Pathogens
Rehoboth	MA53-04	Palmer River	Pathogens
Rehoboth	MA53-05	Palmer River	Pathogens
Rehoboth	MA53-07	Palmer River - West Branch	Pathogens
Rehoboth	MA53-08	Palmer River - East Branch	Pathogens
Rehoboth	MA53-09	Rumney Marsh Brook	Pathogens
Rehoboth	MA53-10	Beaver Dam Brook	Pathogens
Rehoboth	MA53-11	Bad Luck Brook	Pathogens
Rehoboth	MA53-12	Fullers Brook	Pathogens
Rehoboth	MA53-13	Clear Run Brook	Pathogens
Rehoboth	MA53-14	Torrey Creek	Pathogens
Rehoboth	MA53-15	Old Swamp Brook	Pathogens
Rehoboth	MA53-16	Rocky Run	Pathogens
Revere	MA93-15	Pines River	Fecal Coliform
Revere	MA93-44	Saugus River	Fecal Coliform
Revere	MA93-51	Unnamed Tributary	Enterococcus Bacteria
Revere	MA93-52	Lynn Harbor	Fecal Coliform
Revere	MA93-53	Lynn Harbor	Fecal Coliform
Rockland	MA94-03	French Stream	Escherichia Coli (E. Coli)
Rockport	MA93-17	Rockport Harbor	Fecal Coliform
Salem	MA93-09	Danvers River	Fecal Coliform
Salem	MA93-20	Beverly Harbor	Fecal Coliform
Salem	MA93-21	Salem Harbor	Fecal Coliform
Salem	MA93-25	Salem Sound	Fecal Coliform
Salem	MA93-39	Proctor Brook	Escherichia Coli (E. Coli)
Salem	MA93-40	Proctor Brook	Enterococcus Bacteria
Salem	MA93-42	North River	Fecal Coliform
Sandwich	MA95-14	Cape Cod Canal	Fecal Coliform

Sandwich	MA96-30	Scorton Creek	Fecal Coliform
Sandwich	MA96-84	Old Harbor Creek	Fecal Coliform
Sandwich	MA96-85	Mill Creek	Fecal Coliform
Sandwich	MA96-86	Dock Creek	Fecal Coliform
Sandwich	MA96-87	Springhill Creek	Fecal Coliform
Saugus	MA93-15	Pines River	Fecal Coliform
Saugus	MA93-33	Hawkes Brook	Escherichia Coli (E. Coli)
Saugus	MA93-35	Saugus River	Escherichia Coli (E. Coli)
Saugus	MA93-43	Saugus River	Fecal Coliform
Saugus	MA93-44	Saugus River	Fecal Coliform
Saugus	MA93-48	Bennetts Pond Brook	Escherichia Coli (E. Coli)
Saugus	MA93-49	Shute Brook	Fecal Coliform
Saugus	MA93-50	Shute Brook	Escherichia Coli (E. Coli)
Scituate	MA94-01	Cohasset Harbor	Fecal Coliform
Scituate	MA94-02	Scituate Harbor	Fecal Coliform
Scituate	MA94-05	North River	Fecal Coliform
Scituate	MA94-06	North River	Fecal Coliform
Scituate	MA94-07	Herring River	Fecal Coliform
Scituate	MA94-09	South River	Fecal Coliform
Scituate	MA94-19	The Gulf	Fecal Coliform
Scituate	MA94-32	Cohasset Cove	Fecal Coliform
Scituate	MA94-33	Musquashcut Pond	Fecal Coliform
Seekonk	MA53-01	Runnins River	Fecal Coliform
Seekonk	MA53-12	Fullers Brook	Pathogens
Seekonk	MA53-13	Clear Run Brook	Pathogens
Seekonk	MA53-14	Torrey Creek	Pathogens
Sharon	MA62-39	Rumford River	Escherichia Coli (E. Coli)
Sharon	MA73-17	Traphole Brook	Fecal Coliform
Sharon	MA73-31	Unnamed Tributary	Fecal Coliform
Sherborn	MA72-05	Charles River	Pathogens
Somerset	MA61-01	Lee River	Fecal Coliform
Somerset	MA61-02	Lee River	Fecal Coliform
Somerset	MA61-06	Mount Hope Bay	Fecal Coliform
Somerset	MA62-03	Taunton River	Fecal Coliform
Somerset	MA62-04	Taunton River	Fecal Coliform
Somerset	MA62-50	Broad Cove	Fecal Coliform
Stoughton	MA73-20	Beaver Meadow Brook	Fecal Coliform
Stoughton	MA73-32	Unnamed Tributary	Escherichia Coli (E. Coli)
Swampscott	MA93-24	Nahant Bay	Fecal Coliform
Swansea	MA53-03	Palmer River	Pathogens
Swansea	MA53-06	Warren River Pond	Fecal Coliform

Swansea	MA53-16	Rocky Run	Pathogens
Swansea	MA61-01	Lee River	Fecal Coliform
Swansea	MA61-02	Lee River	Fecal Coliform
Swansea	MA61-04	Cole River	Fecal Coliform
Swansea	MA61-07	Mount Hope Bay	Fecal Coliform
Swansea	MA61-08	Kickemuit River	Pathogens
Taunton	MA62-02	Taunton River	Fecal Coliform
Taunton	MA62-56	Three Mile River	Escherichia Coli (E. Coli)
Taunton	MA62-57	Three Mile River	Fecal Coliform
Tewksbury	MA83-07	Strong Water Brook	Fecal Coliform
Tewksbury	MA83-15	Unnamed Tributary	Fecal Coliform
Tewksbury	MA83-18	Shawsheen River	Fecal Coliform
Wakefield	MA93-31	Mill River	Escherichia Coli (E. Coli)
Wakefield	MA93-34	Saugus River	Escherichia Coli (E. Coli)
Wakefield	MA93-35	Saugus River	Escherichia Coli (E. Coli)
Walpole	MA72-10	Stop River	Pathogens
Walpole	MA73-01	Neponset River	Fecal Coliform
Walpole	MA73-01	Neponset River	Escherichia Coli (E. Coli)
Walpole	MA73-06	School Meadow Brook	Fecal Coliform
Walpole	MA73-09	Mine Brook	Fecal Coliform
Walpole	MA73-17	Traphole Brook	Fecal Coliform
Waltham	MA72-07	Charles River	Pathogens
Waltham	MA72-28	Beaver Brook	Pathogens
Wareham	MA95-01	Buttermilk Bay	Fecal Coliform
Wareham	MA95-02	Onset Bay	Fecal Coliform
Wareham	MA95-03	Wareham River	Fecal Coliform
Wareham	MA95-05	Weweantic River	Fecal Coliform
Wareham	MA95-07	Sippican River	Fecal Coliform
Wareham	MA95-29	Agawam River	Fecal Coliform
Wareham	MA95-49	Broad Marsh River	Fecal Coliform
Wareham	MA95-50	Wankinco River	Fecal Coliform
Wareham	MA95-51	Crooked River	Fecal Coliform
Wareham	MA95-52	Cedar Island Creek	Fecal Coliform
Wareham	MA95-53	Beaverdam Creek	Fecal Coliform
Watertown	MA72-07	Charles River	Pathogens
Watertown	MA72-30	Unnamed Tributary	Pathogens
Watertown	MA72-32	Unnamed Tributary	Pathogens
Watertown	MA72-36	Charles River	Pathogens
Wellesley	MA72-06	Charles River	Pathogens
Wellesley	MA72-07	Charles River	Pathogens
Wellesley	MA72-18	Fuller Brook	Pathogens

Wellesley	MA72-25	Rosemary Brook	Pathogens
Wellfleet	MA96-32	Duck Creek	Fecal Coliform
Wellfleet	MA96-33	Herring River	Fecal Coliform
Wellfleet	MA96-34	Wellfleet Harbor	Fecal Coliform
West Bridgewater	MA62-06	Salisbury Plain River	Escherichia Coli (E. Coli)
Weston	MA72-07	Charles River	Pathogens
Westport	MA95-37	West Branch Westport River	Fecal Coliform
Westport	MA95-40	East Branch Westport River	Escherichia Coli (E. Coli)
Westport	MA95-41	East Branch Westport River	Fecal Coliform
Westport	MA95-44	Snell Creek	Escherichia Coli (E. Coli)
Westport	MA95-45	Snell Creek	Escherichia Coli (E. Coli)
Westport	MA95-54	Westport River	Fecal Coliform
Westport	MA95-58	Bread And Cheese Brook	Escherichia Coli (E. Coli)
Westport	MA95-59	Snell Creek	Fecal Coliform
Westwood	MA72-21	Rock Meadow Brook	Pathogens
Westwood	MA73-02	Neponset River	Fecal Coliform
Westwood	MA73-15	Germany Brook	Fecal Coliform
Westwood	MA73-24	Purgatory Brook	Fecal Coliform
Westwood	MA73-25	Pecunit Brook	Escherichia Coli (E. Coli)
Westwood	MA73-27	Ponkapog Brook	Fecal Coliform
Whitman	MA62-09	Beaver Brook	Escherichia Coli (E. Coli)
Whitman	MA62-33	Shumatuscacant River	Escherichia Coli (E. Coli)
Whitman	MA62-38	Meadow Brook	Escherichia Coli (E. Coli)
Wilmington	MA83-18	Shawsheen River	Fecal Coliform
Winthrop	MA93-53	Lynn Harbor	Fecal Coliform
Yarmouth	MA96-12	Bass River	Fecal Coliform
Yarmouth	MA96-35	Chase Garden Creek	Fecal Coliform
Yarmouth	MA96-36	Lewis Bay	Fecal Coliform
Yarmouth	MA96-37	Mill Creek	Fecal Coliform
Yarmouth	MA96-38	Parkers River	Fecal Coliform
Yarmouth	MA96-80	Mill Creek	Fecal Coliform
Yarmouth	MA96-82	Hyannis Inner Harbor	Fecal Coliform

Table F-8: Bacteria or pathogens impaired waterbody names and segment IDs along
with primary municipality and indicator organism identified by the applicable
TMDL. The term primary municipality indicates the municipality in which the
majority of the segment is located, but does not necessarily indicate each
municipality that has regulated discharges to the waterbody segment.

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part A.III.1. as follows:
 - a. The permittee is relieved of additional requirements as of the date when the following conditions are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable to the receiving water

that indicates that no additional stormwater controls for bacteria/pathogens are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL

- b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any additional remaining requirements of Appendix F part A.III.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part A.III.1 to date to reduce bacteria/pathogens in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part A.III.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

IV. Cape Cod Nitrogen TMDL Requirements

There are 19 approved TMDLs for nitrogen for various watersheds, ponds and bays on Cape Cod.¹⁵ The following measuress are needed to ensure that current nitrogen loads from MS4 stormwater discharged into the impaired waterbodies do not increase.

- 1. The operators of traditional and non-traditional MS4s located in municipalities listed in Table F-9 or any other MS4 (traditional and non-traditional) that discharges to any waterbody listed in Table F-9 or their tributaries shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below:
 - a. Enhanced BMPs
 - i. Enhancement of BMPs required by part 2.3 of the permit that shall be implemented during this permit term:
 - 1. part 2.3.2, Public education and outreach: The permittee shall supplement its Residential and Business/Commercial/Institution program with annual timed messages on specific topics. The permittee shall distribute an annual message in the spring (April/May) timeframe that encourages the proper use and disposal of grass clippings and encourages the proper use of slow-release fertilizers. The permittee shall distribute an annual message in the summer (June/July) timeframe encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee shall distribute an annual message in the Fall (August/September/October) timeframe encouraging the proper disposal of leaf litter. The permittee shall deliver an annual message on each of these topics, unless the permittee determines that one or more of these issues is not a significant contributor of nitrogen to discharges from the MS4 and the permittee retains documentation of this finding in the SWMP. All public education messages can be combined with requirements of Appendix H part I, II and III as well as Appendix F part A.III, A.V, B.I, B.II and B.III where appropriate.
 - 2. part 2.3.6, Stormwater Management in New Development and Redevelopment: the requirement for adoption/amendment of the permittee's ordinance or other regulatory mechanism shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for nitrogen removal; retrofit inventory and priority ranking under 2.3.6.1.b shall include consideration of BMPs to reduce nitrogen discharges.

¹⁵ Final nitrogen TMDLs for Cape Cod can be found here: <u>http://www.mass.gov/eea/agencies/massdep/water/watersheds/total-maximum-daily-loads-tmdls.html</u>

 part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: establish requirements for use of slow release fertilizers on permittee owned property currently using fertilizer, in addition to reducing and managing fertilizer use as provided in in part 2.3.7.1; establish procedures to properly manage grass cuttings and leaf litter on permittee property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces; increased street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two (2) times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 – Dec 1; following leaf fall).

Municipality	Waterbody Name
Barnstable	Centerville River
Barnstable	Popponesset Bay
Barnstable	Shoestring Bay
Barnstable	Cotuit Bay
Barnstable	North Bay
Barnstable	Prince Cove
Barnstable	West Bay
Barnstable	Hyannis Inner Harbor
Barnstable	Lewis Bay
Bourne	Phinneys Harbor
Chatham	Crows Pond
Chatham	Bucks Creek
Chatham	Harding Beach Pond
Chatham	Mill Creek
Chatham	Mill Pond
Chatham	Oyster Pond
Chatham	Oyster Pond River
Chatham	Stage Harbor
Chatham	Taylors Pond
Chatham	Frost Fish Creek
Chatham	Ryder Cove
Falmouth	Bournes Pond
Falmouth	Great Pond
Falmouth	Green Pond
Falmouth	Perch Pond
Falmouth	Little Pond
Falmouth	Oyster Pond
Falmouth	Quashnet River
Falmouth	Inner West Falmouth Harbor

Municipality	Waterbody Name
Falmouth	West Falmouth Harbor
Falmouth	Snug Harbor
Falmouth	Harbor Head
Harwich	Muddy Creek - Lower
Harwich	Muddy Creek - Upper
Harwich	Round Cove
Mashpee	Mashpee River
Mashpee	Great River
Mashpee	Hamblin Pond
Mashpee	Jehu Pond
Mashpee	Little River
Orleans	Areys Pond
Orleans	Little Pleasant Bay
Orleans	Namequoit River
Orleans	Paw Wah Pond
Orleans	Pleasant Bay
Orleans	Pochet Neck
Orleans	Quanset Pond
Yarmouth	Mill Creek
Yarmouth	Hyannis Inner Harbor
Yarmouth	Lewis Bay

Table F-9: Waterbodies subject to a Cape Cod nitrogen	TMDL
and the primary municipalities	

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part A.IV.1. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of nitrogen are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part A.IV.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part A.IV.1 to date to reduce nitrogen in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part A.IV.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing

implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

V. Assabet River Phosphorus TMDL Requirements

On September 23, 2004 EPA approved the *Assabet River Total Maximum Daily Load for Total Phosphorus*¹⁶. The following measures are needed to ensure that current phosphorus loads from MS4 stormwater discharged directly or indirectly via tributaries into the Assabet River do not increase.

- 1. The operators of traditional and non-traditional MS4s located in municipalities listed in Table F-10 within the Assabet River Watershed shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below:
 - a. Enhanced BMPs
 - i. Enhancement of BMPs required by part 2.3 of the permit that shall be implemented during this permit term:
 - 1. part 2.3.2, Public education and outreach: The permittee shall supplement its Residential and Business/Commercial/Institution program with annual timed messages on specific topics. The permittee shall distribute an annual message in the spring (March/April) timeframe that encourages the proper use and disposal of grass clippings and encourages the proper use of slowrelease and phosphorous-free fertilizers. The permittee shall distribute an annual message in the summer (June/July) timeframe encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee shall distribute an annual message in the fall (August/September/October) timeframe encouraging the proper disposal of leaf litter. The permittee shall deliver an annual message on each of these topics, unless the permittee determines that one or more of these issues is not a significant contributor of phosphorous to discharges from the MS4 and the permittee retains documentation of this finding in the SWMP. All public education messages can be combined with requirements of Appendix H part I, II and III as well as Appendix F part A.III, A.IV, B.I, B.II and B.III where appropriate.
 - 2. part 2.3.6, Stormwater Management in New Development and Redevelopment: the requirement for adoption/amendment of the permittee's ordinance or other regulatory mechanism shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for phosphorus removal; retrofit inventory and priority ranking under 2.3.6.1.b shall include consideration of BMPs that infiltrate stormwater where feasible.
 - 3. part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: Establish program to properly

¹⁶ Massachusetts Department of Environmental Protection, 2004. Assabet River Total Maximum Daily Load for Total Phosphorus. CN 201.0

manage grass cuttings and leaf litter on permittee property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces; increased street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 – Dec 1; following leaf fall).

Municipality
Acton
Berlin
Bolton
Boxborough
Boylston
Carlisle
Clinton
Concord
Grafton
Harvard
Hudson
Littleton
Marlborough
Maynard
Northborough
Shrewsbury
Stow
Westborough
Westford

Table F-10: Municipalities located in
the Assabet River Watershed

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part A.V.1. as follows.
 - a. The permittee is relieved of its additional requirements as of the date when following conditions are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of phosphorus are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part A.V.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part A.V.1 to

date to reduce phosphorus in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs

ii. The permittee shall continue to implement all requirements of Appendix F part A.V.1 required to be implemented prior to the date of the newly approved TMDL including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.
B. Requirements for Discharges to Impaired Waters with an Approved Out of State TMDL

I. Nitrogen TMDL Requirements

Discharges from MS4s in Massachusetts to waters that are tributaries to the Long Island Sound, which has an approved TMDL for nitrogen¹⁷, are subject to the requirements of this part.

- 1. The operators of traditional and non-traditional MS4s located in municipalities listed in Table F-11 shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below:
 - a. Enhanced BMPs
 - i. Enhancement of BMPs required by part 2.3 of the permit that shall be implemented during this permit term:
 - 1. part 2.3.2, Public education and outreach: The permittee shall supplement its Residential and Business/Commercial/Institution program with annual timed messages on specific topics. The permittee shall distribute an annual message in the spring (April/May) timeframe that encourages the proper use and disposal of grass clippings and encourages the proper use of slow-release fertilizers. The permittee shall distribute an annual message in the summer (June/July) timeframe encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee shall distribute an annual message in the Fall (August/September/October) timeframe encouraging the proper disposal of leaf litter. The permittee shall deliver an annual message on each of these topics, unless the permittee determines that one or more of these issues is not a significant contributor of nitrogen to discharges from the MS4 and the permittee retains documentation of this finding in the SWMP. All public education messages can be combined with requirements of Appendix H part I, II and III as well as Appendix F part A.III, A.IV, A.V, B.II and B.III where appropriate.
 - 2. part 2.3.6, Stormwater Management in New Development and Redevelopment: the requirement for adoption/amendment of the permittee's ordinance or other regulatory mechanism shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for nitrogen removal; retrofit inventory and priority ranking under 2.3.6.1.b shall include consideration of BMPs to reduce nitrogen discharges.
 - 3. part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: establish requirements for use of

¹⁷ Connecticut Department of Environmental Protection. 2000. A Total Maximum Daily Load Analysis to Achieve Water Quality Standards for Dissolved Oxygen in Long Island Sound

slow release fertilizers on permittee owned property currently using fertilizer, in addition to reducing and managing fertilizer use as provided in in part 2.3.7.1; establish procedures to properly manage grass cuttings and leaf litter on permittee property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces; increased street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two (2) times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 – Dec 1; following leaf fall).

- b. Nitrogen Source Identification Report
 - i. Within four years of the permit effective date the permittee shall complete a Nitrogen Source Identification Report. The report shall include the following elements:
 - 1. Calculation of total urbanized area within the permittee's jurisdiction that is within the Connecticut River Watershed, the Housatonic River Watershed, or the Thames River Watershed, incorporating updated mapping of the MS4 and catchment delineations produced pursuant to part 2.3.4.6,
 - 2. All screening and monitoring results pursuant to part 2.3.4.7.d., targeting the receiving water segment(s)
 - 3. Impervious area and DCIA for the target catchment
 - 4. Identification, delineation and prioritization of potential catchments with high nitrogen loading
 - Identification of potential retrofit opportunities or opportunities for the installation of structural BMPs during re-development
 - ii. The final Nitrogen Source Identification Report shall be submitted to EPA as part of the year 4 annual report.
- c. Structural BMPs
 - i. Within five years of the permit effective date, the permittee shall evaluate all properties identified as presenting retrofit opportunities or areas for structural BMP installation under permit part 2.3.6.d.ii. or identified in the Nitrogen Source Identification Report. The evaluation shall include:
 - 1. The next planned infrastructure, resurfacing or redevelopment activity planned for the property (if applicable) OR planned retrofit date;
 - 2. The estimated cost of redevelopment or retrofit BMPs; and
 - 3. The engineering and regulatory feasibility of redevelopment or retrofit BMPs.
 - ii. The permittee shall provide a listing of planned structural BMPs and a plan and schedule for implementation in the year 5 annual

report. The permittee shall plan and install a minimum of one structural BMP as a demonstration project within six years of the permit effective date. The demonstration project shall be installed targeting a catchment with high nitrogen load potential. The permittee shall install the remainder of the structural BMPs in accordance with the plan and schedule provided in the year 5 annual report.

iii. Any structural BMPs listed in Table 4-3 of Attachment 1 to Appendix H installed in the urbanized area by the permittee or its agents shall be tracked and the permittee shall estimate the nitrogen removal by the BMP consistent with Attachment 1 to Appendix H. The permittee shall document the BMP type, total area treated by the BMP, the design storage volume of the BMP and the estimated nitrogen removed in mass per year by the BMP in each annual report.

Adams	North Adams
Agawam	Northampton
Amherst	Oxford
Ashburnham	Palmer
Ashby	Paxton
Auburn	Pelham
Belchertown	Pittsfield
Charlton	Richmond
Cheshire	Russell
Chicopee	Rutland
Dalton	South Hadley
Douglas	Southampton
Dudley	Southbridge
East Longmeadow	Southwick
Easthampton	Spencer
Gardner	Springfield
Granby	Sturbridge
Hadley	Sutton
Hampden	Templeton
Hatfield	Ware
Hinsdale	Webster
Holyoke	West Springfield
Lanesborough	Westfield
Leicester	Westhampton
Lenox	Westminster
Longmeadow	Wilbraham
Ludlow	Williamsburg
Millbury	Winchendon

Monson

Table F-11: Massachusetts municipalities in whichMS4 discharges are within the ConnecticutRiver Watershed, the Housatonic RiverWatershed, or the Thames River Watershed.

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part B.I.1. as follows:
 - a. The permittee is relieved of its additional requirements as of the date when the following conditions are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of nitrogen are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part B.I.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part B.I.1 to date to reduce nitrogen in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part B.I.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

II. Phosphorus TMDL Requirements

There are currently eight approved phosphorus TMDLs for certain waterbody segments in Rhode Island that identify urban stormwater discharges in Massachusetts as sources that are contributing phosphorus to the impaired segments. The TMDLs include the Kickemuit Reservoir, Upper Kikemuit River, Kickemuit River, Ten Mile River, Central Pond, Turner Reservoir, Lower Ten Mile River, and Omega Pond TMDLs¹⁸. Table F-12 lists municipalities in Massachusetts identified in the TMDLs as containing MS4s contributing phosphorus to the impaired waterbody segments in Rhode Island, the impaired receiving water, and the approved TMDL name. Any permittee (traditional or non-traditional) that operates an MS4 in a municipality listed in Table F-12 and that discharges to a waterbody or tributary of a waterbody listed on Table F-12 is subject to the requirements of this part.

- 1. The operators of traditional and non-traditional MS4s located in municipalities listed in Table F-12 and that discharge to a waterbody or a tributary of a waterbody identified on Table F-12 shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below:
 - a. Enhanced BMPs
 - i. Enhancement of BMPs required by part 2.3 of the permit that shall be implemented during this permit term:
 - 1. part 2.3.2, Public education and outreach: The permittee shall supplement its Residential and Business/Commercial/Institution program with annual timed messages on specific topics. The permittee shall distribute an annual message in the spring (March/April) timeframe that encourages the proper use and disposal of grass clippings and encourages the proper use of slow-release and phosphorousfree fertilizers. The permittee shall distribute an annual message in the summer (June/July) timeframe encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee shall distribute an annual message in the fall (August/September/October) timeframe encouraging the proper disposal of leaf litter. The permittee shall deliver an annual message on each of these topics, unless the permittee determines that one or more of these issues is not a significant contributor of phosphorous to discharges from the MS4 and the permittee retains documentation of this finding in the SWMP. All public education messages can be combined with requirements of Appendix H part I, II and III as well as Appendix F part A.III, A.IV, A.V, B.I, and B.III where appropriate.
 - 2. part 2.3.6, Stormwater Management in New Development and Redevelopment: the requirement for

¹⁸ See <u>http://www.dem.ri.gov/programs/benviron/water/quality/rest/reports.htm</u> for all RI TMDL documents. (retrieved 6/30/2014)

adoption/amendment of the permittee's ordinance or other regulatory mechanism shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for phosphorus removal; retrofit inventory and priority ranking under 2.3.6.1.b shall include consideration of BMPs that infiltrate stormwater where feasible.

3. part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: Establish program to properly manage grass cuttings and leaf litter on permittee property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces; increased street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 – Dec 1; following leaf fall).

b. Phosphorus Source Identification Report

- i. Within four years of the permit effective date the permittee shall complete a Phosphorus Source Identification Report. The report shall include the following elements:
 - 1. Calculation of total urbanized area draining to the water quality limited receiving water segments or their tributaries, incorporating updated mapping of the MS4 and catchment delineations produced pursuant to part 2.3.4.6,
 - 2. All screening and monitoring results pursuant to part 2.3.4.7.d., targeting the receiving water segment(s)
 - 3. Impervious area and DCIA for the target catchment
 - 4. Identification, delineation and prioritization of potential catchments with high phosphorus loading
 - 5. Identification of potential retrofit opportunities or opportunities for the installation of structural BMPs during re development, including the removal of impervious area of permittee owned properties
- ii. The phosphorus source identification report shall be submitted to EPA as part of the year 4 annual report.
- c. Structural BMPs
 - i. Within five years of the permit effective date, the permittee shall evaluate all permittee owned properties identified as presenting retrofit opportunities or areas for structural BMP installation under permit part 2.3.6.d.ii or identified in the Phosphorus Source Identification Report that are within the drainage area of the water quality limited water or its tributaries. The evaluation shall include:

- 1. The next planned infrastructure, resurfacing or redevelopment activity planned for the property (if applicable) OR planned retrofit date;
- 2. The estimated cost of redevelopment or retrofit BMPs; and
- 3. The engineering and regulatory feasibility of redevelopment or retrofit BMPs.
- ii. The permittee shall provide a listing of planned structural BMPs and a plan and schedule for implementation in the year 5 annual report. The permittee shall plan and install a minimum of one structural BMP as a demonstration project within the drainage area of the water quality limited water or its tributaries within six years of the permit effective date. The demonstration project shall be installed targeting a catchment with high phosphorus load potential. The permittee shall install the remainder of the structural BMPs in accordance with the plan and schedule provided in the year 5 annual report.
- iii. Any structural BMPs installed in the urbanized area by the permittee or its agents shall be tracked and the permittee shall estimate the phosphorus removal by the BMP consistent with Attachment 3 to Appendix F. The permittee shall document the BMP type, total area treated by the BMP, the design storage volume of the BMP and the estimated phosphorus removed in mass per year by the BMP in each annual report.

Municipality	Receiving Water	TMDL Name
Attleboro	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Omega Pond and	
	Turner Reservoir	
North	Upper Ten Mile	Total Maximum Daily Load
Attleborough	River, Lower Ten	Analysis For The Ten
_	Mile River,	Mile River Watershed
	Central Pond,	
	Omega Pond and	
	Turner Reservoir	
Plainville	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Omega Pond and	
	Turner Reservoir	
Rehoboth	Upper Kikemuit	Fecal Coliform and Total
	River, Kickemuit	Phosphorus
	River, Kickemuit	TMDLs:
	Reservoir	

Municipality	Receiving Water	TMDL Name
		Kickemuit Reservoir, Rhode
		Island (RI0007034L-01)
		Upper Kickemuit River (RI
		0007034R-01)
		Kickemuit River (MA 61-
		08_2004)
Seekonk	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Omega Pond and	
	Turner Reservoir	
Swansea	Upper Kikemuit	Fecal Coliform and Total
	River, Kickemuit	Phosphorus
	River, Kickemuit	TMDLs:
	Reservoir	Kickemuit Reservoir, Rhode
		Island (RI0007034L-01)
		Upper Kickemuit River (RI
		0007034R-01)
		Kickemuit River (MA 61-
		08_2004)

Table F-12: Municipalities in Massachusetts identified in the TMDLs as containing MS4s contributing phosphorus to the impaired waterbody segments in Rhode Island, the impaired receiving water, and the approved TMDL name.

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part B.II.1. as follows:
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of phosphorus are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part B.II.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part B.II.1 to date to reduce phosphorus in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part B.II.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

III. Bacteria and Pathogen TMDL Requirements

There are currently six approved bacteria (fecal coliform bacteria) or pathogen (fecal coliform and/or enterococcus bacteria) TMDLs for certain waterbody segments in Rhode Island that identify urban stormwater discharges in Massachusetts as sources that are contributing bacteria or pathogens to the impaired segments. The TMDLs include the Kickemuit Reservoir, Upper Kikemuit River, Ten Mile River, Lower Ten Mile River and Omega Pond TMDLs¹⁹ Table F-13 lists municipalities in Massachusetts identified in the TMDLs as containing MS4s contributing bacteria or pathogens to the impaired waterbody segments in Rhode Island,, the impaired receiving water, and the approved TMDL name. Any permittee (traditional or non-traditional) that operates an MS4 in a municipality listed in Table F-13 and that discharges to a waterbody or a tributary of a waterbody listed on Table F-13 is subject to the requirements of this part.

- Traditional and non-traditional MS4s operating in the municipalities identified in Table F-13 and that discharge to a waterbody or a tributary of a waterbody identified on Table F-13 shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below::
 - a. Enhanced BMPs
 - i. Enhancement of BMPs required by part 2.3 of the permit that shall be implemented during this permit term:
 - 1. part 2.3.3. Public Education: The permittee shall supplement its Residential program with an annual message encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee or its agents shall disseminate educational materials to dog owners at the time of issuance or renewal of a dog license, or other appropriate time. Education materials shall describe the detrimental impacts of improper management of pet waste, requirements for waste collection and disposal, and penalties for non-compliance. The permittee shall also provide information to owners of septic systems about proper maintenance in any catchment that discharges to a water body impaired for bacteria or pathogens. All public education messages can be combined with requirements of Appendix H part I, II and III as well as Appendix F part A.III, A.IV, A.V, B.I, and B.II where appropriate.
 - 2. part 2.3.4 Illicit Discharge: Catchments draining to any waterbody impaired for bacteria or pathogens shall be designated either Problem Catchments or HIGH priority in implementation of the IDDE program.

¹⁹ See <u>http://www.dem.ri.gov/programs/benviron/water/quality/rest/reports.htm</u> for all RI TMDL documents. (retrieved 6/30/2014)

Municipality	Receiving Water	TMDL Name
Attleboro	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Omega Pond	
North	Upper Ten Mile	Total Maximum Daily Load
Attleborough	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Omega Pond	
Plainville	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Omega Pond	
Rehoboth	Upper Kikemuit	Fecal Coliform and Total
	River, Kickemuit	Phosphorus
	Reservoir	TMDLs:
		Kickemuit Reservoir, Rhode
		Island (RI0007034L-01)
		Upper Kickemuit River (RI
		0007034R-01)
		Kickemuit River (MA 61-
		08_2004)
Seekonk	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Omega Pond	

Table F-13: Municipalities in Massachusetts identified in the TMDLs as containing MS4s contributing bacteria or pathogens to the impaired waterbody segments in Rhode Island,, the impaired receiving water, and the approved TMDL name

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part B.III.1. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of bacteria/pathogens are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL
 - b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part B.III.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part B.III.1 to date to reduce bacteria/pathogens in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix F part B.III.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation

of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

IV. Metals TMDL Requirements

There are currently five approved metals TMDL for a waterbody segment in Rhode Island that that identifies urban stormwater discharges in Massachusetts as sources that are contributing metals (Cadmium, Lead, Aluminum, Iron) to the impaired segment. The TMDLs include the Upper Ten Mile River, Lower Ten Mile River, Central Pond, Turner Reservoir and Omega Pond TMDLs.²⁰ Table F-14 lists municipalities in Massachusetts identified in the TMDLs as containing MS4s contributing metals to the impaired waterbody segments in Rhode Island, the impaired receiving water, the approved TMDL name, and the pollutant of concern. Any permittee (traditional or non-traditional) that operates an MS4 in a municipality listed in Table F-14 and the discharge is to a waterbody or tributary of a waterbody listed on Table F-14 is subject to the requirements of this part.

- Traditional and non-traditional MS4s operating in the municipalities identified in Table F-14 and that discharge to a waterbody or a tributary of a waterbody identified on Table F-14 shall identify and implement BMPs designed to reduce metals discharges from its MS4. To address metals discharges, each permittee shall comply with the following BMPs in addition to the requirements of part 2.3 of the Permit, as described below:
 - a. Enhanced BMPs
 - i. The permittee remains subject to the requirements of part 2.3. of the permit and shall include the following enhancements to the BMPs required by part 2.3 of the permit:
 - 1. part 2.3.6, Stormwater Management in New Development and Redevelopment: stormwater management systems designed on commercial and industrial land use area draining to the water quality limited waterbody shall incorporate designs that allow for shutdown and containment where appropriate to isolate the system in the event of an emergency spill or other unexpected event. EPA also encourages the permittee to require any stormwater management system designed to infiltrate stormwater on commercial or industrial sites to provide the level of pollutant removal equal to or greater than the level of pollutant removal provided through the use of biofiltration of the same volume of runoff to be infiltrated, prior to infiltration.
 - 2. part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: increased street sweeping frequency of all municipal owned streets and parking lots to a schedule determined by the permittee to target areas with potential for high pollutant loads. This may include, but is not limited to, increased street sweeping frequency in commercial areas and high density residential areas, or

²⁰ See <u>http://www.dem.ri.gov/programs/benviron/water/quality/rest/reports.htm</u> for all RI TMDL documents. (retrieved 6/30/2014)

drainage areas with a large amount of impervious area. Prioritize inspection and maintenance for catch basins to ensure that no sump shall be more than 50 percent full. Clean catch basins more frequently if inspection and maintenance activities indicate excessive sediment or debris loadings. Each annual report shall include the street sweeping schedule determined by the permittee to target high pollutant loads.

Municipality	Receiving Water	TMDL Name
Attleboro	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Turner Reservoir,	
	Omega Pond	
North	Upper Ten Mile	Total Maximum Daily Load
Attleborough	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Turner Reservoir,	
	Omega Pond	
Plainville	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Turner Reservoir,	
	Omega Pond	
Seekonk	Upper Ten Mile	Total Maximum Daily Load
	River, Lower Ten	Analysis For The Ten
	Mile River,	Mile River Watershed
	Central Pond,	
	Turner Reservoir,	
	Omega Pond	

Table F-14: Municipalities in Massachusetts identified in the TMDLs as containing MS4s contributing metals to the impaired waterbody segments in Rhode Island, the impaired receiving water, the approved TMDL name, and the pollutant of concern.

- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix F part B.IV.1. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The applicable TMDL has been modified, revised or withdrawn and EPA has approved a new TMDL applicable for the receiving water that indicates that no additional stormwater controls for the control of metals (Cadmium, Lead, Aluminum, Iron) are necessary for the permittee's discharge based on wasteload allocations in the newly approved TMDL

- b. In such a case, the permittee shall document the date of the approved TMDL in its SWMP and is relieved of any remaining requirements of Appendix F part B.IV.1 as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix F part B.IV.1 to date to reduce metals (Cadmium, Lead, Aluminum, Iron) in their discharges including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - The permittee shall continue to implement all requirements of Appendix F part B.IV.1 required to be implemented prior to the date of the newly approved TMDL, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

C. Requirements for Discharges to Impaired Waters with a Regional TMDL

I. The "Northeast Regional Mercury TMDL (2007)"

The Northeast Regional Mercury TMDL does not specify a wasteload allocation or other requirements either individually or categorically for the MS4 discharges and specifies that load reductions are to be achieved through reduction in atmospheric deposition sources. No requirements related to this TMDL are imposed on MS4 discharges under this part. However, if the permittee becomes aware, or EPA or MassDEP determines, that an MS4 discharge is causing or contributing to such impairment to an extent that cannot be explained by atmospheric deposition (e.g. chemical spill, acid landfill leachate or other sources), the permittee shall comply with the requirements of part 2.1.1.d and 2.3.4 of the permit.

ATTACHMENT 1 TO APPENDIX F

Method to Calculate Baseline Phosphorus Load (Baseline), Phosphorus Reduction Requirements and Phosphorus load increases due to development (P_{DEVinc})

The methods and annual phosphorus load export rates presented in Attachments 1, 2 and 3 are for the purpose of measuring load reductions for various stormwater BMPs treating runoff from different site conditions (i.e. impervious or pervious) and land uses (e.g. commercial, industrial, residential). The estimates of annual phosphorus load and load reductions due to BMPs are intended for use by the permittee to measure compliance with its Phosphorus Reduction Requirement under the permit.

This attachment provides the method to calculate a baseline phosphorus load discharging in stormwater for the impaired municipalities subject to Lakes and Ponds TMDL. A complete list of municipalities subject to these TMDLs is presented in Appendix F, Table F-6. This method shall be used to calculate the following annual phosphorus loads:

- 1) Baseline Phosphorus Load for Permittees
- 2) Phosphorus Reduction Requirement

This attachment also provides the method to calculate stormwater phosphorus load increases due to development for the municipalities subject to the Charles River TMDL requirements and the Lakes & Ponds TMDL requirements:

3) Phosphorus Load Increases due to Development

The **Baseline Phosphorus Load** is a measure of the annual phosphorus load discharging in stormwater from the impervious and pervious areas of the impaired Lake Phosphorus Control Plan (LPCP) Area.

The **Baseline Phosphorus Pounds Reduction** referred to as the permittee's **Phosphorus Reduction Requirement** represents the required reduction in annual phosphorus load in stormwater to meet the WLA for the impaired watershed. The percent phosphorus reduction for each watershed (identified in Appendix F, Table F-6) is applied to the Baseline Phosphorus Load to calculate the Phosphorus Pounds Reduction.

The **Phosphorus load increases due to development** (P_{DEVinc}) is the stormwater phosphorus load increases due to development over the previous reporting period and incurred to date. Increases in stormwater phosphorus load from development will increase the permittee's baseline phosphorus load and therefore, the phosphorus reduction requirement.

Examples are provided to illustrate use of the methods. Table 1-1 below provides annual composite phosphorus load export rates (PLERs) by land use category for the Baseline Load and Phosphorus Reduction Requirement calculations. The permittee shall select the land use category that most closely represents the actual use of the watershed. For watersheds with institutional type uses, such as government properties, hospitals, and schools, the permittee shall use the commercial land use category for the purpose of calculating phosphorus loads. Table 1-2 provides annual PLERs by land use category for impervious and pervious areas. The permittee shall select the land use category that most closely represents the actual use of the watershed. For pervious areas, if the hydrologic soil group (HSG) is known, use the appropriate value. If the HSG is not known, assume HSG C conditions for the phosphorus load export rate. For watersheds with

institutional type uses, such as government properties, hospitals, and schools, the permittee shall use the commercial/industrial land use category for the purpose of calculating phosphorus loads. Table 1-3 provides a crosswalk table of land use codes between Tables 1-1 and 1-2 and the codes used by MassGIS.

The composite PLERs in Table 1-1 to be used for calculating Baseline Phosphorus Load are based on the specified directly connected impervious area (DCIA). If the permittee determines through mapping and site investigations that the overall DCIA for the collective area for each land use category is different than the corresponding values in Table 1-1, then the permittee is encouraged to submit this information in its annual report and request EPA to recalculate the composite PLERs for the permittees to use in refining the Baseline Phosphorus Load calculation for the LPCP.

(1) **Baseline Phosphorus Load:** The permittee shall calculate the **Baseline Phosphorus Load** by the following procedure:

- 1) Determine the total area (acre) associated with the impaired watershed;
- 2) Sort the total area associated with the watershed into land use categories;
- 3) Calculate the annual phosphorus load associated with each land use category by multiplying the total area of land use by the appropriate land use-based composite phosphorus load export rate provided in Table 1-1; and
- 4) Determine the Baseline Phosphorus Load by summing the land use loads.

Example 1-1 to determine Baseline Phosphorus Load:

Watershed A is 18.0 acres, with 11.0 acres of industrial area (e.g. access drives, buildings, and parking lots), 3.0 acres of medium-density residential and 4.0 acres of unmanaged wooded area.
The Baseline Phosphorus Load = (Baseline P Load $_{IND}$) + (Baseline P Load $_{MDR}$) + (Baseline P Load $_{FOR}$)
Where:Baseline P Load $_{IND} = (TA_{IND}) x$ (PLER for industrial use (Table 1-1))= 11.0 acre x 1.27 lbs/acre/year= 14.0 lbs P/year
Baseline P Load $_{MDR} = (TA_{MDR}) x$ (PLER for medium density residential (Table 1-1)) = 3.0 acre x 0.49 lbs/acre/year = 1.5 lbs P/year
Baseline P Load $_{FOR} = (TA_{FOR}) x$ (PLER for forest (Table 1-1)) = 4.0 acre x 0.12 lbs/acre/year = 0.5 lbs P/year
Baseline Phosphorus Load = 14.0 lbs P/year + 1.5 lbs P/year + 0.5 lbs P/year = 16.0 lbs P/year

(2) Baseline Phosphorus Pounds Reduction (Phosphorus Reduction Requirement): The Baselines Phosphorus Reduction requirement is the amount of reduction in annual phosphorus load (in pounds) that the permittee is required to achieve in the Watershed. The permittee shall calculate the Phosphorus Reduction Requirement by multiplying the Baseline Phosphorus Load by the applicable percent phosphorus reduction for that watershed specified in Table F-6 (Appendix F).

Example 1-2 to determine Watershed Phosphorus Reduction Requirement: Table F-6 identifies Watershed A's percent phosphorus reduction as 45%; therefore th Watershed Phosphorus Reduction Requirement is:			
Phosphorus Reduction Requirement	= (Baseline Phosphorus Load) x (0.45) = (16.0 lbs P/year) x (0.45) = 7.2 lbs P/year		

(3) Phosphorus load increases due to development (P_{DEVinc}): To estimate the increases in stormwater phosphorus load due to development in the Watershed (either PCP or LPCP Area), the permittee will use the following procedure:

- 1) Determine the total area of development by land use category and calculate the baseline load from that area using the composite PLERs in Table 1-1;
- 2) Distribute the total development area into impervious and pervious subareas by land use category;
- 3) Calculate the phosphorus load due to development (P_{DEV}) for each land use-based impervious and pervious subarea by multiplying the subarea by the appropriate phosphorus load export rate provided in Table 1-2; and
- 4) Determine the phosphorus load increase (P_{DEVinc}) by subtracting the baseline phosphorus load from the increased phosphorus load due to development.

Note: If structural BMPs are installed as part of new development, the P_{DEVinc} will be reduced by the amount of BMP load treated by that BMP as calculated in Attachment 3.

Example 1-3 to determine Phosphorus Load Increases: For the same 15.11 acre	
Watershed A as specified in Example 1-1, a permittee has tracked development in the	
LPCP Area in the last year that resulted in 1.5 acres of medium density residential area	
and 0.5 acres of forest land being converted to high density residential impervious area as	
detailed below. The undeveloped MDR area is pervious area, HSG C soil and the	
undeveloped forest area is pervious, HSG B soil.	

Land Use Category	Baseline Area (acres)	P export rate (lbs P/acre/yr)*	Baseline area unchanged (acres)	P export rate (lbs P/acre/yr)**	Developed Area converted to HDR IA (acres)	P export rate (lbs P/acre/yr)**
Industrial	11.0	1.27	No change		No change	
MDR	3.0	0.49	1.5	0.21	1.5	2.32

Forest	4.0	0.12	3.5	0.12	0.5	2.32
	*From Table 1-1; ** From Table 1-2					
	The phosp	horus load increa	se is calculate	d as:		
	Baseline L	oad = (Baseline J)	P Load IND) +			
		(Baseline P	Load $_{MDR}$) +			
		(Baseline P	Load FOR)			
		= 16.0 lb/y	ear (determine	ed in Example 1-1	.)	
		-		*		
	$P_{DEV} = 0$	TAND X PLERN	$(\mathbf{I}\mathbf{A}_{\text{UDB}} \times \mathbf{P})$	I ERupp)+(PAMp	$x PLER_{MDP}) + (PA)$	COR X
	$PI = (TT_{IND} \times TEET_{IND}) + (TT_{HDR} \times TEET_{HDR}) + (TT_{MDR} \times TEET_{MDR}) + (TT_{HDR} \times TEET_{HDR})$					OK A
		$(11.0.000 \times 1.7)$	(2, 0, 0)	(22) + (15)	5 a a r a * 0.21) + (25*
	_	$(11.0 \text{ acres}^{-1.2})$	(2.0 act)	$(1.5)^{+}($	$(-1)^{-1} = (-1)$	5.5
		(0.12)				
	= 19.0 lbs P/year					
	$\mathbf{P}_{DEVinc} = \mathbf{I}$	P _{DEV} – Baseline I	Load			
	= 2	19.0 – 16.0				
	= 3	3.0 lbs/year				

Land Cover	Representative DCIA, %	Composite PLERs, lb/ac/yr	Composite PLERs, kg/ha/yr
Commercial	57	1.13	1.27
Industrial	67	1.27	1.42
High Density Residential	36	1.04	1.16
Medium Density Residential	16	0.49	0.55
Low Density Residential	11	0.30	0.34
Freeway	44	0.73	0.82
Open Space	8	0.26	0.29
Agriculture	0.4	0.45	0.50
Forest	0.1	0.12	0.13

Table 1-1. Annual composite phosphorus load export rates

Phosphorus Source Category by Land Use	Land Surface Cover	P Load Export Rate, lbs/acre/year	P Load Export Rate, kg/ha/yr	
Commercial (Com) and	Directly connected impervious	1.78	2.0	
Industrial (Ind)	Pervious	See* DevPERV	See* DevPERV	
Multi-Family (MFR) and High-Density Residential	Directly connected impervious	2.32	2.6	
(HDR)	Pervious	See* DevPERV	See* DevPERV	
Medium -Density	Directly connected impervious	1.96	2.2	
	Pervious	See* DevPERV	See* DevPERV	
Low Density Residential	Directly connected impervious	1.52	1.7	
(LDK) - Kulai	Pervious	See* DevPERV	See* DevPERV	
Highway (HWY)	Directly connected impervious	1.34	1.5	
	Pervious	See* DevPERV	See* DevPERV	
Forest (For)	Directly connected impervious	1.52	1.7	
	Pervious	0.13	0.13	
Open Land (Open)	Directly connected impervious	1.52	1.7	
	Pervious	See* DevPERV	See* DevPERV	
Agriculture (Ag)	Directly connected impervious	1.52	1.7	
	Pervious 0.45		0.5	
*Developed Land Pervious (DevPERV)- Hydrologic Soil Group A	Pervious	0.03	0.03	
*Developed Land Pervious (DevPERV)- Hydrologic Soil Group B	Pervious	0.12	0.13	
*Developed Land Pervious (DevPERV) - Hydrologic Soil Group C	Pervious	0.21	0.24	
*Developed Land Pervious (DevPERV) - Hydrologic Soil Group C/D	Pervious	0.29	0.33	
*Developed Land Pervious (DevPERV) - Hydrologic Soil Group D	Pervious	0.37	0.41	

 Table 1-2: Proposed average annual distinct P Load export rates for use in estimating P Load reduction credits the MA MS4 Permit

Table 1-3: Crosswalk of MassGIS land-use categories to land-use groups for P Load Calculations

Mass GIS Land Use LU_CODE	Description	Land Use group for calculating P Load - 2013/14 MA MS4
1	Crop Land	Agriculture
2	Pasture (active)	Agriculture
3	Forest	Forest
4	Wetland	Forest
5	Mining	Industrial
6	Open Land includes inactive pasture	open land
7	Participation Recreation	open land
8	spectator recreation	open land
9	Water Based Recreation	open land
10	Multi-Family Residential	High Density Residential
11	High Density Residential	High Density Residential
12	Medium Density Residential	Medium Density Residential
13	Low Density Residential	Low Density Residential
14	Saltwater Wetland	Water
15	Commercial	Commercial
16	Industrial	Industrial
17	Urban Open	open land
18	Transportation	Highway
19	Waste Disposal	Industrial
20	Water	Water
23	cranberry bog	Agriculture
24	Powerline	open land
25	Saltwater Sandy Beach	open land
26	Golf Course	Agriculture
29	Marina	Commercial
31	Urban Public	Commercial
34	Cemetery	open land
35	Orchard	Forest
36	Nursery	Agriculture
37	Forested Wetland	Forest
38	Very Low Density residential	Low Density Residential
39	Junkyards	Industrial
40	Brush land/Successional	Forest

ATTACHMENT 2 TO APPENDIX F

Phosphorus Reduction Credits for Selected Enhanced Non-Structural BMPs

The permittee shall use the following methods to calculate phosphorus load reduction credits for the following enhanced non-structural control practices implemented in the Watershed:

- 1) Enhanced Sweeping Program;
- 2) Catch Basin Cleaning;
 - and
- 3) Organic Waste and Leaf Litter Collection program

The methods include the use of default phosphorus reduction factors that EPA has determined are acceptable for calculating phosphorus load reduction credits for these practices.

The methods and annual phosphorus load export rates presented in this attachment are for the purpose of counting load reductions for various BMPs treating storm water runoff from varying site conditions (i.e., impervious or pervious surfaces) and different land uses (e.g. industrial and commercial) within the impaired watershed. Table 2-1 below provides annual phosphorus load export rates by land use category for impervious and pervious areas. The estimates of annual phosphorus load and load reductions resulting from BMP implementation are intended for use by the permittee to measure compliance with its Phosphorus Reduction Requirement under the permit.

Examples are provided to illustrate use of the methods. In calculating phosphorus export rates, the permittee shall select the land use category that most closely represents the actual use for the area in question. For watersheds with institutional type uses, such as government properties, hospitals, and schools, the permittee shall use the commercial land use category for the purpose of calculating phosphorus loads. Table 2-2 provides a crosswalk table of land use codes between land use groups in Table 2-1 and the codes used by Mass GIS. For pervious areas, permittees should use the appropriate value for the hydrologic soil group (HSG) if known, otherwise, assume HSG C conditions.

<u>Alternative Methods and/or Phosphorus Reduction Factors</u>: A permittee may propose alternative methods and/or phosphorus reduction factors for calculating phosphorus load reduction credits for these non-structural practices. EPA will consider alternative methods and/or phosphorus reduction factors, provided that the permittee submits adequate supporting documentation to EPA. At a minimum, supporting documentation shall consist of a description of the proposed method, the technical basis of the method, identification of alternative phosphorus reduction factors, supporting calculations, and identification of references and sources of information that support the use of the alternative method and/or factors in the Watershed. If EPA determines that the alternative methods and/or factors are not adequately supported, EPA will notify the permittee and the permittee may receive no phosphorus reduction credit other than a reduction credit calculated by the permittee following the methods in this attachment for the identified practices.

Phosphorus Source Category by Land Use	Land Surface Cover	P Load Export Rate, lbs/acre/year	P Load Export Rate, kg/ha/yr
Commercial (Com) and Industrial	Directly connected impervious	1.78	2.0
(Ind)	Pervious	See* DevPERV	See* DevPERV
Multi-Family (MFR) and High-	Directly connected impervious	2.32	2.6
Delisity Residential (HDR)	Pervious	See* DevPERV	See* DevPERV
Medium -Density Residential	Directly connected impervious	1.96	2.2
(MDR)	Pervious	See* DevPERV	See* DevPERV
Low Density Residential (LDR) -	Directly connected impervious	1.52	1.7
Rufai	Pervious	See* DevPERV	See* DevPERV
Highway (HWY)	Directly connected impervious	1.34	1.5
	Pervious	See* DevPERV	See* DevPERV
Forest (For)	Directly connected impervious	1.52	1.7
	Pervious	0.13	0.13
Open Land (Open)	Directly connected impervious	1.52	1.7
	Pervious	See* DevPERV	See* DevPERV
Agriculture (Ag)	Directly connected impervious	1.52	1.7
	Pervious	0.45	0.5
*Developed Land Pervious (DevPERV) – HSG A	Pervious	0.03	0.03
*Developed Land Pervious (DevPERV) – HSG B	Pervious	0.12	0.13
*Developed Land Pervious (DevPERV) – HSG C	Pervious	0.21	0.24
*Developed Land Pervious (DevPERV) – HSG C/D	Pervious	0.29	0.33
*Developed Land Pervious (DevPERV) – HSG D	Pervious	0.37	0.41

Table 2-1: Proposed average annual distinct P Load export rates for use in estimating P Load reduction credits in the MA MS4 Permit

Notes:

• For pervious areas, if the hydrologic soil group (HSG) is known, use the appropriate value from this table. If the HSG is not known, assume HSG C conditions for the phosphorus load export rate.

• Agriculture includes row crops. Actively managed hay fields and pasture lands. Institutional land uses such as government properties, hospitals and schools are to be included in the commercial and industrial land use grouping for the purpose of calculating phosphorus loading.

• Impervious surfaces within the forest land use category are typically roadways adjacent to forested pervious areas.

Mass GIS Land Use LU_CODE	Description	Land Use group for calculating P Load - 2013/14 MA MS4
1	Crop Land	Agriculture
2	Pasture (active)	Agriculture
3	Forest	Forest
4	Wetland	Forest
5	Mining	Industrial
6	Open Land includes inactive pasture	open land
7	Participation Recreation	open land
8	spectator recreation	open land
9	Water Based Recreation	open land
10	Multi-Family Residential	High Density Residential
11	High Density Residential	High Density Residential
12	Medium Density Residential	Medium Density Residential
13	Low Density Residential	Low Density Residential
14	Saltwater Wetland	Water
15	Commercial	Commercial
16	Industrial	Industrial
17	Urban Open	open land
18	Transportation	Highway
19	Waste Disposal	Industrial
20	Water	Water
23	cranberry bog	Agriculture
24	Powerline	open land
25	Saltwater Sandy Beach	open land
26	Golf Course	Agriculture
29	Marina	Commercial
31	Urban Public	Commercial
34	Cemetery	open land
35	Orchard	Forest
36	Nursery	Agriculture
37	Forested Wetland	Forest
38	Very Low Density residential	Low Density Residential
39	Junkyards	Industrial
40	Brush land/Successional	Forest

 Table 2-2: Crosswalk of Mass GIS land use categories to land use groups for P load calculations

(1) Enhanced Sweeping Program: The permittee may earn a phosphorus reduction credit for conducting an enhanced sweeping program of impervious surfaces. Table 2-2 below outlines the default phosphorus removal factors for enhanced sweeping programs. The credit shall be calculated by using the following equation:

Credit sweeping = IA swept x PLE $_{IC-land use}$ x PRF sweeping x AF (Equation 2-1)

Where:

Credit sweeping	=	Amount of phosphorus load removed by enhanced sweeping
		program (lb/year)
IA swept	=	Area of impervious surface that is swept under the enhanced
		sweeping program (acres)
PLE IC-land use	=	Phosphorus Load Export Rate for impervious cover and specified
		land use (lb/acre/yr) (see Table 2-1)
PRF sweeping	=	Phosphorus Reduction Factor for sweeping based on sweeper type
		and frequency (see Table 2-3).
AF	=	Annual Frequency of sweeping. For example, if sweeping does
		not occur in Dec/Jan/Feb, the AF would be 9 mo./12 mo. = 0.75 .
		For year-round sweeping, $AF=1.0^{1}$

As an alternative, the permittee may apply a credible sweeping model of the Watershed and perform continuous simulations reflecting build-up and wash-off of phosphorus using long-term local rainfall data.

Frequency ¹	Sweeper Technology	PRF sweeping
2/year (spring and fall) ²	Mechanical Broom	0.01
2/year (spring and fall) ²	Vacuum Assisted	0.02
2/year (spring and fall) ²	High-Efficiency Regenerative Air-Vacuum	0.02
Monthly	Mechanical Broom	0.03
Monthly	Vacuum Assisted	0.04
Monthly	High Efficiency Regenerative Air-Vacuum	0.08
Weekly	Mechanical Broom	0.05
Weekly	Vacuum Assisted	0.08
Weekly	High Efficiency Regenerative Air-Vacuum	0.10

Table 2-3: Phosphorus reduction efficiency factors(PRFsweeping) for sweeping impervious areas

¹For full credit for monthly and weekly frequency, sweeping must be conducted year round. Otherwise, the credit should be adjusted proportionally based on the duration of the sweeping season (using AF factor).

² In order to earn credit for semi-annual sweeping the sweeping must occur in the spring following snowmelt and road sand applications to impervious surfaces and in the fall after leaf-fall and prior to the onset to the snow season.

Example 2-1: Calculation of enhanced sweeping program credit (Credit _{sweeping}): A permittee proposes to implement an enhanced sweeping program and perform weekly sweeping from March 1 – December 1 (9 months) in their Watershed, using a vacuum assisted sweeper on 20.3 acres of parking lots and roadways in a high-density residential area of the Watershed. For this site the needed information is:

IA swept	= 20.3 acres
PLE IC-HDR	= 2.32 lb/acre/yr (from Table 2-1)
PRF sweeping	= 0.08 (from Table 2-3)
AF	= (9 months / 12 months) = 0.75

Substitution into equation 2-1 yields a Credit _{sweeping} of 3.2 pounds of phosphorus removed per year.

Credit sweeping	= IA swept x PLE land use x PRF sweeping x AF
	= 20.3 acres x 2.32 lbs/acre/yr x 0.08 x 0.75
	= 2.8 lbs/yr

(2) Catch Basin Cleaning: The permittee may earn a phosphorus reduction credit, Credit $_{CB}$, by removing accumulated materials from catch basins (i.e., catch basin cleaning) in the Watershed such that a minimum sump storage capacity of 50% is maintained throughout the year. The credit shall be calculated by using the following equation:

Credit $_{CB} = IA_{CB} x PLE _{IC-land use} x PRF_{CB}$

(Equation 2-2)

Where:

VV HCI CI		
Credit _{CB}	=	Amount of phosphorus load removed by catch basin cleaning
		(lb/year)
IA _{CB}	=	Impervious drainage area to catch basins (acres)
PLE IC-and use	=	Phosphorus Load Export Rate for impervious cover and specified
		land use (lb/acre/yr) (see Table 2-1)
PRF _{CB}	=	Phosphorus Reduction Factor for catch basin cleaning
		(see Table 2-4)

Table 2-4: Phosphorus reduction efficiency factor (PRF CB) for semi-annual catchbasin cleaning

Frequency	Practice	PRF _{CB}
Semi-annual	Catch Basin Cleaning	0.02

Example 2-2: Calculation for catch basin cleaning credit (Credit <u>CB</u>):

A permittee proposes to clean catch basins in their Watershed (i.e., remove accumulated sediments and contaminants captured in the catch basins) that drain runoff from 15.3 acres of medium-density residential impervious area. For this site the needed information is:

IACB	= 15.3 acre
PLE IC-MDR	= 1.96 lbs/acre/yr (from Table 2-1)
PRF CB	= 0.02 (from Table 2-4)

Substitution into equation 2-2 yields a Credit $_{CB}$ of 0.6 pounds of phosphorus removed per year:

Credit _{CB}	$= IA_{CB} x PLE_{IC-MDR} x PRF_{CB}$
	= 15.3 acre x 1.96 lbs/acre/yr x 0.02
	= 0.6 lbs/yr

(3) Enhanced Organic Waste and Leaf Litter Collection program: The permittee may earn a phosphorus reduction credit by performing regular gathering, removal and disposal of landscaping wastes, organic debris, and leaf litter from impervious surfaces from which runoff discharges to the TMDL waterbody or its tributaries. In order to earn this credit (Credit leaf litter), the permittee must gather and remove all landscaping wastes, organic debris, and leaf litter from impervious roadways and parking lots at least once per week during the period of September 1 to December 1 of each year. Credit can only be earned for those impervious surfaces that are cleared of organic materials in accordance with the description above. The gathering and removal shall occur immediately following any landscaping activities in the Watershed and at additional times when necessary to achieve a weekly cleaning frequency. The permittee must ensure that the disposal of these materials will not contribute pollutants to any surface water discharges. The permittee may use an enhanced sweeping program (e.g., weekly frequency) as part of earning this credit provided that the sweeping is effective at removing leaf litter and organic materials. The Credit leaf litter shall be determined by the following equation:

Credit $_{leaf litter} = (Watershed Area) \times (PLE_{IC-land use}) \times (0.05)$ (Equation 2-3)

W/horo	
VV HULU	•

Credit leaf litter	= Amount of phosphorus load reduction credit for organic
	waste and leaf litter collection program (lb/year)
Watershed Area	= All impervious area (acre) from which runoff discharges to the
	TMDL waterbody or its tributaries in the Watershed
PLE IC-land use	= Phosphorus Load Export Rate for impervious cover and
	specified land use (lbs/acre/yr) (see Table 2-1)
0.05	= 5% phosphorus reduction factor for organic
	waste and leaf litter collection program in the Watershed

Example 2-3: Calculation for organic waste and leaf litter collection program credit (Credit leaf litter): A permittee proposes to implement an organic waste and leaf litter collection program by sweeping the parking lots and access drives at a minimum of once per week using a mechanical broom sweeper for the period of September 1 to December 1 over 12.5 acres of impervious roadways and parking lots in an industrial/commercial area of the Watershed. Also, the permittee will ensure that organic materials are removed from impervious areas immediately following all landscaping activities at the site. For this site the needed information to calculate the Credit leaf litter is:

Watershed Area	= 12.5 acres; and
PLE IC-commercial	= 1.78 lbs/acre/yr (from Table 2-1)

Substitution into equation 2-4 yields a Credit _{leaf litter} of 1.1 pounds of phosphorus removed per year:

Credit leaf litter = (12.5 acre) x (1.78 lbs/acre/yr) x (0.05) = 1.1 lbs/yr

The permittee also may earn a phosphorus reduction credit for enhanced sweeping of roads and parking lot areas (i.e., Credit _{sweeping}) for the three months of use. Using equation 2-1, Credit _{sweeping} is:

Substitution into equation 2-1 yields a Credit $_{\text{sweeping}}$ of 0.28 pounds of phosphorus removed per year.

Credit sweeping = IA swept x PLE _{IC-commercial} x PRF sweeping x AF = 12.5 acre x 1.78 lbs/acre/yr x 0.05 x 0.25 = **0.3 lbs/yr**

ATTACHMENT 3 TO APPENDIX F

<u>Methods to Calculate Phosphorus Load Reductions for Structural Stormwater Best</u> <u>Management Practices</u>

List of Tables:

Table 3-1: Average annual distinct phosphorus load (P Load) export rates for use in estimatin	ng
phosphorus load reduction credits the MA MS4 Permit	10
Table 3-2: MassGIS land-use categories with associated land-use groups for phosphorus load	1
calculations	11
Table 3- 3: Developed Land Pervious Area Runoff Depths based on Precipitation depth and	
Hydrological Soil Groups (HSGs)	20
Table 3- 4: Infiltration Trench (IR = 0.17 in/hr) BMP Performance Table	34
Table 3- 5: Infiltration Trench (IR = 0.27 in/hr) BMP Performance Table	35
Table 3- 6: Infiltration Trench (IR = 0.52 in/hr) BMP Performance Table	36
Table 3- 7: Infiltration Trench (IR = 1.02 in/hr) BMP Performance Table	37
Table 3- 8: Infiltration Trench (IR = 2.41 in/hr) BMP Performance Table	38
Table 3- 9: Infiltration Trench (8.27 in/hr) BMP Performance Table	39
Table 3- 10: Infiltration Basin (0.17 in/hr) BMP Performance Table	40
Table 3- 11: Infiltration Basin (0.27 in/hr) BMP Performance Table	41
Table 3- 12: Infiltration Basin (0.52 in/hr) BMP Performance Table	42
Table 3-13: Infiltration Basin (1.02 in/hr) BMP Performance Table	43
Table 3- 14: Infiltration Basin (2.41 in/hr) BMP Performance Table	44
Table 3- 15: Infiltration Basin (8.27 in/hr) BMP Performance Table	45
Table 3- 16: Biofiltration BMP Performance Table	46
Table 3- 17: Gravel Wetland BMP Performance Table	47
Table 3- 18: Porous Pavement BMP Performance Table	48
Table 3- 19: Wet Pond BMP Performance Table	49
Table 3- 20: Dry Pond BMP Performance Table	49
Table 3- 21: Grass Swale BMP Performance Table	50
Table 3-22: Impervious Area Disconnection through Storage: Impervious Area to Pervious A	rea
Ratio = 8:1	51
Table 3-23: Impervious Area Disconnection through Storage: Impervious Area to Pervious A	rea
Ratio = 6:1	53
Table 3-24: Impervious Area Disconnection through Storage: Impervious Area to Pervious A	rea
Ratio = 4:1	56
Table 3-25: Impervious Area Disconnection through Storage: Impervious Area to Pervious A	rea
Ratio = 2:1	58
Table 3- 26: Impervious Area Disconnection through Storage: Impervious Area to Pervious A	rea
Ratio = 1:1	61
Table 3- 27: Impervious Area Disconnection Performance Table	63
Table 3-28: Performance Table for Conversion of Impervious Areas to Pervious Area based	on
Hydrological Soil Groups	64
Table 3- 29: Performance Table for Conversion of Low Permeable Pervious Area to High	
Permeable Pervious Area based on Hydrological Soil Group	65
List of Figures:	

Figure 3-1: BMP Performance Curve: Infiltration Trench (infiltration rate = 0.17 in/hr)	. 34
Figure 3- 2: BMP Performance Curve: Infiltration Trench (infiltration rate = 0.27 in/hr)	. 35
Figure 3- 3: BMP Performance Curve: Infiltration Trench (infiltration rate = 0.52 in/hr)	. 36
Figure 3- 4: BMP Performance Curve: Infiltration Trench (infiltration rate = 1.02 in/hr)	. 37
Figure 3- 5: BMP Performance Curve: Infiltration Trench (infiltration rate = 2.41 in/hr)	. 38
Figure 3- 6: BMP Performance Curve: Infiltration Trench (infiltration rate = 8.27 in/hr)	. 39
Figure 3- 7: BMP Performance Curve: Infiltration Basin (infiltration rate = 0.17 in/hr)	. 40
Figure 3- 8: BMP Performance Curve: Infiltration Basin (infiltration rate = 0.27 in/hr)	. 41
Figure 3- 9: BMP Performance Curve: Infiltration Basin (infiltration rate = 0.52 in/hr)	. 42
Figure 3- 10: BMP Performance Curve: Infiltration Basin (Soil infiltration rate = 1.02 in/hr)	. 43
Figure 3- 11: BMP Performance Curve: Infiltration Basin (infiltration rate = 2.41 in/hr)	. 44
Figure 3- 12: BMP Performance Curve: Infiltration Basin (infiltration rate = 8.27 in/hr)	. 45
Figure 3- 13: BMP Performance Curve: Biofiltration	. 46
Figure 3- 14: BMP Performance Curve: Gravel Wetland	. 47
Figure 3- 15: BMP Performance Curve: Porous Pavement	. 48
Figure 3- 16: BMP Performance Curve: Dry Pond	. 49
Figure 3- 17: BMP Performance Curve: Grass Swale	. 50
Figure 3- 18: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 8:1 for HSG A Soils	. 51
Figure 3- 19: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 8:1 for HSG B Soils	. 52
Figure 3- 20: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 8:1 for HSG C Soils	. 52
Figure 3- 21: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 8:1 for HSG D Soils	. 53
Figure 3- 22: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 6:1 for HSG A Soils	. 54
Figure 3- 23: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 6:1 for HSG B Soils	. 54
Figure 3- 24: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Ratio = 6:1 for HSG C Soils	. 33
Figure 3- 25: Impervious Area Disconnection through Storage: Impervious Area to Pervious	
Area Katio = 6:1 for HSG D Soils	
Figure 3- 26: Impervious Area Disconnection through Storage: Impervious Area to Pervious	50
Area Katio = 4:1 for HSG A Soils	. 36
Figure 3- 27: Impervious Area Disconnection through Storage: Impervious Area to Pervious	57
Area Katio = 4:1 for HSG B Solls	. 57
Figure 3- 28: Impervious Area Disconnection through Storage: Impervious Area to Pervious	57
Area Ratio = 4:1 for HSG C Solls	. 57
rigure 5-29: Impervious Area Disconnection through Storage: Impervious Area to Pervious	50
Alta Kallo – 4.1 IOI HSU D SOIIS	. 38
rigure 5- 50: Impervious Area Disconnection through Storage: Impervious Area to Pervious	50
AICA KAUO- 2.1 IOF HOU A DOIIS	. 39
Area Detion 2:1 for USC D Soils	50
AICa KAUO- 2.1 IOI IIBU B BOIIS	. 39

60
60
61
62
62
63
64

<u>Methods to Calculate Phosphorus Load Reductions for Structural Stormwater Best</u> <u>Management Practices in the Watershed</u>

This attachment provides methods to determine design storage volume capacities and to calculate phosphorus load reductions for the following structural Best Management Practices (structural BMPs) for a Watershed:

- 1) Infiltration Trench;
- 2) Infiltration Basin or other surface infiltration practice;
- 3) Bio-filtration Practice;
- 4) Gravel Wetland System;
- 5) Porous Pavement;
- 6) Wet Pond or wet detention basin;
- 7) Dry Pond or detention basin; and
- 8) Dry Water Quality Swale/ Grass Swale.

Additionally, this attachment provides methods to design and quantify associated phosphorus load reduction credits for the following four types of semi-structural/non-structural BMPs

- 9) Impervious Area Disconnection through Storage (e.g., rain barrels, cisterns, etc);
- 10) Impervious Area Disconnection;
- 11) Conversions of Impervious Area to Permeable Pervious Area; and
- 12) Soil Amendments to Enhance Permeability of Pervious Areas.

Methods and examples are provided in this Attachment to calculate phosphorus load reductions for structural BMPs for the four following purposes:

- 1) To determine the design volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area is 100% impervious;
- 2) To determine the phosphorus load reduction for a structural BMP with a known design volume when the contributing drainage area is 100% impervious;
- To determine the design volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area has impervious and pervious surfaces; and
- 4) To determine the phosphorus load reduction for a structural BMP with a known design volume when the contributing drainage area has impervious and pervious surfaces.

Examples are also provided for estimating phosphorus load reductions associated with the four semi-structural/non-structural BMPs.

Also, this attachment provides the methodology for calculating the annual stormwater phosphorus load that will be delivered to BMPs for treatment (BMP Load) and to be used for quantifying phosphorus load reduction credits. The methods and annual phosphorus export load rates presented in this attachment are for the purpose of counting load reductions for various BMPs treating storm water runoff from varying site conditions (i.e., impervious or pervious surfaces) and different land uses (e.g. commercial and industrial). The estimates of annual phosphorus load and load reductions by BMPs are to demonstrate compliance with the permittee's Phosphorus Reduction Requirement under the permit.

Structural BMP performance credits: For each structural BMP type identified above (BMPs 1-8), long-term cumulative performance information is provided to calculate phosphorus load reductions or to determine needed design storage volumes to achieve a specified reduction target (e.g., 65% phosphorus load reduction). The performance information is expressed as cumulative phosphorus load removed (% removed) depending on the physical storage capacity of the structural BMP (expressed as inches of runoff from impervious area) and is provided at the end of this Attachment (see Tables 3-1 through 3-18 and performance curves Figures 3-1 through 3-17). Multiple tables and performance curves are provided for the infiltration practices to represent cumulative phosphorus load reduction performance for six infiltration rates (IR), 0.17, 0.27, 0.53, 1.02, 2.41, and 8.27 inches/hour. These infiltration rates represent the saturated hydraulic conductivity of the soils. The permittee may use the performance curves provided in this attachment to interpolate phosphorus load removal reductions for field measured infiltration rates that are different than the infiltration rates used to develop the performance curves. Otherwise, the permittee shall use the performance curve for the IR that is nearest, but less than, the field measured rate. Physical storage capacity equals the total physical storage volume of the control structure to contain water at any instant in time. Typically, this storage capacity is comprised of the surface ponding storage volume prior to overflow and subsurface storage volumes in storage units and pore spaces of coarse filter media. Table 3-30 provides the formulae to calculate physical storage capacities for the structural control types for using the performance curves.

Semi-Structural/Non-structural BMP performance credits: For each semi-structural/nonstructural BMP type identified above (BMPs 9-12), long-term cumulative performance information is provided to calculate phosphorus load reductions or to determine needed design specifications to achieve a desired reduction target (e.g., 50% phosphorus load reduction). The performance information is expressed as cumulative runoff volume reduction (% removed) depending on the design specifics and actual field conditions. Cumulative percent runoff volume reduction is being used to estimate the cumulative phosphorus load reduction credit for these BMPs. To represent a wide range of potential conditions for implementing these types of BMPs, numerous performance tables and curves have been developed to reflect a wide range of potential conditions and designs such as varying storage volumes (expressed in terms of varying ratios of storage volume to impervious area (0.1 to 2.0 inches)); varying ratios of impervious source area to receiving pervious area based on hydrologic soil groups (HSGs) A, B, C and D (8:1, 6:1, 4:1, 2: 1 and 1:1); and varying discharge time periods for temporary storage (1, 2 or 3 days). The default credits are provided at the end of this Attachment (see Tables 3-19 through 3-26 and performance curves Figures 3-18 through 3-38).

EPA will consider phosphorus load reductions calculated using the methods provided below to be valid for the purpose of complying with the terms of this permit for BMPs that have not been explicitly modeled if the desired BMP has functionality that is similar to one of the simulated BMP types. Please note that only the surface infiltration and the infiltration trench BMP types were simulated to direct storm water runoff into the ground (i.e., infiltration). All of the other simulated BMPs represent practices that have either under-drains or impermeable liners and therefore, are not hydraulically connected to the sub-surface soils (i.e., no infiltration). Following are some simple guidelines for selecting the BMP type and/or determining whether the results of any of the BMP types provided are appropriate for another BMP of interest.

Infiltration Trench is a practice that provides temporary storage of runoff using the void spaces within the soil/sand/gravel mixture that is used to backfill the trench for subsequent infiltration into the surrounding sub-soils. Performance results for the infiltration trench can be used for all subsurface infiltration practices including systems that include pipes and/or chambers that provide temporary storage. Also, the results for this BMP type can be used for bio-retention systems that rely on infiltration when the majority of the temporary storage capacity is provided in the void spaces of the soil filter media and porous pavements that allow infiltration to occur.

Surface Infiltration represents a practice that provides temporary surface storage of runoff (e.g., ponding) for subsequent infiltration into the ground. Appropriate practices for use of the surface infiltration performance estimates include infiltration basins, infiltration swales, rain gardens and bio-retention systems that rely on infiltration and provide the majority of storage capacity through surface-ponding. If an infiltration system includes both surface storage through ponding and a lessor storage volume within the void spaces of a coarse filter media, then the physical storage volume capacity used to determine the long-term cumulative phosphorus removal efficiency from the infiltration basin performance curves would be equal to the sum of the surface storage volume and the void space storage volume. General design specifications for various surface infiltration systems are provided in the most recent version of *the Massachusetts Stormwater Handbook, Volume 2/Chapter2* (<u>http://www.mass.gov/eea/docs/dep/water/laws/i-thru-z/v2c2.pdf</u>).

Bio-filtration is a practice that provides temporary storage of runoff for filtering through an engineered soil media. The storage capacity is typically made of void spaces in the filter media and temporary ponding at the surface of the practice. Once the runoff has passed through the filter media it is collected by an under-drain pipe for discharge. The performance curve for this control practice assumes zero infiltration. If a filtration system has subsurface soils that are suitable for infiltration, then user should use the either performance curves for the infiltration trench or the infiltration basin depending on the predominance of storage volume made up by free standing storage or void space storage. Depending on the design of the filter media manufactured or packaged bio-filter systems such as tree box filters may be suitable for using the bio-filtration performance results. Design specifications for bio-filtration systems are provided in the most recent version of *the Massachusetts Stormwater Handbook, Volume 2/Chapter2* (http://www.mass.gov/eea/docs/dep/water/laws/i-thru-z/v2c2.pdf).

Gravel Wetland performance results should be used for practices that have been designed in accordance or share similar features with the design specifications for gravel wetland systems provided in the most recent version of *the Massachusetts Stormwater Handbook, Volume 2/Chapter2* (http://www.mass.gov/eea/docs/dep/water/laws/i-thru-z/v2c2.pdf).

Porous Pavement performance results represent systems with an impermeable under-liner and an under-drain. *If porous pavement systems do not have an impermeable under-liner so that filtered runoff can infiltrate into sub-soils then the performance results for an infiltration trench may be used for these systems.* Design specifications for porous pavement systems are provided in the most recent version of *the Massachusetts Stormwater Handbook, Volume 2/Chapter2* (http://www.mass.gov/eea/docs/dep/water/laws/i-thru-z/v2c2.pdf). **Extended Dry Detention Pond** performance results should only be used for practices that have been designed in accordance with the design specifications for extended dry detention ponds provided in the most recent version of *the Massachusetts Stormwater Handbook, Volume 2/Chapter2* (http://www.mass.gov/eea/docs/dep/water/laws/i-thru-z/v2c2.pdf)

Dry Water Quality Swale/ Grass Swale performance results should only be used for practices that have been designed in accordance with the design specifications for a water quality dry swale provided in the most recent version of *the Massachusetts Stormwater Handbook, Volume 2/Chapter2* (http://www.mass.gov/eea/docs/dep/water/laws/i-thru-z/v2c2.pdf)

Impervious Area Disconnection using Storage (e.g., rain barrels, cistern, etc) performance results are for collecting runoff volumes from impervious areas such as roof tops, providing temporary storage of runoff volume using rain barrels, cisterns or other storage containers, and discharging stored volume to adjacent permeable pervious surfaces over an extended period of time.

Impervious Area Disconnection performance results are for diverting runoff volumes from impervious areas such as roadways, parking lots and roof tops, and discharging it to adjacent vegetated permeable surfaces that are of sufficient size with adequate soils to receive the runoff without causing negative impacts to adjacent down-gradient properties. Careful consideration must be given to the ratio of impervious area to the pervious area that will receive the discharge. Also, devices such as level spreaders to disperse the discharge and provide sheet flow should be employed whenever needed to increase recharge and avoid flow concentration and short circuiting through the pervious area. Soil testing is needed to classify the permeability of the receiving pervious area in terms of HSG.

Conversion of Impervious Area to Permeable Pervious Area phosphorus load reduction credits are for replacing existing impervious surfaces (such as traditional pavements and buildings with roof tops) with permeable surfaces. To be eligible for credit, it is essential that the area previously covered with impervious surface be restored to provide natural or enhanced hydrologic functioning so that the surface is permeable. Sub-soils beneath pavements are typically highly compacted and will require reworking to loosen the soil and the possible addition of soil amendments to restore permeability. Soil testing is needed to classify the permeability (in terms of HSG) of the restored pervious area.

Soil Amendments to Increase Permeability of Pervious Areas performance results are for the practice of improving the permeability of pervious areas through incorporation of soil amendments, tilling and establishing dense vegetation. This practice may be used to compliment other practices such as impervious area disconnection to improve overall performance and increase reduction credits earned. Soil testing is needed to classify the permeability (in terms of HSG) of the restored pervious area.

Alternative Methods:

A permittee may propose alternative long-term cumulative performance information or alternative methods to calculate phosphorus load reductions for the structural BMPs identified above or for other structural BMPs not identified in this Attachment.

EPA will consider alternative long-term cumulative performance information and alternative methods to calculate phosphorus load reductions for structural BMPs provided that the permittee provides EPA with adequate supporting documentation. At a minimum, the supporting documentation shall include:

- 1) Results of continuous BMP model simulations representing the structural BMP, using a verified BMP model and representative long-term (i.e., 10 years) climatic data including hourly rainfall data;
- 2) Supporting calculations and model documentation that justify use of the model, model input parameters, and the resulting cumulative phosphorus load reduction estimate;
- 3) If pollutant removal performance data are available for the specific BMP, model calibration results should be provided; and
- 4) Identification of references and sources of information that support the use of the alternative information and method.

If EPA determines that the long-term cumulative phosphorus load reductions developed based on alternative information are not adequately supported, EPA will notify the permittee in writing, and the permittee may receive no phosphorus reduction credit other than a reduction credit calculated by the permittee using the default phosphorus reduction factors provided in this attachment for the identified practices. The permittee is required to submit to EPA valid phosphorus load reductions for structural BMPs in the watershed in accordance with the submission schedule requirements specified in the permit and Appendix F.

Method to Calculate Annual Phosphorus Load Delivered to BMPs (BMP Load)

The **BMP Load** is the annual phosphorus load from the drainage area to each proposed or existing BMP used by permittee to claim credit against its stormwater phosphorus load reduction requirement (i.e., Phosphorus Reduction Requirement). The BMP Load is the starting point from which the permittee calculates the reduction in phosphorus load achieved by each existing and proposed BMP.

Examples are provided to illustrate use of the methods. Table 3-1 below provides annual phosphorus load export rates (PLERs) by land use category for impervious and pervious areas. The permittee shall select the land use category that most closely represents the actual use of the watershed. For pervious areas, if the hydrologic soil group (HSG) is known, use the appropriate value. If the HSG is not known, assume HSG C conditions for the phosphorus load export rate. For watersheds with institutional type uses, such as government properties, hospitals, and schools, the permittee shall use the commercial/industrial land use category for the purpose of calculating phosphorus loads. Table 3-2 provides a crosswalk table of land use codes between land use groups in Table 3-1 and the codes used by MassGIS.
<u>BMP Load</u>: To estimate the annual phosphorus load reduction that a storm water BMP can achieve, it is first necessary to estimate the amount of annual phosphorus load that the BMP will receive or treat (BMP Load).

For a given BMP:

- 1) Determine the total drainage area to the BMP;
- 2) Distribute the total drainage area into impervious and pervious subareas by land use category as defined by Tables 3-1 and 3-2;
- 3) Calculate the phosphorus load for each land use-based impervious and pervious subarea by multiplying the subarea by the appropriate phosphorus load export rate provided in Table 3-1; and
- 4) Determine the total annual phosphorus load to the BMP by summing the calculated impervious and pervious subarea phosphorus loads.

Example 3-1 to determine phosphorus load to a proposed BMP: A permittee is proposing a surface stormwater infiltration system that will treat runoff from an industrial site with an area of 12.87 acres (5.21 hectares) and is made up of 10.13 acres of impervious cover (e.g., roadways, parking areas and rooftops), 1.85 acres of landscaped pervious area and 0.89 acres of wooded area both with HSG C soils. The drainage area information for the proposed BMP is:

BMP Subarea ID	Land Use Category	Cover Type	Area (acres)	P export rate (lb/acre/yr)*
1	Industrial	impervious	10.13	1.78
2	Landscaped (HSG C)	pervious	1.85	0.21
3	Forest (HSG C)	pervious	0.89	0.12

*From Table 3-1

The phosphorus load to the proposed BMP (BMP Load) is calculated as:

BMP Load = $(IA_{Ind} \times PLER_{Ind}) + (PA_{Ind} \times PLER_{Ind}) + (PA_{FOREST} \times PLER_{For})$ = $(10.13 \times 1.78) + (1.85 \times 0.21) + (0.89 \times 0.12)$ = **18.53 lbs P/year**

Phosphorus Source Category by Land Use	Land Surface Cover	P Load Export Rate, lbs/acre/year	P Load Export Rate, kg/ha/yr
Commercial (Com) and	Directly connected impervious	1.78	2.0
Industrial (Ind)	Pervious	See* DevPERV	See* DevPERV
Multi-Family (MFR) and High-Density Residential	Directly connected impervious	2.32	2.6
(HDR)	Pervious	See* DevPERV	See* DevPERV
Medium -Density	Directly connected impervious	1.96	2.2
Residential (MDR)	Pervious	See* DevPERV	See* DevPERV
Low Density Residential	Directly connected impervious	1.52	1.7
(LDK) - Kulai	Pervious	See* DevPERV	See* DevPERV
Highway (HWY)	Directly connected impervious	1.34	1.5
	Pervious	See* DevPERV	See* DevPERV
Forest (For)	Directly connected 1.52		1.7
	Pervious	0.13	0.13
Open Land (Open)	Directly connected impervious	1.52	1.7
	Pervious	See* DevPERV	See* DevPERV
Agriculture (Ag)	Directly connected impervious	1.52	1.7
	Pervious	0.45	0.5
*Developed Land Pervious (DevPERV)- Hydrologic Soil Group A	Pervious	0.03	0.03
*Developed Land Pervious (DevPERV)- Hydrologic Soil Group B	Pervious	0.12	0.13
*Developed Land Pervious (DevPERV) - Hydrologic Soil Group C	Pervious	0.21	0.24
*Developed Land Pervious (DevPERV) - Hydrologic Soil Group C/D	Pervious	0.29	0.33
*Developed Land Pervious (DevPERV) - Hydrologic Soil Group D	Pervious	0.37	0.41

Table 3-1: Average annual distinct phosphorus load (P Load) export rates for use in estimating phosphorus load reduction credits the MA MS4 Permit

Mass GIS Land Use LU_CODE	Description	Land Use group for calculating P Load - 2013/14 MA MS4
1	Crop Land	Agriculture
2	Pasture (active)	Agriculture
3	Forest	Forest
4	Wetland	Forest
5	Mining	Industrial
6	Open Land includes inactive pasture	open land
7	Participation Recreation	open land
8	spectator recreation	open land
9	Water Based Recreation	open land
10	Multi-Family Residential	High Density Residential
11	High Density Residential	High Density Residential
12	Medium Density Residential	Medium Density Residential
13	Low Density Residential	Low Density Residential
14	Saltwater Wetland	Water
15	Commercial	Commercial
16	Industrial	Industrial
17	Urban Open	open land
18	Transportation	Highway
19	Waste Disposal	Industrial
20	Water	Water
23	cranberry bog	Agriculture
24	Powerline	open land
25	Saltwater Sandy Beach	open land
26	Golf Course	Agriculture
29	Marina	Commercial
31	Urban Public	Commercial
34	Cemetery	open land
35	Orchard	Forest
36	Nursery	Agriculture
37	Forested Wetland	Forest
38	Very Low Density residential	Low Density Residential
39	Junkyards	Industrial
40	Brush land/Successional	Forest

 Table 3- 2: MassGIS land-use categories with associated land-use groups for phosphorus load calculations

(1) Method to determine the design volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area is 100% impervious:

Flow Chart 1 illustrates the steps to determine the design volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area is 100% impervious.



Flow Chart 1: Method to determine BMP design volume to achieve a known phosphorous load reduction when contributing drainage area is 100% impervious.

- 1) Determine the desired cumulative phosphorus load reduction target (P target) in percentage for the structural BMP;
- 2) Determine the contributing impervious drainage area (IA) in acres to the structural BMP;
- **3)** Determine the structural BMP type (e.g., infiltration trench, gravel wetland). For infiltration systems, determine the appropriate infiltration rate for the location of the BMP in the Watershed;
- **4)** Using the cumulative phosphorus removal performance curve for the selected structural BMP (Figures 3-1 through 3-18), determine the storage volume for the BMP (BMP-Volume _{IA-in}), in inches of runoff, needed to treat runoff from the contributing IA to achieve the reduction target;
- 5) Calculate the corresponding BMP storage volume in cubic feet (BMP-Volume IA-ft³) using BMP-Volume IA-in determined from step 4 and equation 3-1:

BMP-Volume $_{IA-ft}^3 = IA$ (acre) x BMP-Volume $_{IA-in}$ x 3630 ft³/ac-in (Equation 3-1)

- 6) Provide supporting calculations using the dimensions and specifications of the proposed structural BMP showing that the necessary storage volume, BMP-Volume IA-ft³, determined from step 5 will be provided to achieve the P _{Target}; and
- 7) Calculate the cumulative phosphorus load reduction in pounds of phosphorus (BMP-Reduction _{lbs-P}) for the structural BMP using the BMP Load (as calculated from the procedure in Attachment 1 to Appendix F) and P _{target} by using equation 3-2:

BMP-Reduction $_{lbs-P} = BMP \text{ Load } x (P_{target} / 100)$ (Equation 3-2)

Example 3-2 to determine design volume of a structural BMP with a 100% impervious drainage area to achieve a known phosphorus load reduction target:

A permittee is considering a surface infiltration practice to capture and treat runoff from 2.57 acres (1.04 ha) of commercial impervious area that will achieve a 70% reduction in annual phosphorus load. The infiltration practice would be located adjacent to the impervious area. The permittee has measured an infiltration rate (IR) of 0.39 inches per hour (in/hr) in the vicinity of the proposed infiltration practice. Determine the:

- A) Design storage volume needed for an surface infiltration practice to achieve a 70% reduction in annual phosphorus load from the contributing drainage area (BMP-Volume $_{IA-ft}^{3}$); and
- **B)** Cumulative phosphorus reduction in pounds that would be accomplished by the BMP (BMP-Reduction _{lbs-P})

<u>Solution:</u>

1) Contributing impervious drainages area (IA) = 2.57 acres

BMP type is a surface infiltration practice (i.e., basin) with an infiltration rate (IR) of 0.39 in/hr

Solution continued:

3) Phosphorus load reduction target (P $_{target}$) = 70%

4) The performance curve for the infiltration basin (i.e., surface infiltration practice), Figure 3-8, IR = 0.27 in/hr is used to determine the design storage volume of the BMP (BMP-Volume IA-in) needed to treat runoff from the contributing IA and achieve a P target = 70%. The curve for an infiltration rate of 0.27 in/hr is chosen because 0.27 in/hr is the nearest simulated IR that is less than the field measured IR of 0.39 in/hr. From Figure 3-8, the BMP-Volume IA-in for a P target = 70% is 0.36 in.

5) The BMP-Volume $_{IA-in}$ is converted to cubic feet (BMP-Volume $_{IA-ft}$ ³) using Equation 3-1:

BMP-Volume $_{IA-ft}^3$ = IA (acre) x BMP-Volume $_{IA-in}$ x 3,630 ft³/acre-in BMP-Volume $_{IA-ft}^3$ = 2.57 acre x 0.36 in x 3,630 ft³/acre-in = **3,359 ft³**

6) A narrow trapezoidal infiltration basin with the following characteristics is proposed to achieve the P $_{Target}$ of 70%:

Length (ft)	Design Depth (ft)	Side Slopes	Bottom area (ft ²)	Pond surface area (ft ²)	Design Storage
					Volume (ft ³)
355	1.25	3:1	1,387	4,059	3,404

The volume of the proposed infiltration practice, 3,404 ft³, exceeds the BMP-Volume $_{IA-ft}^{3}$ needed, 3,359 ft³ and is sufficient to achieve the P Target of 70%.

7) The cumulative phosphorus load reduction in pounds of phosphorus for the infiltration practice (BMP-Reduction _{lbs-P}) is calculated using Equation 3-2. The BMP Load is first determined using the method described above.

BMP Load = IA x impervious cover phosphorus export loading rate for commercial use (see Table 3-1)

= $2.57 \operatorname{acres x} 1.78 \operatorname{lbs/acre/yr}$

= 4.58 lbs/yr

BMP-Reduction $_{lbs-P}$ = BMP Load x (P $_{target}$ /100) BMP-Reduction $_{lbs-P}$ = 4.58 lbs/yr x (70/100) = **3.21 lbs/yr**

<u>Alternate Solution</u>: Alternatively, the permittee could determine the design storage volume needed for an IR = 0.39 in/hr by performing interpolation of the results from the surface

infiltration performance curves for IR = 0.27 in/hr and IR = 0.52 in/hr as follows (replacing steps 3 and 4 on the previous page):

Alternate solution continued:

Using the performance curves for the infiltration basin (i.e., surface infiltration practice), Figures 3-8, IR = 0.27 in/hr and 3-9, IR = 0.52 in/hr, interpolate between the curves to determine the design storage volume of the BMP (BMP-Volume IA-in) needed to treat runoff from the contributing IA and achieve a P target = 70%.

First calculate the interpolation adjustment factor (IAF) to interpolate between the infiltration basin performance curves for infiltration rates of 0.27 and 0.52 in/hr:

$$IAF = (0.39 - 0.27)/(0.52 - 0.27) = 0.48$$

From the two performance curves, develop the following table to estimate the general magnitude of the needed storage volume for an infiltration swale with an IR = 0.39 in/hr and a P _{target} of 70%.

Table Example 3-1-1: Interpolation Table for determining design storage volume of infiltration basin with IR = 0.39 in/hr and a phosphorus load reduction target of 70%

BMP	% Phosphorus Load	% Phosphorus Load	Interpolated % Phosphorus Load
Storage	Reduction IR = 0.27 in/hr	Reduction IR = 0.52 in/hr	Reduction IR = 0.39 in/hr (PR _{IR=0.39})
Volume	$(PR_{IR=0.27})$	$(PR_{IR=0.52})$	$PR_{IR=0.39} = IAF(PR_{IR=0.52} - PR_{IR=0.27}) +$
			PR _{IR=0.27}
0.3	64%	67%	65%
0.4	74%	77%	75%
0.5	79%	82%	80%

As indicated from Table Example 3-1, the BMP-Volume $_{IA-in}$ for $PR_{IR=0.39}$ of 70% is between 0.3 and 0.4 inches and can be determined by interpolation:

BMP-Volume _{IA-in} = $(70\% - 65\%)/(75\% - 65\%) \times (0.4 \text{ in} - 0.3 \text{ in}) + 0.3 \text{ in}$ = 0.35 inches

5 alternative) Convert the resulting BMP-Volume IA-in to cubic feet (BMP-Volume IA-ft³) using equation 3-1:

BMP-Volume $_{IA-ft}^3$ = 2.57 acre x 0.35 in x 3,630 ft³/acre-in = 3,265 ft³

(2) <u>Method to determine the phosphorus load reduction for a structural BMP with a known</u> design volume when the contributing drainage area is 100% impervious:

Flow Chart 2 illustrates the steps to determine the phosphorus load reduction for a structural BMP with a known design volume when the contributing drainage area is 100% impervious.



Flow Chart 2: Method to determine the phosphorus load reduction for a BMP with a known design volume when contributing drainage area is 100% impervious.

- 1) Identify the structural BMP type and contributing impervious drainage area (IA);
- Document the available storage volume (ft³) of the structural BMP (BMP-Volume ft³) using the BMP dimensions and design specifications (e.g., maximum storage depth, filter media porosity);
- **3)** Convert BMP-Volume _{ft}³ into inches of runoff from the contributing impervious area (BMP-Volume _{IA-in}) using equation 3-3:

BMP-Volume $_{IA-in}$ = BMP-Volume $_{ft}^3$ / IA (acre) x 12 in/ft x 1 acre/43560 ft² (Equation 3-3)

4) Determine the % phosphorus load reduction for the structural BMP (BMP Reduction %-P) using the appropriate BMP performance curve (Figures 3-1 through 3-18) and the BMP-Volume IA-in calculated in step 3; and

5) Calculate the cumulative phosphorus load reduction in pounds of phosphorus for the structural BMP (BMP Reduction _{lbs-P}) using the BMP Load as calculated from the procedure described above and the percent phosphorus load reduction determined in step 4 by using equation 3-4:

BMP Reduction $_{lbs-P}$ = BMP Load x (BMP Reduction $_{\%-P}/100$) (Equation 3-4)

Example 3-2: Determine the phosphorus load reduction for a structural BMP with a known storage volume capacity when the contributing drainage area is 100% impervious:

A permittee is considering a bio-filtration system to treat runoff from 1.49 acres of high density residential (HDR) impervious area. Site constraints would limit the bio-filtration system to have a surface area of 1200 ft² and the system would have to be located next to the impervious drainage area to be treated. The design parameters for the bio-filtration system are presented in Table Example 3-2-1.

Components of representation	Parameters	Value
	Maximum depth	0.5 ft
Ponding	Surface area	1200 ft ²
	Vegetative parameter ^a	85-95%
	Depth	2.5 ft
Soil mix	Porosity	0.40
	Hydraulic conductivity	4 inches/hour
	Depth	0.67 ft
Gravel layer	Porosity	0.40
	Hydraulic conductivity	14 inches/hour
Orifice #1	Diameter	0.5 ft

Table Example 3-2-1: Design parameters for bio-filtration system for Example 3-2

^a Refers to the percentage of surface covered with vegetation

Determine the:

- A) Percent phosphorus load reduction (BMP Reduction %-P) for the specified bio-filtration system and contributing impervious drainage area; and
- **B)** Cumulative phosphorus reduction in pounds that would be accomplished by the biofiltration system (BMP-Reduction _{lbs-P})

Solution:

- 1) The BMP is a bio-filtration system that will treat runoff from 1.49 acres of impervious area (IA = 1.49 acre);
- 2) The available storage volume capacity (ft^3) of the bio-filtraton system (BMP-Volume $BMP-ft^3$) is determined using the surface area of the system, depth of ponding, and the porosity of the filter media:

BMP-Volume _{BMP-ft}³ = (surface area x pond maximum depth) + ((soil mix depth + gravel layer depth)/12 in/ft) x surface area x gravel layer porosity) = $(1,200 \text{ ft}^2 \text{ x } 0.5 \text{ ft}) + ((38/12) \text{ x } 1,200 \text{ ft}^2 \text{ x } 0.4)$ = $2,120 \text{ ft}^3$

Solution continued:

The available storage volume capacity of the bio-filtration system in inches of runoff from the contributing impervious area (BMP-Volume IA-in) is calculated using equation 3-3:

BMP-Volume _{IA-in} = (BMP-Volume $_{ft}^3$ / IA (acre) x 12 in/ft x 1 acre/43560 ft² BMP-Volume _{IA-in} = (2120 ft³/1.49 acre) x 12 in/ft x 1 acre/43560 ft² = 0.39 in

- 4) Using the bio-filtration performance curve shown in Figure 3-13, a 51% phosphorus load reduction (BMP Reduction %-P) is determined for a bio-filtration system sized for 0.39 in of runoff from 1.49 acres of impervious area; and
- 5) Calculate the cumulative phosphorus load reduction in pounds of phosphorus for the biofiltration system (BMP Reduction _{lbs-P}) using the BMP Load as calculated from the procedure described above and the BMP Reduction _{%-P} determined in step 4 by using equation 3-4. First, the BMP Load is determined as specified above:

BMP Load = IA x impervious cover phosphorus export loading rate for HDR (see Table 3-1) = 1.49 acres x 2.32 lbs/acre/yr = 3.46 lbs/yr BMP Reduction by P = BMP Load x (BMP Reduction % P/100)

BMP Reduction $_{lbs-P}$ = BMP Load x (BMP Reduction $_{h-P}/100$) BMP Reduction $_{lbs-P}$ = 3.46 lbs/yr x (51/100) = **1.76 lbs/yr**

(3) Method to determine the design storage volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area has impervious and pervious surfaces:

Flow Chart 3 illustrates the steps to determine the design storage volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area has impervious and pervious surfaces.



Flow Chart 3: Method to determine the design storage volume of a BMP to reach a known P load reduction when both impervious and pervious drainage areas are present.

- 1) Determine the desired cumulative phosphorus load reduction target (P target) in percentage for the structural BMP;
- Characterize the contributing drainage area to the structural BMP by identifying the following information for the impervious and pervious surfaces: Impervious area (IA) - Area (acre) and land use (e.g., commercial)

Pervious area (PA) – Area (acre) and runoff depths based on hydrologic soil group (HSG) and rainfall depth. Table 3-3 provides values of runoff depth from pervious areas for various rainfall depths and HSGs. Soils are assigned to an HSG on the basis of their permeability. HSG A is the most permeable, and HSG D is the least permeable. HSG categories for pervious areas in the drainage area shall be estimated by consulting local soil surveys prepared by the National Resource Conservation Service (NRCS) or by a storm water professional evaluating soil testing results from the drainage area. If the HSG condition is not known, a HSG D soil condition should be assumed.

Developed Land Pervious Area Runoff Depths based on Precipitation depth and Hydrological Soil					
		Gr	oups		
		R	lunoff Depth, inc	hes	
Rainfall Depth,	Pervious HSG			Pervious HSG	
Inches	Α	Pervious HSG B	Pervious HSG C	C/D	Pervious HSG D
0.10	0.00	0.00	0.00	0.00	0.00
0.20	0.00	0.00	0.01	0.02	0.02
0.40	0.00	0.00	0.03	0.05	0.06
0.50	0.00	0.01	0.05	0.07	0.09
0.60	0.01	0.02	0.06	0.09	0.11
0.80	0.02	0.03	0.09	0.13	0.16
1.00	0.03	0.04	0.12	0.17	0.21
1.20	0.04	0.05	0.14	0.27	0.39
1.50	0.08	0.11	0.39	0.55	0.72
2.00	0.14	0.22	0.69	0.89	1.08

Table 3- 3: Developed Land Pervious Area Runoff Depths based on Precipitation depth and Hydrological Soil Groups (HSGs)

Notes: Runoff depths derived from combination of volumetric runoff coefficients from Table 5 of *Small Storm Hydrology and Why it is Important for the Design of Stormwater Control Practices*, (Pitt, 1999), and using the Stormwater Management Model (SWMM) in continuous model mode for hourly precipitation data for Boston, MA, 1998-2002.

- 3) Determine the structural BMP type (e.g., infiltration trench, gravel wetland). For infiltration systems, determine the appropriate infiltration rate for the location of the BMP in the Watershed;
- Using the cumulative phosphorus removal performance curve for the selected structural BMP, determine the storage volume capacity of the BMP in inches needed to treat runoff from the contributing impervious area (BMP-Volume IA-in);

5) Using Equation 3-5 below and the pervious area runoff depth information from Table 3-3-1, determine the total volume of runoff from the contributing pervious drainage area in cubic feet (BMP Volume PA- ft³) for a rainfall size equal to the sum of BMP Volume IA-in, determined in step 4. The runoff volume for each distinct pervious area must be determined;

BMP-Volume $_{PA ft}^3 = \sum (PA x (runoff depth) x 3,630 ft^3/acre-in)_{(PA1,...PAn)}$ (Equation 3-5)

6) Using equation 3-6 below, calculate the BMP storage volume in cubic feet (BMP-Volume _{IA&PA-ft}³) needed to treat the runoff depth from the contributing impervious (IA) and pervious areas (PA);

BMP-Volume $_{IA\&PA-ft}^3$ = BMP Volume $_{PA-ft}^3$ + (BMP Volume $_{IA-in} x IA$ (acre) x 3,630 ft³/acre-in) (Equation 3-6)

- 7) Provide supporting calculations using the dimensions and specifications of the proposed structural BMP showing that the necessary storage volume determined in step 6, BMP-Volume IA&PA-ft³, will be provided to achieve the P Target; and
- 8) Calculate the cumulative phosphorus load reduction in pounds of phosphorus (BMP-Reduction _{lbs-P}) for the structural BMP using the BMP Load (as calculated from the procedure in Attachment 1 to Appendix F) and the P target by using equation 3-2:

BMP-Reduction $_{lbs-P}$ = BMP Load x (P $_{target}$ /100) (Equation 3-2)

Example 3-3: Determine the design storage volume of a structural BMP to achieve a known phosphorus load reduction target when the contributing drainage area has impervious and pervious surfaces

A permittee is considering a gravel wetland system to treat runoff from a high-density residential (HDR) site. The site is 7.50 acres of which 4.00 acres are impervious surfaces and 3.50 acres are pervious surfaces. The pervious area is made up of 2.5 acres of lawns in good condition surrounding cluster housing units and 1.00 acre of stable unmanaged woodland. Soils information indicates that all of the woodland and 0.50 acres of the lawn is hydrologic soil group (HSG) B and the other 2.00 acres of lawn are HSG C. The permittee wants to size the gravel wetland system to achieve a cumulative phosphorus load reduction (P $_{Target}$) of 55% from the entire 7.50 acres.

Determine the:

A) Design storage volume needed for a gravel wetland system to achieve a 55% reduction in annual phosphorus load from the contributing drainage area (BMP-Volume $IA\&PA-ft^3$); and

B) Cumulative phosphorus reduction in pounds that would be accomplished by the BMP (BMP-Reduction _{lbs-P})

Example 3-3 continued: Solution:

1) The BMP type is gravel wetland system.

2) The phosphorus load reduction target (P $_{Target}$) = 55%.

3) Using the cumulative phosphorus removal performance curve for the gravel wetland system shown in Figure 3-14, the storage volume capacity in inches needed to treat runoff from the contributing impervious area (BMP Volume _{IA-in}) is 0.71 in;

Using equation 3-5 and the pervious runoff depth information from Table 3-3, the volume of runoff from the contributing pervious drainage area in cubic feet (BMP Volume $_{PA-ft}^3$) for a rainfall size equal to 0.71 in is summarized in Table Example 3-3-A. As indicated from Table 3-3, the runoff depth for a rainfall size equal to 0.71 inches is between 0.6 and 0.8 inches and can be determined by interpolation (example shown for runoff depth of HSG C):

Runoff depth (HSG C) = $(0.71 - 0.6)/(0.8 - 0.6) \times (0.09 \text{ in} - 0.06 \text{ in}) + 0.06 \text{ in}$ = 0.07 inches

ID	Туре	Pervious Area (acre)	HSG	Runoff (in)	Runoff = (runoff) x PA (acre-in)	Runoff = Runoff (acre-in) x 3630 ft3/acre-in (ft3)
PA1	Grass	2.00	С	0.07	0.14	508
PA2	Grass	0.50	В	0.01	0.0	0.0
PA3	Woods	1.00	В	0.01	0.0	0.0
Total		3.50			0.14	508

Table Example 3-3-A: Runoff contributions from pervious areas for HDR site

4) Using equation 3-6, determine the BMP storage volume in cubic feet (BMP-Volume $I_{A\&PA-ft}^{3}$) needed to treat 0.71 inches of runoff from the contributing impervious area (IA) and the runoff of 0.14 acre-in from the contributing pervious areas, determined in step 5 is:

BMP Volume_{IA&PA-ft}³ = BMP Volume_{PA ac-in} + (BMP Volume_{IA-in} x IA (acre)) x 3,630 ft³/acre-in)

BMP Volume_{IA&PA-ft}³ = (508 ft³+ (0.71 in x 4.00 acre)) x 3,630 ft³/acre-in = 10,817 ft³

5) Table Example 3-3-B provides design details for of a potential gravel wetland system

Solution continued:

Table Exam	ole 3-3-	B: Design	details for	gravel	wetland system
					•

Gravel Wetland System	Design Detail	Depth	Surface Area	Volume
Components		(ft)	(ft^2)	(ft^3)
Sediment Forebay	10% of Treatment Volume			
Pond area		1.33	896	1,192
Wetland Cell #1	45% of Treatment Volume			
Pond area		2.00	1,914	3,828
Gravel layer	porosity = 0.4	2.00	1,914	1,531
Wetland Cell #2	45% of Treatment Volume			
Pond area		2.00	1,914	3,828
Gravel layer	porosity = 0.4	2.00	1,914	1,531

The total design storage volume for the proposed gravel wetland system identified in Table Example 3-3-C is 11,910 ft³. This volume is greater than 11,834 ft³ ((BMP-Volume $_{IA\&PA-ft}$ ³), calculated in step 6) and is therefore sufficient to achieve a P $_{Target}$ of 55%.

6) The cumulative phosphorus load reduction in pounds of phosphorus (BMP-Reduction $_{lbs-P}$) for the proposed gravel wetland system is calculated by using equation 3-2 with the BMP Load and the P $_{target} = 55\%$.

BMP-Reduction $_{lbs-P}$ = BMP Load x (P $_{target}$ /100) (Equation 3-2)

Using Table 3-1, the BMP Load is calculated: BMP Load = (IA x PLER HDR) + (PA lawn HSG B x PLER HSG B) + (PA lawn HSG C x PLER HSG C) + (PA forest x PA PLER For) = (4.00 acre x 2.32 lbs/acre/yr) + (0.50 acres x 0.12 lbs/acre/yr) + (1.00 acre x 0.21 lbs/acre/yr) + (1.00 acres x 0.13) = 9.68 lbs/yr BMP-Reduction $_{lbs-P}$ = BMP Load x (P $_{target}$ /100) BMP-Reduction $_{lbs-P}$ = 9.68 lbs/yr x 55/100 = **5.32 lbs/yr**

(4) Method to determine the phosphorus load reduction for a structural BMP with a known storage volume when the contributing drainage area has impervious and pervious surfaces:

Flow Chart 4 illustrates the steps to determine the phosphorus load reduction for a structural BMP with a known storage volume when the contributing drainage area has impervious and pervious surfaces.



Flow Chart 4: Method to determine the phosphorus load reduction for a BMP with known storage volume when both pervious and impervious drainage areas are present.

1) Identify the type of structural BMP and characterize the contributing drainage area to the structural BMP by identifying the following information for the impervious and pervious surfaces:

Impervious area (IA) – Area (acre) and land use (e.g., commercial)

Pervious area (PA) – Area (acre) and runoff depth based on hydrologic soil group (HSG) and size of rainfall event. Table 3-3 provides values of runoff depth for various rainfall depths and HSGs. Soils are assigned to an HSG based on their permeability. HSG categories for pervious areas in the Watershed shall be estimated by consulting local soil surveys prepared by the National Resource Conservation Service (NRCS) or by a storm water professional evaluating soil testing results from the Watershed. If the HSG condition is not known, a HSG C/D soil condition should be assumed.

- 2) Determine the available storage volume (ft³) of the structural BMP (BMP-Volume ft³) using the BMP dimensions and design specifications (e.g., maximum storage depth, filter media porosity);
- **3)** To estimate the phosphorus load reduction of a BMP with a known storage volume capacity, it is first necessary to determine the portion of available BMP storage capacity (BMP-Volume t^3) that would treat the runoff volume generated from the contributing impervious area (IA) for a rainfall event with a depth of *i* inches (in). This will require knowing the corresponding amount of runoff volume that would be generated from the contributing pervious area (PA) for the same rainfall event (depth of *i* inches). Using equation 3-6a below, solve for the BMP capacity that would be available to treat runoff from the contributing imperious area for the unknown rainfall depth of *i* inches (see equation 3-6b):

BMP-Volume
$$_{ft}^3$$
 = BMP-Volume $_{(IA-ft^3)i}$ + BMP-Volume $_{(PA-ft^3)i}$ (Equation 3-6a)

Where:

BMP-Volume f^{3} = the available storage volume of the BMP;

BMP-Volume $(IA-ft^3)_i$ = the available storage volume of the BMP that would fully treat runoff generated from the contributing impervious area for a rainfall event of size *i* inches; and

BMP-Volume $_{(PA-ft^3)i}$ = the available storage volume of the BMP that would fully treat runoff generated from the contributing pervious area for a rainfall event of size *i* inches

Solving for BMP-Volume (IA-ft³)*i*:

BMP-Volume $(IA-ft^3)_i = BMP-Volume ft^3 - BMP-Volume (PA-ft^3)_i$ (Equation 3-6b)

To determine BMP-Volume $(IA-ft^3)i$, requires performing an iterative process of refining estimates of the rainfall depth used to calculate runoff volumes until the rainfall depth used results in the sum of runoff volumes from the contributing IA and PA equaling the available BMP storage capacity (BMP-Volume ft^3). For the purpose of estimating BMP performance, it will be considered adequate when the IA runoff depth (in) is within 5% IA runoff depth used in the previous iteration.

For the first iteration (1), convert the BMP-Volume $_{ft}^3$ determined in step 2 into inches of runoff from the contributing impervious area (BMP Volume $_{(IA-in)1}$) using equation 3-7a.

BMP-Volume $_{(IA-in)1} = (BMP-Volume_{ft}^3/IA (acre)) \times (12 in/ft/43,560 ft^2/acre)$ (Equation 3-7a);

For iterations 2 through n (2...n), convert the BMP Volume $(IA-ft^3)_{2...n}$, determined in step 5a below, into inches of runoff from the contributing impervious area (BMP Volume $(IA-in)_{2...n}$) using equation 3-7b.

BMP-Volume $_{(IA-in)2...n} = (BMP-Volume _{(IA-ft^3)2...n} / IA (acre)) x (12 in/ft /43,560 ft^2/acre) (Equation 3-7b);$

4) For 1 to n iterations, use the pervious runoff depth information from Table 3-3 and equation 3-8 to determine the total volume of runoff (ft³) from the contributing PA (BMP Volume PA-ft³) for a rainfall size equal to the sum of BMP-Volume (IA-in)1, determined in step 3. The runoff volume for each distinct pervious area must be determined.

BMP Volume $_{(PA-ft^3)1...n} = \sum ((PA x (runoff depth)_{(PA1, PA2..PAn)} x (3,630 ft^3/acre-in) (Equation 3-8))$

5) For iteration 1, estimate the portion of BMP Volume that is available to treat runoff from only the IA by subtracting BMP-Volume $_{PA-ft}^3$, determined in step 4, from BMP-Volume $_{ft}^3$, determined in step 2, and convert to inches of runoff from IA (see equations 3-9a and 3-9b):

BMP-Volume $(IA-ft^3)_2 = ((BMP-Volume_{ft^3} - BMP Volume_{(PA-ft^3)}))$ (Equation 3-9a)

BMP-Volume $_{(IA-in)2} = (BMP-Volume _{(IA-ft^3)2}/IA (acre)) x (12 in/ft x 1 acre/43,560 ft^2) (Equation 3-9b)$

If additional iterations (i.e., 2 through n) are needed, estimate the portion of BMP volume that is available to treat runoff from only the IA (BMP-Volume (IA-in)3..n+1) by subtracting BMP Volume $(PA-ft^3)2..n$, determined in step 4, from BMP Volume $(IA-ft^3)3..n+1$, determined in step 5, and by converting to inches of runoff from IA using equation 3-9b):

- **6)** For iteration a (an iteration between 1 and n+1), compare BMP Volume _{(IA-in)a} to BMP Volume _{(IA-in)a-1} determined from the previous iteration (a-1). If the difference in these values is greater than 5% of BMP Volume _{(IA-in)a} then repeat steps 4 and 5, using BMP Volume _{(IA-in)a} as the new starting value for the next iteration (a+1). If the difference is less than or equal to 5 % of BMP Volume _{(IA-in)a} then the permittee may proceed to step 7;
- 7) Determine the % phosphorus load reduction for the structural BMP (BMP Reduction _{%-P}) using the appropriate BMP performance curve and the BMP-Volume _{(IA-in)n} calculated in the final iteration of step 5; and
- **8)** Calculate the cumulative phosphorus load reduction in pounds of phosphorus for the structural BMP (BMP Reduction _{lbs-P}) using the BMP Load as calculated from the procedure in Attachment 1 to Appendix F and the percent phosphorus load reduction (BMP Reduction _{%-P}) determined in step 7 by using equation 3-4:

BMP Reduction $_{lbs-P}$ = BMP Load x (BMP Reduction $_{\%-P}/100$) (Equation 3-4)

Example 3-4: Determine the phosphorus load reduction for a structural BMP with a known design volume when the contributing drainage area has impervious and pervious surfaces

A permittee is considering an infiltration basin to capture and treat runoff from a portion of the medium density residential area (MDR). The contributing drainage area is 16.55 acres and has 11.75 acres of impervious area and 4.8 acres of pervious area (PA) made up mostly of lawns and landscaped areas that is 80% HSG D and 20% HSG C. An infiltration basin with the following specifications can be placed at the down-gradient end of the contributing drainage area where soil testing results indicates an infiltration rate (IR) of 0.28 in/hr:

Structure	Bottom area (acre)	Top surface area (acre)	Maximum pond depth (ft)	Design storage volume (ft ³)	Infiltration Rate (in/hr)
Infiltration basin	0.65	0.69	1.65	48,155	0.28

Table Example 3-4-A: Infiltration basin characteristics

Determine the:

- A) Percent phosphorus load reduction (BMP Reduction _{%-P}) for the specified infiltration basin and the contributing impervious and pervious drainage area; and
- **B)** Cumulative phosphorus reduction in pounds that would be accomplished by the BMP (BMP-Reduction _{lbs-P})

Example continued:

Solution:

1) A surface infiltration basin is being considered. Information for the contributing impervious (IA) and pervious (PA) areas are summarized in Tables Example 3-4-A and Example 3-4-B, respectively.

Die Example 5-4-D. Impervious area chara					
ID	Land	Area			
	use	(acre)			
IA1	MDR	11.75			

Table Example 3-4-B: Impervious area characteristics

ID	Area (acre)	Hydrologic Soil Group (HSG)
PA1	3.84	D
PA2	0.96	С

- 2) The available storage volume (ft³) of the infiltration basin (BMP-Volume ft³) is determined from the design details and basin dimensions; BMP-Volume ft³ = 48,155 ft³.
- 3) To determine what the BMP design storage volume is in terms of runoff depth (in) from IA, an iterative process is undertaken:

Solution Iteration 1

For the first iteration (1), the BMP-Volume_{ft}³ is converted into inches of runoff from the contributing impervious area (BMP Volume _{(IA-in)1}) using equation 3-5a.

BMP Volume $_{(IA-in)1} = (48,155 \text{ ft}^2/11.75 \text{ acre}) \times (12 \text{ in/ft}/43,560 \text{ ft}^2/\text{acre})$ = 1.13 in

4-1) The total volume of runoff (ft³) from the contributing PA (BMP Volume _{PA-ft}³) for a rainfall size equal to the sum of BMP Volume _{(IA-in)1} determined in step 3 is determined for each distinct pervious area identified in Table Example 3-4-B using the information from Table 3-3 and equation 3-5. Interpolation was used to determine runoff depths.

BMP Volume $_{(PA-ft^3)1} = ((3.84 \text{ acre x} (0.33 \text{ in}) + (0.96 \text{ acre x} (0.13 \text{ in})) \times 3,630 \text{ ft}^3/\text{acre-in})$ = 5052 ft³

5-1) For iteration 1, the portion of BMP Volume that is available to treat runoff from only the IA is estimated by subtracting the BMP Volume (PA-ft³)1, determined in step 4-1, from BMP Volumeft³, determined in step 2, and converted to inches of runoff from IA:

BMP Volume $_{(IA-ft^3)2} = 48,155 \text{ ft}^3 - 5052 \text{ ft}^3$ = 43,103 ft^3 BMP Volume $_{(IA-in)2} = (43,103 \text{ ft}^3/11.75 \text{ acre}) \times (12 \text{ in/ft } \times 1 \text{ acre}/43,560 \text{ ft}^2)$ = 1.01 in

Solution continued:

6-1) The % difference between BMP Volume (IA-in) 2, 1.01 in, and BMP Volume (IA-in)1, 1.13 in is determined and found to be significantly greater than 5%:

% Difference = $((1.13 \text{ in} - 1.01 \text{ in})/1.01 \text{ in}) \times 100$ = 12% Therefore, steps 4 through 6 are repeated starting with BMP Volume (IA-in) 2 = 1.01 in.

Solution Iteration 2

4-2) BMP-Volume $_{(PA-ft^3)2} = ((3.84 \text{ acre x } 0.21 \text{ in}) + (0.96 \text{ acre x } 0.12 \text{ in})) \times 3,630 \text{ ft}^3/\text{acre-in} = 3,358 \text{ ft}^3$

5-2) BMP-Volume $_{(IA-ft^3)3} = 48,155 \text{ ft}^3 - 3,358 \text{ ft}^3$ = 44,797 ft³ BMP-Volume $_{(IA-in)3} = (44,797 \text{ ft}^3/11.75 \text{ acre}) \times (12 \text{ in/ft } \times 1 \text{ acre}/43,560 \text{ ft}^2)$ = 1.05 in

6-2) % Difference = $((1.05 \text{ in} - 1.01 \text{ in})/1.05 \text{ in}) \times 100$ = 4%

The difference of 4% is acceptable.

7) The % phosphorus load reduction for the infiltration basin (BMP Reduction %-P) is determined by using the infiltration basin performance curve for an infiltration rate of 0.27 in/hr and the treatment volume (BMP-Volume Net IA-in = 1.05 in) calculated in step 5-2 and is BMP Reduction %-P = 93%.

The performance curve for IR = 0.27 is used rather than interpolating between the performance curves for IR = 0.27 in/hr and 0.52 in/hr to estimate performance for IR = 0.28 in/hr. An evaluation of the performance curves for IR = 0.27 in/hr and IR = 0.52 in/hr for a design storage volume of 1.05 in indicate a small difference in estimated performance (BMP Reduction $_{\text{\%-P}}$ = 93% for IR = 0.27 in/hr and BMP Reduction $_{\text{\%-P}}$ = 95% for IR = 0.52 in/hr).

 8) The cumulative phosphorus load reduction in pounds of phosphorus (BMP-Reduction lbs-P) for the proposed infiltration basin is calculated by using equation 3-2 with the BMP Load and the P target of 93%.

```
BMP-Reduction _{lbs-P} = BMP Load x (P _{target} /100) (Equation 3-2)
```

Using Table 3-1, the BMP load is calculated: BMP Load = (IA x impervious cover phosphorus export loading rate for industrial) + (PA _{HSG C} x pervious cover phosphorus export loading rate for HSG D) + (PA _{HSG C} x pervious cover phosphorus export loading rate for HSG C)

Solution continued:

= (11.75 acre x 1.96 lbs/acre/yr) + (3.84 acre x 0.37 lbs/acre/yr)+ (0.96 acre x 0.21 lbs/acre/yr) = 24.65 lbs/yr

BMP-Reduction $_{lbs-P} = 24.22 \ lbs/yr \ x \ 93/100 = 22.93 \ lbs/yr$

Example 3-5: Determine the phosphorus load reduction for disconnecting impervious area using storage with delayed release.

A commercial operation has an opportunity to divert runoff from 0.75 acres of impervious roof top to a 5000 gallon (668.4 ft³) storage tank for temporary storage and subsequent release to 0.09 acres of pervious area (PA) with HSG C soils.

Determine the:

- A) Percent phosphorus load reduction rates (BMP Reduction %-P) for the specified impervious area (IA) disconnection and storage system assuming release times of 1, 2 and 3 days for the stored volumes to discharge to the pervious area; and
- B) Cumulative phosphorus reductions in pounds that would be accomplished by the system (BMP-Reduction _{lbs-P}) for the three storage release times, 1, 2 and 3 days.

Solution:

1. Determine the storage volume in units of inches of runoff depth from contributing impervious area:

Storage Volume $_{IA-in} = (668.4 \text{ ft}^3/(0.75 \text{ acre x } 43.560 \text{ ft}^2/\text{acre})) \times 12 \text{ inch/ft}$ = 0.25 inches

2. Determine the ratio of the contributing impervious area to the receiving pervious area: IA:PA = 0.75 acres/0.09 acres

3. Using Table 3-21 for a IA:PA ratio of 8:1, determine the phosphorus load reduction rates for a storage volume of 0.25 inches that discharges to HSG C with release rates of 1, 2 and 3 days: Using interpolation the reduction rates are shown in Table 3-5-A:

Fable Example 3-5-A: Reduction Rates							
Percent Phosphorus load reduction for							
IA disconnection with storage HSG C							
Storage	Storage r	elease rat	e, days				
Volume IA-in	1	2	3				
0.25	39%	42%	43%				

4. The cumulative phosphorus load reduction in pounds of phosphorus for the IA disconnection with storage (BMP-Reduction Ibs-P) is calculated using Equation 3-2. The BMP Load is first determined using the method described above.

Solution continue	d:				
BMP Load = IA x	phosphorus exp	oort loadin	g rate for	commerci	al IA (see Table 3-1)
= 0.75	acres x 1.78 lbs	s/acre/yr			
= 1.34	lbs/yr				
BMP Reduction Ibs-	$_{P} = BMP Load$	x (BMP F	Reduction	%-p/100)	
BMP Reduction Ibs-	$_{\rm P} = 1.34 \; \rm lbs/yr$	x (39/100))		
	= 0.53 lbs/yr				
Table Example 3-5	-B presents the	BMP Red	luction Ibs	_{s-P} for each	of the release rates:
	Table Exar	nple 3-5-l	B: Reduc	tion Load	
	Phosphoru	us load re	duction f	for IA	
	disconnectio	n with sto	rage HS	G C, lbs	
	Storage	Storage	release ra	ate, days	
	Volume IA-in	1	2	3	
	0.25	0.53	0.56	0.58	

Example 3-6: Determine the phosphorus load reduction for disconnecting impervious area with and without soil augmentation in the receiving pervious area.

The same commercial property as in example 3-5 wants to evaluate disconnecting drainage from the 0.75 acre impervious roof top and discharging it directly to 0.09 acres of pervious area (PA) with HSG C. Also, the property has the opportunity to purchase a small adjoining area (0.06 acres), also HSG C, to increase the size of the receiving PA from 0.09 to 0.15 acres and to allow the property owner to avoid having to install a drainage structure to capture overflow runoff from the PA. The property owner has been informed that the existing PA soil can be tilled and augmented with soil amendments to support denser vegetative growth and improve hydrologic function to approximate HSG B.

Determine the:

- A) Percent phosphorus load reduction rates (BMP Reduction %-P) for the specified impervious area (IA) disconnection to both the 0.09 and 0.15 acre receiving PAs with and without soil augmentation; and
- B) Cumulative phosphorus reductions in pounds that would be accomplished by the IA disconnection for the various scenarios (BMP-Reduction _{lbs-P}).

Solution:

1. Determine the ratio of the contributing impervious area to the receiving pervious area:

IA:PA = 0.75 acres/0.09 acres = 8.3 IA:PA = 0.75 acres/0.15 acres = 5.0

Solution Continued:

 Using Table 3-26 and Figure 3-40 for a IA:PA ratios of 8:1 and 5:1, respectively, determine the phosphorus load reduction rates for IA disconnections to HSG C and HSG B:

Percent Phosphorus load reduction rates for IA disconnection					
Dessiving DA	IA:PA				
Receiving FA	8:1	5:1			
HSG C	7%	14%			
HSG B (soil augmentation)	14%	22%			

Table Example 3-6-A: Reduction Rates

3. The cumulative phosphorus load reduction in pounds of phosphorus for the IA disconnection with storage (BMP-Reduction _{lbs-P}) is calculated using Equation 3-2. The BMP Load was calculated in example 3-5 and is 1.34 lbs/yr.

BMP Reduction $_{lbs-P}$ = BMP Load x (BMP Reduction $_{h-P}/100$) For PA of 0.09 acres HSG C the BMP Reduction $_{lbs-P}$ is calculated as follows: BMP Reduction $_{lbs-P(0.09ac-HSG C)}$ = 1.34 lbs/yr x (7/100)

= 0.09 lbs/yr

Table Example 3-6-B presents the BMP Reduction _{lbs-P} for each of the scenarios:

Table Examp	ole 3-6-B: Reduction

Pounds Phosphorus load reduction for IA disconnection, lbs/yr					
Receiving PA	Area of Receiving PA, acres				
	0.09	0.15			
HSG C	0.09	0.19			
HSG B (soil augmentation)	0.19	0.29			

Example 3-7: Determine the phosphorus load reduction for converting impervious area to permeable/pervious area.

A municipality is planning upcoming road reconstruction work in medium density residential (MDR) neighborhoods and has identified an opportunity to convert impervious surfaces to permeable/pervious surfaces by narrowing the road width of 3.7 miles (mi) of roadway from 32 feet (ft) to 28 ft and eliminating 3.2 miles of 4 ft wide paved sidewalk (currently there are sidewalks on both sides of the roadways targeted for restoration). The newly created permeable/pervious area will be tilled and treated with soil amendments to support vegetated growth in order to restore hydrologic function to at least HSG B. Determine the:

- A) Percent phosphorus load reduction rate (BMP Reduction %-P) for the conversion of impervious area (IA) to permeable/pervious area (PA); and
- B) Cumulative phosphorus reduction in pounds that would be accomplished by the project (BMP-Reduction _{lbs-P}).

Solution:

1. Determine the area of IA to be converted to PA:

New PA = (((3.7 mi x 4 ft) + (3.2 mi x 4 ft)) x 5280 ft/mi)/43,560 ft²/acre = 3.35 acres

- Using Table 3-27, the phosphorus load reduction rate for converting IA to HSG B is 94.1%
- 3. The BMP Load is first determined using the method described above.

BMP Load = IA x phosphorus export loading rate for MDR IA (see Table 3-1)

= 3.35 acres x 1.96 lbs/acre/yr

= 6.57 lbs/yr

4. The cumulative phosphorus load reduction in pounds of phosphorus for the IA conversion (BMP-Reduction _{lbs-P}) is calculated using Equation 3-2.

BMP Reduction $_{lbs-P}$ = BMP Load x (BMP Reduction $_{\%-P}/100$)

BMP Reduction $_{lbs-P} = 6.57 lbs/yr x (94.1/100)$

= 6.18 lbs/yr

Table 3- 4: Infiltration Trench (IR = 0.17 in/hr) BMP Performance Table

Infiltration Trench (IR = 0.17 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Runoff Volume Reduction	14.7%	27.6%	48.6%	64.1%	74.9%	82.0%	91.6%	95.4%
Cumulative Phosphorus Load Reduction	18%	33%	57%	73%	83%	90%	97%	99%



Infiltration Trench (IR = 0.27 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1 0.2 0.4 0.6 0.8 1.0 1.5 2.0					2.0		
Runoff Volume Reduction	17.8%	32.5%	55.0%	70.0%	79.3%	85.2%	93.3%	96.3%
Cumulative Phosphorus Load Reduction	20%	37%	63%	78%	86%	92%	97%	99%

Table 3- 5: Infiltration Trench (IR = 0.27 in/hr) BMP Performance Table



Infiltration Trench (IR = 0.52 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1 0.2 0.4 0.6 0.8 1.0 1.5 2.0					2.0		
Runoff Volume Reduction	22.0%	38.5%	61.8%	75.7%	83.7%	88.8%	95.0%	97.2%
Cumulative Phosphorus Load Reduction	23%	42%	68%	82%	89%	94%	98%	99%

Table 3- 6: Infiltration Trench (IR = 0.52 in/hr) BMP Performance Table



Infiltration Trench (IR = 1.02 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1 0.2 0.4 0.6 0.8 1.0 1.5 2.0					2.0		
Runoff Volume Reduction	26.3%	44.6%	68.2%	81.0%	88.0%	92.1%	96.5%	98.3%
Cumulative Phosphorus Load Reduction	27%	47%	73%	86%	92%	96%	99%	100%

Table 3-7: Infiltration Trench (IR = 1.02 in/hr) BMP Performance Table



Infiltration Trench (IR = 2.41 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1 0.2 0.4 0.6 0.8 1.0 1.5 2.0					2.0		
Runoff Volume Reduction	34.0%	54.7%	78.3%	88.4%	93.4%	96.0%	98.8%	99.8%
Cumulative Phosphorus Load Reduction	33%	55%	81%	91%	96%	98%	100%	100%

Table 3-8: Infiltration Trench (IR = 2.41 in/hr) BMP Performance Table



Infiltration Trench (8.27 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction									
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0	
Runoff Volume Reduction	53.6%	76.1%	92.6%	97.2%	98.9%	99.5%	100.0%	100.0%	
Cumulative Phosphorus Load Reduction	50%	75%	94%	98%	99%	100%	100%	100%	

Table 3- 9: Infiltration Trench (8.27 in/hr) BMP Performance Table



Infiltration Basin (0.17 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Runoff Volume Reduction	13.0%	24.6%	44.2%	59.5%	70.6%	78.1%	89.2%	93.9%
Cumulative Phosphorus Load Reduction	35%	52%	72%	82%	88%	92%	97%	99%

Table 3- 10: Infiltration Basin (0.17 in/hr) BMP Performance Table



Infiltration Basin (0.27 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Runoff Volume Reduction	16.3%	29.8%	51.0%	66.0%	76.0%	82.4%	91.5%	95.2%
Cumulative Phosphorus Load Reduction	37%	54%	74 %	85%	90%	93%	98%	99%

Table 3- 11: Infiltration Basin (0.27 in/hr) BMP Performance Table



Infiltration Basin (0.52 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Runoff Volume Reduction	20.2%	35.6%	58.0%	72.6%	81.3%	86.9%	94.2%	96.7%
Cumulative Phosphorus Load Reduction	38%	56%	77%	87%	92%	95%	98%	99%

Table 3- 12: Infiltration Basin (0.52 in/hr) BMP Performance Table



Infiltration Basin (1.02 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Runoff Volume Reduction	24.5%	42.0%	65.6%	79.4%	86.8%	91.3%	96.2%	98.1%
Cumulative Phosphorus Load Reduction	41%	60%	81%	90%	94%	97%	99%	100%

Table 3- 13: Infiltration Basin (1.02 in/hr) BMP Performance Table



Infiltration Basin (2.41 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction								
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Runoff Volume Reduction	32.8%	53.8%	77.8%	88.4%	93.4%	96.0%	98.8%	99.8%
Cumulative Phosphorus Load Reduction	46%	67%	87%	94%	97%	98%	100%	100%

Table 3- 14: Infiltration Basin (2.41 in/hr) BMP Performance Table


Infiltration Basin (8.27 in/hr) BMP Performance Table: Long-Term Phosphorus Load Reduction											
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0			
Runoff Volume Reduction	54.6%	77.2%	93.4%	97.5%	99.0%	99.6%	100.0%	100.0%			
Cumulative Phosphorus Load Reduction	59%	81%	96%	99%	100%	100%	100%	100%			

Table 3- 15: Infiltration Basin (8.27 in/hr) BMP Performance Table



Biofiltration BMP Performance Tal	ole: Lo	ong-Te	erm Pl	hosph	orus L	load F	Reduc	tion			
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0			
Cumulative Phosphorus Load Reduction	19%	34%	53%	64%	71%	76%	84%	89%			

Table 3- 16: Biofiltration BMP Performance Table





Gravel Wetland BMP Performa	ance T Redu	able:	Long-	Term	Phosp	ohorus	s Loac				
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0			
Cumulative Phosphorus Load Reduction	19%	26%	41%	51%	57%	61%	65%	66%			

Table 3- 17: Gravel Wetland BMP Performance Table



Figure 3-14: BMP Performance Curve: Gravel Wetland

Porous Pavement BMP Per Long-Term Phosphorus L	forma oad F	ance Reduc	Table):						
BMP Capacity: Depth of Filter Course Area (inches)	12.0	18.0	24.0	32.0						
Cumulative Phosphorus Load Reduction	62%	70%	75%	78%						

 Table 3- 18: Porous Pavement BMP Performance Table

Figure 3-15: BMP Performance Curve: Porous Pavement



Wet Pond BMP Performance Tabl	e: Lo	ng-T	erm F	Phospl	norus	Load F	Reduct	tion	
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)0.10.20.40.60.81.01.52.0									
Cumulative Phosphorus Load Reduction	14%	25%	37%	44%	48%	53%	58%	63%	

Table 3- 19: Wet Pond BMP Performance Table

Table 3- 20: Dry Pond BMP Performance Table

Dry Pond BMP Performance Table:	Long	g-Ter	m Pl	hosp	horus	Load F	Reduct	ion
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)	0.1	0.2	0.4	0.6	0.8	1.0	1.5	2.0
Cumulative Phosphorus Load Reduction	3%	6%	8%	9%	11%	12%	13%	14%



Figure 3-16: BMP Performance Curve: Dry Pond

Grass Swale BMP Performance Tabl	e: Lo	ong-	Гerm	Phos	phorus	s Load	Redu	ction			
BMP Capacity: Depth of Runoff Treated from Impervious Area (inches)0.10.20.40.60.81.01.52.0											
Cumulative Phosphorus Load Reduction	2%	5%	9%	13%	17%	21%	29%	36%			

Table 3- 21: Grass Swale BMP Performance Table





Imper	ervious Area Disconnection through Storage : Impervious Area to Pervious Area Ratio = 8:1												
Storage				Total]	Runoff Vo	olume (TP) Reduct	ion Perc	entages				
volume to		HSG A			HSG B		HSG C			HSG D			
impervious area ratio	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	
0.1 in	24%	23%	22%	24%	23%	22%	24%	23%	22%	22%	22%	21%	
0.2 in	40%	38%	37%	40%	38%	37%	37%	38%	37%	24%	26%	27%	
0.3 in	52%	50%	49%	52%	50%	49%	40%	46%	49%	24%	26%	27%	
0.4 in	61%	59%	58%	59%	59%	58%	40%	48%	54%	24%	26%	27%	
0.5 in	67%	66%	64%	62%	66%	64%	40%	48%	56%	24%	26%	27%	
0.6 in	70%	71%	70%	62%	70%	70%	40%	48%	56%	24%	26%	27%	
0.8 in	71%	78%	77%	62%	73%	77%	40%	48%	56%	24%	26%	27%	
1.0 in	71%	80%	80%	62%	73%	79%	40%	48%	56%	24%	26%	27%	
1.5 in	71%	81%	87%	62%	73%	81%	40%	48%	56%	24%	26%	27%	
2.0 in	71%	81%	88%	62%	73%	81%	40%	48%	56%	24%	26%	27%	

Table 3- 22: Impervious Area Disconnection through Storage: Impervious Area to Pervious AreaRatio = 8:1

Figure 3- 18: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 8:1 for HSG A Soils







Figure 3- 20: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 8:1 for HSG C Soils







Table 3- 23: Impervious Area Disconnection through Storage: Impervious Area to Pervious AreaRatio = 6:1

Imp	ervious .	Area Dis	connect	ion thro	ugh Stor	age: Imp	ervious	Area to	Pervious	s Area R	atio = 6	:1				
Rain barrel volume to		Total Runoff Volume and Phosphorus Load (TP) Reduction Percentages														
impervious		HSG A			HSG B			HSG C		HSG D						
area ratio	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day				
0.1 in	24%	23%	22%	24%	23%	22%	24%	23%	22%	23%	23%	22%				
0.2 in	40%	38%	37%	40%	38%	37%	40%	38%	37%	28%	30%	33%				
0.3 in	52%	50%	49%	52%	50%	49%	47%	50%	49%	29%	31%	34%				
0.4 in	61%	59%	58%	61%	59%	58%	48%	55%	58%	29%	31%	34%				
0.5 in	67%	66%	64%	67%	66%	64%	48%	57%	63%	29%	31%	34%				
0.6 in	73%	71%	70%	70%	71%	70%	48%	57%	65%	29%	31%	34%				
0.8 in	78%	78%	77%	71%	78%	77%	48%	57%	66%	29%	31%	34%				
1.0 in	79%	81%	80%	71%	79%	80%	48%	57%	66%	29%	31%	34%				
1.5 in	79%	87%	88%	71%	80%	87%	48%	57%	66%	29%	31%	34%				
2.0 in	79%	87%	91%	71%	80%	87%	48%	57%	66%	29%	31%	34%				



Figure 3- 22: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 6:1 for HSG A Soils

Figure 3- 23: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 6:1 for HSG B Soils







Figure 3- 25: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 6:1 for HSG D Soils



Imp	ervious	Area Dis	sconnect	ion throu	ugh Stora	age: Imp	ervious A	Area to I	Pervious	Area Ra	ntio = 4:1	1				
Storage		Total Runoff Volume and Phosphorus Load (TP) Reduction Percentages														
volume to		HSG A			HSG B			HSG C		HSG D						
area ratio	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day				
0.1 in	24%	23%	22%	24%	23%	22%	24%	23%	22%	24%	23%	22%				
0.2 in	40%	38%	37%	40%	38%	37%	40%	38%	37%	37%	37%	37%				
0.3 in	52%	50%	49%	52%	50%	49%	52%	50%	49%	39%	42%	45%				
0.4 in	61%	59%	58%	61%	59%	58%	58%	59%	58%	39%	42%	47%				
0.5 in	67%	66%	64%	67%	66%	64%	60%	65%	64%	40%	42%	47%				
0.6 in	73%	71%	70%	73%	71%	70%	61%	68%	70%	40%	42%	47%				
0.8 in	79%	78%	77%	79%	78%	77%	61%	69%	75%	40%	42%	47%				
1.0 in	82%	81%	80%	80%	81%	80%	61%	69%	76%	40%	42%	47%				
1.5 in	87%	89%	88%	80%	87%	88%	61%	69%	76%	40%	42%	47%				
2.0 in	87%	91%	91%	80%	88%	91%	61%	69%	76%	40%	42%	47%				

 Table 3- 24: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area

 Ratio = 4:1

Figure 3- 26: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 4:1 for HSG A Soils







Figure 3- 28: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 4:1 for HSG C Soils







 Table 3- 25: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area

 Ratio = 2:1

Impe	Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 2:1													
Storage		То	tal Runc	off Volun	ne and P	hosphor	us Load	(TP) Re	duction	Percenta	ages			
volume to		HSG A			HSG B			HSG C		HSG D				
area ratio	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day		
0.1 in	24%	23%	22%	24%	23%	22%	24%	23%	22%	24%	23%	22%		
0.2 in	40%	38%	37%	40%	38%	37%	40%	38%	37%	40%	38%	37%		
0.3 in	52%	50%	49%	52%	50%	49%	52%	50%	49%	51%	50%	49%		
0.4 in	61%	59%	58%	61%	59%	58%	61%	59%	58%	57%	58%	57%		
0.5 in	67%	66%	64%	67%	66%	64%	67%	66%	64%	59%	62%	63%		
0.6 in	73%	71%	70%	73%	71%	70%	72%	71%	70%	59%	62%	67%		
0.8 in	79%	78%	77%	79%	78%	77%	77%	78%	77%	59%	62%	67%		
1.0 in	82%	81%	80%	82%	81%	80%	78%	81%	80%	59%	62%	67%		
1.5 in	89%	89%	88%	89%	89%	88%	78%	84%	88%	59%	62%	67%		
2.0 in	92%	92%	91%	91%	92%	91%	78%	84%	89%	59%	62%	67%		



Figure 3- 30: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio= 2:1 for HSG A Soils

Figure 3- 31: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio= 2:1 for HSG B Soils







Figure 3- 33: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio= 2:1 for HSG D Soils



Impe	Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 1:1												
Storage		To	tal Runo	off Volun	ne and P	hosphori	us Load	(TP) Red	duction	Percenta	ages		
volume to		HSG A			HSG B			HSG C		HSG D			
area ratio	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	1-day	2-day	3-day	
0.1 in	24%	23%	22%	24%	23%	22%	24%	23%	22%	24%	23%	22%	
0.2 in	40%	38%	37%	40%	38%	37%	40%	38%	37%	40%	38%	37%	
0.3 in	52%	50%	49%	52%	50%	49%	52%	50%	49%	52%	50%	49%	
0.4 in	61%	59%	58%	61%	59%	58%	61%	59%	58%	61%	59%	58%	
0.5 in	67%	66%	64%	67%	66%	64%	67%	66%	64%	67%	66%	64%	
0.6 in	73%	71%	70%	73%	71%	70%	73%	71%	70%	72%	71%	70%	
0.8 in	79%	78%	77%	79%	78%	77%	79%	78%	77%	78%	78%	77%	
1.0 in	82%	81%	80%	82%	81%	80%	82%	81%	80%	79%	80%	80%	
1.5 in	89%	89%	88%	89%	89%	88%	89%	89%	88%	80%	82%	86%	
2.0 in	92%	92%	91%	92%	92%	91%	91%	92%	91%	80%	82%	86%	

 Table 3- 26: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area

 Ratio = 1:1

Figure 3- 34: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 1:1 for HSG A Soils







Figure 3- 36: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 1:1 for HSG C Soils





Figure 3- 37: Impervious Area Disconnection through Storage: Impervious Area to Pervious Area Ratio = 1:1 for HSG D Soils

	Table 3-27:	Impervious	Area Disconn	ection Perfor	mance Table
--	-------------	------------	--------------	---------------	-------------

Impervious area	Soil type of Receiving Pervious Area			
to pervious area ratio	HSG A	HSG B	HSG C	HSG D
8:1	30%	14%	7%	3%
6:1	37%	18%	11%	5%
4:1	48%	27%	17%	9%
2:1	64%	45%	33%	21%
1:1	74%	59%	49%	36%
1:2	82%	67%	60%	49%
1:4	85%	72%	67%	57%





Table 3- 28: Performance Table for Conversion of Impervious Areas to Pervious Area based onHydrological Soil Groups

	Cumulative Reduction in Annual Stormwater Phosphorus Load					
Land-Use Group	Conversion of impervious area to pervious area-HSG A	Conversion of impervious area to pervious area-HSG B	Conversion of impervious area to pervious area-HSG C	Conversion of impervious area to pervious area-HSG C/D	Conversion of impervious area to pervious area-HSG D	
Commercial (Com) and Industrial (Ind)	98.5%	93.5%	88.0%	83.5%	79.5%	
Multi-Family (MFR) and High-Density Residential (HDR)	98.8%	95.0%	90.8%	87.3%	84.2%	
Medium -Density Residential (MDR)	98.6%	94.1%	89.1%	85.0%	81.4%	
Low Density Residential (LDR) - "Rural"	98.2%	92.4%	85.9%	80.6%	75.9%	
Highway (HWY)	98.0%	91.3%	84.0%	78.0%	72.7%	
Forest (For)	98.2%	92.4%	85.9%	80.6%	75.9%	
Open Land (Open)	98.2%	92.4%	85.9%	80.6%	75.9%	
Agriculture (Ag)	70.6%	70.6%	70.6%	70.6%	70.6%	

		<u></u>	<u>-</u>		
	Cumulative Reduction in Annual SW Phosphorus Load from Pervious Area				
Land Cover	Conversion of pervious area HSG D to pervious area- HSG A	Conversion of pervious area HSG D to pervious area- HSG B	Conversion of pervious area HSG D to pervious area- HSG C	Conversion of pervious area HSG C to pervious area- HSG A	Conversion of pervious area HSG C to pervious area- HSG B
Developed Pervious Land	92.7%	68.3%	41.5%	83.5%	79.5%

Table 3- 29: Performance Table for Conversion of Low Permeable Pervious Area to High Permeable Pervious Area based on Hydrological Soil Group

Table 3-30 Method for determining stormwater of	control design volume (DSV) (i.e.	, capacity) using Long-term cumulative
performance curves		

Stormwater Control Type	Description	Applicable Structural Stormwater Control Performance Curve	Equation for calculating Design Storage Capacity for Estimating Cumulative Reductions using Performances Curves
Infiltration Trench	Provides temporary storage of runoff using the void spaces within the soil/sand/gravel mixture that is used to backfill the trench for subsequent infiltration into the surrounding sub-soils.	Infiltration Trench (6 infiltration rates: 0.17, 0.27, 0.52, 1.02, 2.41 and 8.27 inches per hour)	DSV = void space volumes of gravel and sand layersDSV = (L x W x Dstone x nstone) + (L x W x Dsand x nsand)
Subsurface Infiltration	Provides temporary storage of runoff using the combination of storage structures (e.g., galleys, chambers, pipes, etc.) and void spaces within the soil/sand/gravel mixture that is used to backfill the system for subsequent infiltration into the surrounding sub-soils.	Infiltration Trench (6 infiltration rates: 0.17, 0.27, 0.52, 1.02, 2.41 and 8.27 inches per hour)	DSV = Water storage volume of storage units and void space volumes of backfill materials. Example for subsurface galleys backfilled with washed stone: DSV = $(L \times W \times D)_{galley} + (L \times W \times D_{stone} \times n_{stone})$
Surface Infiltration	Provides temporary storage of runoff through surface ponding storage structures (e.g., basin or swale) for subsequent infiltration into the underlying soils.	Infiltration Basin (6 infiltration rates: 0.17, 0.27, 0.52, 1.02, 2.41 and 8.27 inches per hour)	$\begin{split} DSV &= \text{Water volume of storage structure before bypass.} \\ Example for linear trapezoidal vegetated swale \\ DSV &= (L x ((W_{bottom} + W_{top@Dmax})/2) x D) \end{split}$
Rain Garden/Bio- retention (no underdrains)	Provides temporary storage of runoff through surface ponding and possibly void spaces within the soil/sand/gravel mixture that is used to filter runoff prior to infiltration into underlying soils.	Infiltration Basin (6 infiltration rates: 0.17, 0.27, 0.52, 1.02, 2.41 and 8.27 inches per hour)	DSV = Ponding water storage volume and void space volumes of soil filter media. Example for raingarden : DSV = $(A_{pond} \times D_{pond}) + (A_{soil} \times D_{soil} \times n_{soil mix})$
Tree Filter (no underdrain)	Provides temporary storage of runoff through surface ponding and void spaces within the soil/sand/gravel mixture that is used to filter runoff prior to infiltration into underlying soils.	Infiltration Trench (6 infiltration rates: 0.17, 0.27, 0.52, 1.02, 2.41 and 8.27 inches per hour)	DSV = Ponding water storage volume and void space volumes of soil filter media. DSV = (L x W x D _{ponding}) + (L x W x D _{soil} x n _{soil mix})
Bio-Filtration (w/underdrain)	Provides temporary storage of runoff for filtering through an engineered soil media. The storage capacity includes void spaces in the filter media and temporary ponding at the surface. After runoff has passed through the filter media it is collected by an under-drain pipe for discharge. Manufactured or packaged bio-filter systems such as tree box filters may be suitable for using the bio-filtration performance results.	Bio-filtration	DSV = Ponding water storage volume and void space volume of soil filter media. Example of a linear biofilter: DSV = (L x W x D _{ponding})+ (L x W x D _{soil} x n _{soil})
Gravel Wetland	Based on design by the UNH Stormwater Center (UNHSC). Provides temporary surface ponding storage of runoff in a vegetated wetland cell that is eventually routed to an underlying saturated gravel internal storage reservoir (ISR) for nitrogen treatment. Outflow is controlled by an elevated orifice that has its invert elevation equal to the top of the ISR layer and provides a retention time of at least 24 hours.	Gravel Wetland	DSV = pretreatment volume + ponding volume + void space volume of gravel ISR. DSV = (A pretreatment x Dpre Treatment)+ (A wetland x Dponding)+ (AISR x Dgravel x ngravel)
Porous Pavement with subsurface infiltration	Provides filtering of runoff through a filter course and temporary storage of runoff within the void spaces of a subsurface gravel reservoir prior to infiltration into subsoils.	Infiltration Trench (6 infiltration rates: 0.17, 0.27, 0.52, 1.02, 2.41 and 8.27 inches per hour)	$DSV = void space volumes of gravel layer$ $DSV = (L x W x D_{stone} x n_{stone})$
Porous pavement w/ impermeable underliner w/underdrain	Provides filtering of runoff through a filter course and temporary storage of runoff within the void spaces prior to discharge by way of an underdrain.	Porous Pavement	Depth of Filter Course = D_{FC}
Wet Pond	Provides treatment of runoff through routing through permanent pool.	Wet Pond	DSV= Permanent pool volume prior to high flow bypass DSV=Apond x Dpond (does not include pretreatment volume)
Extended Dry Detention Basin	Provides temporary detention storage for the design storage volume to drain in 24 hours through multiple out let controls.	Dry Pond	DSV= Ponding volume prior to high flow bypass DSV=Apond x Dpond (does not include pretreatment volume)
Dry Water Quality Swale/Grass Swale	Based on MA design standards. Provides temporary surface ponding storage of runoff in an open vegetated channel through permeable check dams. Treatment is provided by filtering of runoff by vegetation and check dams and infiltration into subsurface soils.	Grass swale	DSV = Volume of swale at full design depth DSV=Lswale x Aswale
Definitions: DSV = Design Sto surface area for calculating volu	orage Volume = physical storage capacity to hold water; VSV = Void Space Volume; L = leaume; Infiltration rate = saturated soil hydraulic conductivity	ngth, $\mathbf{W} = $ width, $\mathbf{D} = $ depth at design cap	acity before bypass, \mathbf{n} = porosity fill material, \mathbf{A} = average

Pollutant Causing Impairment	Monitoring Parameter	EPA or Approved Method No.
Aluminum	Aluminum, Total	200.7; 200.8; 200.9
Ammonia (Un-ionized)	Ammonia – Nitrogen	350.1
Arsenic	Arsenic, Total	200.7; 200.8; 200.9
Cadmium	Cadmium, Total	200.7; 200.8; 200.9
Chlordane	NMR	608; 625
Chloride	Chloride	300
Chromium (total)	Chromium, Total	200.7; 200.8; 200.9
Copper	Copper, Total	200.7; 200.8; 200.9
DDT	NMR	608; 625
DEHP (Di-sec-octyl phthalate)	NMR	
Dioxin (including 2,3,7,8-TCDD)	NMR	613; 1613
Dioxin (2,3,7,8-Tetrachlorodibenzo-p-dioxin only)	NMR	613
Lead	Lead, Total	200.7; 200.8; 200.9
Mercury in Water Column	NMR unless potentially present such (e.g., salvage yards crushing vehicles with Hg switches)	200.7; 200.8; 200.9
Nitrogen (Total)	Nitrogen, Total	351.1/351.2 + 353.2
Pentachlorophenol (PCP)	NMR	
Petroleum Hydrocarbons	Oil and Grease	1664
Phosphorus (Total)	Phosphorus, Total	365.1; 365.2; 365.3; SM 4500-P-E
Polychlorinated biphenyls	NMR	
Polycyclic Aromatic Hydrocarbons (PAHs) (Aquatic Ecosystems)	PAHs	610; 1625
Sulfide-Hydrogen Sulfide	NMR	
Mercury in Fish Tissue	NMR	
PCB in Fish Tissue	NMR	
Total Dissolved Solids	Total Dissolved Solids	160.1
Total Suspended Solids (TSS)	Total Suspended Solids	160.2, 180.1
Turbidity	Total Suspended Solids and Turbidity	160.2, 180.1
Secchi disk transparency	Total Suspended Solids	160.2
Sediment Screening Value (Exceedence)	Total Suspended Solids	160.2

Appendix G Massachusetts Small MS4 Permit Monitoring Requirements For Discharges into Impaired Waters – Parameters and Methods

Sedimentation/Siltation	Total Suspended Solids	160.2
Bottom Deposits	Total Suspended Solids	160.2
Color	NMR	
pH, High	pH	150.2
pH, Low	pH	150.2
Taste and Odor	NMR	
Temperature, water	NMR	
Salinity	Specific Conductance	120.1
Enterococcus	Enterococcus	1106.1; 1600; Enterolert® 12 22.
Escherichia coli	E. coli	1103.1; 1603; Colilert [®] 12 16, Colilert-18 [®] 12 15 16.; mColiBlue- 24 [®] 17.
Fecal Coliform	Fecal Coliform	1680; 1681
Organic Enrichment (Sewage) Biological Indicators	Enterococcus (marine waters) or E. coli (freshwater)	1106.1; 1600
Debris/Floatables/Trash	NMR	or
Foam/Flocs/Scum/Oil Slicks	Contact MassDEP	1103.1; 1603
Oil and Grease	Oil and Grease	
Chlorophyll	Total Phosphorus (freshwater)	
Chlorophyn-a	Total Nitrogen (marine waters)	1664
Nutriant/Eutrophisation Dialogical Indicators	Total Phosphorus (freshwater)	365.1; 365.2; 365.3
Nutrient/Eutrophication Biological indicators	Total Nitrogen (marine waters)	351.1/351.2 + 353.2
	Dissolved Oxygen	365.1; 365.2; 365.3
	Temperature	351.1/351.2 + 353.2
Dissolved oxygen saturation / Oxygen Dissolved	BOD ₅	360.1; 360.2
Dissolved oxygen saturation / Oxygen, Dissolved	Total Phosphorus (freshwater)	SM-2550
	Total Nitrogen (marine waters)	SM-5210
Excess Algal Growth	Total Phosphorus (freshwater)	365.1; 365.2; 365.3
	Total Nitrogen (marine waters)	351.1/351.2 + 353.2
Aquatic Plants (Macrophytes)	NMR	

Abnormal Fish deformities, erosions, lesions, tumors (DELTS)	NMR	
Abnormal Fish Histology (Lesions)	NMR	
Estuarine Bioassessments	Contact MassDEP	
Fishes Bioassessments	Contact MassDEP	
Aquatic Macroinvertebrate Bioassessments	Contact MassDEP	
Combined Biota/Habitat Bioassessments	Contact MassDEP	
Habitat Assessment (Streams)	Contact MassDEP	
Lack of a coldwater assemblage	Contact MassDEP	
Fish Kills	Contact MassDEP	
Whole Effluent Toxicity (WET)	Contact MassDEP	
Ambient Bioassays Chronic Aquatic Toxicity	Contact MassDEP	
Sediment Bioassays Acute Toxicity Freshwater	Contact MassDEP	
Sediment Bioassays Chronic Toxicity Freshwater	Contact MassDEP	
Fish-Passage Barrier	NMR	
Alteration in stream-side or littoral vegetative covers	NMR	
Low flow alterations	NMR	
Other flow regime alterations	NMR	
Physical substrate habitat alterations	NMR	
Other anthropogenic substrate alterations	NMR	
Non-Native Aquatic Plants	NMR	
Eurasian Water Milfoil, Myriophyllum spicatum	NMR	
Zebra mussel, Dreissena polymorph	NMR	
Other	Contact MassDEP	

Notes:

NMR" indicates no monitoring required

"Total Phosphorus (freshwater)" indicates monitoring required for total phosphorus where stormwater discharges to a water body that is freshwater

"Total Nitrogen (marine water)" indicates monitoring required for total nitrogen where stormwater discharges to a water body that is a marine or estuarine water

APPENDIX H

Requirements Related to Discharges to Certain Water Quality Limited Waterbodies

Table of Contents

I.	Discharges to water quality limited waterbodies and their tributaries where nitrogen is the cause of the impairment
II.	Discharges to water quality limited waterbodies and their tributaries where phosphorus is the cause of the impairment
III.	Discharges to water quality limited waterbodies where bacteria or pathogens is the cause of the impairment
IV.	Discharges to water quality limited waterbodies where chloride is the cause of the impairment
V.	Discharges to water quality limited waterbodies and their tributaries where solids, oil and grease (hydrocarbons), or metals is the cause of the impairment

Attachment 1- Nitrogen Reduction Credits For Selected Structural BMPs

I. <u>Discharges to water quality limited waterbodies and their tributaries where nitrogen is the cause of the impairment</u>

- 1. Part 2.2.2.a.i. of the permit identifies the permittees subject to additional requirements to address nitrogen in their stormwater discharges because they discharge to waterbodies that are water quality limited due to nitrogen, or their tributaries, without an EPA approved TMDL. Permittees identified in part 2.2.2.a.i of the permit must identify and implement BMPs designed to reduce nitrogen discharges in the impaired catchment(s). To address nitrogen discharges each permittee shall comply with the following requirements:
 - a. Additional or Enhanced BMPs
 - i. The permittee remains subject to all the requirements of part 2.3. of the permit and shall include the following enhancements to the BMPs required by part 2.3 of the permit:
 - 1. Part 2.3.2, Public education and outreach: The permittee shall supplement its Residential and Business/Commercial/Institution program with annual timed messages on specific topics. The permittee shall distribute an annual message in the spring (April/May) timeframe that encourages the proper use and disposal of grass clippings and encourages the proper use of slow-release fertilizers. The permittee shall distribute an annual message in the summer (June/July) timeframe encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee shall distribute an annual message in the Fall (August/September/October) timeframe encouraging the proper disposal of leaf litter. The permittee shall deliver an annual

message on each of these topics, unless the permittee determines that one or more of these issues is not a significant contributor of nitrogen to discharges from the MS4 and the permittee retains documentation of this finding in the SWMP. All public education messages can be combined with requirements of Appendix H part II and III as well as Appendix F part A.III, A.IV, A.V, B.I, B.II and B.III where appropriate.

- 2. Part 2.3.6, Stormwater Management in New Development and Redevelopment: the requirement for adoption/amendment of the permittee's ordinance or other regulatory mechanism shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for nitrogen removal; retrofit inventory and priority ranking under 2.3.6.1.b shall include consideration of BMPs to reduce nitrogen discharges.
- 3. Part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: establish requirements for use of slow release fertilizers on permittee owned property currently using fertilizer, in addition to reducing and managing fertilizer use as provided in 2.3.7.1; establish procedures to properly manage grass cuttings and leaf litter on permittee property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces; increase street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 Dec 1; following leaf fall).
- b. Nitrogen Source Identification Report
 - i. Within four years of the permit effective date the permittee shall complete a Nitrogen Source Identification Report. The report shall include the following elements:
 - 1. Calculation of total MS4 area draining to the water quality limited water segments or their tributaries, incorporating updated mapping of the MS4 and catchment delineations produced pursuant to part 2.3.4.6,
 - 2. All screening and monitoring results pursuant to part 2.3.4.7.d., targeting the receiving water segment(s)
 - 3. Impervious area and DCIA for the target catchment
 - 4. Identification, delineation and prioritization of potential catchments with high nitrogen loading
 - 5. Identification of potential retrofit opportunities or opportunities for the installation of structural BMPs during redevelopment
 - ii. The final Nitrogen Source Identification Report shall be submitted to EPA as part of the year 4 annual report.
- c. Potential Structural BMPs

- i. Within five years of the permit effective date, the permittee shall evaluate all permittee-owned properties identified as presenting retrofit opportunities or areas for structural BMP installation under permit part 2.3.6.d.ii. or identified in the Nitrogen Source Identification Report that are within the drainage area of the impaired water or its tributaries. The evaluation shall include:
 - 1. The next planned infrastructure, resurfacing or redevelopment activity planned for the property (if applicable) OR planned retrofit date;
 - 2. The estimated cost of redevelopment or retrofit BMPs; and
 - 3. The engineering and regulatory feasibility of redevelopment or retrofit BMPs.
- ii. The permittee shall provide a listing of planned structural BMPs and a plan and schedule for implementation in the year 5 annual report. The permittee shall plan and install a minimum of one structural BMP as a demonstration project within the drainage area of the water quality limited water or its tributaries within six years of the permit effective date. The demonstration project shall be installed targeting a catchment with high nitrogen load potential. The permittee shall install the remainder of the structural BMPs in accordance with the plan and schedule provided in the year 5 annual report.
- iii. Any structural BMPs listed in Table 3 of Attachment 1 to Appendix H already existing or installed in the regulated area by the permittee or its agents shall be tracked and the permittee shall estimate the nitrogen removal by the BMP consistent with Attachment 1 to Appendix H. The permittee shall document the BMP type, total area treated by the BMP, the design storage volume of the BMP and the estimated nitrogen removed in mass per year by the BMP in each annual report.
- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix H part I.1. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The receiving water and all downstream segments are determined to no longer be impaired due to nitrogen by MassDEP and EPA concurs with such determination.
 - ii. An EPA approved TMDL for the receiving water or downstream receiving water indicates that no additional stormwater controls for the control of nitrogen are necessary for the permittee's discharge based on wasteload allocations as part of the approved TMDL.
 - b. In such a case, the permittee shall document the date of the determination provided for in paragraph a. above or the approved TMDL date in its SWMP and is relieved of any additional requirements of Appendix H part I.1. as of the applicable date and the permittee shall comply with the following:

- i. The permittee shall identify in its SWMP all activities that have been implemented in accordance with the requirements of Appendix H part I.1. as of the applicable date to reduce nitrogen in its discharges, including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
- The permittee shall continue to implement all requirements of Appendix H part I.1. required to be done prior to the date of determination or the date of the approved TMDL, including ongoing implementation of identified nonstructural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

II. <u>Discharges to water quality limited waterbodies and their tributaries where phosphorus is</u> <u>the cause of the impairment</u>

- 1. Part 2.2.2.b.i. of the permit identifies the permittees subject to additional requirements to address phosphorus in their stormwater discharges because they discharge to waterbodies that are water quality limited due to phosphorus, or their tributaries, without an EPA approved TMDL. Permittees identified in part 2.2.2.b.i. of the permit must identify and implement BMPs designed to reduce phosphorus discharges in the impaired catchment(s). To address phosphorus discharges each permittee shall comply with the following requirements:
 - a. Additional or Enhanced BMPs
 - i. The permittee remains subject to the requirements of part 2.3. of the permit and shall include the following enhancements to the BMPs required by part 2.3 of the permit:
 - 1. Part 2.3.2, Public education and outreach: The permittee shall supplement its Residential and Business/Commercial/Institution program with annual timed messages on specific topics. The permittee shall distribute an annual message in the spring (March/April) timeframe that encourages the proper use and disposal of grass clippings and encourages the proper use of slow-release and phosphorous-free fertilizers. The permittee shall distribute an annual message in the summer (June/July) timeframe encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee shall distribute an annual message in the fall (August/September/October) timeframe encouraging the proper disposal of leaf litter. The permittee shall deliver an annual message on each of these topics, unless the permittee determines that one or more of these issues is not a significant contributor of phosphorous to discharges from the MS4 and the permittee retains documentation of this finding in the SWMP. All public education messages can be combined with requirements of Appendix H part I and III as well as Appendix F part A.III, A.IV, A.V, B.I, B.II and B.III where appropriate.
 - 2. Part 2.3.6, Stormwater Management in New Development and Redevelopment: the requirement for adoption/amendment of the permittee's ordinance or other regulatory mechanism shall include a requirement that new development and redevelopment stormwater management BMPs be optimized for phosphorus removal; retrofit inventory and priority ranking under 2.3.6.1.b shall include consideration of BMPs that infiltrate stormwater where feasible.
 - 3. Part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: Establish procedures to properly manage grass cuttings and leaf litter on permittee property, including prohibiting blowing organic waste materials onto adjacent impervious surfaces; increased street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a

minimum of two times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 - Dec 1; following leaf fall).

- b. Phosphorus Source Identification Report
 - i. Within four years of the permit effective date the permittee shall complete a Phosphorus Source Identification Report. The report shall include the following elements:
 - 1. Calculation of total MS4 area draining to the water quality limited receiving water segments or their tributaries, incorporating updated mapping of the MS4 and catchment delineations produced pursuant to part 2.3.4.6,
 - 2. All screening and monitoring results pursuant to part 2.3.4.7.d., targeting the receiving water segment(s)
 - 3. Impervious area and DCIA for the target catchment
 - 4. Identification, delineation and prioritization of potential catchments with high phosphorus loading
 - 5. Identification of potential retrofit opportunities or opportunities for the installation of structural BMPs during redevelopment, including the removal of impervious area
 - ii. The phosphorus source identification report shall be submitted to EPA as part of the year 4 annual report.
- c. Potential Structural BMPs
 - i. Within five years of the permit effective date, the permittee shall evaluate all permittee-owned properties identified as presenting retrofit opportunities or areas for structural BMP installation under permit part 2.3.6.d.ii or identified in the Phosphorus Source Identification Report that are within the drainage area of the water quality limited water or its tributaries. The evaluation shall include:
 - 1. The next planned infrastructure, resurfacing or redevelopment activity planned for the property (if applicable) OR planned retrofit date;
 - 2. The estimated cost of redevelopment or retrofit BMPs; and
 - 3. The engineering and regulatory feasibility of redevelopment or retrofit BMPs.
 - ii. The permittee shall provide a listing of planned structural BMPs and a plan and schedule for implementation in the year 5 annual report. The permittee shall plan and install a minimum of one structural BMP as a demonstration project within the drainage area of the water quality limited water or its tributaries within six years of the permit effective date. The demonstration project shall be installed targeting a catchment with high phosphorus load potential. The permittee shall install the

remainder of the structural BMPs in accordance with the plan and schedule provided in the year 5 annual report.

- iii. Any structural BMPs installed in the regulated area by the permittee or its agents shall be tracked and the permittee shall estimate the phosphorus removal by the BMP consistent with Attachment 3 to Appendix F. The permittee shall document the BMP type, total area treated by the BMP, the design storage volume of the BMP and the estimated phosphorus removed in mass per year by the BMP in each annual report.
- 2. At any time during the permit term the permittee may be relieved of additional requirements in Appendix H part II.1. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The receiving water and all downstream segments are determined to no longer be impaired due to phosphorus by MassDEP and EPA concurs with such determination.
 - ii. An EPA approved TMDL for the receiving water or downstream receiving water indicates that no additional stormwater controls for the control of phosphorus are necessary for the permittee's discharge based on wasteload allocations as part of the approved TMDL.
 - b. In such a case, the permittee shall document the date of the determination provided for in paragraph a. above or the approved TMDL date in its SWMP and is relieved of any additional requirements of Appendix H part II.1. as of the applicable date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities that have been implemented in accordance with the requirements of Appendix H part II.1. as of the applicable date to reduce phosphorus in its discharges, including implementation schedules for non structural BMPs and any maintenance requirements for structural BMPs
 - The permittee shall continue to implement all requirements of Appendix H part II.1. required to be done prior to the date of determination or the date of the approved TMDL, including ongoing implementation of identified nonstructural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications.

III. <u>Discharges to water quality limited waterbodies where bacteria or pathogens is the cause of the impairment</u>

- 1. Consistent with part 2.2.2.c.i. of the permit, permittees that discharge to waterbodies that are water quality limited due to bacteria or pathogens, without an EPA approved TMDL, are subject to the following additional requirements to address bacteria or pathogens in their stormwater discharges.
- 2. Additional or Enhanced BMPs
 - a. The permittee remains subject to the requirements of part 2.3. of the permit and shall include the following enhancements to the BMPs required by part 2.3 of the permit:
 - Part 2.3.2. Public Education and outreach: The permittee shall supplement its Residential program with an annual message encouraging the proper management of pet waste, including noting any existing ordinances where appropriate. The permittee or its agents shall disseminate educational materials to dog owners at the time of issuance or renewal of a dog license, or other appropriate time. Education materials shall describe the detrimental impacts of improper management of pet waste, requirements for waste collection and disposal, and penalties for non-compliance. The permittee shall also provide information to owners of septic systems about proper maintenance in any catchment that discharges to a water body impaired for bacteria or pathogens. All public education messages can be combined with requirements of Appendix H part I and II as well as Appendix F part A.III, A.IV, A.V, B.I, B.II and B.III where appropriate.
 - ii. Part 2.3.4 Illicit Discharge: The permittee shall implement the illicit discharge program required by this permit. Catchments draining to any waterbody impaired for bacteria or pathogens shall be designated either Problem Catchments or HIGH priority in implementation of the IDDE program.
- 3. At any time during the permit term the permittee may be relieved of additional requirements in Appendix H part III.2. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The receiving water is determined to be no longer impaired due to bacteria or pathogens by MassDEP and EPA concurs with such a determination.
 - ii. An EPA approved TMDL for the receiving water indicates that no additional stormwater controls are necessary for the control of bacteria or pathogens from the permittee's discharge based on wasteload allocations as part of the approved TMDL.
 - iii. The permittee's discharge is determined to be below applicable water quality criteria¹ and EPA agrees with such a determination. The permittee shall submit data to EPA that accurately characterizes the concentration of bacteria or pathogens in their discharge. The characterization shall include water quality

¹ Applicable water quality criteria are the state standards that have been federally approved as of the effective date of this permit and are compiled by EPA at <u>http://www.epa.gov/waterscience/standards/wqslibrary/</u>

and flow data sufficient to accurately assess the concentration of bacteria or pathogens in all seasons during storm events of multiple sizes and for the duration of the storm events including the first flush, peak storm flow and return to baseflow.

- b. In such a case, the permittee shall document the date of the determination, date of approved TMDL or date of EPA concurrence that the discharge meets water quality criteria in its SWMP and is relieved of any additional requirements of Appendix H part III.2. as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix H part III.2. to date to reduce bacteria or pathogens in its discharges, including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix H part III.3. required to be done prior to the date of determination date, date of approved TMDL, or date of EPA concurrence that the discharge meets water quality criteria, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications

IV. Discharges to water quality limited waterbodies where chloride is the cause of the impairment

- 1. Consistent with part 2.2.2.c.i. of the permit, permittees that discharge to waterbodies that are water quality limited due to chloride, without an EPA approved TMDL, are subject to the following additional requirements to address chloride in their stormwater discharges.
- 2. Permittees discharging to a waterbody listed as impaired due to chloride in categories 5 or 4b on the Massachusetts Integrated Report of waters listed pursuant to Clean Water Act sections 303(d) and 305(b) shall develop a Salt Reduction Plan that includes specific actions designed to achieve salt reduction on municipal roads and facilities, and on private facilities that discharge to its MS4 in the impaired catchment(s). The Salt Reduction Plan shall be completed within three years of the effective date of the permit and include the BMPs in part IV.4. below. The Salt Reduction Plan shall be fully implemented five years after the effective date of the permit.
- 3. Permittees that, during the permit term, become aware that their discharge is to a waterbody that is impaired due to chloride must update their Salt Reduction Plan within 60 days of becoming aware of the situation to include salt reduction practices targeted at lowering chloride in discharges to the impaired waterbody. If the permittee does not have a Salt Reduction Plan already in place, then the permittee shall complete a Salt Reduction Plan that includes the BMPs in part IV 4) below within 3 years of becoming aware of the situation and fully implement the Salt Reduction Plan within 5 years of becoming aware of the situation.
- 4. Additional or Enhanced BMPs
 - a. For municipally maintained surfaces:
 - i. Tracking of the types and amount of salt applied to all permittee owned and maintained surfaces and reporting of salt use beginning in the year of the completion of the Salt Reduction Plan in the permittee's annual reports;
 - ii. Planned activities for salt reduction on municipally owned and maintained surfaces, which shall include but are not limited to the following unless the permittee determines one or more of the following is not applicable to its system and documents that determination as part of the Salt Reduction Plan:
 - Operational changes such as pre-wetting, pre-treating the salt stockpile, increasing plowing prior to de-icing, monitoring of road surface temperature, etc.;
 - Implementation of new or modified equipment providing prewetting capability, better calibration rates, or other capability for minimizing salt use;
 - Training for municipal staff and/or contractors engaged in winter maintenance activities;
 - Adoption of guidelines for application rates for roads and parking lots (see *Winter Parking Lot and Sidewalk Maintenance*

Manual (Revised edition June 2008) http://www.pca.state.mn.us/publications/parkinglotmanual.pdf; and the application guidelines on page 17 of Minnesota Snow and Ice Control: Field Handbook for Snow Operators (September 2012) http://www.mnltap.umn.edu/publications/handbooks/documents /snowice.pdf for examples);

- Regular calibration of spreading equipment;
- Designation of no-salt and/or low salt zones;
- Measures to prevent exposure of salt stockpiles (if any) to precipitation and runoff; and
- An estimate of the total tonnage of salt reduction expected by each activity.
- b. For privately maintained facilities that discharge to the MS4:
 - i. Establish an ordinance, bylaw, or other regulatory mechanism requiring measures to prevent exposure of any salt stockpiles to precipitation and runoff at all commercial and industrial properties within the regulated area.
 - ii. Part 2.3.2. Public Education and Outreach: The permittee shall supplement its Commercial/Industrial education program with an annual message to private road salt applicators and commercial and industrial site owners on the proper storage and application rates of winter deicing material. The educational materials shall be disseminated in the November/December timeframe and shall describe steps that can be taken to minimize salt use and protect local waterbodies.
 - iii. Part 2.3.6, Stormwater Management in New Development and Redevelopment – establish procedures and requirements to minimize salt usage and require the use of salt alternatives where the permittee deems necessary.
- c. The completed Salt Reduction Plan shall be submitted to EPA along with the annual report following the Salt Reduction Plan's completion. Each subsequent annual report shall include an update on Plan implementation progress, any updates to the Salt Reduction Plan deemed necessary by the permittee, as well as the types and amount of salt applied to all permittee owned and maintained surfaces.
- 5. At any time during the permit term the permittee may be relieved of additional requirements in Appendix H part IV as follows:
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The receiving water is determined to be no longer impaired due to chloride by MassDEP and EPA concurs with such a determination.
 - ii. An EPA approved TMDL for the receiving water indicates that no additional stormwater controls are necessary for the control of chloride from the
permittee's discharge based on wasteload allocations as part of the approved TMDL.

- iii. The permittee's discharge is determined to be below applicable water quality criteria² and EPA agrees with such a determination. The permittee shall submit data to EPA that accurately characterizes the concentration of chloride in their discharge during the deicing season (November March). The characterization shall include water quality and flow data sufficient to accurately assess the concentration of chloride in the deicing season during storm events of multiple sizes and for the duration of the storm events including the first flush, peak storm flow and return to baseflow and include samples collected during deicing activities.
- b. In such a case, the permittee shall document the date of the determination, date of approved TMDL or date of EPA concurrence that the discharge meets water quality criteria in its SWMP and is relieved of any additional requirements of Appendix H part IV as of that date and the permittee shall comply with the following:
 - i. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix H part IV to date to reduce chloride in its discharges, including implementation schedules for non-structural BMPs
 - ii. The permittee shall continue to implement all requirements of Appendix H part IV required to be done by the date of determination date, date of approved TMDL, or date of EPA concurrence that the discharge meets water quality criteria, including ongoing implementation of identified non-structural BMPs

² Applicable water quality criteria are the state standards that have been federally approved as of the effective date of this permit and are compiled by EPA at <u>http://www.epa.gov/waterscience/standards/wqslibrary/</u>

V. <u>Discharges to water quality limited waterbodies and their tributaries where solids, oil and</u> grease (hydrocarbons), or metals is the cause of the impairment

- 1. Consistent with part 2.2.2.c.i. of the permit, permittees that discharge to waterbodies that are water quality limited due to solids, metals, or oil and grease (hydrocarbons), without an EPA approved TMDL, are subject to the following additional requirements to address solids, metals, or oil and grease (hydrocarbons) in their stormwater discharges.
- 2. Additional or Enhanced BMPs
 - a. The permittee remains subject to the requirements of part 2.3. of the permit and shall include the following enhancements to the BMPs required by part 2.3 of the permit:
 - i. Part 2.3.6, Stormwater Management in New Development and Redevelopment: stormwater management systems designed on commercial and industrial land use area draining to the water quality limited waterbody shall incorporate designs that allow for shutdown and containment where appropriate to isolate the system in the event of an emergency spill or other unexpected event. EPA also encourages the permittee to require any stormwater management system designed to infiltrate stormwater on commercial or industrial sites to provide the level of pollutant removal equal to or greater than the level of pollutant removal provided through the use of biofiltration of the same volume of runoff to be infiltrated, prior to infiltration.
 - ii. Part 2.3.7, Good House Keeping and Pollution Prevention for Permittee Owned Operations: increased street sweeping frequency of all municipal owned streets and parking lots to a schedule determined by the permittee to target areas with potential for high pollutant loads. This may include, but is not limited to, increased street sweeping frequency in commercial areas and high density residential areas, or drainage areas with a large amount of impervious area. Prioritize inspection and maintenance for catch basins to ensure that no sump shall be more than 50 percent full. Clean catch basins more frequently if inspection and maintenance activities indicate excessive sediment or debris loadings. Each annual report shall include the street sweeping schedule determined by the permittee to target high pollutant loads.
- 3. At any time during the permit term the permittee may be relieved of additional requirements in Appendix H part V.2. applicable to it when in compliance with this part.
 - a. The permittee is relieved of its additional requirements as of the date when one of the following criteria are met:
 - i. The receiving water is determined to be no longer impaired due to solids, metals, or oil and grease (hydrocarbons) by MassDEP and EPA concurs with such a determination.
 - ii. An EPA approved TMDL for the receiving water indicates that no additional stormwater controls are necessary for the control of solids, metals, or oil and grease (hydrocarbons) from the permittee's discharge based on wasteload allocations as part of the approved TMDL.

- iii. The permittee's discharge is determined to be below applicable water quality criteria and EPA agrees with such a determination³. The permittee shall submit data to EPA that accurately characterizes the concentration of bacteria or pathogens in their discharge. The characterization shall include water quality and flow data sufficient to accurately assess the concentration of bacteria or pathogens in all seasons during storm events of multiple sizes and for the duration of the storm events including the first flush, peak storm flow and return to baseflow.
- b. In such a case, the permittee shall document the date of the determination, date of approved TMDL or date of EPA concurrence that the discharge meets water quality criteria in its SWMP and is relieved of any additional requirements of Appendix H part V.2. as of that date and the permittee shall comply with the following:
 - iv. The permittee shall identify in its SWMP all activities implemented in accordance with the requirements of Appendix H part V.2. to date to reduce solids, metals, or oil and grease (hydrocarbons) in its discharges, including implementation schedules for non-structural BMPs and any maintenance requirements for structural BMPs
 - v. The permittee shall continue to implement all requirements of Appendix H part V.3. required to be done by the date of determination date, date of approved TMDL, or date of EPA concurrence that the discharge meets water quality criteria, including ongoing implementation of identified non-structural BMPs and routine maintenance and replacement of all structural BMPs in accordance with manufacturer or design specifications

³ Applicable water quality criteria are the state standards that have been federally approved as of the effective date of this permit and are compiled by EPA at <u>http://www.epa.gov/waterscience/standards/wqslibrary/</u>

ATTACHMENT 1 TO APPENDIX H

The estimates of nitrogen load reductions resulting from BMP installation are intended for informational purposes only and there is no associated permittee-specific required nitrogen load reduction in the Draft Permit. Nitrogen load reduction estimates calculated consistent with the methodologies below may be used by the permittee to comply with future permit requirements providing the EPA determines the calculated reductions are appropriate for demonstrating compliance with future permit requirements. This attachment provides the method and an example to calculate the BMP nitrogen load as well as methods to calculate nitrogen load reductions for structural BMPs in an impaired watershed.

BMP N Load:

The **BMP N Load** is the annual nitrogen load from the drainage area to each proposed or existing BMP used by permittee. This measure is used to estimate the amount of annual nitrogen load that the BMP will receive or treat (BMP N Load).

To calculate the BMP N Load for a given BMP:

- 1) Determine the total drainage area to the BMP and sort the total drainage area into two categories: total impervious area (IA) and total pervious area (PA);
- 2) Calculate the nitrogen load associated with impervious area (N Load _{IA}) and the pervious area (N Load _{PA}) by multiplying the IA and PA by the appropriate land use-based nitrogen load export rate provided in Table 1; and
- 3) Determine the total nitrogen load to the BMP by summing the calculated impervious and pervious subarea nitrogen loads.

Nitrogen Source Category by	Land Surface	Nitrogen Load Export Rate,	Nitrogen Load Export Rate,
Land Use	Cover	lbs/ac/yr	kg/ha/yr
All Impervious Cover	Impervious	14.1	15.8
*Developed Land Pervious			
(DevPERV)- HSG A	Pervious	0.3	0.3
*Developed Land Pervious			
(DevPERV)- HSG B	Pervious	1.2	1.3
*Developed Land Pervious			
(DevPERV) – HSG C	Pervious	2.4	2.7
*Developed Land Pervious			
(DevPERV) - HSG C/D	Pervious	3.0	3.4
*Developed Land Pervious			
(DevPERV) - HSG D	Pervious	3.7	4.1
Notes: For pervious areas, if the h	ydrologic soil group (HSG) is known, use th	ne appropriate value

Table 1: Annual nitrogen load export rates

Notes: For pervious areas, if the hydrologic soil group (HSG) is known, use the appropriate value from this table. If the HSG is not known, assume HSG C/D conditions for the nitrogen load export rate.

Example 1 to determine nitrogen load to a proposed BMP when the contributing drainage area is 100% impervious: A permittee is proposing a storm water infiltration system that will treat runoff from 1.49 acres of impervious area.

Components of representation	Parameters	Value			
Donding	Maximum depth	0.33 ft			
ronanig	Surface area	645 ft ²			
	Depth	2.0 ft			
Soil mix	Porosity	0.24			
	Hydraulic conductivity	2.5 inches/hour			
	Depth	2.50 ft			
Stone Reservoir (ISR)	Porosity	0.42			
	Hydraulic conductivity	500 inches/hour			
ISR Volume: System Storage Volume	Ratio	0.56			
		12 in			
Orifices	Diameter	Installed 2.5 above impermeable soil			
		layer			

 Table 1-1: Design parameters for Bio-filtration w/ ISR systems for Example 1

Determine:

- A) Percent nitrogen load reduction (BMP Reduction %-N) for the specified bio-filtration w/ISR system and contributing impervious drainage area; and
- **B**) Nitrogen reduction in pounds that would be accomplished by the bio-filtration w/ISR system (BMP-Reduction _{lbs-N})

Solution:

- 1) The BMP is a bio-filtration w/ISR system that will treat runoff from 1.49 acres of impervious area (IA = 1.49 acre);
- 2) The available storage volume capacity (ft³) of the bio-filtration w/ISR system (BMP-Volume _{BMP-ft³}) is determined using the surface area of the system, depth of ponding, the porosity of the filter media and the porosity of the stone reservoir:

BMP-Volume $_{BMP-ft}^3$ =Surface area x (pond maximum depth + (soil mix depth x soil mix porosity) + stone reservoir depth x gravel layer porosity)) = 520 ft² x (0.33 ft + (2.0ft x 0.24) + (2.5 ft x 0.42)) = 1,200 ft³

3) The available storage volume capacity of the bio-filtration w/ISR system in inches of runoff from the contributing impervious area (BMP-Volume _{IA-in}) is calculated using equation 1:

BMP-Volume $_{IA-in} = (BMP-Volume _{ft}^3/IA (acre) x 12 in/ft x 1 acre/43560 ft² (Equation 1)$

Example 1 Continued:

BMP-Volume _{IA-in} = (1,200 ft³/1.49 acre) x 12 in/ft x 1 acre/43560 ft² = 0.22 in

- 4) Using the Regional Performance Curve shown in Figure 1 for a bio-filtration w/ ISR system, a 61% nitrogen load reduction (BMP Reduction %-N) is determined for a bio-filtration w/ ISR systems sized for 0.22 in of runoff from 1.49 acres of impervious area; and
- **5**) Calculate the nitrogen load reduction in pounds of nitrogen for the bio-filtration w/ISR system (BMP Reduction _{lbs-N}) using the BMP Load calculation method shown above in Example 1 and the BMP Reduction _{%-N} determined in step 4 by using equation 2.

First, the BMP Load is determined as specified in Example 1:

 $BMP \text{ Load} = IA (acre) \times 14.1 \text{ lb/ac/yr} \\ = 1.49 \text{ acres } \times 14.1 \text{ lbs/acre/yr} \\ = 21.0 \text{ lbs/yr} \\ BMP \text{ Reduction}_{\text{lbs-N}} = BMP \text{ Load } \times (BMP \text{ Reduction}_{\%-N}/100) \text{ (Equation 2)} \\ BMP \text{ Reduction}_{\text{lbs-N}} = 21 \text{ lbs/yr} \times (61/100) \\ = 12.8 \text{ lbs/yr} \\ \end{bmatrix}$

<u>Method to determine the nitrogen load reduction for a structural BMP with a known</u> storage volume when the contributing drainage area has impervious and pervious surfaces



Flow Chart 2 (previous page). Method to determine the nitrogen load reduction for a BMP with known storage volume when both pervious and impervious drainage areas are present.

1) Identify the type of structural BMP and characterize the contributing drainage area to the structural BMP by identifying the following information for the impervious and pervious surfaces:

Impervious area (IA) – Area (acre) and export rate (Table 1)

Pervious area (**PA**) – Area (acre) and runoff depth based on hydrologic soil group (HSG) and size of rainfall event. Table 2 provides values of runoff depth for various rainfall depths and HSGs. Soils are assigned to an HSG based on their permeability. HSG categories for pervious areas in the Watershed shall be estimated by consulting local soil surveys prepared by the National Resource Conservation Service (NRCS) or by a storm water professional evaluating soil testing results from the Watershed. If the HSG condition is not known, a HSG D soil condition should be assumed.

	Ru	inoff Depth, inche	5
Rainfall Depth,	Pervious HSG	Pervious HSG	Pervious HSG
Inches	A/B	С	D
0.10	0.00	0.00	0.00
0.20	0.00	0.01	0.02
0.40	0.00	0.03	0.06
0.50	0.00	0.05	0.09
0.60	0.01	0.06	0.11
0.80	0.02	0.09	0.16
1.00	0.03	0.12	0.21
1.20	0.04	0.14	0.39
1.50	0.11	0.39	0.72
2.00	0.24	0.69	1.08

Table 2: Developed Land Pervious Area Runoff Depthsbased on Precipitation depth and Hydrological Soil Groups (HSGs)

Notes: Runoff depths derived from combination of volumetric runoff coefficients from Table 5 of *Small Storm Hydrology and Why it is Important for the Design of Stormwater Control Practices*, Pitt, 1999 and using the Stormwater Management Model (SWMM) in continuous model mode for hourly precipitation data for Boston, MA, 1998-2002.

Determine the available storage volume (ft³) of the structural BMP (BMP-Volume ft³) using the BMP dimensions and design specifications (e.g., maximum storage depth, filter media porosity);

3) To estimate the nitrogen load reduction of a BMP with a known storage volume capacity, it is first necessary to determine the portion of available BMP storage capacity (BMP-Volume $_{\rm ft}^3$) that would treat the runoff volume generated from the contributing impervious area (IA) for a rainfall event with a depth of *i* inches (in). This will require knowing the corresponding amount of runoff volume that would be generated from the contributing pervious area (PA) for the same rainfall event (depth of *i* inches). Using equation 3 below, solve for the BMP capacity that would be available to treat runoff from the contributing imperious area for the unknown rainfall depth of *i* inches (see equation 4):

BMP-Volume $_{ft}^3$ = BMP-Volume $_{(IA-ft^3)i}$ + BMP-Volume $_{(PA-ft^3)i}$ (Equation 3)

= the available storage volume of the BMP
= the available storage volume of the BMP that would fully
treat runoff generated from the contributing impervious
area for a rainfall event of size <i>i</i> inches
= the available storage volume of the BMP that would fully
treat runoff generated from the contributing pervious area
for a rainfall event of size <i>i</i> inches

Solving for BMP-Volume (IA-ft³)*i*:

BMP-Volume $_{(IA-ft^3)i}$ = BMP-Volume $_{ft^3}$ - BMP-Volume $_{(PA-ft^3)i}$ (Equation 4)

To determine BMP-Volume $(IA-ft^3)i$, requires performing an iterative process of refining estimates of the rainfall depth used to calculate runoff volumes until the rainfall depth used results in the sum of runoff volumes from the contributing IA and PA equaling the available BMP storage capacity (BMP-Volume ft^3). For the purpose of estimating BMP performance, it will be considered adequate when the IA runoff depth (in) is within 5% IA runoff depth used in the previous iteration.

For the first iteration (1), convert the BMP-Volume $_{ft}^3$ determined in step 2 into inches of runoff from the contributing impervious area (BMP Volume $_{(IA-in)1}$) using equation 5.

BMP-Volume $(IA-in)I = (BMP-Volumeft^3 / IA (acre)) x (12 in/ft /43,560 ft^2/acre) (Equation 5);$

For iterations 2 through n (2...n), convert the BMP Volume $(IA-ft^3)_{2...n}$, determined in step 5a below, into inches of runoff from the contributing impervious area (BMP Volume $(IA-in)_{2...n}$) using equation 6.

BMP-Volume $_{(IA-in)2...n} = (BMP-Volume _{(IA-ft^3)2...n} / IA (acre)) x (12 in/ft /43,560 ft^2/acre) (Equation 6);$

4) For 1 to n iterations, use the pervious runoff depth information from Table 2 and equation 7 to determine the total volume of runoff (ft³) from the contributing PA (BMP Volume

 $_{PA-ft}^{3}$) for a rainfall size equal to the sum of BMP-Volume $_{(IA-in)1}$, determined in step 3. The runoff volume for each distinct pervious area must be determined.

BMP Volume $_{(PA-ft^3)1...n} = \sum ((PA x (runoff depth)_{(PA1, PA2..PAn)} x (3,630 ft^3/acre-in) (Equation 7)$

5) For iteration 1, estimate the portion of BMP Volume that is available to treat runoff from only the IA by subtracting BMP-Volume $_{PA-ft}^3$, determined in step 4, from BMP-Volume $_{ft}^3$, determined in step 2, and convert to inches of runoff from IA (see equations 8 and 9):

BMP-Volume $(IA-ft^3)_2 = ((BMP-Volume_{ft}^3 - BMP Volume_{(PA-ft^3)}))$ (Equation 8)

BMP-Volume $_{(IA-in)2} = (BMP-Volume _{(IA-ft^3)2}/IA (acre)) \times (12 in/ft \times 1 acre/43,560 ft^2)$ (Equation 9)

If additional iterations (i.e., 2 through n) are needed, estimate the portion of BMP volume that is available to treat runoff from only the IA (BMP-Volume (IA-in)3..n+1) by subtracting BMP Volume $(PA-ft^3)2..n$, determined in step 4, from BMP Volume $(IA-ft^3)3..n+1$, determined in step 5, and by converting to inches of runoff from IA using equation 9):

- **6)** For iteration A (an iteration between 1 and n+1), compare BMP Volume _{(IA-in)a} to BMP Volume _{(IA-in)a-1} determined from the previous iteration (a-1). If the difference in these values is greater than 5% of BMP Volume _{(IA-in)a} then repeat steps 4 and 5, using BMP Volume _{(IA-in)a} as the new starting value for the next iteration (a+1). If the difference is less than or equal to 5 % of BMP Volume _{(IA-in)a} then the permittee may proceed to step 7.
- 7) Determine the % nitrogen load reduction for the structural BMP (BMP Reduction _{%-N}) using the appropriate BMP curve on Figure 1 or 2 and the BMP-Volume _{(IA-in)n} calculated in the final iteration of step 5; and
- **8**) Calculate the nitrogen load reduction in pounds of nitrogen for the structural BMP (BMP Reduction _{lbs-N}) using the BMP Load as calculated above in Example 1 and the percent nitrogen load reduction (BMP Reduction _{%-N}) determined in step 7 by using equation 10:

BMP Reduction $_{lbs-N}$ = BMP Load x (BMP Reduction $_{N/100}$) (Equation 10)

Example 2: Determine the nitrogen load reduction for a structural BMP with a known design volume when the contributing drainage area has impervious and pervious surfaces

A permittee is considering an infiltration basin to capture and treat runoff from a portion of the Watershed draining to the impaired waterbody. The contributing drainage area is 16.55 acres and is 71% impervious. The pervious drainage area (PA) is 80% HSG D and 20% HSG C. An infiltration basin with the following specifications can be placed at the down-gradient end of the contributing drainage area where soil testing results indicates an infiltration rate (IR) of 0.28 in/hr:

Example continued:

Structure	Bottom	Top	Maximum	Design	Infiltration
	area	surface	pond depth	storage	Rate
	(acre)	area (acre)	(ft)	volume (ft ³)	(in/hr)
Infiltration basin	0.65	0.69	1.65	48,155	0.28

Determine the:

- A) Percent nitrogen load reduction (BMP Reduction _{%-N}) for the specified infiltration basin and the contributing impervious and pervious drainage area; and
- **B**) Nitrogen reduction in pounds that would be accomplished by the BMP (BMP-Reduction _{lbs-N})

Solution:

1) A surface infiltration basin is being considered. Information for the contributing impervious (IA) and pervious (PA) areas are summarized in below.

Impervious area characteristics										
ID	% Impervious	Area (acre)								
IA1	100	11.75								

Pervious area characteristics									
ID	Area (acre)	Hydrologic Soil							
		Group (HSG)							
PA1	3.84	D							
PA2	0.96	С							

Dominus ques characteristics

- 2) The available storage volume (ft³) of the infiltration basin (BMP-Volume $_{ft}^3$) is determined from the design details and basin dimensions; BMP-Volume $_{ft}^3 = 48,155$ ft³.
- **3)** To determine what the BMP design storage volume is in terms of runoff depth (in) from IA, an iterative process is undertaken:

Solution Iteration 1

For the first iteration (1), the BMP-Volume $_{ft}^3$ is converted into inches of runoff from the contributing impervious area (BMP Volume $_{(IA-in)1}$) using equation 5.

BMP Volume $_{(IA-in)1} = (48,155 \text{ ft}^2/11.75 \text{ acre}) \times (12 \text{ in/ft}/43,560 \text{ ft}^2/\text{acre})$ = 1.13 in

Solution Continued:

4-1) The total volume of runoff (ft³) from the contributing PA (BMP Volume _{PA-ft³}) for a rainfall size equal to the sum of BMP Volume _{(IA-in)1} determined in step 3 is determined

for each distinct pervious area using the information from Table 2 and equation 7. Interpolation was used to determine runoff depths.

BMP Volume $_{(PA-ft^3)1} = ((3.84 \text{ acre x} (0.33 \text{ in}) + (0.96 \text{ acre x} (0.13 \text{ in})) \times 3,630 \text{ ft}^3/\text{acre-in})$ = 5052 ft³

5-1) For iteration 1, the portion of BMP Volume that is available to treat runoff from only the IA is estimated by subtracting the BMP Volume (PA-ft³)1, determined in step 4-1, from BMP Volumeft³, determined in step 2, and converted to inches of runoff from IA:

BMP Volume $_{(IA-ft^3)2} = 48,155 \text{ ft}^3 - 5052 \text{ ft}^3$ = 43,103 ft³ BMP Volume $_{(IA-in)2} = (43,103 \text{ ft}^3/11.75 \text{ acre}) \times (12 \text{ in/ft } \times 1 \text{ acre}/43,560 \text{ ft}^2)$ = 1.01 in

6-1) The % difference between BMP Volume (IA-in) 2, 1.01 in, and BMP Volume (IA-in) 1, 1.13 in is determined and found to be significantly greater than 5%:

% Difference = $((1.13 \text{ in} - 1.01 \text{ in})/1.01 \text{ in}) \times 100$ = 12%

Therefore, steps 4 through 6 are repeated starting with BMP Volume $(IA-in)_2 = 1.01$ in.

Solution Iteration 2

4-2) BMP-Volume $_{(PA-ft^3)2} = ((3.84 \text{ acre x } 0.21 \text{ in}) + (0.96 \text{ acre x } 0.12 \text{ in})) \times 3,630 \text{ ft}^3/\text{acre-in} = 3,358 \text{ ft}^3$

5-2) BMP-Volume $(IA-ft^3)_3 = 48,155 \text{ ft}^3 - 3,358 \text{ ft}^3$ = 44,797 ft³

BMP-Volume $(IA-in)_3 = (44,797 \text{ ft}^3/11.75 \text{ acre}) \times (12 \text{ in/ft } \times 1 \text{ acre}/43,560 \text{ ft}^2)$ = 1.05 in

6-2) % Difference = $((1.05 \text{ in} - 1.01 \text{ in})/1.05 \text{ in}) \times 100$ = 4%

The difference of 4% is acceptable.

Soluti	on Continued:										
7)	7) The % nitrogen load reduction for the infiltration basin (BMP Reduction _{%-N}) is										
	determined by using the RR treatment curve in Figure 2 and the treatment volume (BMP-										
	Volume $_{\text{Net IA-in}} = 1.05$ in) calculated in step 5-2 and is BMP Reduction $_{\text{M-N}} = 56\%$.										
9)	The nitrogen load reduction in pounds of nitrogen (BMP-Reduction \mathbb{I}_{N-N}) for the proposed										
-)	infiltration has in is calculated by using equation 11 with the BMP Load (as determined										
	by the procedure in Example 4-1) and the N $_{}$ of 56%										
	by the procedure in Example 4-1) and the iv target of 5070.										
	BMP Reduction $y = x = BMP N I \text{ ord } x (N + 100)$ (Equation 11)										
	Divid - Reduction Ibs-N = Divid IV Load X (IV target / 100) (Equation 11)										
Follow	ring example 1 the DMD load is calculated:										
FOIIOW	DEPARTURE 1, the DIVIP Todu IS calculated.										
	BMP N Load = (IA x impervious cover nitrogen export loading rate)										
	+ (PA _{HSG D} x pervious cover nitrogen export loading rate, HSG D										
	+ (PA _{HSG C} x pervious cover nitrogen export loading rate, HSG C)										
	= (16.55 acre x 15.4 lbs/acre/yr) + (3.84 acre x 3.7 lbs/acre/yr) +										
	(0.96 acre x 2.4 lbs/acre/yr)										
	= 271.4 lbs/vr										
	<i>2</i> , 1. 1 100/ y1										
	BMD Reduction $y_{1} = 275.13$ lbs/yr y 56/100 - 152.0 lbs/yr										
	Divit - Reduction $108-N = 2/3.13 108/yt = 132.0 108/yt$										



Figure 1: Regional BMP Performance Curve for Annual Nitrogen Load Removal: System Design by the University of New Hampshire Stormwater Center (UNHSWC)

able 5. Classification of Divit to Determine Millogen Reduction								
Structural BMP	Classification							
Infiltration Trench	Runoff Reduction (RR)							
Infiltration Basin or other surface infiltration	Runoff Reduction (RR)							
practice								
Bioretention Practice	Runoff Reduction (RR)							
Gravel Wetland System	Stormwater Treatment (ST)							
Porous Pavement	Runoff Reduction (RR)							
Wet Pond or wet detention basin	Stormwater Treatment (ST)							
Dry Pond or detention basin	Runoff Reduction (RR)							
Water Quality Swale	Runoff Reduction (RR)							

Table 3. Classification of BMP to Determine Nitrogen Reduction¹

¹Recommendations of the Expert Panel to Define Removal Rates for New State Stormwater Performance Standards <u>http://chesapeakestormwater.net/wp-content/plugins/download-monitor/download.php?id=25</u>, Retrieved 12/14/2012



Figure 2: Total Nitrogen Removal for RR and ST Practices

Adopted from: Final CBP Approved Expert Panel Report on Stormwater Retrofits <u>http://chesapeakestormwater.net/wp-content/plugins/download-monitor/download.php?id=25</u>, Retrieved 12/14/2012

STORMWATER MANAGEMENT PLAN

APPENDIX D

2016 Notice of Intent



Part I: C	General Cond	litions							
General Information									
Name of	Name of Municipality or Organization: Hopedale State: MA								
EPA NP	EPA NPDES Permit Number (if applicable): W-040560								
Primar	y MS4 Prog	ram Manager Con	tact Informati	ion					
Name:	Steven Sette		Title:	Town Adm	ninistrator				
Street A	ddress Line 1	78 Hopedale Street P.	O. Box 7						
Street A	ddress Line 2:								
City:	Hopedale			State:	МА	Zip Code:	01747		
Email:	ssette@hoped	ale-ma.gov	Phone	Number: (5	08) 634-2203				
Fax Nun	nber: (508) 634	4-2200							
Other	Information								
Stormw (web ad	ater Manageme ddress or physica	ent Program (SWMP) L Il location, if already com	ocation oleted):	mpleted Dur	ing Permit Ye	ar 2 and Posted	to Town	n Website (2019-2020)	
Engini Endange Nationa	ered Species Ac	rvation Act (NHPA) Determinatior	Complete? Yes	lete? Yes		Eligibility Criter (check all that a Eligibility Criter (check all that a	ia pply): ia pply):	□ A □ B ⊠ C	
Cł	neck the box if y	your municipality or or	ganization was co	overed under	the 2003 MS	4 General Permi	t		
MS4 In Estimat (Part II, I Web add If outfall m or paper cc	ed Percent of (II, IV or V, Subpa dress where MS ap is unavailable or opy of the outfall ma	e (if covered under the 200 Outfall Map Complet ort B.3.(a.) of 2003 permi 64 map is published: In the internet an electronic ap must be included with	3 permit) e? 90% A PDF of the Tow	If 100% of estimated m's Drainage	2003 require date of comp Map, includi	ments not met, o detion (MM/DD/ ng all outfalls ar	enter an (YY): nd receiv	06/30/20 ing waters, is attached.	
NOI submission (see section V for submission options) Regulatory Authorities (if covered under the 2003 permit)									
Illicit Di (Part II, I	ischarge Detec II, IV or V, Subpa	ction and Elimination art B.3.(b.) of 2003 permi	(IDDE) Authority	Adopted?	No	Effective Date of Date of Adoptic	or Estima on (MM/I	ted DD/YY): 06/30/20	
Constru (Part II,II	uction/Erosion II,IV or V, Subpar	and Sediment Contro rt B.4.(a.) of 2003 permit	ol (ESC) Authority)	y Adopted?	No	Effective Date of Date of Adoptic	or Estima on (MM/I	ted DD/YY): 06/30/20	
Post- Co (Part II, I	onstruction St II, IV or V, Subpa	ormwater Manageme art B.5.(a.) of 2003 permi	ent Adopted? (t)		No	Effective Date of Adoptic	or Estima on (MM/I	ted DD/YY): 06/30/20	

Part II: Summary of Receiving Waters

Please list the waterbodies to which your MS4 discharges. For each waterbody, please report the number of outfalls discharging into it and, if applicable, the segment ID and any impairments.

Massachusetts list of impaired waters: Massachusetts 2014 List of Impaired Waters- http://www.mass.gov/eea/docs/dep/water/resources/07v5/14list2.pdf

Waterbody that receives flow from the MS4 and segment ID if applicable	Number of outfalls into receiving water segment	Chloride	Chlorophyll-a	Dissolved Oxygen/ DO Saturation	Nitrogen	Oil & Grease/ PAH	Phosphorus	Solids/ TSS/ Turbidity	E. coli	Enterococcus	Other pollutant(s) causing impairments
Charles River (MA72-03)	1										DDT, Excess Algal Growth, Organic Enrichment (Sewage) Biological Indicators
Hopedale Pond (Formally MA51065 now part of MA51-35)	15										Non-Native Aquatic Plants, Macrophytes, PCB in Fish Tissue
Mill River (MA51-35)	21										Non-Native Aquatic Plants, Macrophytes, PCB in Fish Tissue
Spindleville Pond (MA51158)	2										
Wetland by Freedom Street	1										
Wetland near Centennial Street	5										
Unnamed stream by Driftway Street	2										
Wetland by Culter Street	1										
Wetland behind Dutcher Street	1										
Wetland by Taft Circle	1										
Wetland by Home Park Avenue	1										
Wetland by Greene Street and Oakview Lane	2										
Wetland near Malquinn Drive	1										
Unnamed steam by Jones Road and Tammie Road	2										
Wetland by Lapworth Circle	1										
Wetland by Gaskill Circle	2										
Wetland by Centennial Street	5										
Wetland by Patrick Road	4										

Hopedale

Hopedale											Page 3 of 20
Waterbody that receives flow from the MS4 and segment ID if applicable	Number of outfalls into receiving water segment	Chloride	Chlorophyll-a	Dissolved Oxygen/ DO Saturation	Nitrogen	Oil & Grease/ PAH	Phosphorus	Solids/ TSS/ Turbidity	E. coli	Enterococcus	Other pollutant(s) causing impairments
Wetland by Hammond Road	2										
Unnamed stream by Briarcliff Road	1										
Wetland by Spruce Circle	1										
Wetland by Greene Street and Oakview Lane	6										
Wetland by Greene Street	1										
Wetland on Hopedale Street by Greene Street	5										
Wetland near Mill River by Greene Street	1										
Wetland by Dana Park	1										
Wetland by Mantoni Drive	1										
Wetland by Mill Street and Laurelwood Drive	1										
Unnamed stream by Heron Lane	1										
Wetland by Forest Path and Heron Lane	3										
Wetland by Country Club Lane	1										
Wetland by Larkin Lane and Harmony Trail	2										
Wetland by Haven Way	3										
Wetland by Liberty Circle	5										

Click to lengthen table

Part III: Stormwater Management Program Summary

Identify the Best Management Practices (BMPs) that will be employed to address each of the six Minimum Control Measures (MCMs). For municipalities/organizations whose MS4 discharges into a receiving water with an approved Total Maximum Daily Load (TMDL) and an applicable waste load allocation (WLA), identify any additional BMPs employed to specifically support the achievement of the WLA in the TMDL section at the end of part III.

For each MCM, list each existing or proposed BMP by category and provide a brief description, responsible parties/departments, measurable goals, and the year the BMP will be employed (public education and outreach BMPs also requires a target audience). Use the drop-down menus in each table or enter your own text to override the drop down menu.

MCM 1: Public Education and Outreach

BMP Media/Category (enter your own text to override the drop down menu)	BMP Description	Targeted Audience	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goał	Beginning Year of BMP Imple- mentation
Newspaper Articles/Press Releases/Meeting	Include information in the Town's newspaper regarding Hopedale's stormwater management program specifically targeting residents and how they can impact stormwater and receiving water quality.	Residents	Highway Department	Submit article for publication in the Town newspaper on how residents can impact stormwater and receiving water quality.	FY20
Newspaper Articles/Press Releases/Meeting	Include information in the Town's newspaper regarding Hopedale's stormwater management program specifically targeting businesses, institutions and commercial facilities and how they can impact stormwater and receiving water quality.	Businesses, Institutions and Commercial Facilities	Highway Department	Submit article for publication in the Town newspaper on how businesses, institutions and commercial facilities can impact stormwater and receiving water quality.	FY20

Hopedale

Page 5 of 20

Brochures/Pamphlets	Distribute brochures to prospective developers and contractors providing general information on stormwater management on construction sites and the Town's erosion and sediment control rules and regulations.	Developers (construction)	Planning Board	Distribute brochure/ make brochure available at Town Hall to all prospective developers and maintain a list of all recipients.	FY21
Brochures/Pamphlets	Distribute educational materials to industrial properties regarding stormwater best management practices, including equipment inspection, waste disposal, dumpster maintenance, use and storage of de-icing materials, and parking lot sweeping.	Industrial Facilities	Highway Department	Distribute brochure during Permit Year 3 and maintain a list of all recipients.	FY21
Brochures/Pamphlets	Distribute a flyer about proper septic system maintenance to septic system owners.	Residents	Board of Health	Maintain a list of all recipients of the flyer.	FY22
Brochures/Pamphlets	Distribute brochure about the benefits of adopting low impact development practices such as disconnecting impervious surfaces.	Businesses, Institutions and Commercial Facilities	Highway Department, Conservation Commission	Have Chamber of Commerce distribute brochures. Track number of brochures distributed.	FY22
Brochures/Pamphlets	Promote LID practices such as installation of vegetated filter strips to treat stormwater onsite and infiltrate to offset impervious area created through development.	Developers (construction)	Highway Department, Board of Health, Conservation Commission	Distribute brochures at Town Hall. Track number of brochures distributed.	FY23

Hopedale

Page 6 of 20

Brochures/Pamphlets	Promote LID practices such as installing on- site stormwater treatment systems and reducing impervious area footprint.	Industrial Facilities	Highway Department, Board of Health, Conservation Commission	Distribute brochures at Town Hall. Track number of brochures distributed.	FY23

Part III: Stormwater Management Program Summary (continued)

MCM 2: Public Involvement and Participation

BMP Categorization	Brief BMP Description (enter your own text to override the drop down menu)	Responsible Department/Parties (enter your own text to override the drop down menu)	Additional Description/ Measurable Goal	Beginning Year of BMP Imple- mentation
Public Review	SWMP Review	Highway Department	Allow annual review of stormwater management plan and posting of stormwater management plan on website	FY20
Public Participation	Recycling Program	Board of Health	The Town will continue to accept recyclable materials and track material collected.	FY19
Public Participation	Household haz. waste/used oil collection	Highway Department	The Town will work with the Town's contracted waste hauler and the Board of Health to continue to sponsor Hazardous Waste Collection Days.	FY19

Hopedale

Page 8 of 20

Part III: Stormwater Management Program Summary (continued)

MCM 3: Illicit Discharge Detection and Elimination (IDDE)

BMP Categorization (enter your own text to override the drop down menu)	BMP Description	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)	Beginning Year of BMP Imple- mentation
SSO inventory	Develop SSO inventory in accordance with permit conditions.	Highway Department	Complete within 1 year of effective date of permit.	FY20
Storm sewer system map	Create map and update during IDDE program completion.	Highway Department	Update map within 2 years of effective date of permit and complete full system map 10 years after effective date of permit.	FY20
Written IDDE program	Create written IDDE program.	Highway Department	Complete within 1 year of the effective date of permit and update as required.	FY20
Implement IDDE program	Implement catchment investigations according to program and permit conditions.	Highway Department	Complete 10 years after effective date of permit	FY20
Employee training	Train employees on IDDE implementation,	Highway Department	Train annually	FY20
Conduct dry weather screening	Conduct in accordance with outfall screening procedure and permit conditions.	Highway Department	Complete 3 years after effective date of permit.	FY21
Conduct wet weather screening	Conduct in accordance with outfall screening procedure.	Highway Department	Complete 10 years after effective date of permit.	FY23
Ongoing screening	Conduct dry weather and wet weather screening (as necessary).	Highway Department	Complete ongoing outfall screening upon completion of IDDE program.	FY29

Hopedale

Page 10	ot.	20
---------	-----	----

Priority Ranking	Assess and rank the potential for all catchments to have illicit discharges. Identify catchments with System Vulnerability Factors that will necessitate wet weather sampling.	Highway Department	Complete within 2 year of permit effective date.	FY20
Follow-up Ranking	Update catchment prioritization and ranking as dry weather screening information becomes available.	Highway Department	Complete within 3 years of permit effective date.	FY21
Catchment Investigation Procedures	Develop written catchment investigation procedures and incorporate into IDDE Plan	Highway Department	Complete within 18 months of permit effective date	FY20
	1			

Part III: Stormwater Management Program Summary (continued)

MCM 4: Construction Site Stormwater Runoff Control

BMP Categorization (enter your own text to override the drop down menu or entered text)	BMP Description	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)	Beginning Year of BMP Imple- mentation
Site inspection and enforcement of Erosion and Sediment Control (ESC) measures	The Town's existing Erosion Control Bylaw outlines enforcement procedures. Existing bylaws and regulations will be reviewed and updated as needed to ensure compliance with permit conditions.	Highway Department, Planning Board	Complete within 2 years of the effective date of permit. Report the number of site inspections and enforcement actions annually.	FY20
Site Plan Review	The Town has in place a written Site Plan Review Submission Requirements and Procedures. Written procedures will be reviewed and updated as needed to ensure they meet the requirements of the permit.	Highway Department, Planning Board	Complete within 2 years of the effective date of permit. Report on the number of site plan reviews conducted, and enforcement actions taken annually.	FY20
Erosion and Sediment Control	The Town's Stormwater Regulations currently provide enforcement procedures. Existing bylaws and regulations will be reviewed and updated as needed to ensure compliance with permit conditions.	Highway Department, Planning Board	Continue to enforce existing sediment and erosion control requirements, and update regulations as needed within 2 years of the permit effective date.	FY20

порецате	Ho	ped	lal	e
----------	----	-----	-----	---

Page 12 of 20

Waste Control	Adoption of requirements to control wastes, including but not limited to, discarded building materials, concrete truck wash out,	Highway Department	Complete within 2 years of the effective date of permit	FY20
	chemicals, litter, and sanitary wastes			

÷.,

Part III: Stormwater Management Program Summary (continued)

MCM 5: Post-Construction Stormwater Management in New Development and Redevelopment

BMP Categorization (enter your own text to override the drop down menu or entered text)	BMP Description	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)	Beginning Year of BMP Imple- mentation
As-built plans for on-site stormwater control	The procedures to require submission of as- built drawings and ensure long term operation and maintenance will be a part of the SWMP	Highway Department	Require submission of as-built plans for completed projects	FY20
Target properties to reduce impervious areas	Identify at least 5 permittee-owned properties that could be modified or retrofitted with BMPs to reduce impervious areas and update annually	Highway Department	Complete 4 years after effective date of permit and report annually on retrofitted properties	FY22
Allow green infrastructure	Develop a report assessing existing local regulations to determine the feasibility of making green infrastructure practices allowable when appropriate site conditions exist	Highway Department	Complete 4 years after effective date of permit and implement recommendations of report	FY22
Street design and parking lot guidelines	Develop a report assessing requirements that affect the creation of impervious cover. The assessment will help determine if changes to design standards for streets and parking lots can be modified to support low impact design options.	Highway Department	Complete 4 years after effective date of permit and implement recommendations of report	FY22

3

Hopedale			P	age 14 of 20
Ensure any stormwater controls or management practices for new development and redevelopment meet the retention or treatment requirements of the permit and all applicable requirements of the Massachusetts Stormwater Handbook	Adoption, amendment, or modification of a regulatory mechanism to meet permit requirements	Highway Department	Complete 2 years after effective date of permit	FY20
]	
			1	
	-			

Part III: Stormwater Management Program Summary (continued)

MCM 6: Municipal Good Housekeeping and Pollution Prevention

BMP Categorization (enter your own text to override the drop down menu or entered text)	BMP Description	Responsible Department/Parties (enter your own text to override the drop down menu)	Measurable Goal (all text can be overwritten)	Beginning Year of BMP Imple- mentation
O&M procedures	Create written O&M procedures including all requirements contained in 2.3.7.a.ii for parks and open spaces, buildings and facilities, and vehicles and equipment	Highway Department, Park Commission, Local Schools	Complete and implement 2 years after effective date of permit	FY20
Inventory all permittee-owned parks and open spaces, buildings and facilities, and vehicles and equipment	Create inventory	Highway Department, Parks Commission, Local Schools	Complete 2 years after effective date of permit and implement annually	FY20
Infrastructure O&M	Establish and implement program for repair and rehabilitation of MS4 infrastructure	Highway Department	Complete 2 years after effective date of permit	FY20
Stormwater Pollution Prevention Plan (SWPPP)	Create SWPPPs for maintenance garages, transfer stations, and wastewater treatment facility.	Highway Department	Complete and implement 2 years after effective date of permit	FY20
Catch basin cleaning	Establish schedule for catch basin cleaning such that each catch basin is no more than 50% full and clean catch basins on that schedule	Highway Department	Clean catch basins on established schedule and report number of catch basins cleaned and volume of material removed annually	FY20
Street sweeping program	Sweep all streets and permitee-owned parking lots in accordance with permit conditions	Highway Department	Sweep all streets and permitee-owned parking lots once per year in the spring	FY20
Road salt use optimization program	Establish and implement a program to minimize the use of road salt	Highway Department	Implement salt use optimization during deicing season	FY20

Hopedale Page 16 of 20				
Inspection and maintenance of stormwater treatment structures	Establish and implement inspection and maintenance procedures and frequencies	Highway Department	Inspect and maintain treatment structures at least annually	FY20
Catch Basin Cleaning Optimization	Develop and implement a plan to optimize inspection, cleaning and maintenance of catch basins to ensure that permit conditions are met.	Highway Department	Complete within 2 years of permit effective date.	FY20
	1			
]			

Part III: Stormwater Management Program Summary (continued)

Actions for Meeting Total Maximum Daily Load (TMDL) Requirements

Use the drop-down menus to select the applicable TMDL, action description to meet the TMDL requirements, and the responsible department/parties. If no options are applicable, or more than one, enter your own text to override drop-down menus.

Applicable TMDL	Action Description	Responsible Department/Parties (enter your own text to override the drop down menu)	
Charles River Watershed (Bacteria/Pathogen)	Adhere to requirements in part A.III of Appendix F	Highway Department, Board of Health	
Upper/Middle Charles River (Phosphorus)	Adhere to requirements in part A.I of Appendix F	Highway Department, Planning Board	

Part III: Stormwater Management Program Summary (continued)

Actions for Meeting Requirements Related to Water Quality Limited Waters

Use the drop-down menus to select the pollutant causing the water quality limitation and enter the waterbody ID(s) experiencing excursions above water quality standards for that pollutant. In addition, if you are subject to additional requirements due to a downstream nutrient impairment (see Part 2.2.2 of the permit) select the pollutant of concern and indicate applicable waterbody IDs or write "all waterbodies" if applicable. Choose the action description from the dropdown menu and indicate the responsible party. If no options are applicable, or more than one, **enter your own text to override drop-down menus**.

Pollutant	Waterbody ID(s)	Action Description	Responsible Department/Parties (enter your own text to override the drop down menu)
Phosphorus	Blackstone River (MA51-06)	Adhere to requirements in part I of Appendix H	Highway Department, Planning Board

Part IV: Notes and additional information

Use the space below to indicate the part(s) of 2.2.1 and 2.2.2 that you have identified as not applicable to your MS4 because you do not discharge to the impaired water body or a tributary to an impaired water body due to nitrogen or phosphorus. Provide all supporting documentation below or attach additional documents if necessary. Also, provide any additional information about your MS4 program below.

Through consultation with the US Fish & Wildlife, it was determined that the only threatened species within Hopedale is the northern long-eared bat. Actions currently proposed within this Notice of Intent will not affect this species. As Best Management Practices are constructed in the future, the Town will consult with US Fish & Wildlife prior to construction activities.

Comprehensive mapping of the drainage system has been completed, including mapping of drainage piping, catch basins and manholes in addition to outfalls. Some areas need to be revisited to ensure that all regulated outfalls have been mapped. This is projected to be completed in Permit Year 2. With what has been mapped, there are no federal historic properties near an outfall. Once mapping has been revisited, this will be confirmed.

The provisions within the Town's existing regulatory documents will be further clarified, and restructured as needed, to meet the full intent of the 2003 and the 2016 MS4 Permit during Permit Year 2.

Part V: Certification

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, I certify that the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name:	Steven Sette	Title:	Town Administrator
Signature:	SEASIA	Date:	5/2/19

[To be signed according to Appendix B, Subparagraph B.11, Standard Conditions]

Note: When prompted during signing, save the document under a new file name


United States Department of the Interior

FISH AND WILDLIFE SERVICE New England Ecological Services Field Office 70 Commercial Street, Suite 300 Concord, NH 03301-5094 Phone: (603) 223-2541 Fax: (603) 223-0104 <u>http://www.fws.gov/newengland</u>



April 18, 2019

In Reply Refer To: Consultation Code: 05E1NE00-2019-SLI-1453 Event Code: 05E1NE00-2019-E-03499 Project Name: Hopedale MS4 - Endangered Species Act Determination

Subject: List of threatened and endangered species that may occur in your proposed project location, and/or may be affected by your proposed project

To Whom It May Concern:

The enclosed species list identifies threatened, endangered, proposed and candidate species, as well as proposed and final designated critical habitat, that may occur within the boundary of your proposed project and/or may be affected by your proposed project. The species list fulfills the requirements of the U.S. Fish and Wildlife Service (Service) under section 7(c) of the Endangered Species Act (Act) of 1973, as amended (16 U.S.C. 1531 *et seq.*).

New information based on updated surveys, changes in the abundance and distribution of species, changed habitat conditions, or other factors could change this list. Please feel free to contact us if you need more current information or assistance regarding the potential impacts to federally proposed, listed, and candidate species and federally designated and proposed critical habitat. Please note that under 50 CFR 402.12(e) of the regulations implementing section 7 of the Act, the accuracy of this species list should be verified after 90 days. This verification can be completed formally or informally as desired. The Service recommends that verification be completed by visiting the ECOS-IPaC website at regular intervals during project planning and implementation for updates to species lists and information. An updated list may be requested through the ECOS-IPaC system by completing the same process used to receive the enclosed list.

The purpose of the Act is to provide a means whereby threatened and endangered species and the ecosystems upon which they depend may be conserved. Under sections 7(a)(1) and 7(a)(2) of the Act and its implementing regulations (50 CFR 402 *et seq.*), Federal agencies are required to utilize their authorities to carry out programs for the conservation of threatened and endangered species and to determine whether projects may affect threatened and endangered species and/or designated critical habitat.

A Biological Assessment is required for construction projects (or other undertakings having similar physical impacts) that are major Federal actions significantly affecting the quality of the human environment as defined in the National Environmental Policy Act (42 U.S.C. 4332(2) (c)). For projects other than major construction activities, the Service suggests that a biological evaluation similar to a Biological Assessment be prepared to determine whether the project may affect listed or proposed species and/or designated or proposed critical habitat. Recommended contents of a Biological Assessment are described at 50 CFR 402.12.

If a Federal agency determines, based on the Biological Assessment or biological evaluation, that listed species and/or designated critical habitat may be affected by the proposed project, the agency is required to consult with the Service pursuant to 50 CFR 402. In addition, the Service recommends that candidate species, proposed species and proposed critical habitat be addressed within the consultation. More information on the regulations and procedures for section 7 consultation, including the role of permit or license applicants, can be found in the "Endangered Species Consultation Handbook" at:

http://www.fws.gov/endangered/esa-library/pdf/TOC-GLOS.PDF

Please be aware that bald and golden eagles are protected under the Bald and Golden Eagle Protection Act (16 U.S.C. 668 *et seq.*), and projects affecting these species may require development of an eagle conservation plan (http://www.fws.gov/windenergy/ eagle_guidance.html). Additionally, wind energy projects should follow the wind energy guidelines (http://www.fws.gov/windenergy/) for minimizing impacts to migratory birds and bats.

Guidance for minimizing impacts to migratory birds for projects including communications towers (e.g., cellular, digital television, radio, and emergency broadcast) can be found at: http://www.fws.gov/migratorybirds/CurrentBirdIssues/Hazards/towers/towers.htm; http://www.towerkill.com; and http://www.fws.gov/migratorybirds/CurrentBirdIssues/Hazards/towers/comtow.html.

We appreciate your concern for threatened and endangered species. The Service encourages Federal agencies to include conservation of threatened and endangered species into their project planning to further the purposes of the Act. Please include the Consultation Tracking Number in the header of this letter with any request for consultation or correspondence about your project that you submit to our office.

Attachment(s):

Official Species List

Official Species List

This list is provided pursuant to Section 7 of the Endangered Species Act, and fulfills the requirement for Federal agencies to "request of the Secretary of the Interior information whether any species which is listed or proposed to be listed may be present in the area of a proposed action".

This species list is provided by:

New England Ecological Services Field Office

70 Commercial Street, Suite 300 Concord, NH 03301-5094 (603) 223-2541

Project Summary

Consultation Code:	05E1NE00-2019-SLI-1453
Event Code:	05E1NE00-2019-E-03499
Project Name:	Hopedale MS4 - Endangered Species Act Determination
Project Type:	** OTHER **
Project Description:	Hopedale, Massachusetts MS4 NOI

Project Location:

Approximate location of the project can be viewed in Google Maps: <u>https://www.google.com/maps/place/42.12902407757173N71.54062931517345W</u>



Counties: Norfolk, MA | Worcester, MA

Endangered Species Act Species

There is a total of 1 threatened, endangered, or candidate species on this species list.

Species on this list should be considered in an effects analysis for your project and could include species that exist in another geographic area. For example, certain fish may appear on the species list because a project could affect downstream species.

IPaC does not display listed species or critical habitats under the sole jurisdiction of NOAA Fisheries¹, as USFWS does not have the authority to speak on behalf of NOAA and the Department of Commerce.

See the "Critical habitats" section below for those critical habitats that lie wholly or partially within your project area under this office's jurisdiction. Please contact the designated FWS office if you have questions.

1. <u>NOAA Fisheries</u>, also known as the National Marine Fisheries Service (NMFS), is an office of the National Oceanic and Atmospheric Administration within the Department of Commerce.

Mammals

NAME	STATUS
Northern Long-eared Bat <i>Myotis septentrionalis</i>	Threatened
No critical habitat has been designated for this species. Species profile: <u>https://ecos.fws.gov/ecp/species/9045</u>	

Critical habitats

THERE ARE NO CRITICAL HABITATS WITHIN YOUR PROJECT AREA UNDER THIS OFFICE'S JURISDICTION.

STORMWATER MANAGEMENT PLAN

APPENDIX E

2003 Annual Reports Reference



2003 MS4 PERMIT ANNUAL REPORTS REFERENCE

Year 1 Annual Report (2003-2004)

https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2004/Hopedale04rpt.pdf

Year 2 Annual Report (2004-2005) https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2005/hopedale.pdf

Year 3 Annual Report (2005-2006) https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2006/Hopedale06rpt.pdf

Year 7 Annual Report (2009-2010) https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2010/Hopedale10.pdf

Year 8 Annual Report (2010-2011) https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2011/Hopedale11.pdf

Year 9 Annual Report (2011-2012) https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2012/Hopedale12.pdf

Year 10 Annual Report (2012-2013) https://www3.epa.gov/region1/npdes/stormwater/assets/pdfs/ma/reports/2013/Hopedale13.pdf

STORMWATER MANAGEMENT PLAN

APPENDIX F

MS4 Checklists by Permit Year



Checklist for Year 1 MS4 Permit Requirements – Hopedale, MA

Completion Due Date	Requirement	Task	Permit Section for	Completed?
10/1/2018	Notice of Intent (NOI)	Prepare and Submit NOI for Permit Coverage 90 days from the permit effective date	1.7.2 & Appendix E	Yes
6/30/2019	Stormwater Management Plan (SWMP)	Develop written SWMP	1.10	Yes
6/30/2019	Charles River Pathogens TMDL	Implement public education initiatives; Rank tributary catchments as high for IDDE Investigation	F.A.III.1.a.i.1	Yes
6/30/2019	Phosphorus Impaired Water Bodies	Implement public education initiatives; Sweep streets and municipal parking lots a minimum of two times per year in catchments tributary to phosphorus impaired water bodies	H.II.1.a.i.1; H.II.1.a.i.3	Yes
6/30/2019	Public Education	Fulfill public education initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.2	Yes
6/30/2019	Public Participation	Fulfill public participation initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.3	Yes
6/30/2019	Sanitary Sewer Overflow (SSO) Inventory	Document all SSOs that have occurred in the last 5 years	2.3.4.4.b	Yes
6/30/2019	Illicit Discharge Detection and Elimination (IDDE) Plan	Develop written IDDE plan to satisfy permit requirements.	2.3.4.6	Yes
6/30/2019	Catchment Delineation	Delineate outfall & interconnection catchment areas	2.3.4.5	Yes
6/30/2019	Catchment Prioritization & Ranking	Assess and rank the potential for all catchments to have illicit discharges	2.3.4.7	Yes
6/30/2019	IDDE Employee Training	Continue to train municipal employees on illicit discharge detection and monitoring.	2.3.4.11	Yes
6/30/2019	Construction Site Runoff Control	Create written procedures for inspection of construction sites for proper sediment &	2.3.5.c	No

	Regulatory Updates/SOPs	erosion controls, and conducting site plan reviews. Incorporate requirements for waste control. Reference Stormwater Manual for Sediment & Erosion Control BMPs.		
6/30/2019	Street Sweeping	Sweep streets a minimum of once a year in the spring. Include miles cleaned or volume or mass of material removed in the annual report.	2.3.7.a.iii.3	Yes
6/30/2019	Catch Basin Cleaning	Clean catch basins annually to ensure the no catch basin is more than 50% full. Report catch basins cleaned and volume of material removed annually.	2.3.7.a.iii.3	Yes
6/30/2019	Winter Road Maintenance SOP	Develop and implement winter road maintenance procedures including use and storage of sand/salt, and snow storage practices.	2.3.7.a.iii.5	Yes
6/30/2019	Stormwater BMP Inspection & Maintenance	Inspect stormwater treatment structures (BMPs) at least annually and conduct maintenance as necessary. Track number of structures maintained and inspected annually.	2.3.7.a.iii.6	Yes

Checklist for	Year 2 MS4	Permit Rec	uirements -	- Hopedale.	MA
0110014101101			1411 011101110	1100000000	

Completion Due Date	Requirement	Task	Permit Section for Reference	Completed?
6/30/2020	Stormwater Management Plan (SWMP)	Update written SWMP	1.10	Yes
6/30/2020	Charles River Phosphorus TMDL	Perform legal analysis to ensure authority to implement Phosphorus Control Plan	F.A.I Table F-1 Item 1-1	Partial Completion
6/30/2020	Charles River Pathogens TMDL	Implement public education initiatives	F.A.III.1.a.i.1	Yes
6/30/2020	Phosphorus Impaired Water Bodies	Implement public education initiatives; Modify stormwater regulations to require that new development and redevelopment BMPs are optimized for phosphorus removal; Development of a program to manage grass clippings and leaf litter on permittee-owned property; Sweep streets and municipal parking lots a minimum of two times per year in catchments tributary to phosphorus impaired water bodies	H.II.1.a.i.1; H.II.1.a.i.2; H.II.1.a.i.3	Partial Completion
6/30/2020	Public Education	Fulfill public education initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.2	Yes
6/30/2020	Public Participation	Fulfill public participation initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.3	Yes
6/30/2020	Update Drainage Map	Update town-wide MS4 mapping to include impaired waters, BMPs, interconnections, and open channel conveyances.	2.3.4.5	Yes
6/30/2020	IDDE Employee Training	Continue to train municipal employees on illicit discharge detection and monitoring.	2.3.4.11	Yes
6/30/2025	IDDE Investigation of Problem Catchments	Begin investigation of problem catchments	2.3.4.8.a	Partial Completion
6/30/2020	Post-Construction Stormwater Runoff	Update existing stormwater regulations as needed to	2.3.6.a.ii	No

	Control Regulatory Updates	include compliance with the Stormwater Management Standards, to meet retention and treatment requirements, to meet as-built requirements and provide for long term operation & maintenance of BMPs.		
6/30/2020	Inventory of Municipal Facilities	Develop an inventory of all permittee-owned facilities.	2.3.7.a.ii	Yes
6/30/2020	Operation and Maintenance Procedures	Develop a written set of O&M procedures for municipal facilities, activities and MS4 infrastructure	2.3.7.a.i & 2.3.7.a.iii	Yes
6/30/2020	Stormwater Pollution Prevention Plans (SWPPP)	Develop written SWPPPs for municipal waste handling facilities.	2.3.7.b	Yes
6/30/2020	Street Sweeping	Sweep streets a minimum of once a year in the spring. Include miles cleaned or volume or mass of material removed in the annual report.	2.3.7.a.iii.3	Yes
6/30/2020	Catch Basin Cleaning Optimization	Develop and implement a catch basin cleaning schedule with a goal of ensuring no catch basin is more than 50 % full. Document catch basins inspected and cleaned, including total mass removed and proper disposal.	2.3.7.a.iii.2	Yes
6/30/2020	Stormwater BMP Inspection & Maintenance	Inspect all stormwater treatment structures (BMPs) at least annually and conduct maintenance as necessary. Track number of structures maintained and inspected annually.	2.3.7.a.iii.6	Yes

Completion Due Date	Requirement	Task	Permit Section for Reference	Completed?
6/30/2021	Stormwater Management Plan (SWMP)	Update written SWMP	1.10	Yes
6/30/2021	Charles River Phosphorus TMDL	Perform Funding Assessment to provide for implementation of Phosphorus Control Plan	F.A.I Table F-1 Item 1-2	
6/30/2021	Charles River Pathogens TMDL	Implement public education initiatives	F.A.III.1.a.i.1	
6/30/2021	Phosphorus Impaired Water Bodies	Implement public education initiatives; Sweep streets and municipal parking lots a minimum of two times per year in catchments tributary to phosphorus impaired water bodies	H.II.1.a.i.1; H.II.1.a.i.3	
6/30/2021	Public Education	Fulfill public education initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.2	
6/30/2021	Public Participation	Fulfill public participation initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.3	
6/30/2021	Update Drainage Map	Update town-wide drainage mapping as needed to include MS4 infrastructure.	2.3.4.5	
6/30/2021	IDDE Employee Training	Continue to train municipal employees on illicit discharge detection and monitoring.	2.3.4.11	
6/30/2021	Dry Weather Outfall Screening and Sampling	Sample all outfalls and interconnections (excluding problem outfalls and excluded outfalls) for dry weather flow and sample flow if present.	2.3.4.7.b	
6/30/2021	Update Catchment Ranking	Update catchment ranking and prioritization based on dry weather outfall sampling data.	2.3.4.7.b.iii.c.iii	
6/30/2025	Continue IDDE Investigation of	Continue investigation of problem catchments	2.3.4.8.a	

	Problem Catchments			
6/30/2028	Begin IDDE Investigation of High and Low Priority Catchments	Begin investigation of high and low priority catchments	2.3.4.8.a	
6/30/2021	Street Sweeping	Sweep streets a minimum of once a year in the spring. Include miles cleaned or volume or mass of material removed in the annual report.	2.3.7.a.iii.3	
6/30/2021	Catch Basin Cleaning	Clean catch basins annually to ensure the no catch basin is more than 50% full. Report catch basins cleaned and volume of material removed annually.	2.3.7.a.iii.3	
6/30/2021	Stormwater BMP Inspection & Maintenance	Inspect all stormwater treatment structures (BMPs) at least annually and conduct maintenance as necessary. Track number of structures maintained and inspected annually.	2.3.7.a.iii.6	

Completion Due Date	Requirement	Task	Permit Section for Reference	Completed?
6/30/2022	Stormwater Management Plan (SWMP)	Update written SWMP	1.10	
6/30/2022	Charles River Phosphorus TMDL	Define scope of Phosphorus Control Plan	F.A.I Table F-1 Item 1-3	
6/30/2022	Charles River Pathogens TMDL	Implement public education initiatives	F.A.III.1.a.i.1	
6/30/2022	Phosphorus Impaired Water Bodies	Implement public education initiatives; Inventory and priority ranking of permittee- owned property and infrastructure that can be retrofitted with BMPs to include consideration of BMPs that infiltrate stormwater Sweep streets and municipal parking lots a minimum of two times per year in catchments tributary to phosphorus impaired water bodies; Develop Phosphorus Source Identification Report;	H.II.1.a.i.1; H.II.1.a.i.2; H.II.1.a.i.3; H.II.1.b	
6/30/2022	Public Education	Fulfill public education initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.2	
6/30/2022	Public Participation	Fulfill public participation initiatives aimed at target audiences as outlined in the Town's NOI and this SWMP	2.3.3	
6/30/2022	Update Drainage Map	Update town-wide drainage mapping as needed to include MS4 infrastructure.	2.3.4.5	
6/30/2022	IDDE Employee Training	Continue to train municipal employees on illicit discharge detection and monitoring.	2.3.4.11	
6/30/2025	Continue IDDE Investigation of Problem Catchments	Continue investigation of problem catchments	2.3.4.8.a	

6/30/2028	Continue IDDE Investigation of High and Low Priority Catchments	Continue investigation of high and low priority catchments	2.3.4.8.a
6/30/2028	Begin Wet Weather Outfall Screening and Sampling	Begin sampling outfalls and interconnections with System Vulnerability Factors during wet weather	2.3.4.8.c
6/30/2022	Street Design and Parking Lot Guidelines	Develop a report assessing requirements that affect the creation of impervious cover to determine if design standards for streets and parking lots can be modified to support low impact design options.	2.3.6.b
6/30/2022	Green Infrastructure Practices	Develop a report assessing the barriers and incentives for Green Infrastructure/LID techniques.	2.3.6.c
6/30/2022	BMP Retrofit Identification	Identify 5 permittee-owned properties that could be retrofitted with stormwater BMPs.	2.3.6.d
6/30/2022	Street Sweeping	Sweep streets a minimum of once a year in the spring. Include miles cleaned or volume or mass of material removed in the annual report.	2.3.7.a.iii.3
6/30/2022	Catch Basin Cleaning	Clean catch basins annually to ensure the no catch basin is more than 50% full. Report catch basins cleaned and volume of material removed annually.	2.3.7.a.iii.3
6/30/2022	Stormwater BMP Inspection & Maintenance	Inspect all stormwater treatment structures (BMPs) at least annually and conduct maintenance as necessary. Track number of structures maintained and inspected annually.	2.3.7.a.iii.6

Completion Due Date	Requirement	Task	Permit Section for Reference	Completed?
	Stormwater			
6/30/2023	Management Plan (SWMP)	Update written SWMP	1.10	
6/30/2023	Charles River	Define written Phase I of	F.A.I Table	
	Phosphorus TMDL	Phosphorus Control Plan	F-1 Items 1-	
		including Structural and Non-	4 through	
		Structural Controls, O&M	1-8	
		Plan, Implementation Plan & Cost Estimate		
6/30/2023	Charles River	Implement public education	F.A.III.1.a.i.1	
	Pathogens IMDL	initiatives		
6/30/2023	Phosphorus	Implement public education	H 1 a i 1 [,]	
0,00/2020	Impaired Water	initiatives. Sweep streets and	HII1ai3	
	Bodies	municipal parking lots a	H.II.1.c	
		minimum of two times per		
		year in catchments tributary to		
		phosphorus impaired water		
		bodies; Evaluate all permittee-		
		owned properties identified as		
		presenting retroit		
		structural BMP installation or		
		identified in the Phosphorus		
		Source Identification Report &		
		Develop implementation plan		
0.100.10000		and schedule		
6/30/2023	Public Education	Fulfill public education	000	
		audiences as outlined in the	2.3.2	
		Town's NOI and this SWMP		
6/20/2022	Dublic Darticipation	Fulfill public participation		
0/30/2023	Fublic Failicipation	initiatives aimed at target	233	
		audiences as outlined in the	2.0.0	
		Town's NOI and this SWMP		
6/30/2023	Update Drainage	Update town-wide drainage	2.3.4.5	
	Мар	mapping as needed to		
6/20/0202		Include MS4 Intrastructure.		
0/30/2023	Training	continue to train municipal	02111	
		detection and monitoring.	2.0.4.11	

6/30/2025	Continue IDDE Investigation of Problem Catchments	Continue investigation of problem catchments	2.3.4.8.a	
6/30/2028	Continue IDDE Investigation of High and Low Priority Catchments	Continue investigation of high and low priority catchments	2.3.4.8.a	
6/30/2028	Continue Wet Weather Outfall Screening and Sampling	Begin sampling outfalls and interconnections with System Vulnerability Factors during wet weather	2.3.4.8.c	
6/30/2023	Street Sweeping	Sweep streets a minimum of once a year in the spring. Include miles cleaned or volume or mass of material removed in the annual report.	2.3.7.a.iii.3	
6/30/2023	Catch Basin Cleaning	Clean catch basins annually to ensure the no catch basin is more than 50% full. Report catch basins cleaned and volume of material removed annually.	2.3.7.a.iii.3	
6/30/2023	Stormwater BMP Inspection & Maintenance	Inspect all stormwater treatment structures (BMPs) at least annually and conduct maintenance as necessary. Track number of structures maintained and inspected annually.	2.3.7.a.iii.6	

STORMWATER MANAGEMENT PLAN

APPENDIX G

Public Education Materials





Put Waste in its Place for Clean Water in Hopedale, MA

As a business owner, you are responsible for all pollutants that leave your property. You play a big role in keeping our waterways clean and healthy! Do your part by keeping your property clean and properly storing your trash until pick-up.

OCAI



- Inspect your dumpster daily.
- Make sure the lid is kept closed and locked.
- Check for leaks and replace, if needed.
- Schedule regular trash pick-ups to prevent the dumpster from becoming too full.

Why is this necessary?

Rain that falls into and around your dumpsters can pick up trash and dirt as it drains away. Much of this water, or stormwater, ends up in our lakes, rivers, and streams. It's the fastest growing type of water pollution in Massachusetts. Stormwater pollution is bad business for our state's waterways. It harms fish and wildlife, makes our water unsafe to drink, and can spoil outdoor activities.

> Business owners can do their part to keep Massachusetts' waterways clean. Find more tips like these at www.ThinkBlueMassachusetts.org



- - Don't place leaking containers in the dumpster when emptying trash.
 - Though it's sure to get smelly, never hose down the inside of your dumpster.

NUMPSTED



DON'T



Stop Erosion in its Tracks to Keep Our Waters Clean

DO

DON'T



What can you do?

- Find out if you need a Construction General Permit.
- Visit Hopedale's conservation commission before you disturb the soil.
- Pick a combination of erosion and sediment controls that work for your site.
- This includes practices that protect natural landscape features, like streams and wetlands, and stabilize soil.
- You will also need to use practices to protect and maintain silt fences, storm drain inlets, and construction entrances.

Why is this necessary?

- Water that falls on your construction site either soaks into the ground or runs off into storm drains.
- Water and pollution that goes into storm drains eventually ends up in lakes, rivers, and streams.
- Once these pollutants reach waterways, they can harm fish and other wildlife. They can even make our water unsafe to drink.
- Most importantly, allowing polluted runoff to leave your site and enter a storm drain or waterway is against the law.

Learn more at: www.ThinkBlueMassachusetts.org



Get wise about leaf litter. Consider your options.

- 1. Mulch leaves in place with your lawn mower to put valuable nutrients back into your soil.
- 2. Gather leaves and other "yard waste" into a compost pile, let overwinter and decompose, and then use as fertilizer next growing season.
- 3. Offer your leaves to a neighbor who may be able to use them for composting.
- Residential Brush can be brought to the Recycling Center located at the entrance at the Sewer Treatment Place on Route 16.

Did you know?

The combination of rainfall with leaves on our driveways, sidewalks, streets, and parking lots can produce stormwater runoff into local rivers, streams, and lakes that is loaded with nutrients. Proper use or disposal of leaves will help to minimize contamination of stormwater runoff and protect our water resources.

PERMITS ARE REQUIRED

Residents of Hopedale can purchase a permit sticker at the Recycling Center from an attendant for \$10.

Hopedale's Recycling Center Operating Hours: April 1, 2019 – December 31, 2019 Saturdays - 8:00 am to 3:00 pm Closed during the Winter Months of January, February and March



For more information, call the Board of Health at 508-634-2203 Ext. 222.



Keep Pollution at Bay - One Parking Lot at a Time

As a business owner, you play an important role in keeping our waterways clean and healthy! Follow these tips to reduce polluted runoff, prevent flooding, and make a good impression with your customers.



DO

- Maintain storm drains and stormwater structures 3-4 times per year, and clean and repair as necessary
- Sweep parking lots regularly to collect trash and debris.
- Provide covered trash cans, recycling bins, and cigarette butt receptacles in highly visible areas.
- Consider a dumpster enclosure, pad or fence around dumpsters.

DON'T



- Don't wash vehicles in your parking lot. Use a car wash or vehicle wash bays that direct dirty wash water to the sewer, not storm drains.
- Don't leave dumpsters open.
- Don't let trash cans overflow.

Why is this necessary?

Rain that falls on and around your site can pick up trash, dirt, and chemical residue as it drains away. Much of this water, or stormwater, ends up in our lakes, rivers, and streams. It's the fastest growing type of water pollution in Massachusetts. Stormwater pollution is bad business for our State's waterways. It harms fish and wildlife, makes our water unsafe to drink, and can spoil outdoor activities.

Business owners can do their part to keep Massachusetts' waterways clean. Find more tips like these at <u>www.ThinkBlueMassachusetts.org</u>.



localtownpages edale

Voice of

PRSRT STD **ECRWSS** U.S. POSTAGE PAID PERMIT NO. 142 SPRINGFIELD, MA

Postal Customer Local

June 2020

Changes to the **2020 Annual Town Elections**

1111111111111111111 ABSENTEE OFFICIAL BALLOT ANNUAL TOWN ELECTION OPEDALE, MASSACHUSETTS JUNE 16, 2020 1. 1. 1.1.1 INSTRUCTIONS TO VOTERS INSTRUCTIONS TO VOTERS sky till in the OWAL to the RIGHT of your choice(it to the number of candidates to be marked for e ne is not printed on the ballion write the candidat ne provided and completely fill in the OWAL. co(s) like this . A TO VOTE O me and add ROAD COMMISSIONER PARK COMMISSIONER BOARD OF SELECTMAN CHAEL J. LEDONE INGINAN R. KEYES 100-01 SCHOOL COMMITTEE PLANNING BOARD RISTI BRYTOWSKI BOARD OF HEALTH TREE WARDEN PLANNING BOARD HOUSING AUTHORITY EO F. LYONS TO ELI LEINO SON G. MacDONALD WATER AND SEWER PLANNING BOARD LIBRARY TRUSTEE PARK COMMISSIONER -

Vol. 6 No. 4

.

10

By SUSAN MANNING

Thanks to the Covid - 19 pandemic, the annual town elections were moved from May 12 to June 16.

According to Town Clerk Lisa Pedroli, There hasn't been any negative feedback from the public regarding these changes

moving the election," she said, noting that the Selectmen also spoke about it last week at their meeting.

cial whose term would have expired on May 12, would remain in their position until the election.

of election date include:

at 8 PM (Residents can register online at www.registertovotema.com, as long as you have a signature on file with the Registry of Motor Vehicles, which could be a MA driver's license or a State ID card.)

Hopedale Softball Looking for its Fourth Straight Sectional Title

BY CHRISTOPHER TREMBLAY, STAFF SPORTS WRITER

Entering the 2020 season, the Hopedale softball team was looking to secure its fourth straight Division 3 Central Championship.

Having won the Sectionals over the last three years, the Blue Raiders were looking to get past the Semi Final round of the State Tournament, where they've fallen all three years at the hands of Turner Falls. While Hopedale may have been hoping to exercise the demons of the past, the Blue raiders couldn't have expected what they were about to experience.

"It is always our goal to play as well as we can and

make it into the tournament, win the Sectionals and then the States. It's been pretty much the same thing over the eight years I've been here," Hopedale Coach Shanna Lathrop said. "This season was going to be something that we have never had to deal with before."

Playing in the Dual Valley Conference, Hopedale has always scheduled a season with schools not only in Division 3, but Division 1 and 2 as well to get ready for the tournament. The challenging schedule has shown to be the right move for the Blue Raiders as they have owned the Sectional Tournament but have not been able to get past the

> SOFTBALL continued on page 3



STAFF WRITER

Free to Every Home and Business Every Month

Your Community

"I have not heard any concerns about

It was decided that any incumbent offi-

New deadlines involved with the change

• New voter registration, Friday, June 5

ELECTION continued on page 2







Do Your "Doody" for Clean Water

You hate stepping in it. And fish hate swimming in it, too! Dogs produce a lot of waste which, if not disposed of properly, can end up in our waterways. Do your part to keep our waters and public areas clean and healthy! Bag your pet's waste and throw it in a trashcan.



Did you know that the average dog can produce nearly a pound of waste each day?

- Pet waste left on lawns and in public spaces is not only gross. It can be quite harmful too.
- Pet waste contains twice as much bacteria as human waste!
- If left in your yard, pet waste can kill grass and other plants.
- Adults and children who come in contact with it can get sick.
- When pet waste washes into storm drains and waterways, it can make the water unhealthy for people and wildlife.
- Pet waste in waterways can even cause algae to grow, making the water turn an unpleasant green color.

Do your "doody" in both public areas and in your yard.

To learn more, visit the www.ThinkBlueMassachusetts.org



Do Your Part. Be SepticSmart!



Aquifer

830-F-180-03 May 2018

septicsmart

(SAM)



Lawn and Garden Tips to Help Curb Stormwater Pollution



Under Massachusetts law, only apply fertilizer with phosphorus if: 1. A soil test shows that phosphorus is needed; or

2. During the first growing season for a newly established lawn.

Contact the UMass Cooperative Extension Soil Nutrient Testing Laboratory to learn how to conduct a routine soil test: <u>https://ag.umass.edu/services/soil-plant-nutrient-testing-laboratory/ordering-information-forms</u>

Learn more at: www.ThinkBlueMassachusetts.org





Gas, Oil, and Grease...Oh My! Do Your Part to Stop Spills and Leaks at the Source

DO

DON'T





What can you do?

- Inspect your vehicles and equipment for leaks regularly.
- Use drip pans to catch fluids and keep a cleanup kit nearby in case a spill occurs.
- Cleanup spills immediately.

Why is this necessary?

- Gasoline, oil, and grease from vehicles and equipment can wash into storm drains.
- Water that enters storm drains eventually ends up in our lakes, rivers, and streams.
- Once pollutants reach these waterways, they can harm fish and other wildlife.
- This pollution can even make our water unsafe to drink.

Your industrial facility may be covered by a Multi-Sector General Permit. Under this type of permit, your facility needs to have a Stormwater Pollution Prevention Plan. This plan shows the steps you will take to reduce stormwater pollution. To learn more, check with the Hopedale's conservation commission.

Learn more at: www.ThinkBlueMassachusetts.org



What's the Problem with Dog Waste?

Dog waste left in our yards, forest areas and parks can have many adverse effects on the environment.

It's full of harmful bacteria and excess nutrients.

Besides being a neighborhood nuisance, dog waste can make people sick, especially children who are more likely to come into contact with it while playing.

Dog waste left on lawns can also kill or damage grass and other plants.

When dog waste is washed into lakes or streams, the waste decays, uses up oxygen in the water, and sometimes releases ammonia. This can kill fish!

Dog waste also contains nutrients that encourage weed and algae growth.

Too much of these nutrients turn water cloudy and green . . . imagine this in your backyard pond or stream!





Managing dog waste properly is something easy that everyone can do to make a difference in the quality of our surface waters.



DOG WASTE AND SURFACE WATER QUALITY

Did You Know?

There are over _____ licensed dogs in our town.

Each of these dogs produces about 3⁄4 pound of solid waste and over 7 billion bacteria daily!

STORMWATER MANAGEMENT PLAN

APPENDIX H

Regulatory Mechanisms





Rainfall and snowmelt in the Town of Hopedale goes untreated into our stormwater system, then directly into local streams, ponds, rivers and lakes.

As it flows, stormwater picks up contaminants and pollutants in its path.

That's why it's important to make sure that dog waste and its pollutants do not end up in the storm drains.

What's So Bad About Dog Waste?

Bacteria and other parasites found in pet waste, such as Giardia and Cryptosporidium, can survive for long periods when left on the ground.

During a rain storm, these pollutants can be washed into local rivers and ponds and into local drinking water supplies.

Individual actions can result in significant water quality improvements when carried out by many people.

Unlike some forms of stormwater pollutants, individual people can easily and economically manage dog waste and help keep our waters safe and aesthetically pleasing.

How You Can Help



BRING IT – Always bring a plastic bag when you walk your dog.

BAG IT – Use the bag as a glove to pick up the dog waste. Scoop it up and turn the bag inside out around the waste.

DISPOSE IT – Properly dispose of dog waste by putting it in a trash can. Never throw dog waste down a storm drain.

AND REMEMBER

- Pick up after your pet in your yard
- Only bring your dog where dogs are allowed.



Town of Hopedale Stormwater Management Bylaw

SECTION 1. PURPOSE

- A. Increased volumes of stormwater, contaminated stormwater runoff from impervious surfaces, and soil erosion and sedimentation are major causes of:
 - 1. impairment of water quality;
 - 2. decreased flow in lakes, ponds, streams, rivers, wetlands and groundwater;
 - 3. contamination of drinking water supplies;
 - 4. erosion of stream channels;
 - 5. alteration or destruction of aquatic and wildlife habitat;
 - 6. flooding;
 - 7. overloading or clogging of municipal catch basins and storm drainage systems; and
 - 8. flooding and erosion on abutting properties.

The United States Environmental Protection Agency (EPA) has identified sedimentation from land disturbance activities and polluted stormwater runoff from land development and redevelopment as major sources of water pollution, impacting drinking water supplies, natural habitats, and recreational resources. Regulation of activities that result in the disturbance of land and the creation of stormwater runoff is necessary for the protection of the Town of Hopedale's water bodies and groundwater resources, to safeguard the health, safety, and welfare of the general public and protect the natural resources of the Town.

In addition, this bylaw establishes stormwater management standards for the final conditions that result from development and redevelopment projects to minimize adverse impacts offsite and downstream which would be borne by abutters, townspeople and the general public.

- B. The objectives of this bylaw are to:
 - 1. protect water resources;
 - 2. require practices that eliminate soil erosion and sedimentation;
 - 3. control the volume and rate of stormwater runoff resulting from land disturbance activities in order to minimize potential impacts of flooding;
 - 4. require practices to manage and treat stormwater runoff generated from new development and redevelopment;
 - 5. protect groundwater and surface water from degradation or depletion;
 - 6. promote infiltration and the recharge of groundwater;
 - 7. prevent pollutants from entering the municipal storm drain system;
 - 8. prevent flooding and erosion to abutting properties;

- 9. ensure that soil erosion and sedimentation control measures and stormwater runoff management practices are incorporated into the site planning and design process and are implemented and maintained;
- 10. ensure adequate long-term operation and maintenance of stormwater best management practices so that they work as designed;
- 11. require practices to control waste such as discarded building materials, concrete truck washout, chemicals, litter, and sanitary waste at construction sites that may cause adverse impacts to water quality;
- 12. comply with state and federal statutes and regulations relating to stormwater discharges; and
- 13. establish the Town of Hopedale's legal authority to ensure compliance with the provisions of this **b**ylaw through inspection, monitoring and enforcement.

SECTION 2. APPLICABILITY

A. This Stormwater Bylaw applies to all activities which require a Stormwater Management Permit (SMP) in accordance with Section 5 - Applicability, of the Regulations. No activities which require a SMP may commence until a SMP is issued by the Planning Board, regardless of whether other local permits have been received.

SECTION 3. ADMINISTRATION

- A. The Planning Board shall be the permit granting authority for the issuance of Stormwater Management Permits and shall administer, implement and enforce this Section. Any powers granted to or duties imposed upon the Planning Board may be delegated to its employees or agents or other municipal employees as appropriate. Permit applications shall be submitted, considered and issued only in accordance with the provisions of this Section and the Regulations adopted pursuant to this Section.
- B. Stormwater Regulations. The Planning Board shall adopt, and may periodically amend, rules and regulations relating to the terms, conditions, definitions, enforcement, fees (including application, inspection and/or consultant fees), procedures and administration of this Chapter. The Regulations shall be adopted by majority vote after conducting a public hearing. Such hearing date shall be advertised once in a newspaper of general local circulation, at least fourteen (14) days prior to the hearing date. Failure of the Planning Board to adopt such Regulations or a legal declaration of their invalidity by a court shall not act to suspend or invalidate the effect of this Chapter.

Stormwater Management Permit procedures and submission requirements shall be defined and included as part of the Stormwater Regulations. Such Regulations shall include, but shall not be limited to:

- 1. A requirement that Stormwater Management Permits be issued within 60 days of the date of filing a complete application, unless an extension of time has been granted.
- 2. A procedure for distribution to and review of permit applications by the Town of Hopedale Public Health Administrator and the Director of the Highway Department.
- 3. A requirement for applicants to submit an Operation and Maintenance Plan for the stormwater management system.
- 4. Performance standards which require that projects must meet the Stormwater Management Standards of the Massachusetts Stormwater Management Handbook. The Planning Board will utilize the criteria and information, including specifications and standards, of the latest edition of the Massachusetts Stormwater Management Handbook for execution of the provisions of

this Section. This Handbook includes a list of acceptable stormwater treatment practices, including the specific design criteria for each stormwater practice. The Handbook may be updated and expanded periodically, based on improvements in engineering, science, monitoring, and local maintenance experience. Unless specifically altered in the Stormwater Regulations, stormwater management practices that are designed, constructed, and maintained in accordance with these design and sizing criteria will be presumed to be protective of Massachusetts water quality standards.

- C. Waivers. Strict compliance with this Section or the Stormwater Regulations may be waived by the Planning Board when, in the judgment of the Board, such action is not inconsistent with the purposes of this Section or the Regulations.
- D. Actions by the Planning Board. The Planning Board may take any of the following actions on an application for a Stormwater Management Permit: Approval, Approval with Conditions, or Disapproval. A Permit may be disapproved if the Planning Board determines that the requirements of this Section or the Regulations are not met.
- E. Appeals. A decision of the Planning Board shall be final. Further relief of a decision by the Planning Board made under this Section shall be reviewable in the Superior Court in an action filed within 60 days thereof, in accordance with M.G.L. Ch 249 § 4.

SECTION 4. ENFORCEMENT

- A. When the Planning Board or its agent determines that an activity is not being carried out in accordance with the requirements of this Section, Stormwater Regulations or SMP, it shall issue a written notice of violation to the owner of the property. Persons receiving a notice of violation may be required to:
 - 1. Halt all construction activities until there is compliance. A "stop work order" will be in effect until the Planning Board or its agent confirms that the activity is in compliance and the violation has been satisfactorily addressed.
 - 2. Maintain, install or perform additional erosion and sedimentation control measures;
 - 3. Monitor, analyze and report to the Planning Board;
 - 4. Remediate erosion and sedimentation resulting directly or indirectly from the activity.

Failure to address a notice of violation in the time specified therein may result in penalties in accordance with the enforcement measures authorized in this Section.

- B. Penalty. Any person who violates any provision of this Section, Regulations, or SMP issued thereunder, may be punished by a fine of not more than \$300.00. Each day or part thereof that such violation occurs or continues shall constitute a separate offense, and each provision of the Section, Regulations or SMP violated, shall constitute a separate offense.
- C. Non-Criminal Disposition. As an alternative to the penalty identified in Section 4.B of this bylaw, the Town of Hopedale may elect to utilize the non-criminal disposition procedure of the Bylaws of the Town of Hopedale. Each day or part thereof that such violation occurs or continues shall constitute a separate offense, and each provision of this Chapter, Regulation or permit violated shall constitute a separate offense.

SECTION 5. SEVERABILITY

The invalidity of any section, provision, paragraph, sentence, or clause of this Chapter shall not invalidate any section, provision, paragraph, sentence or clause thereof, nor shall it invalidate any permit or determination that previously has been issued.


Town of Hopedale Stormwater Management Rules & Regulations

SECTION 1. PURPOSE

A. The purpose of these regulations is to protect, maintain and enhance the public health, safety, environment, and general welfare by establishing minimum requirements and procedures to control the adverse effects of soil erosion and sedimentation, construction and post-development stormwater runoff, decreased groundwater recharge and nonpoint source pollution associated with new development, redevelopment and other land alterations, as more specifically addressed in the Town of Hopedale's Stormwater Management Bylaw.

SECTION 2. DEFINITIONS

- A. The definitions contained herein apply to the Town of Hopedale Stormwater Management Bylaw and the Rules and Regulations adopted thereunder. Terms not defined in the section shall be construed according to their customary and usual meaning unless the context indicates a special or technical meaning.
- B. All definitions are provided in Appendix A of the Town of Hopedale Stormwater Management Rules and Regulations.

SECTION 3. AUTHORITY

- A. The Rules and Regulations contained herein have been adopted by the Hopedale Planning Board, hereafter referred to as the Board, in accordance with the Town of Hopedale Stormwater Management Bylaw.
- B. Nothing in these Rules and Regulations is intended to replace or be in derogation of the requirements of the Stormwater Management Bylaw by the Town of Hopedale or any Rules and Regulations adopted thereunder. Any project or activity subject to the provisions of the above-cited Bylaws or Rules and Regulations must comply with the specifications of each. In case of conflict, the more stringent provisions shall apply.
- C. These Rules and Regulations may be periodically amended by the Board in accordance with the procedures outlines in the Town of Hopedale's Stormwater Management Bylaw.
- D. The Board may make revisions to the fee schedule periodically as it sees fit, by the vote of the Board after public notice and opportunity for comments.

SECTION 4. ADMINISTRATON

A. The Board, shall administer, implement and enforce the Regulations. Any powers granted to or duties imposed upon the Board may be delegated in writing by the Board to its employees or agents.

- B. The Board may designate another Town Board, Commission or Department employee thereof or consultant as its authorized agent or designee for the purposes of site inspections of the stormwater management system, and erosion and sediment controls during construction, or site inspection of the stormwater management system post-construction to confirm long-term operation and maintenance in accordance with the requirements of these Regulations.
- C. The Board will distribute copies of the stormwater management applications to the Town of Hopedale Conservation Administrator, Board of Health Administrator, Highway Department Director, and Director of the Water and Sewer Department for review. The Town Clerk shall receive a copy of the stormwater management application directly from the applicant at the same time the application is filed with the Board.
- D. The Board may adopt, and periodically amend, rules and regulations relating to the procedures and administration of these Regulations, by majority vote of *the Board*, after conducting a public hearing to receive comments on any proposed revisions. Such hearing dates shall be advertised in a newspaper of general local circulation, at least seven (7) days prior to the hearing date.

SECTION 5. APPLICABILITY

- A. No person may undertake a construction activity, including clearing, grading and excavation that results in a land disturbance that will disturb equal to or greater than three quarters (3/4) of an acre of land or will disturb less than three quarters (3/4) of an acre of land but is part of a larger common plan of development or sale that will ultimately disturb equal to or greater than three quarters (3/4) of an acre of land draining to the Town of Hopedale's municipal separate storm sewer system without a permit from the Board. Construction activity does not include routine maintenance that is performed to maintain the original line and grade, hydraulic capacity or the original purpose of the site.
- B. Exemptions

Normal maintenance and improvement of land in agricultural use as defined by the Wetlands Protection Act regulation 310 CMR 10.04;

Repair of septic systems when required by the Board of Health for the protection of public health;

Construction of utilities other than drainage (gas, water, electric, telephone, etc.) that will not alter terrain or drainage patterns.

Maintenance of the Town's existing drainage system, including, but not limited to removal of trees, debris, sediment and trash from swales, brooks, culverts, and any other impediment to the flow of the Town's drainage system.

Maintenance of existing landscaping, gardens or lawn areas associated with a single family dwelling;

The construction of fencing that will not substantially alter existing terrain or drainage patterns; and

Construction of utilities other than drainage (gas, water, electric, telephone, etc.) which will not alter terrain or drainage patterns.

SECTION 6. PERMITS and PROCEDURE

A. Stormwater Management Permits

Applicants for projects requiring a SMP shall be required to submit the materials as specified in this section, and are required to meet the stormwater management criteria. Once issued, a SMP shall be valid for a period of 3 years.

- B. SMP Submission Requirements
 - 1. The applicant shall submit six (6) copies of a completed application package with *the Board* and one electronic copy on CD. The applicant shall also simultaneously file an additional copy of the completed application with the Town Clerk. The SMP application package shall include:
 - a. A completed application form with original signatures of all owners. While the applicant can be a representative, the permittee must be the owner of the site.
 - b. A current list of abutters, certified by the Assessor's Office; (abutters at their mailing addresses shown on the most recent applicable tax list of the assessors, including owners of land directly opposite on any public or private street or way, and abutters to the abutters within 300 feet of the property line of the applicant, including any in another municipality).
 - c. One envelope for each abutter on the list of abutters and postage sufficient to send the hearing notice by first class mail.
 - d. Application and review fees.
 - e. Stormwater Management Plan.
 - f. Erosion and Sediment Control Plan.
 - g. Operation and Maintenance Plan.

C. Entry

Filing an application for a permit grants *the Board*, its agent, or designee as specified per Section 5.0 of the bylaw permission to enter the site throughout the term of the application process and the SMP to verify the information in the application and to inspect for compliance with the SMP.

D. Other Boards

The Board shall notify the Town Clerk of receipt of the application, and shall give one copy of the application package to the Planning Board, the Conservation Commission, and Highway Department.

E. Fee Structure

The Board shall obtain with each submission an Application Fee established by the Board to cover expenses connected with the public hearing and application review of the Stormwater Management Permit and a technical Review Fee sufficient to cover professional review. The Board is authorized to retain a Registered Professional Engineer or other professional consultant to advise the Board on any or all aspects of these plans. Applicants must pay review fees before the review process may begin.

An Application Fee to cover expenses connected with the review of the Stormwater Management Permit application and a technical Review Fee sufficient to cover professional review services for the project shall be submitted with each application. Failure to pay Application and Review Fees may be grounds for SMP disapproval. Unless indicated otherwise, fees are payable at the time of application and are non-refundable.

1. Review Fees

The Board is authorized to require an applicant to pay a Review Fee to pay for the reasonable costs and expenses for specific expert engineering and other consultant services to advise the Board on any or all aspects of the SMP application and plans deemed necessary by the Board to come to a final decision on the application and to monitor compliance with a SMP. The services for which a fee may be utilized include, but are not limited to, wetland survey and delineation, hydrologic and drainage analysis, wildlife evaluation, stormwater quality analysis, site inspections, surety review, as-built plan review, and analysis of legal issues.

- a. SMP Application An initial deposit is required. After submission of the SMP Application, the Board will obtain an estimate from its consultant as to the total estimated cost of review of the submitted materials. If the amount of the estimate is greater than the initial deposit, the applicant shall deposit the remaining balance with the Department of Land Use, Planning and Permitting. Consultant review will not begin until the full estimated amount has been provided.
- b. An additional review fee deposit shall be collected from the applicant, if during the review, the deposit is found insufficient to cover the actual cost of the review. The additional review fee shall be based upon a cost estimate from the consultant performing the review, to complete the review.
- c. The Board is authorized to require an applicant to pay reasonable costs and expenses for certain activities which utilize the services of Town Staff. This includes such activities as inquiries concerning potential projects as well as site inspections not associated with a pending permit application.
- d. Review fees collected after SMP issuance for the purpose of monitoring compliance, surety review, site inspections, etc. shall be based on an estimate from the consultant to perform the service to the Board.
- e. The Review fees collected under this section shall be administered in accordance with MGL Chapter 44 § 53G or § 53E ¹/₂.
- F. Public Hearing.

The Board shall hold a public hearing within twenty-one (21) days of the receipt of a complete application and shall take final action within twenty-one (21) days from the close of the hearing unless such time is extended by agreement between the applicant and the Planning Board, Board of Health, Highway Department and Conservation Commission. Notice of the public hearing shall be given by publication in a local paper of general circulation, by posting and by first-class mailings to abutters at least seven (7) days prior to the hearing.

G. Actions.

The Board's action, rendered in writing, shall consist of either:

- 1. Approval of the Stormwater Management Permit Application based upon determination that the proposed plan meets the Standards in Section 7 and will adequately protect the water resources of the community and is in compliance with the requirements set forth in these regulations;
- 2. Approval of the Stormwater Management Permit Application subject to any conditions, modifications or restrictions required by the Board which will ensure that the project meets the Standards in Section 7 and adequately protects water resources, set forth in these Regulations;
- 3. Disapproval of the Stormwater Management Permit Application based upon a determination that the proposed plan, as submitted, does not meet the Standards in Section 7 or adequately protect water resources, as set forth in these Regulations.
- H. Failure to Act

Failure of the Board to take final action upon an Application within the time specified above shall be deemed to be approval of said Application. Upon certification by the Town Clerk that the allowed time has passed without Board action, the Board must issue a Stormwater Management Permit.

- I. Plan Changes and Extensions
 - 1. The permittee, must notify the Board in writing of any drainage change or alteration in the system authorized in a Stormwater Management Permit before any change or alteration is made. If the Board determines that the change or alteration is significant, based on the Stormwater Management Standards in Section 7.B. and accepted construction practices, the Board may require that an amended application be filed, and a public hearing held.
 - 2. Should a land-disturbing activity associated with a SMP not begin during the 2-year period following permit issuance, the Board may evaluate the existing stormwater management plan to determine whether it still satisfies local program requirements and to verify that all design factors are still valid. If the Board finds the previously filed plan to be inadequate, the Board may require that a modified plan shall be submitted and approved prior to the commencement of land-disturbing activities.
 - 3. In the event that the land-disturbing activity associated with a SMP is not completed or begun within 3 years following permit issuance, the applicant/owner may request an extension of the SMP, for a period not to exceed 2 years. A request for extension must be submitted to the Board prior to the expiration of the SMP. Only one such extension may be granted by the Board. An extension may be granted by the Board at its discretion at a public meeting by majority vote.
- J. Appeals of Actions of the Board

A decision of the Board shall be final. Further relief of a decision by the Board made under this bylaw and Regulations shall be reviewable in the Superior Court in an action filed within 60 days thereof, in accordance with M.G.L. Ch. 249. § 4. If such an appeal results in denial of the project approval, the SMP shall be revoked.

- K. Stormwater Management Plan
 - 1. The Stormwater Management Plan shall contain sufficient information for the Board to evaluate the environmental impact, effectiveness, and acceptability of the measures proposed by the applicant for reducing adverse impacts from stormwater runoff. This plan shall be in accordance with the criteria established in the Regulations and must be submitted with the stamp and signature of a Professional Engineer.

The Stormwater Management Plan shall fully describe the project in drawings, narrative and calculations. Required contents of the Stormwater Management Plan are provided in Appendix B.

- L. Erosion and Sediment Control Plan
 - 1. The Erosion and Sediment Control Plan shall be designed to ensure compliance with the SMP, the Regulations, and if applicable, the NPDES General Permit for Storm Water Discharges from Construction Activities. In addition, the plan shall ensure that the Massachusetts Surface Water Quality Standards (314 CMR 4.00) are met in all seasons.
 - 2. If a project requires a Stormwater Pollution Prevention Plan (SWPPP) per the NPDES General Permit for Storm Water Discharges from Construction Activities, then the permittee is required to submit a complete copy of the SWPPP (including the signed Notice of Intent and approval letter). If the SWPPP meets the requirements of the NPDES General Permit, it will be considered equivalent to the Erosion and Sediment Control Plan described in this section.
 - 3. Erosion and Sediment Control Plan Contents

The Erosion and Sediment Control Plan shall contain sufficient information to describe the nature and purpose of the proposed development, pertinent conditions of the site and the adjacent areas, and proposed erosion and sedimentation controls. The applicant shall submit such material as is necessary to show that the proposed development will comply with the design requirements listed in Section 7.0. Required contents of the Erosion and Sediment Control Plan are provided in Appendix C.

- M. Operations and Maintenance Plan
 - 1. The operation and maintenance plan (O&M Plan) shall be designed to ensure compliance with the SMP, the Bylaw and the Regulations, and that the Massachusetts Surface Water Quality Standards, 314 CMR 4.00 are met in all seasons and throughout the life of the system. The O&M Plan shall remain on file with the Board and shall be an ongoing requirement.
 - 2. Required contents of the Operation and Maintenance Plan are provided in Appendix D.
 - 3. Changes to Operation and Maintenance Plans
 - a. The owner(s) of the stormwater management system shall notify the Board immediately of any change in ownership, Responsible Parties, contact information or assignment of financial responsibility.
 - b. The inspection and maintenance schedule in the Maintenance Agreement may be amended to achieve the purposes of the Regulations, by mutual agreement of the Board and the Responsible Parties. Amendments must be in writing and signed by all Responsible Parties.
- N. Stormwater Management Easement(s).
 - 1. Stormwater management easements shall be provided by the property owner(s) as necessary for:
 - a. access for facility inspections and maintenance,
 - b. preservation of stormwater runoff conveyance, infiltration, and detention areas and facilities, including flood routes for the 100-year storm event.
 - c. direct maintenance access by heavy equipment to structures requiring regular cleanout.
 - 2. The purpose of each easement shall be specified in the maintenance agreement signed by the property owner.
 - 3. Stormwater management easements are required for all areas used for off-site stormwater control, unless a waiver is granted by the Board.

Easements shall be recorded with the Worcester County Registry of Deeds prior to issuance of a Certificate of Completion by the Board .

SECTION 7. STORMWATER MANAGEMENT CRITERIA

At a minimum, all projects subject to a SMP shall comply with the performance standards of the most recent version of the Massachusetts Department of Environmental Protection (DEP) Stormwater Management Standards and accompanying Stormwater Management Handbook, as well as the criteria contained in this section.

A. Post-Development Additional Criteria

All stormwater management plans shall comply with the performance criteria provided in Appendix E, unless otherwise provided for in the Regulations.

B. Erosion and Sediment Control Additional Criteria

All erosion and sediment controls shall comply with the performance criteria provided in Appendix F, unless otherwise provided for in the Regulations.

SECTION 8. WAIVERS

- A. The Board may waive strict compliance with any requirement of the Bylaw or the Regulations where such action is:
 - 1. Allowed by federal, state and local statutes and/or regulations.
 - 2. In the public interest, and
 - 3. Not inconsistent with the purpose and intent of the Bylaw or the Regulations.
- B. Requests for waivers shall be submitted in writing. The request shall be accompanied by an explanation or documentation supporting the waiver request and demonstrating that strict application of the Bylaw or the Regulations does not further the purpose or intent of the Bylaw or Regulations. It is recommended that an applicant discuss waiver requests with the Board or its agent or designee prior to a formal submission.
- C. All waiver requests shall be discussed and voted on at the public hearing for the project.
- D. If in the Board 's opinion, additional time or information is required for review of a waiver request, the Board may continue a hearing to a date certain announced at the meeting. In the event the applicant objects to a continuance, or fails to provide requested information, the waiver request shall be denied.

SECTION 9. SURETY

The Board may require the permittee to post before the start of land disturbance or construction activity, a surety bond, irrevocable letter of credit, cash, or other acceptable security. The form of the bond shall be approved by town counsel, and be in an amount deemed sufficient by the Board to ensure that the work will be completed in accordance with the permit. If the project is phased, the Board may release part of the bond as each phase is completed in compliance with the permit but the bond may not be fully released until the Board has received the final inspection report as required by Section 10 and issued a Certificate of Completion.

SECTION 10. INSPECTIONS

- A. Construction Commencement
 - 1. Notice of Construction Commencement

The permittee must notify the Board at least 48 hours prior to the commencement of activities permitted by a SMP and in advance of construction of critical components of the stormwater management system. Notification shall be in writing, via letter, fax or e-mail.

2. Pre-Construction Meeting

The Board may require a pre-construction meeting prior to starting clearing, excavation, construction or land disturbing activity by the permittee. The permittee's technical representative, the general contractor or any other person with authority to make changes to the project, shall meet with the Board or its representative to review construction sequencing and the permitted plans and their implementation.

B. Construction Inspection

Unless indicated otherwise in an issued SMP, inspections of the stormwater management system and erosion and sediment controls during construction shall occur as directed in this section. Written inspection reports shall be submitted to the Board within 48 hours of the inspection. The owner must retain all construction inspection records and reports for a minimum of 5 years from the date of issuance of the Certificate of Completion.

At the discretion of the Board, the inspections shall be conducted by the Board's agent, designee or a professional engineer who has been approved by the Board, at the expense of the permittee. The permittee is responsible for arranging for the Board's agent/representative to be on-site when items are required to be inspected.

The inspection reports must identify any incidents of non-compliance with the permit conditions. Where a report does not identify any incidents of non-compliance, the report must contain a statement that the construction project or site is in compliance with the SMP.

- 1. Inspections of the project site shall be at the following stages, at a minimum:
 - a. Initial Site Inspection: prior to issuance of a SMP.
 - b. Stormwater Management System: The completed stormwater management system, or any component thereof, prior to backfilling of any underground drainage or stormwater conveyance structures.
 - c. The physical markers showing the limits of land disturbance shall be inspected daily.
 - d. Erosion and Sediment Control Plan: At least once every 7 calendar days and within 24 hours of the end of a storm event of 0.5 inches or greater, from the start of construction until the site is permanently stabilized. Inspection frequency may be reduced to at least once a month if the site is temporarily stabilized or runoff is unlikely due to winter conditions (e.g., site is covered with snow, ice, or the ground is frozen). The permittee is required to notify the Board of any change in inspection frequency, including termination of inspections due to site stabilization.
 - e. If a project requires a Stormwater Pollution Prevention Plan (SWPPP) per the NPDES General Permit for Storm Water Discharges from Construction Activities (Construction General Permit), then the permittee is required to submit all Inspection Reports to the Board. If the Inspection Reports meet the requirements of the Construction General Permit, it will be considered equivalent to the Erosion and Sediment Control Inspection as described above.
- 2. All written inspection reports shall contain the following information, at a minimum:
 - The date and location of the inspection;
 - Names, titles and qualifications of personnel making the inspection.
 - a. Stormwater Management Plan Inspection reports of stormwater management systems shall also contain the following:
 - i. Whether construction is in compliance with the approved stormwater management plan,
 - ii. Variations from the approved construction specifications, and
 - iii. Any other variations or violations of the conditions of the approved stormwater management plan.
 - b. Erosion and Sediment Control Inspections of the erosion and sediment controls shall also contain the following:
 - i. Weather information and a description of any discharges occurring at the time of the inspection,
 - ii. Weather information for the period since the last inspection (or since commencement of construction activity if the first inspection) including a best

estimate of the beginning of each storm event, duration of each storm event, approximate amount of rainfall for each storm event (in inches), and whether any discharges occurred,

- iii. Location(s) of discharges of sediment or other pollutants from the site,
- iv. Location(s) of BMPs that need to be maintained,
- v. Location(s) of BMPs that failed to operate as designed or proved inadequate for a particular location,
- vi. Location(s) where additional BMPs are needed that did not exist at the time of inspection, and
- vii. Corrective action required including any changes to the SWPPP necessary and implementation dates.
- 3. Erosion and Sediment Control Inspections

Inspections of the erosion and sediment control practices used on the site are necessary to ensure they are in accord with the approved Erosion and Sediment Control Plan. Inspections must include all areas of the site disturbed by construction activity and areas used for storage of materials that are exposed to precipitation. Inspectors must look for evidence of, or the potential for, pollutants entering the stormwater conveyance system. Sedimentation and erosion control measures identified in the Erosion and Sediment Control Plan must be observed to ensure proper operation. Discharge locations must be inspected to ascertain whether erosion control measures are effective in preventing significant impacts to waters of the United States, where accessible. Where discharge locations are inaccessible, nearby downstream locations must be inspected to the extent that such inspections are practicable. Locations where vehicles enter or exit the site must be inspected for evidence of off-site sediment tracking.

- C. Inadequacy of Stormwater Management System and Erosion and Sediment Control Plan
 - 1. If existing BMPs need to be modified or if additional BMPs are necessary for any reason, implementation must be completed before the next storm event whenever practicable. If implementation before the next storm event is impracticable, the situation must be documented in the SWPPP and alternative BMPs must be implemented as soon as possible.
 - 2. If the stormwater management system is found to be inadequate by virtue of physical evidence of operational failure, even though it was built as called for in the SMP or Stormwater Management Plan, it shall be corrected by the permittee before the Certificate of Completion is issued.
 - 3. If the Board determines that there is a failure to comply with the Stormwater Management Plan, the property owner shall be notified in writing of the nature of the violation and the required corrective actions. A Stop Work Order shall be issued until any violations are corrected and all work previously completed has received approval of the Board.

SECTION 11. FINAL REPORTS

Upon completion of the work, the permittee shall submit a report (including certified as-built construction plans) from a Professional Engineer certifying that all erosion and sediment control devices, and approved changes and modifications, have been completed in accordance with the conditions of the approved permit. Any discrepancies should be noted in the cover letter.

SECTION 12. PROJECT COMPLETION

A. As-Built Plans and Final Inspection

- 1. After the stormwater management system has been constructed and before the surety has been released, the permittee shall submit "as-built" record drawings for all stormwater management facilities, practices and controls, which must be prepared and certified by a Professional Engineer. As-built plans shall be full size plans which reflect the "as built" conditions, including all final grades. All changes to project design should be recorded in red ink on plans to define changes made. All work deleted, corrections in elevations, and changes in materials, should be shown on the as-built drawings. As-builts shall be submitted no later than two (2) years from project completion and must be submitted prior to issuance of a Certificate of Completion.
- 2. The Board's agent/representative shall inspect the system to confirm its "as-built" features. The inspector shall also evaluate the effectiveness of the system during actual storm conditions for a period of up to one year from date of issuance of the Certificate of Completion. If the inspector finds the system adequate, a report to this effect shall be submitted to *the Board*.
- B. Certificate of Completion
 - 1. Upon completion of the project which is subject of the SMP, the applicant is responsible for providing certification that the completed project is in accordance with the SMP and the approved plans and specifications, and that all required inspections have been performed.
 - 2. The Board will issue a written Certificate of Completion upon receipt of the final inspection and reports, including the as-builts, and/or upon otherwise determining that all SMP work has been satisfactorily completed in conformance with the Regulations.

SECTION 13. PERPETUAL INSPECTION AND MAINTENANCE

A. Maintenance Responsibility

The owner of the property on which work has been done pursuant to a SMP for private stormwater management facilities, or any other person or agent in control of such property, shall maintain in good condition and promptly repair and restore all grade surfaces, walls, drains, dams and structures, vegetation, erosion and sedimentation controls, and other protective devices. Such repairs or restoration and maintenance shall be in accordance with approved plans.

- B. Maintenance Inspections
 - 1. Stormwater management facilities and practices included in an O&M Plan with a Maintenance Agreement in accordance with the Regulations must undergo ongoing inspections to document maintenance and repair needs and ensure compliance with the requirements of the Agreement, the Plan, and the Regulations.
 - 2. At a minimum, inspections shall occur during the first year of operation and in accordance with the O&M plan in the SMP.
 - 3. Inspection reports shall be completed and retained by the parties responsible for the operation and maintenance of the stormwater management facility. Reports shall be submitted to the Board upon request. Inspection reports for stormwater management systems shall include:
 - a. The date of inspection,
 - b. Name of inspector,
 - c. The condition of each BMP, including components such as:
 - i. Pretreatment devices.
 - ii. Vegetation or filter media.
 - iii. Fences or other safety devices.
 - iv. Spillways, valves, or other control structures.

- v. Embankments, slopes, and safety benches.
- vi. Reservoir or treatment areas.
- vii. Inlet and outlet channels and structures.
- viii. Underground drainage.
- ix. Sediment and debris accumulation in storage and forebay areas (including catch basins).
- x. Any nonstructural practices.
- xi. Any other item that could affect the proper function of the stormwater management system.
- d. Description of the need for maintenance.
- C. Right-Of-Entry for Inspection

The Board, its agents, officers, and employees shall have authority to enter upon privately owned land for the purpose of performing their duties under these Regulations and may make or cause to be made such examinations, surveys, or sampling as the Board deems necessary, subject to the constitutions and laws of the United States and the Commonwealth.

D. Records of Maintenance and Repair Activities

Parties responsible for the operation and maintenance of a stormwater management facility shall provide records of all maintenance and repairs to the Board upon request. Parties responsible for the operation and maintenance of a stormwater management facility shall make records of all maintenance and repairs, and shall retain the records for at least 5 years. These records shall be made available to the Board during inspection of the facility and at other reasonable times upon request.

- E. Failure to Maintain
 - 1. If a Responsible Party fails or refuses to meet the requirements of the inspection and maintenance agreement, the Board, after thirty (30) days written notice (except that in the event the violation constitutes an immediate danger to public health or public safety, 24 hours notice shall be sufficient), may correct a violation of the design standards or maintenance requirements by performing the necessary work to place the facility or practice in proper working condition. In the event that the responsible person, permittee or subsequent owners do not follow maintenance procedures and programs for stormwater facilities as approved by the Board, the Board or its agents shall have the authority to expend any portion of the Stormwater Maintenance Surety to provide such maintenance and repairs as needed. In the event the repairs exceed the value of the surety, the Board may assess the owner(s) of the facility for the additional cost of repair work which shall be a lien on the property until paid.
 - 2. After notification is provided to the Responsible Party for carrying out the maintenance plan of any deficiencies discovered from an inspection of a stormwater management system, the Responsible Party shall have 30 days or other time frame mutually agreed to between the Board and the Responsible Party, to correct the deficiencies. The Board shall then conduct a subsequent inspection to ensure completion of repairs.

SECTION 14. ENFORCEMENT

- A. The Board or an authorized agent of the Board shall enforce the regulations, orders, violation notices, and enforcement orders, and may pursue all civil and criminal remedies for such violations.
- B. Orders

- 1. The Board or an authorized agent of the Board may issue a written order to enforce the provisions of the regulations thereunder, which may include requirements to:
 - a. cease and desist from construction or land disturbing activity until there is compliance with the regulations and the stormwater management permit;
 - b. repair, maintain, or replace the stormwater management system or portions thereof in accordance with the operation and maintenance plan;
 - c. perform monitoring, analyses, and reporting; and/or
 - d. remediate adverse impact resulting directly or indirectly from malfunction of the stormwater management system.
- 2. If the enforcing person determines that abatement or remediation of adverse impacts is required, the order shall set forth a deadline by which such abatement or remediation must be completed. Said order shall further advise that, should the violator or property owner fail to abate or perform remediation within the specified deadline, the Town may, at its option, undertake such work, and the property owner shall reimburse the Town's expenses.
- 3. Within thirty (30) days after completing all measures necessary to abate the violation or to perform remediation, the violator and the property owner shall be notified of the costs incurred by the Town, including administrative costs. The violator or property owner may file a written protest objecting to the amount or basis of costs with the Board within thirty (30) days of receipt of the notification of the costs incurred. If the amount due is not received by the expiration of the time in which to file a protest or within thirty (30) days following a decision of the Board affirming or reducing the costs, or from a final decision of a court of competent jurisdiction, the costs shall become a special assessment against the property owner and shall constitute a lien on the owner's property for the amount of said costs. Interest shall begin to accrue on any unpaid costs at the statutory rate provided in G.L. Ch. 59, § 57, after the thirty-first day at which the costs first become due.

Fines. Any person who violates any provision of the regulations, order or permit issued thereunder, shall be punished by a fine of not more than \$300.00. Each day or part thereof that such violation occurs or continues shall constitute a separate offense.

Non-Criminal Disposition. As an alternative to criminal prosecution or civil action, the Planning Board may elect to utilize the non-criminal disposition procedure set forth in G.L. Ch. 40, §21D, pursuant to the provisions of MGL chapter 40, paragraph 21D, and the Town's Noncriminal Disposition Bylaw (Chapter1, General Provisions, Article II, Penalties; Noncriminal Disposition), in which case the Planning Board or its designated agent shall be the enforcing person. The penalty shall be \$300.00 for each day or part thereof that such violation occurs or continues shall constitute a separate offense.

- C. Appeals. The decisions or orders of the Board shall be final. Further relief shall be to a court of competent jurisdiction.
- D. Remedies Not Exclusive The remedies listed in the Regulations are not exclusive of any other remedies available under any applicable federal, state or local law.

SECTION 15. SEVERABILITY

If any provision, paragraph, sentence, or clause of these Regulations shall be held invalid for any reason, all other provisions shall continue in full force and effect.

APPENDICES FOR STORMWATER REGULATIONS

Town of Hopedale, MA

APPENDIX A: DEFINITIONS

The following definitions supplement those included in the Town of Hopedale Stormwater Management Bylaw.

ABUTTER: The owner(s) of land abutting the activity.

AGRICULTURE: The normal maintenance or improvement of land in agricultural or aquacultural use, as defined by the Massachusetts Wetlands Protection Act and its implementing regulations.

ALTERATION OF DRAINAGE CHARACTERISTICS: Any activity on an area of land that changes the water quality, force, direction, timing or location of runoff flowing from the area. Such changes include change from distributed runoff to confined, discrete discharge, change in the volume of runoff from the area; change in the peak rate of runoff from the area; and change in the recharge to groundwater on the area.

APPLICANT: Shall be the owner of record of all of the land shown on any plan submitted for approval to the Planning Board in accordance with the Stormwater Management Bylaw and Regulations, any person or persons acting on behalf of the applicant for purposes of preparing and submitting plans and documents to the Planning Board, and may include engineers, surveyors, contractors or attorneys, and may also include any person or persons having an equitable interest in the land under an agreement or option to purchase the land. The owner shall certify in writing the identity of each applicant who is authorized to submit plans and/or documents and act on behalf of the owner. Without such certification an applicant shall not act on behalf of the owner. The applicant shall submit the title reference or references from the Worcester County Registry of Deeds indicating the owner of record. All applications shall include original signatures of all owners.

AUTHORIZED ENFORCEMENT AGENCY: The Planning Board, hereafter the Board, and its employees or agents who will be in charge of enforcing the requirements of these Regulations.

BEST MANAGEMENT PRACTICE (BMP): An activity, procedure, restraint, or structural improvement that helps to reduce the quantity or improve the quality of stormwater runoff.

THE BOARD – Town of Hopedale Planning Board

CLEARING: Any activity that removes the vegetative surface cover.

CONSTRUCTION AND WASTE MATERIALS: Excess or discarded building or site materials, including but not limited to concrete truck washout, chemicals, litter and sanitary waste at a construction site that may adversely impact water quality.

DEVELOPMENT: The modification of land to accommodate a new use or expansion of use, usually involving construction.

DISTURBANCE OF LAND: Any action that causes a change in the position, location, or arrangement of soil, sand rock, gravel of similar earth material.

EROSION AND SEDIMENTATION CONTROL PLAN: A document containing narrative, drawings and details developed by a qualified professional engineer (PE) or a public land surveyor (PLS), which includes best management practices, or equivalent measures designed to control surface runoff, erosion and sedimentation during pre-construction and construction related land

disturbance activities.

ESTIMATED HABITAT OF RARE WILDLIFE AND CERTIFIED VERNAL POOLS: Habitats delineated for state-protected rare wildlife and certified vernal pools for use with the Wetlands Protection Act Regulations (310 CMR 10.00) and the Forest Cutting Practices Act Regulations (304 CMR 11.00).

GRADING: Changing the level or shape of the ground surface.

GRUBBING: The act of clearing land surface by digging up roots and stumps.

IMPAIRED WATER: A water is impaired if it does not meet one or more of its designated use(s). For purposes of the MS4 permit, "impaired" refers to categories 4 and 5 of the five-part categorization approach used for classifying the water quality standards attainment status for water segments under the Total Maximum Daily Load (TMDL) program. Impaired waters compilations are also sometimes referred to as "303(d) lists." Category 5 waters are impaired because at least one designated use is not being supported or is threatened and a TMDL is needed. Category 4 waters indicate that at least one designated use is not being supported but a TMDL is not needed (4a indicates that a TMDL has been approved or established by EPA; 4b indicates other required control measures are expected in result in the attainment of water quality standards in a reasonable period of time; and 4c indicates that the nonattainment of the water quality standard is the result of pollution (e.g. habitat) and is not caused by a pollutant.

IMPERVIOUS SURFACE: Any material or structure on or above the ground that prevents water infiltrating the underlying soil. Impervious surface includes without limitation roads, paved parking lots, sidewalks, and roof tops.

LAND-DISTURBING ACTIVITY OR LAND DISTURBANCE: Any activity that causes a change in the position or location of soil, sand, rock, gravel, or similar earth material.

LAND-DISTURBANCE PERMIT: A permit issued by the Planning Board.

LOT: An area or parcel of land or any part thereof, in common ownership, designated on a plan filed with the Town of Hopedale by its owner or owners as a separate lot.

LOW-IMPACT DEVELOPMENT (LID): The use of innovative stormwater management systems that are modelled after natural hydrologic features. Rainfall is managed at the source using small, cost-effective landscape features located at the lot level.

MASSACHUSETTS STORMWATER MANAGEMENT STANDARDS: The Stormwater Standards and accompanying Stormwater Handbook, as amended, issued by the Department of Environmental Protection pursuant to authority under the Wetlands Protection Act, M.G.L. c. 131, §40, and the Massachusetts Clean Waters Act, M.G.L. c. §26-53. The Stormwater Management Standards are incorporated in the Wetlands Protection Act Regulations, 310 CMR 10.05(6)(k) and the Water Quality Certification Regulations, 314 CMR 9.06(6)(a).

MUNICIPAL SEPARATE STORM SEWER SYSTEM (MS4) or MUNICIPAL STORM DRAIN SYSTEM: The system of conveyances designed or used for collecting or conveying stormwater, including any road with a drainage system, street, gutter, curb, inlet, piped storm drain, pumping facility, retention or detention basin, natural or man-made or altered drainage channel, reservoir, and

other drainage structure that together comprise the storm drainage system owned or operated by the Town of Hopedale.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) CONSTRUCTION GENERAL PERMIT: A permit issued under the authority of the Clean Water Act (CWA) by the Environmental Protection Agency (EPA) which authorizes the discharge of stormwater (and certain authorized non-stormwater discharges) from construction sties that disturb one acre or more of land, and form smaller sites that are part of a larger common plan of development. This permit requires operators of such construction sites to implement stormwater controls to minimize the amount of sediment and other pollutants associated with construction sites from being discharged in stormwater runoff.

NEW DEVELOPMENT: Any construction activities or land alteration resulting in total earth disturbances greater than or equal to three quarters (3/4) of an acre (or activities that disturb less than three quarters (3/4) of an acre of land but are part of a larger common plan of development disturbing greater than three quarters (3/4) of an acre) on an area that has not previously been developed to include impervious cover.

OPERATION AND MAINTENANCE PLAN: A plan setting up the functional, financial and organizational mechanisms for the ongoing operation and maintenance of a stormwater management system to ensure that it continues to function as designed.

OUTFALL: The point at which stormwater flows out from a point source discernible, confined and discrete conveyance into waters of the Commonwealth.

OUTSTANDING RESOURCE WATERS (ORWs): Waters designated by Massachusetts Department of Environmental Protection as ORWs. These waters have exceptional sociologic, recreational, ecological and/or aesthetic values and are subject to more stringent requirements under both the Massachusetts Water Quality Standards (314 CMR 4.00) and the Massachusetts Stormwater Management Standards. ORWs include vernal pools certified by the Natural Heritage Program of the Massachusetts Department of Fisheries and Wildlife and Environmental Law Enforcement, all Class A designated public water supplies with their bordering vegetated wetlands, and other waters specifically designated.

OWNER: Shall be the owner of record of all the land shown on any plan submitted. The owner shall submit the title reference or references from the Worcester County Registry of Deeds indicating the owner of record.

PERSON: An individual, partnership, association, firm, company, trust, corporation, agency, authority, department or political subdivision of the Commonwealth or the federal government, to the extent permitted by law, and any officer, employee, or agent of such person.

POINT SOURCE: Any discernible, confined, and discrete conveyance, including but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, or container from which pollutants are or may be discharged.

PRE-CONSTRUCTION: All activity in preparation for construction.

PRIORITY HABITAT OF RARE SPECIES: Habitats delineated for rare plant and animal populations protected pursuant to the Massachusetts Endangered Species Act and its regulations.

PRIVATE STORM DRAIN SYSTEM or PRIVATE SEPARATE STORM SEWER SYSTEM: The system of conveyances designed or used for collecting or conveying stormwater, including any road with a drainage system, street, gutter, curb, inlet, piped storm drain, pumping facility, retention or detention basin, natural or man-made or altered drainage channel, reservoir, and other drainage structure that together comprise the storm drainage system that is not owned and maintained by the Town.

REDEVELOPMENT: Any construction, land alteration, or improvement of impervious surfaces resulting in total earth disturbances greater than three quarters (3/4) of an acre (or activities that disturb less than three quarters (3/4) of an acre of land but are part of a larger common plan of development disturbing greater than three quarters (3/4) of an acre) that does not meet the definition of new development (see above).

RESPONSIBLE PARTIES: owner(s), persons with financial responsibility, and persons with operational responsibility.

RUNOFF: Rainfall, snowmelt, or irrigation water flowing over the ground surface.

SEDIMENT: Mineral or organic soil material that is transported by wind or water, from its origin to another location; the product of erosion processes.

SEDIMENTATION: The process or act of deposition of sediment.

SITE: Any lot or parcel of land or area of property where land-disturbing activities are, were, or will be performed.

SLOPE: The incline of a ground surface expressed as a ratio of horizontal distance to vertical distance.

SOIL: Any earth, sand, rock, gravel, or similar material.

STABILIZATION: The use, singly or in combination, of mechanical, structural, or vegetative methods, to prevent or retard erosion.

STORMWATER: Storm water runoff, snow melt runoff, and surface water runoff and drainage.

STORMWATER MANAGEMENT PLAN: A document containing narrative, drawings and details prepared by a qualified professional engineer (PE) or a professional public land surveyor (PLS), which includes structural and non-structural best management practices to manage and treat stormwater runoff generated from regulated development activity. A stormwater management plan also includes an Operation and Maintenance Plan describing the maintenance requirements for structural best management practices.

STRIP: Any activity which removes the vegetative ground surface cover, including tree removal, clearing, grubbing, and storage or removal of topsoil.

TOTAL MAXIMUM DAILY LOAD (TMDL): A TMDL is a calculation of the maximum amount of a pollutant that a waterbody can receive while still meeting water quality standards, and allocation of that amount to the pollutant's sources.

TSS: Total Suspended Solids.

VERNAL POOLS: Temporary bodies of freshwater which provide critical habitat for a number of vertebrate and invertebrate wildlife species.

WATERCOURSE: A natural or man-man channel through which water flows or a stream of water, including a river, brook, or underground stream.

WETLAND RESOURCE AREA: Areas specified in the Massachusetts Wetlands Protection Act G.L. c. 131, § 40.

WETLANDS: Tidal and non-tidal areas characterized by saturated or nearly saturated soils most of the year that are located between terrestrial (land-based) and aquatic (water-based) environments, including freshwater marshes around ponds and channels (rivers and streams), brackish and salt marshes; common names include marshes, swamps and bogs.

APPENDIX B: STORMWATER MANAGEMENT PLAN CONTENTS

Applications for a Stormwater Management Permit (SMP) shall include the materials as specified in this section.

- A. The application for a stormwater management permit shall consist of submittal of a Stormwater Management Plan to the Board. This Stormwater Management Plan shall contain sufficient information for the Board to evaluate the environmental impact, effectiveness, and acceptability of the measures proposed by the applicant for reducing adverse impacts from stormwater. The Plan shall be designed to meet the Massachusetts Stormwater Management Standards as set forth in Part B of this section and DEP Stormwater Management Handbook Volumes I and II. The Stormwater Management Plan shall fully describe the project in drawings, and narrative. It shall include:
 - 1. Contact Information. The name, address, and telephone number of all persons having a legal interest in the property and the tax reference parcel identification number of the property or properties affected.
 - 2. Brief narrative description of the project and description of how and where stormwater will be controlled.
 - 3. A current locus map,
 - 4. Existing Site Plan depicting the existing conditions on the site.
 - 5. The existing zoning, and land use at the site and abutting properties,
 - 6. The proposed land use,
 - 7. The location(s) of existing and proposed easements,
 - 8. The location of existing and proposed utilities,
 - 9. The site's existing & proposed topography with contours at 2-foot intervals,
 - 10. The existing site hydrology,
 - 11. A description & delineation of existing stormwater conveyances, impoundments, and wetlands on or adjacent to the site or into which stormwater flows,
 - 12. A delineation of 100-year flood plains, if applicable,
 - 13. Estimated seasonal high groundwater elevation (November to April) in areas to be used for stormwater retention, detention, or infiltration,
 - 14. The existing and proposed vegetation and ground surfaces with runoff coefficients for each,
 - 15. A drainage area map showing pre and post construction watershed boundaries, drainage area and stormwater flow paths,
 - 16. A description and drawings of all components of the proposed drainage system including:
 - a. locations, cross sections, and profiles of all brooks, streams, drainage swales and their method of stabilization,
 - b. all measures for the detention, retention or infiltration of water,
 - c. all measures for the protection of water quality,
 - d. the structural details for all components of the proposed drainage systems and stormwater management facilities,
 - e. notes on drawings specifying materials to be used, construction specifications, and typicals, and

- f. expected hydrology with supporting calculations.
- 17. Proposed improvements including location of buildings or other structures, impervious surfaces, and drainage facilities, if applicable,
- 18. Timing, schedules, and sequence of development including clearing, stripping, rough grading, construction, final grading, and vegetative stabilization,
- 19. A maintenance schedule for the period of construction, and
- 20. Any other information requested by the Board.
- B. Design Standards
 - 1. Standards. All projects requiring a Stormwater Management Permit shall meet the Massachusetts Stormwater Management Standards as well as the requirements outlined in this section.
 - 2. Low-Impact Development. Low-Impact Design (LID) practices shall be implemented in all projects to the maximum extent feasible. Applicants shall address each of the following LID principles in the project narrative:
 - Preservation of natural areas;
 - Tree Protection;
 - Vegetation and landscaping;
 - Riparian buffer protection;
 - Limit land disturbance during construction;
 - Limit new impervious surfaces;
 - Promote the use of vegetative (green infrastructure) stormwater controls;
 - Disconnect flow paths;
 - Promote infiltration; and
 - Capture and reuse stormwater.

Applicants not incorporating low-impact development practices into their plans must indicate why LID is not feasible at the site.

- 3. The design of treatment and infiltration practices shall follow the guidance in Volume 2 of the Massachusetts Stormwater Handbook, as amended, or other federally or state approved BMP design guidance.
- 4. Stormwater management systems for new development sites shall be designed to meet an average annual pollutant removal equivalent to 90% of the average annual load of Total Suspended Solids (TSS) related to the total post-construction impervious area on the site AND 60% of the average annual load of Total Phosphorus (TP) related to the total post-construction impervious surface area on the site.
 - a. Average annual pollutant removal requirements are achieved through one of the following methods:
 - installing BMPs that meet the pollutant removal percentages based on calculations developed consistent with EPA Region 1's BMP Accounting and Tracking Tool (2016) or other BMP performance evaluation tool provided by EPA Region 1, where available. If EPA Region 1 tools do not address the planned or installed BMP performance, then any federally or State-approved BMP design guidance or performance standards (e.g., the MA Stormwater Management Handbook) may be used to calculate BMP performance; or
 - retaining the volume of runoff equivalent to, or greater than, one (1.0) inch multiplied by the total post-construction impervious surface area on the new development site;

- meeting a combination of retention and treatment that achieves the above standards; or
- utilizing offsite mitigation that meets the above standards within the same USGS HUC12 as the new development site within the limits of the town.
- 5. Stormwater management systems on redevelopment sites shall be designed to meet an average annual pollutant removal equivalent to 80% of the average annual post-construction load of Total Suspended Solids (TSS) related to the total post-construction impervious area on the site AND 50% of the average annual load of Total Phosphorus (TP) related to the total post-construction impervious surface area on the site.
 - a. Average annual pollutant removal requirements are achieved through one of the following methods:
 - Installing BMPs that meet to pollutant removal percentages based on calculations developed consistent with EPA Region 1's BMP Accounting and Tracking Tool (2016) or other BMP performance evaluation tool provided by EPA Region 1, where available. If EPA Region 1 tools do not address the planned or installed BMP performance, then any federally or State-approved BMP design guidance or performance standards (e.g., the MA Stormwater Management Handbook) may be used to calculate BMP performance; or
 - retaining the volume of runoff equivalent to, or greater than, one (1.0) inch multiplied by the total post-construction impervious surface area on the new development site;
 - meeting a combination of retention and treatment that achieves the above standards; or
 - utilizing offsite mitigation that meets the above standards within the same USGS HUC12 as the redevelopment site within the limits of the town.
- 6. All Stormwater Management Best Management Practices employed on new development and redevelopment sites within a watershed of a water body with a phosphorus impairment shall be shown to be optimized for phosphorus removal by the standards set forth by the Massachusetts Stormwater Management Handbook or the approved TMDL, if it exists, whichever is more strict. The justification and design of such BMPs must include a methodology for assessing BMP performance. Pollutant removal shall be consistent with EPA Region 1's Evaluation tool.
- 7. Redevelopment activities that are exclusively limited to maintenance and improvement of existing roadways, (including widening less than a single lane, adding shoulders, correcting substandard intersections, improving existing drainage systems, and repaving projects) shall improve existing conditions where feasible and are exempt from the redevelopment requirements of this section. Roadway widening or improvements that increase the amount of impervious area on the redevelopment site by greater than or equal to a single lane width shall meet the requirements of this section for redevelopment fully.
- 8. Project Changes

The permittee, or their agent, shall notify the Board in writing of any change or alteration of a land-disturbing activity authorized in a Stormwater Management Permit before any change or alteration occurs. If the Board determines that the change or alteration is significant, based on the design requirements and accepted construction practices, the Board may require that an amended Stormwater Management Permit application be filed and a public hearing held. If any change or deviation from the Stormwater Management Permit occurs during a project, the Board may require the installation of interim measures before approving the change.

APPENDIX C: EROSION AND SEDIMENT CONTROL PLAN CONTENTS

- 1. The Erosion and Sediment Control Plan shall contain sufficient information to describe the nature and purpose of the proposed development, pertinent conditions of the site and the adjacent areas, and proposed erosion and sedimentation controls. The applicant shall submit such material as is necessary to show that the proposed development will comply with the design requirements listed. The design requirements for sediment and erosion control BMPs shall also be consistent with the design standards set forth in the Massachusetts Stormwater Handbook.
- 2. The design requirements of the Erosion and Sediment Control Plan are:
 - a. Minimize total area of disturbance;
 - b.Sequence activities to minimize simultaneous areas of disturbance;
 - c. Minimize peak rate of runoff in accordance with the Massachusetts Stormwater Management Handbook and Stormwater Management Standards;
 - d.Minimize soil erosion and control sedimentation during construction, provided that prevention of erosion is preferred over sedimentation control;
 - e. Divert uncontaminated water around disturbed areas;
 - f. Maximize groundwater recharge;
 - g.Install and maintain all Erosion and Sediment Control measures in accordance with the manufacturer's specifications and good engineering practices;
 - h.Prevent off-site transport of sediment;
 - i. Protect and manage on and off-site material storage areas (overburden and stockpiles of dirt, borrow areas, or other areas used solely by the permitted project are considered a part of the project);
 - j. Comply with applicable Federal, State and local laws and regulations including waste disposal, sanitary sewer or septic system regulations, and air quality requirements, including dust control;
 - k. Prevent significant alteration of habitats mapped by the Massachusetts Natural Heritage & Endangered Species Program as Endangered, Threatened or Of Special Concern, Estimated Habitats of Rare Wildlife and Certified Vernal Pools, and Priority Habitats of Rare Species from the proposed activities;
 - 1. Institute interim and permanent stabilization measures, which shall be instituted on a disturbed area as soon as practicable but no more than 14 days after construction activity has temporarily or permanently ceased on that portion of the site;
 - m. Properly manage on-site construction and waste materials; and
 - n. Prevent off-site vehicle tracking of sediments.
- 3. Erosion and Sedimentation Control Plan Content.

The Plan shall contain the following information:

- a. Names, addresses, and telephone numbers of the owner, applicant, and person(s) or firm(s) preparing the plan;
- b. Title, date, north arrow, names of abutters, scale, legend, and locus map;
- c. Location and description of natural features including:
 - 1. Watercourses and water bodies, wetland resource areas and all floodplain information, including the 100-year flood elevation based upon the most recent Flood Insurance Rate Map, or as calculated by a professional engineer for areas not assessed on these maps;

- 2. Existing vegetation including tree lines, canopy layer, shrub layer, and ground cover, and trees with a caliper twelve (12) inches or larger, noting specimen trees and forest communities; and
- 3. Habitats mapped by the Massachusetts Natural Heritage & Endangered Species Program as Endangered, Threatened or of Special Concern, Estimated Habitats of Rare Wildlife and Certified Vernal Pools, and Priority Habitats of Rare Species within five hundred (500) feet of any construction activity.
- d. Lines of existing abutting streets showing drainage and driveway locations and curb cuts;
- e. Existing soils, volume and nature of imported soil materials;
- f. Topographical features including existing and proposed contours at intervals no greater than two (2) feet with spot elevations provided when needed;
- g. Surveyed property lines showing distances and monument locations, all existing and proposed easements, rights-of-way, and other encumbrances, the size of the entire parcel, and the delineation and number of square feet of the land area to be disturbed;
- h. Drainage patterns and approximate slopes anticipated after major grading activities (Construction Phase Grading Plans);
- i. Location and details of erosion and sediment control measures with a narrative of the construction sequence/phasing of the project, including both operation and maintenance for structural and non-structural measures, interim grading, and material stockpiling areas;
- j. Path and mechanism to divert uncontaminated water around disturbed areas, to the maximum extent practicable;
- k. Location and description of industrial discharges, including stormwater discharges from dedicated asphalt plants and dedicated concrete plants, which are covered by this permit;
- 1. Stormwater runoff calculations in accordance with the Department of Environmental Protection's Stormwater Management Handbook and Stormwater Management Standards;
- m. Location and description of and implementation schedule for temporary and permanent seeding, vegetative controls, and other stabilization measures;
- n. A description of construction and waste materials expected to be stored on-site. The Plan shall include a description of controls to reduce pollutants from these materials, including storage practices to minimize exposure of the materials to stormwater, and spill prevention and response;
- o. A description of provisions for phasing the project where three quarters (3/4) of an acre of area or greater is to be altered or disturbed;
- p. Plans must be stamped and certified by a qualified Professional Engineer registered in Massachusetts; and
- q. Such other information as is required by the Board.

APPENDIX D – OPERATION AND MAINTENANCE PLAN CONTENTS

- 1. The name(s) of the owner(s) for all components of the system
- 2. A map showing the location of the systems and facilities including easements, catch basins, manholes/access lids, main, and stormwater devices.
- 3. Maintenance agreements that specify:
 - a. The names and addresses of the person(s) responsible for operation and maintenance
 - b. The person(s) responsible for financing maintenance and emergency repairs.
 - c. A Maintenance Schedule for all drainage structures, including swales and ponds.
 - d. A list of easements with the purpose and location of each.
 - e. The signature(s) of the owner(s).
- 4. Changes to Operation and Maintenance Plans
 - a. The owner(s) of the stormwater management system must notify the Board of changes in ownership or assignment of financial responsibility.
 - b. The maintenance schedule in the Maintenance Agreement may be amended to achieve the purposes of these Regulations by mutual agreement of the Board and the Responsible Parties. Amendments must be in writing and signed by all Responsible Parties. Responsible Parties shall include owner(s), persons with financial responsibility, and persons with operational responsibility.

APPENDIX E: POST-DEVELOPMENT ADDITIONAL CRITERIA

All stormwater management plans shall comply with the following performance criteria unless otherwise provided for in the Regulations.

1. Hydrologic Basis for Design of Structural Practices

For facility sizing criteria, the basis for hydrologic and hydraulic evaluation of development sites are as follows:

- a. Impervious cover is measured from the site plan and includes any material or structure on or above the ground that prevents water from infiltrating through the underlying soil. Impervious surface is defined to include, without limitation: paved parking lots, sidewalks, rooftops, driveways, patios, and paved, gravel and compacted dirt surfaced roads.
- b. Off-site areas shall be assessed based on their "pre-developed condition" for computing the water quality volume (i.e., treatment of only on-site areas is required). However, if an offsite area drains to a proposed BMP, flow from that area must be accounted for in the sizing of a specific practice.
- c. Off-site areas draining to a proposed facility should be modeled as "present condition" for peak-flow attenuation requirements.
- d. The length of sheet flow used in time of concentration calculations is limited to no more than 50 feet for predevelopment conditions and 50 feet for post development conditions.
- e. Detention time for the one-year storm is defined as the center of mass of the inflow hydrograph and the center of mass of the outflow hydrograph.
- f. The models TR-55 and TR-20 (or approved equivalent) will be used for determining peak discharge rates.
- g. If an off-site area drains to a facility, off-site areas should be modeled, assuming an "ultimate buildout condition" upstream.
- h. Determination of flooding and channel erosion impacts to receiving streams due to land development projects shall be measured at each point of discharge from the development project and such determination shall include any runoff from the balance of the watershed which also contributes to that point of discharge.
- The specified design storms shall be defined as a 24-hour storm using the rainfall Data i. contained in the Cornell University Atlas of Precipitation for the Northeastern United States and Southeastern Canada, Publication No. RR 93-5. September 1993 (www.nrcc.cornell.edu/reports/RR_93-5.html), and the Cornell University Atlas of Short-Duration Precipitation Extremes for the Northeastern United States and Southeastern Canada, Publication No. RR 95-1, March 1995 (www.nrcc.cornell.edu/reports/RR 95-1.html).
- j. Proposed residential, commercial, or industrial subdivisions shall apply these stormwater management criteria to the land development as a whole. Individual lots in new subdivisions shall not be considered separate land development projects, but rather the entire subdivision shall be considered a single land development project. Hydrologic parameters shall reflect the ultimate land development and shall be used in all engineering calculations.

APPENDIX F: EROSION AND SEDIMENT CONTROL ADDITIONAL CRITERIA

All erosion and sediment controls shall comply with the following performance criteria unless otherwise provided for in the Regulations.

1. General Erosion and Sediment Control Criteria

The following are the minimum General Erosion and Sediment Control criteria:

- a. Minimize total area of disturbance and protect natural features and soil.
- b. Sequence activities to minimize simultaneous areas of disturbance. Mass clearings and grading of the entire site shall be avoided.
- c. Minimize peak rate of runoff in accordance with the Massachusetts Stormwater Standards.
- d. Minimize soil erosion and control sedimentation during construction, provided that prevention of erosion is preferred over sedimentation control.
- e. Divert uncontaminated water around disturbed areas.
- f. Maximize groundwater recharge.
- g. Install and maintain all Erosion and Sediment Control measures in accordance with the manufacturer's specifications and good engineering practices.
- h. Prevent off-site transport of sediment.
- i. Protect and manage on and off-site material storage areas (overburden and stockpiles of dirt, borrow areas, or other areas used solely by the permitted project are considered a part of the project).
- j. Comply with applicable Federal, State and local laws and regulations including waste disposal, sanitary sewer or septic system regulations, and air quality requirements, including dust control.
- k. Prevent significant alteration of habitats mapped by the Massachusetts Natural Heritage & Endangered Species Program as Endangered, Threatened or Of Special Concern, Estimated Habitats of Rare Wildlife and Certified Vernal Pools, and Priority Habitats of Rare Species from the proposed activities.
- 1. Institute interim and permanent stabilization measures, which shall be instituted on a disturbed area as soon as practicable but no more than 14 days after construction activity has temporarily or permanently ceased on that portion of the site.
- m. Properly manage on-site construction and waste materials.
- n. Prevent off-site vehicle tracking of sediments.
- o. Dust shall be controlled at the site.
- p. Divert offsite runoff from highly erodible soils and steep slopes to stable areas.

2. Specific Erosion and Sediment Control Criteria

The following are minimum Specific Erosion and Sediment Control criteria:

- a. Prior to any land disturbance activities commencing on the site, the developer shall physically mark limits of no land disturbance on the site with tape, signs, or orange construction fence, so that workers can see the areas to be protected. The physical markers shall remain in place until a Certificate of Completion has been issued.
- b. Appropriate erosion and sediment control measures shall be installed prior to soil disturbance. Measures shall be taken to control erosion within the project area. Sediment in runoff water shall be trapped and retained within the project area. Wetland areas and surface waters shall be protected from sediment.

- c. Sediment shall be removed once the volume reaches ¹/₄ to ¹/₂ the height of a hay bale. Sediment shall be removed from silt fence prior to reaching the load-bearing capacity of the silt fence which may be lower than ¹/₄ to ¹/₂ the height.
- d. Sediment from sediment traps or sedimentation ponds shall be removed when design capacity has been reduced by 50 percent.
- e. BMPs to be used for infiltration after construction shall not be used as BMPs during construction unless otherwise approved by the Board. Many infiltration technologies are not designed to handle the high concentrations of sediments typically found in construction runoff, and thus must be protected from construction related sediment loadings.
- f. Soil stockpiles must be stabilized or covered at the end of each workday. Stockpile side slopes shall not be greater than 2:1. All stockpiles shall be surrounded by sediment controls.
- g. Disturbed areas remaining idle for more than 14 days shall be stabilized with seeding, wood chips bark mulch, tarpaulins, or any other approved methods.
- h. For active construction areas such as borrow or stockpile areas, roadway improvements and areas within 50 feet of a building under construction, a perimeter sediment control system shall be installed and maintained to contain soil.
- i. A tracking pad or other approved stabilization method shall be constructed at all entrance/exist points of the site to reduce the amount of soil carried onto roadways and off the site.
- j. On the cut side of roads, ditches shall be stabilized immediately with rock rip-rap or other non-erodible liners, or where appropriate, vegetative measures such as hydroseeding or jute matting.
- k. Permanent seeding shall be undertaken in the spring from March through May, and in late summer and early fall from August to October 15. During the peak summer months and in the fall after October 15, when seeding is found to be impractical, appropriate temporary stabilization shall be applied. Permanent seeding may be undertaken during the summer if plans provide for adequate mulching and watering.
- 1. All slopes steeper than 3:1 (h:v, 33.3%), as well as perimeter dikes, sediment basins or traps, and embankments must, upon completion, be immediately stabilized with sod, seed and anchored straw mulch, or other approved stabilization measures. Areas outside of the perimeter sediment control system must not be disturbed.
- m. Temporary sediment trapping devices must not be removed until permanent stabilization is established in all contributory drainage areas.
- n. All temporary erosion and sediment control measures shall be removed after final site stabilization. Disturbed soil areas resulting from the removal of temporary measures shall be permanently stabilized within 30 days of removal.

APPENDIX G: STORMWATER MANAGEMENT PERMIT APPLICATION AND REVIEW FEE SCHEDULE FORMS

STORMWATER MANAGEMENT PERMIT APPLICATION

To the Board:

are

The undersigned wishes to submit a Stormwater Management Permit Application as defined in the Stormwater Management Bylaw of the Town of Hopedale Section 6 and requests a review and determination by *the Board* of the Stormwater Management Plan.

The Stormwater Management	Plan involves property	where owner's title to the land is derived
under deed from	, dated	, and recorded in the Worcester County
Registry of Deeds, Book	, Page, or Lan	d Court Certificate of Title No
Registered in	District, Book	, Page

Give a brief summary of the nature of the project.

_____.

The property (building) is described as being loo	ated at; it is currently used as
	, and the changes proposed to be made

The project is located on the parcel shown on Assessors Map _____, Parcel _____.

Applicant's Signature	Owners' Signature(s)
Applicant's Name (print)	Owners' Names(s)
Applicant's Address	<u>-</u>
Owners' Address	

Date Received by Town Clerk:______Signature ______

Please note: 1) An applicant for a Stormwater Management Plan Review must file with the Board a completed Stormwater Management Permit Application Form, a list of abutters, three (3) copies of the Stormwater Management Plan Package, three (3) copies of the Sediment and Erosion Control Plan; three (3) copies of the Operation and Maintenance Plan, and the Application and Review Fees as noted in the Stormwater Management Plan Review Fee Schedule. 2) The applicant shall also file a copy of the Stormwater Management Plan, Erosion and Sediment Control Plan, Operation & Maintenance Plan, and the Application Form with the Town Clerk. The date of receipt by the Town Clerk shall be the official filing date. 3) This application grants the Board and its agents permission to enter the property for inspection and verification of information submitted in the application.

Stormwater Management Plan Review Fee Schedule

The following fee schedules are minimum fees. The Board may require higher fees if deemed necessary for proper review of an application or to ensure compliance.

Lot Area	Professional Review Fee	Application Fee
Less Than 3 Acres	\$	\$
3 to 10 Acres	\$	\$
Greater than 10 Acres	\$ times the acreag	ge \$
Resubmittal/Amendment		
Filing Fee	\$	
Review Fee	\$	

GENERAL

- 1. Any application not accompanied by the appropriate fee shall be deemed incomplete. Payment must be made to the Board in cash, money order, bank or certified check payable to the Town of Hopedale.
- 2. An Applicant's failure to pay any additional review or inspection fee within five business days of receipt of the notice that further fees are required shall be grounds for disapproval.
- 3. The Board will publish the public notice and send abutter notifications. Abutter notification shall be by certified mail-return receipt requested. The applicant shall pay all costs associated with the publication and notification requirements. These costs shall not be imposed on the applicant if the applicant completes the public notice and abutter notification requirements, and provides the Board with copies of the public notices and the return receipt cards.

Professional review fees include engineering review, legal review, and clerical fees associated with the public hearing and permit processing. A fee estimate may be provided by the Board's consulting engineer.



Town of Hopedale Bylaw Governing Discharges To The Municipal Storm Drain System

SECTION 1. PURPOSE

Increased and contaminated stormwater runoff is a major cause of impairment of water quality and flow in lakes, ponds, streams, rivers, wetlands and groundwater; contamination of drinking water supplies; alteration or destruction of aquatic and wildlife habitat; and flooding.

Regulation of illicit connections and discharges to the municipal storm drain system is necessary for the protection of the Town's water bodies and groundwater, and to safeguard the public health, safety, welfare and the environment.

The objectives of this by-law are:

- to prevent pollutants from entering the Town's municipal separate storm sewer system (MS4);
- to prohibit illicit connections and unauthorized discharges to the MS4;
- to require the removal of all such illicit connections;
- to comply with state and federal statutes and regulations relating to stormwater discharges; and
- to establish the legal authority to ensure compliance with the provisions of this by-law through inspection, monitoring, and enforcement.

SECTION 2. DEFINITIONS

For the purposes of this by-law, the following shall mean:

AUTHORIZED ENFORCEMENT AGENCY: The Planning Board (hereafter the Board), its employees or agents designated to enforce this by-law.

BEST MANAGEMENT PRACTICE (BMP): An activity, procedure, restraint, or structural improvement that helps to reduce the quantity or improve the quality of stormwater runoff.

CLEAN WATER ACT: The Federal Water Pollution Control Act (33 U.S.C. § 1251 et seq.) as hereafter amended.

DISCHARGE OF POLLUTANTS: The addition from any source of any pollutant or combination of pollutants into the municipal storm drain system or into the waters of the United States or Commonwealth from any source.

GROUNDWATER: Water beneath the surface of the ground.

ILLICIT CONNECTION: A surface or subsurface drain or conveyance, which allows an illicit discharge into the municipal storm drain system, including without limitation sewage, process wastewater, or wash water and any connections from indoor drains, sinks, or toilets, regardless of whether said connection was previously allowed, permitted, or approved before the effective date of this by-law.

ILLICIT DISCHARGE: Direct or indirect discharge to the municipal storm drain system that is not composed entirely of stormwater, except as exempted in Section 7. The term does not include a discharge in compliance with a NPDES Storm Water Discharge Permit or a Surface Water Discharge Permit, or resulting from fire-fighting activities exempted pursuant to Section 7, subsection 4, of this by-law.

IMPERVIOUS SURFACE: Any material or structure on or above the ground that prevents water infiltrating the underlying soil. Impervious surface includes without limitation roads, paved parking lots, sidewalks, and rooftops.

MUNICIPAL SEPARATE STORM SEWER SYSTEM (MS4) or MUNICIPAL STORM

DRAIN SYSTEM: The system of conveyances designed or used for collecting or conveying stormwater, including any road with a drainage system, street, gutter, curb, inlet, piped storm drain, pumping facility, retention or detention basin, natural or man-made or altered drainage channel, reservoir, and other drainage structure that together comprise the storm drainage system owned or operated by the Town of Hopedale.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) STORM

WATER DISCHARGE PERMIT: A permit issued by United States Environmental Protection Agency or jointly with the State that authorizes the discharge of pollutants to waters of the United States.

NON-STORMWATER DISCHARGE: Discharge to the municipal storm drain system not composed entirely of stormwater.

PERSON: An individual, partnership, association, firm, company, trust, corporation, agency, authority, department or political subdivision of the Commonwealth or the federal government, to the extent permitted by law, and any officer, employee, or agent of such person.

POLLUTANT: Any element or property of sewage, agricultural, industrial or commercial waste, runoff, leachate, heated effluent, or other matter whether originating at a point or nonpoint source, that is or may be introduced into any sewage treatment works or waters of the Commonwealth. Pollutants shall include without limitation:

- 1. paints, varnishes, and solvents;
- 2. oil and other automotive fluids;
- 3. non-hazardous liquid and solid wastes and yard wastes;
- 4. refuse, rubbish, garbage, litter, or other discarded or abandoned objects, ordnances, accumulations and floatables;
- 5. pesticides, herbicides, and fertilizers;
- 6. hazardous materials and wastes; sewage, fecal coliform and pathogens;
- 7. dissolved and particulate metals;
- 8. animal wastes;
- 9. rock, sand, salt, soils;
- 10. construction wastes and residues; and
- 11. noxious or offensive matter of any kind.

PROCESS WASTEWATER: Water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any material, intermediate product, finished product, or waste product.

RECHARGE: The process by which groundwater is replenished by precipitation through the percolation of runoff and surface water through the soil.

STORMWATER: Storm water runoff, snow melt runoff, and surface water runoff and drainage.

SURFACE WATER DISCHARGE PERMIT. A permit issued by the Department of Environmental Protection (DEP) pursuant to 314 CMR 3.00 that authorizes the discharge of pollutants to waters of the Commonwealth of Massachusetts.

TOXIC OR HAZARDOUS MATERIAL or WASTE: Any material, which because of its quantity, concentration, chemical, corrosive, flammable, reactive, toxic, infectious or radioactive characteristics, either separately or in combination with any substance or substances, constitutes a present or potential threat to human health, safety, welfare, or to the environment. Toxic or hazardous materials include any synthetic organic chemical, petroleum product, heavy metal, radioactive or infectious waste, acid and alkali, and any substance defined as Toxic or Hazardous under G.L. Ch.21C and Ch.21E, and the regulations at 310 CMR 30.000 and 310 CMR 40.0000.

WATERCOURSE: A natural or man-made channel through which water flows or a stream of water, including a river, brook or underground stream.

WATERS OF THE COMMONWEALTH: All waters within the jurisdiction of the Commonwealth, including, without limitation, rivers, streams, lakes, ponds, springs, impoundments, estuaries, wetlands, coastal waters, and groundwater.

WASTEWATER: Any sanitary waste, sludge, or septic tank or cesspool overflow, and water that during manufacturing, cleaning or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct or waste product.

SECTION 3. APPLICABILITY

This by-law shall apply to flows entering the municipally owned storm drainage system.

SECTION 4. AUTHORITY

This bylaw is adopted under the authority granted by the Home Rule Amendment of the Massachusetts Constitution and the Home Rule Procedures Act, and pursuant to the regulations of the federal Clean Water Act found at 40 CFR 122.34.

SECTION 5. RESPONSIBILITY FOR ADMINISTRATION

The Board shall administer, implement and enforce this by-law. Any powers granted to or duties imposed upon the Board may be delegated in writing by the Board to employees or agents of the Board.

SECTION 6. REGULATIONS

The Board may promulgate rules and regulations to effectuate the purposes of this by-law. Failure by the Board to promulgate such rules and regulations shall not have the effect of suspending or invalidating this by-law.

SECTION 7. PROHIBITED ACTIVITIES

Illicit Discharges. No person shall dump, discharge, cause or allow to be discharged any pollutant or nonstormwater discharge into the municipal separate storm sewer system (MS4), into a watercourse, or into the waters of the Commonwealth.

Illicit Connections. No person shall construct, use, allow, maintain or continue any illicit connection to the municipal storm drain system, regardless of whether the connection was permissible under applicable law, regulation or custom at the time of connection.

Obstruction of Municipal Storm Drain System. No person shall obstruct or interfere with the normal flow of stormwater into or out of the municipal storm drain system without prior written approval from the Board.

SECTION 8. EXEMPTIONS

Discharge or flow resulting from fire-fighting activities.

The following non-stormwater discharges or flows are exempt from the prohibition of non-stormwaters provided that the source is not a significant contributor of a pollutant to the municipal storm drain system:

- 1. Waterline flushing;
- 2. Flow from potable water sources;
- 3. Springs;
- 4. Natural flow from riparian habitats and wetlands;
- 5. Diverted stream flow;
- 6. Rising groundwater;
- 7. Uncontaminated groundwater infiltration as defined in 40 CFR 35.2005(20), or uncontaminated pumped groundwater;
- 8. Water from exterior foundation drains, footing drains (not including active groundwater dewatering systems), crawl space pumps, or air conditioning condensation;
- 9. Discharge from landscape irrigation or lawn watering;
- 10. Water from individual residential car washing;
- 11. Discharge from dechlorinated swimming pool water (less than one ppm chlorine) provided the water is allowed to stand for one week prior to draining and the pool is drained in such a way as not to cause a nuisance;
- 12. Discharge from street sweeping;
- 13. Dye testing, provided verbal notification is given to the Board prior to the time of the test;
- 14. Non-stormwater discharge permitted under a NPDES permit or a Surface Water Discharge Permit, waiver, or waste discharge order administered under the authority of the United States Environmental Protection Agency or the Department of Environmental Protection, provided that the discharge is in full compliance with the requirements of the permit, waiver, or order and applicable laws and regulations; and
- 15. Discharge for which advanced written approval is received from the Board as necessary to protect public health, safety, welfare or the environment.

SECTION 9. EMERGENCY SUSPENSION OF STORM DRAINAGE SYSTEM ACCESS

The Board may suspend municipal storm drain system access to any person or property without prior written notice when such suspension is necessary to stop an actual or threatened discharge of pollutants that presents imminent risk of harm to the public health, safety, welfare or the environment. In the event any person fails to comply with an emergency suspension order, the Authorized Enforcement Agency may take all reasonable steps to prevent or minimize harm to the public health, safety, welfare or the environment.

SECTION 10. NOTIFICATION OF SPILLS

Notwithstanding other requirements of local, state or federal law, as soon as a person responsible for a facility or operation, or responsible for emergency response for a facility or operation has information of or suspects a release of materials at that facility or operation resulting in or which may result in discharge of pollutants to the municipal drainage system or waters of the Commonwealth, the person shall take all necessary steps to ensure containment, and cleanup of the release. In the event of a release of oil or hazardous materials, the person shall immediately notify the municipal fire and police departments as well as the Highway Department and Conservation Commission. In the event of a release of non-hazardous material, the reporting person shall notify the Authorized Enforcement Agency no later than the next business day. The reporting person shall provide to the Authorized Enforcement Agency written confirmation of all telephone, facsimile or in person notifications within three business days thereafter. If the discharge of prohibited materials is from a commercial or industrial facility, the facility owner or operator of the facility shall retain on-site a written record of the discharge and the actions taken to prevent its recurrence. Such records shall be retained for at least three years.

SECTION 11. ENFORCEMENT

The Board or an authorized agent of the Board shall enforce this by-law, regulations, orders, violation notices, and enforcement orders, and may pursue all civil and criminal remedies for such violations.

Civil Relief. If a person violates the provisions of this by-law, regulations, permit, notice, or order issued thereunder, the Board may seek injunctive relief in a court of competent jurisdiction restraining the person from activities which would create further violations or compelling the person to perform abatement or remediation of the violation.

Orders. The Board or an authorized agent of the Board may issue a written order to enforce the provisions of this by-law or the regulations thereunder, which may include: (a) elimination of illicit connections or discharges to the MS4; (b) performance of monitoring, analyses, and reporting; (c) that unlawful discharges, practices, or operations shall cease and desist; and (d) remediation of contamination in connection therewith.

If the enforcing person determines that abatement or remediation of contamination is required, the order shall set forth a deadline by which such abatement or remediation must be completed. Said order shall further advise that, should the violator or property owner fail to abate or perform remediation within the specified deadline, the Town may, at its option, undertake such work, and expenses thereof shall be charged to the violator.

Within thirty (30) days after completing all measures necessary to abate the violation or to perform remediation, the violator and the property owner will be notified of the costs incurred by the Town, including administrative costs. The violator or property owner may file a written protest objecting to the amount or basis of costs with the Board within thirty (30) days of receipt of the notification of the costs incurred. If the amount due is not received by the expiration of the time in which to file a protest or within thirty (30) days following a decision of the Board affirming or reducing the costs, or from a final decision of a court of competent jurisdiction, the costs shall become a special assessment against the property owner and shall constitute a lien on the owner's property for the amount of said costs. Interest shall begin to accrue on any unpaid costs at the statutory rate provided in G.L. Ch. 59, _ 57 after the thirty-first day at which the costs first become due.

Criminal Penalty. Any person who violates any provision of this by-law, regulation, order or permit issued thereunder, shall be punished by a fine of not more than \$250. Each day or part thereof that such violation occurs or continues shall constitute a separate offense.

Non-Criminal Disposition. As an alternative to criminal prosecution or civil action, the Planning Board may elect to utilize the non-criminal disposition procedure set forth in G.L. Ch. 40, §21D, pursuant to the provisions of MGL chapter 40, paragraph 21D, and the Town's Noncriminal Disposition Bylaw (Chapter1, General Provisions, Article II, Penalties; Noncriminal Disposition), , in which case the Planning Board or its designated agent shall be the enforcing person. The penalty for the 1st violation shall be \$100. The penalty for each subsequent violation shall be \$300.00. Each day or part thereof that such violation occurs or continues shall constitute a separate offense.

Entry to Perform Duties Under this By-Law. To the extent permitted by state law, or if authorized by the owner or other party in control of the property, *the Board*, its agents, officers, and employees may enter upon privately owned property for the purpose of performing their duties under this by-law and regulations and may make or cause to be made such examinations, surveys or sampling as *the Board* deems reasonably necessary.

Appeals. The decisions or orders of *the Board* shall be final. Further relief shall be to a court of competent jurisdiction.

Remedies Not Exclusive The remedies listed in this by-law are not exclusive of any other remedies available under any applicable federal, state or local law.

SECTION 12. SEVERABILITY

The provisions of this by-law are hereby declared to be severable. If any provision, paragraph, sentence, or clause, of this by-law or the application thereof to any person, establishment, or circumstances shall be held invalid, such invalidity shall not affect the other provisions or application of this by-law.

SECTION 13. TRANSITIONAL PROVISIONS

Residential property owners shall have 60 days from the effective date of the by-law to comply with its provisions provided good cause is shown for the failure to comply with the bylaw during that period.
of mature woodlands may be disturbed. No more than forty-five percent (45%) of woodlands may be disturbed. In addition:

- 13. The developer shall designate a new woodland area on a part of the site not forested.
- 14. The new woodland area shall consist of one and two tenths (1.2) times the surface acreage of the woodland area additionally disturbed pursuant to Division 5501.0 (B).
- 15. Only plant materials listed in Division 5801.0 under "woodland" shall be counted as meeting the requirements for replanted woodland pursuant to this subsection. The number and size of plants required is specified in Divisions 5800.0 and 5803.0.

Division 5502.0 Wetlands.

All wetlands and the degree to which they may be encroached upon shall be governed by 310 CMR 10.00 et seq as promulgated by Mass. D.E.Q.E. under M.G.L. c. 131, s. 40, and additionally by the soils and hydrology of the site.Wetlands minus areas of encroachment shall remain as permanently restricted open space.

Division 5503.0 Drainageways.

- A. No more than fifty percent (50%) of such areas shall be developed.
- **B.** The remaining fifty percent (50%) shall remain as permanent restricted open space. Regrading, stripping of vegetation, or filling is permitted in these areas, provided that:
 - 16. The time of concentration of stormwater flows remains unchanged or is lengthened;
 - 17. Storm-water and groundwater storage capacities are unchanged or increased;
 - Natural vegetation is installed (see Division 5801.0);
 - 19. The resultant new drainageway has less velocity than preexisted or reduces streambank erosion through the provision of erosion control

measures, undertaken and contained in Division 5506.0;

20. The amount of regrading, stripping of vegetation' and filling is limited, additionally by Division 5402.0 (Topography Protection Regulations).

Division 5504.0 Stormwater Runoff.

- **A. Detention**. Each development shall provide for on-site or off-site detention of excess stormwater runoff resulting from that development. For the purpose of this article, "excess stormwater runoff" shall include all increases in stormwater.
- **B.** Limitation On stormwater runoff. No development shall cause downstream property owners, water courses, channels, or conduits to receive stormwater runoff from proposed developments at a higher peak flow rate than would have resulted from same storm event, occurring over the site of the proposed development with the land in its natural undeveloped condition.
- **C. Storage capacity.** All stormwater storage facilities shall be designed with sufficient capacity to accommodate all runoff caused by the development in excess of the runoff which would have resulted from the site if left in its natural, undeveloped condition. The storage capacity of all the storage facilities shall be sufficient to store one hundred and fifteen percent (115%) of the excess flow, in each watershed, which would result from the 100-year storm of 24 hour duration.
- **D. Design regulations.** All detention facilities and improvements required by this division shall comply with the following regulations:
 - 21. **Storage volumes.** Storage may be provided by wet or dry bottom basins or reservoirs or rooftop storage facilities.
 - 22. **Maximum depth.** The maximum planned depth of stormwater stored shall not exceed five (5) feet unless natural ground conditions lend themselves to greater depths.
 - 23. **Outlet control structures.** Outlet control structures shall be designed as simply as possible and shall operate automatically. They will be designed to limit discharges into

existing or planned downstream channels or conduits so as not to exceed the existing flow of the site in its natural condition.

- 24. **Spillway.** Emergency overflow facilities shall be provided unless inflow is controlled to divert flows when the basin is at capacity.
- 25. **Dry bottom basin.** For basins designed without permanent pools:
- **a. Interior drainage.** Provisions must be made to facilitate interior drainage, to include the provision of natural grades to outlet structures, longitudinal and transverse grades to perimeter drainage facilities, or the installation of subsurface drains.
- **b. Multipurpose features.** These may be designed to serve secondary purposes for passive recreation, open space, or other types of uses which will not be adversely affected by occasional or intermittent flooding.
- **c.** Cleaning. The basins shall be designed for periodic cleaning and removal of sediments, which shall be removed from the site or otherwise disposed of in an appropriate manner.
 - 26. **Wet basins.** For basins designed with permanent pools:
- **d.** Depth for fish. If fish are used to help keep the basin clean, at least onequarter (0.25) of the area of the permanent pool must have a minimum depth of ten (10) feet.
- e. Facilities for emptying. For emergency purposes, cleaning, or shoreline maintenance, facilities shall be provided or plans prepared for the use of auxiliary equipment to permit emptying and drainage.
- **f. Pollution abatement.** Natural or mechanical aeration facilities may be required when the quality of the influent and detention time would result in a lowering of dissolved oxygen content in the basin.
- **g.** Cleaning. The basins shall be designed to include sediment traps in all inlets. Sediment traps shall be designed to permit periodic cleaning and maintenance. A basin maintenance plan shall be developed to insure that the design depths of the basin will remain over time.

- 27. **Detention storage.** All or a portion of the detention storage may also be provided in underground detention facilities.
- **E. Maintenance of facilities.** The developer shall be responsible for the maintenance of all improvements until such time as complete ownership of a developed parcel containing aforementioned improvements is relinquished by the developer. The developer shall not, however, transfer these improvements for the purpose of maintenance until he has complied with the above and until he has received final approval for its construction. Thereafter, all detention improvements shall be maintained in perpetuity and cannot be developed for any other use which would limit or cause to limit the use for detention.
- **F. Inspection of facilities.** The developer's engineer shall be required to inspect all drainage facilities under construction and certify their compliance with approved plans. When facilities are not constructed according to approved plans, the Building Inspector has the explicit authority to compel compliance and require correction of any situations which are not according to the approved plans.

Division 5505.0 Soil Suitability for On-Site Disposal.

On-site septic system disposal shall meet the standards imposed by the Hopedale Health Board and governing State Agencies.

Division 5506.0 Soil Erosion and Sedimentation Control.

- **A.** A soil erosion and sedimentation control plan shall be required as part of the definitive site plan review package whenever a development will involve clearing, grading, transporting, or other earth-disturbing practices that conform to any one of the following:
 - 28. Excavation, fill, or any combination thereof will exceed five hundred (500) cubic yards.
 - 29. Fill will exceed three (3) feet in vertical depth at its deepest point as measured from the natural ground surface.
 - 30. Excavation will exceed four (4) feet in vertical depth at its deepest point as measured from the natural ground surface.
 - 31. Excavation, fill or any combination thereof will exceed an area of four thousand (4,000) square feet.

32. Plant and/or tree cover is to be removed from an area exceeding four thousand (4,000) square feet.

Whenever any land located in a stream, stream channel, or body of water is disturbed, a soil erosion and sedimentation control plan shall be provided.

B. Definitions. For the purposes of this section:

Soil erosion – shall mean any removal and /or loss of soil by the action of water, ice, or wind. Erosion includes both the detachment and transport of soil particles.

Sedimentation – shall mean the settling out of the soil particles which are transported by water or wind.

Erodable slope – shall mean all slopes with inclines in excess of four (4) percent.

Large flat surface area (unpaved) – shall mean an area which is flat or whose slope is less than four (4) percent and which consists of more than one thousand (1,000) square feet of exposed soil.

- **C.** All measures necessary to minimize soil erosion and to control sedimentation in the disturbed land area shall be provided. Specifically: minimize velocities of water runoff, maximize protection of disturbed areas from stormwater runoff, and retain sedimentation within the development site as early as possible following disturbances. A list of major problem areas for erosion and sedimentation control follows. For each one, the purpose(s) of requiring control is described.
 - 33. **Erodable slopes:** prevent detachment and transportation of soil particles from slope.
 - 34. Streams, streambeds, streambanks: bodies of water, pond shorelines: prevent detachment and transportation of soil particles.
 - 35. **Drainageways:** prevent detachment and transportation of soil particles (which would otherwise deposit in streams, bodies of water, or wetlands); promote deposit of sediment loads (traversing the areas) before these reach bodies of water.
 - 36. Land adjacent to streams, ponds, and wetlands: prevent detachment and transportation of soil particles.

- 37. Enclosed drainage structure: prevent sedimentation in structure, erosion at the outfall of system, and deposit of sediment loads within system or beyond it.
- 38. Large flat surface areas (unpaved): prevent detachment of soil particles and their off-site transportation.
- 39. **Impervious surfaces:** prevent the detachment and transportation of soil particles (in response to an increase in the rate and / or volume of runoff of the site or its concentration caused by impervious surfaces).
- 40. **Borrow or stockpile areas:** divert runoff from the face of slopes which are exposed in the excavation process; convey runoff in stabilized channels to stable disposal points; leave borrow areas and stockpile in stable condition.
- 41. **Adjacent properties:** prevent their erosion and / or being deposited with sediment.
- **D.** It is suggested that <u>The Massachusetts Conservation Guide</u>, <u>Volume I Erosion and</u> <u>Sediment Control in Site Development</u>, be used to comply with this division, provided that the zoning officer specifically determines that it complies with Division 5506.0.

DIVISION 5600.0 Pervious Space.

Pervious space is that land within a residential ring excluding all impervious land areas. It is the portion of the land which has the ability to directly recharge the local ground water. For the purpose of Section 16, there are two (2) forms of pervious space: restricted open space (ROS) and outdoor living space (OLS). The sum of the ROS percentage and the OLS percentage must equal one hundred (100) percent.

Division 5601.0 Restricted Open Space (ROS).

- **A.** Land which is required by Section 16 to remain as restricted open space may be used for passive recreation, resource protection, amenity and other purposes specified in this division. Restricted open-space land shall not be occupied by buildings, roads, road rights-of-way or parking areas.
- **B.** All restricted open space required by Section 16 following requirements:

STORMWATER MANAGEMENT PLAN

Appendix I

Standard Operating Procedures





westonandsampson.com

55 Walkers Brook Drive, Suite 100 Reading, MA 01867 tel: 978.532.1900

OPERATIONS & MAINTENANCE

PLAN

MS4 GENERAL PERMIT COMPLIANCE



JUNE 2021

TOWN OF Hopedale MASSACHUSETTS



TABLE OF CONTENTS

	Page
TABLE	OF CONTENTSi
LIST C	IF APPENDICES ii
1.0 1.1 1.2	INTRODUCTION
2.0 2.1 2.2	PARKS AND OPEN SPACE
3.0 3.1 3.2 3.3 3.4 3.5	MUNICIPAL BUILDINGS AND FACILITIES 3-1 Overview 3-1 Use, Storage, & Disposal of Petroleum Products and Other Stormwater Pollutants .3-1 Employee Training 3-1 Spill Prevention and Response 3-2 Waste Management and Other Applicable Good Housekeeping Practices 3-2
4.0 4.1 4.2 4.3 4.4 4.5	MUNICIPAL VEHICLES AND EQUIPMENT. 4-1 Overview 4-1 Municipal Vehicle Storage, Maintenance, and Repair 4-1 Municipal Vehicle and Equipment Fueling 4-1 Municipal Vehicle Washing 4-1 Other Applicable Good House Keeping/ Pollution Prevention Practices 4-2
5.0 5.1 5.2 5.3 5.4 5.5	INFRASTRUCTURE OPERATIONS AND MAINTENANCE 5-1 Drainage System Overview 5-1 Catch Basin Cleaning 5-1 Street Sweeping 5-2 Inspection and Maintenance of Stormwater Treatment Structures 5-3 Winter Road Maintenance 5-3

westonandsampson.com

Weston & Sampson

.....

LIST OF APPENDICES

APPENDIX A:	Inventory of Municipal Parks, Open Space, Buildings, and Facilities
	Municipal Vehicle Inventory

- APPENDIX B: Standard Operating Procedures Parks and Open Space
- APPENDIX C: Standard Operating Procedures Municipal Buildings and Facilities
- APPENDIX D: Standard Operating Procedures Vehicles and Equipment
- APPENDIX E: Standard Operating Procedures Catch Basin Inspection and Cleaning
- APPENDIX F: Standard Operating Procedures Street Sweeping
- APPENDIX G: Standard Operating Procedures Inspection and Maintenance of Stormwater Treatment Structures
- APPENDIX H: Standard Operating Procedures Salt Use Optimization/ Winter Road Maintenance

1.0 INTRODUCTION

1.1 Requirement for Standard Operating Procedures

The 2016 Massachusetts MS4 General Permit, which came into effect on July 1, 2018, regulates discharges from small municipal separate storm sewer systems (MS4s) to waters of the United States. The Permit requires MS4 operators to develop, implement, and enforce a stormwater management program (SWMP). The purpose of the SWMP is to reduce the discharge of pollutants from the MS4 to the maximum extent practicable, to protect water quality, and to satisfy the applicable water quality requirements of the Clean Water Act. MS4 operators are required to implement various Best Management Practices (BMPs) for each of the six minimum control measures. These minimum control measures are as follows:

- Public Education and Outreach
- Public Involvement/Participation
- Illicit Discharge Detection and Elimination
- Construction Site Stormwater Runoff Control
- Post-Construction Stormwater Management in New Development and Redevelopment
- Good Housekeeping and Pollution Prevention for Municipal Operations

As part of the minimum control measure for Good Housekeeping and Pollution Prevention for Municipal Operations, Section 2.3.7 of the 2016 MS4 Permit requires regulated communities to develop and implement a written Operations and Maintenance (O&M) program for municipal activities and facilities. The O&M program serves to prevent or reduce pollutant runoff and protect water quality, and is required to include the following components:

- 1. Written O&M procedures for the following activities/facilities:
 - a. Parks and open space
 - b. Buildings and facilities where pollutants are exposed to stormwater runoff
 - c. Vehicles and equipment
- 2. An inventory of all permittee-owned facilities
- 3. A written program outlining the necessary actions the permittee will implement so that the MS4 is properly maintained to reduce the discharge of pollutants from the MS4, including:
 - a. Optimization of routine inspections, cleaning and maintenance of catch basins
 - b. Implementation of procedures for sweeping and/or cleaning streets and municipally owned parking lots
 - c. Proper storage and disposal of catch basin cleanings and street sweepings
 - d. Implementation of procedures for winter road maintenance
 - e. Implementation of inspection and maintenance frequencies and procedures for storm drain systems and stormwater treatment structures
- 4. Written records for all maintenance activities, inspections and training.



To address these requirements, Standard Operating Procedures (SOPs) associated with these municipal activities and facilities were taken and/or adapted from templates developed by the EPA and the Central Massachusetts Regional Stormwater Coalition (CMRSWC). These templates were developed for use by MS4 communities in complying with the permit requirements outlined above. These pre-developed SOPs are either being implemented by the Town as is or adjusted to fit current practices as long as these practices meet all MS4 requirements.

1.2 Applicability

The operation and maintenance procedures outlined in this document and the accompanying SOPs apply to all the facilities, vehicles, and equipment denoted in the inventory in Appendix A, as well as any activities associated with each facility, vehicle, or piece of equipment. They shall also apply to all drainage infrastructure owned or operated by the Town. The inventory will be updated annually to reflect any changes in property or equipment ownership, or procedures.



2.0 PARKS AND OPEN SPACE

2.1 Overview

The Town of Hopedale performs regular maintenance on parks and open spaces to ensure health, safety, and aesthetic appeal throughout the town. Maintenance consists of mowing, seeding, weeding, pruning, mulching, irrigation, and solid waste management. The Town of Hopedale does not use pesticides in its parks; however, fertilizer is applied in the spring. Stormwater pollutants that can be generated from these activities include nutrients, organics, sediment, trash, and bacteria.

The Town of Hopedale owns and maintains the following parks and open spaces:

- Hopedale Town Park
- Hopedale Town Beach
- Draper Field
- Adin Street Triangle Park

The location of each park and open space area is included in the Parks and Open Space Inventory in Appendix A.

2.2 Operation and Maintenance Activities

The Town of Hopedale performs most of the maintenance at the locations listed above using in-house resources. All lawns are mowed, weeded, irrigated, and seeded/reseeded by The Town. The Town is also responsible for trimming and pruning trees and shrubs, maintaining mulch in shrub beds, and removing leaves in the fall. All trash, leaves and clippings are disposed of at the Hopedale Recycling Center located at the entrance of the Sewer Treatment plant off Route 16. This plan highlights materials or activities that may be potential sources of stormwater pollution. Signs for proper disposal of dog waste are posted around all parks, and an informational flyer discussing proper disposal of waste and the potential impact that dog waste can have on water quality is provided on the Town's website.

Appendix B provides Standard Operating Procedures that the Town should follow for all operation and maintenance activities in its parks and open spaces, including:

• B.1 Parks and Open Space Management



3.0 MUNICIPAL BUILDINGS AND FACILITIES

3.1 Overview

Hopedale owns and operates a variety of different buildings that have the potential for pollutants to be exposed to stormwater runoff. A complete list and the location can be seen in Appendix A. Below is the list of Municipal buildings owned and operated by the Town of Hopedale:

- Town Hall
- General Draper High School
- Highway Department
- Police Department

- Town Library
- Hopedale Water Tower
- Green Street Water Treatment Plant
- Hopedale Wastewater Treatment Facility

3.2 Use, Storage, & Disposal of Petroleum Products and Other Stormwater Pollutants

The Town has restrictions in place regarding the use, storage, and disposal of petroleum products and other stormwater pollutants to prevent the potential for polluted stormwater. Red, leak-proof gas cans are used to for handling and use of flammable liquids such as gasoline. Waste oil is stored at the Highway Department facility garage in one waste oil container in the Mechanics Bay with a capacity of 55-gallons with secondary containment.

There is a fuel island located at the Highway Department facility, both the Diesel and Gasoline tanks are underground, and inspected daily by a certified operator.

Appendix C provides Standard Operating Procedures that the Town should follow for the use, storage, and disposal of petroleum or other hazardous products utilized at municipal facilities, including:

- C.1: Fuel and Oil Handling
- C.2: Hazardous Materials Storage and Handling

3.3 Employee Training

The Town has developed an employee training program, which provides information regarding stormwater pollution prevention and good housekeeping practices for municipal operations. Management practices included as part of the training program consist of: (1) minimizing and preventing exposure of vehicles and equipment to stormwater, (2) good housekeeping operations, (3) preventative maintenance, (4) spill prevention and response, (5) erosion and sediment control, (6) stormwater runoff management, (7) management of salt and piles containing salt and (8) maintenance of control measures. Training on the proper use, storage, and disposal of petroleum products is also included.

The Town will have Stormwater Pollution Prevention Plans (SWPPPs) in place for the Highway Department by the end of Permit Year 3 (June 30, 2021). Employees from the Water Department, Sewer Department and Highway Department will complete annual training on the management practices outlined in the SWPPP.



3.4 Spill Prevention and Response

The Town of Hopedale does not have a spill prevention and response plan. Facilities with the potential for spills have spill kits. Spill kits are located at the Highway Department specifically in the Main Building and Mechanics Bay. These spill kits are stored near areas where oil and other chemicals are kept, and where there is ongoing vehicle and equipment storage/maintenance. The kits include speedi-dri absorbent and brooms. The Mechanics Bay has a specific container that is used for proper disposal of spill response materials.

Good Housekeeping measures are in place to minimize the risk of spilled pollutants entering nearby surface waters. All transfers to and from fuel oil and chemical tanks on site are observed by qualified personnel trained in spill response procedures. Hydraulic equipment is kept in good repair to prevent leaks. Equipment and vehicles are regularly inspected to avoid situations that may result in leaks, spills, and other releases of pollutants that could be conveyed with stormwater to receiving waters. The fueling area at the Highway Department Facility is inspected daily for signs of spills or leaks, which includes inspection of hoses and fittings. Any spills are cleaned up immediately or are properly marked by barricades. Grease and oil spills are treated with an absorbent compound.

Appendix C provides additional Standard Operating Procedures that the Town should follow for spill response at all facilities, including:

• C.3: Spill Response and Cleanup

3.5 Waste Management and Other Applicable Good Housekeeping Practices

Waste from all municipal facilities is picked up by a contracted waste disposal company.

Building maintenance is conducted to minimize the potential for stormwater pollution. This includes practices such as using tarps and drop cloths when painting or sanding, routinely checking buildings for leaks, and sweeping facility parking lots and driveways.

Appendix C also provides Standard Operating Procedures pertaining to waste management and facility housekeeping, including:

• C.4: Operations and Maintenance of Municipal Buildings and Facilities

There are other Standard Operating Procedures that are applicable to municipal buildings and facilities but are discussed and referenced exclusively in other sections. These include the following:

- SOPs for lawn maintenance and landscaping activities, which are included under Section 2.0, Parks and Open Space
- SOPs for vehicle and equipment storage, washing, and fueling, which are discussed in Section 4.0, Municipal Vehicles and Equipment
- SOPs for street sweeping, snow disposal, and the storage and application of deicing materials, which are discussed exclusively under Section 5.0, Infrastructure Operations and Maintenance



4.0 MUNICIPAL VEHICLES AND EQUIPMENT

4.1 Overview

The Highway Department is responsible for only the vehicles utilized by the Highway Department employees, as well as the vehicles utilized by the Water Department. The Sewer Department is responsible for all vehicles utilized by the Sewer Department. All other departments have their vehicles serviced by a third party. An inventory of all vehicles operated and maintained by municipality departments is included in Appendix A.

4.2 Municipal Vehicle Storage, Maintenance, and Repair

Vehicle maintenance facilities have the potential for spills that could contaminate stormwater. Potential pollutants associated with municipal vehicle storage, maintenance, and repair activities include oil and grease, petroleum products, metals, organics and chlorides.

In Hopedale, vehicle maintenance is performed within the Highway Department facility garage. This maintenance includes all changing of fluids. Employees use spigots/funnels to minimize drips/leaks, use drip pans when changing fluids, and have absorbing compounds available for use in the event of a spill. The maintenance garage is equipped with floor drains, which discharge to a tight tank. Spill prevention practices are still encouraged to reduce the amount of oil entering the oil-water separator or the sanitary sewer.

At the Highway Department's Main Building and Mechanics Bay, all vehicles are stored inside to the most practicable extent.

4.3 Municipal Vehicle and Equipment Fueling

All Town vehicles are fueled on site at the Highway Department Facility's fuel island. Fuel is supplied by two separate diesel and gasoline tanks both buried underground. Both tanks are 4,000-gallons located in the back parking lot of the Highway Department. The tanks are assessed daily for leaks. The island is uncovered with no secondary containment. Potential stormwater pollutants associated with municipal vehicle and equipment fueling include oil and grease, petroleum products, trash, metals and organics. The fueling area is inspected regularly for signs of spills or leaks, and there is a concrete pad below the fueling station. Spill response procedures are in place.

4.4 Municipal Vehicle Washing

Potential stormwater pollutants associated with municipal vehicle washing include sediment, nutrients, chlorides, trash, metals, oil & grease, petroleum products and organics.

All vehicle washing is conducted outside of the Highway Department facility building on an impervious surface. The washing area is within proximity of stormwater drains. It is recommended that the Highway Department consider adding filters to the catch basins that collect the wash water to filter out soap and sediment before it discharging to surface waters.



4.5 Other Applicable Good House Keeping/ Pollution Prevention Practices

Appendix D provides Standard Operating Procedures related to vehicle and equipment operation and maintenance, including:

• D.1: Operations and Maintenance of Municipal Vehicles and Equipment

There are other Standard Operating Procedures that are applicable to Municipal Vehicles and Equipment but are discussed and referenced exclusively in other sections. These include the following:

- SOPs for the use, storage, and disposal of petroleum products; SOPs for spill prevention and response, and SOPs for waste management, which are included under Section 3.0, Municipal Buildings and Facilities
- SOPs for street sweeping, which are discussed exclusively under Section 5.0, Infrastructure Operations and Maintenance



5.0 INFRASTRUCTURE OPERATIONS AND MAINTENANCE

5.1 Drainage System Overview

Hopedale has developed a comprehensive map of the Town's drainage system in GIS, which includes town-wide mapping of outfalls, culverts, drain manholes, catch basins, drainage pipes, swales, etc. The system consists of approximately:

- 48.7 Miles of Drainage pipe
- 996 municipal catch basins,
- 564 municipal storm drain manholes,
- 141 municipal outfalls

There are formal waste collection receptacles at all parks. Hopedale has several outfalls that discharge directly to surface waters, and few that discharge to infiltration or leaching basins which infiltrate stormwater directly into the ground. Structural BMPs have been installed throughout Hopedale. These include detention basins, grasses swales and oil/water separators.

5.2 Catch Basin Cleaning

The Highway Department performs routine inspections, cleaning, and maintenance of their 996 catch basins that are located within the MS4 regulated area, the number of catch basins is based off of recent mapping and investigations. The Town of Hopedale will implement the following catch basin inspection and cleaning procedures to reduce the discharge of pollutants from the MS4. In 2020, the Town of Hopedale cleaned and inspected all catch basins throughout the town and plan to clean and inspect all the structures in the spring/summer of 2021 season. Hopedale plans on measuring depths of sediment, bottom of inlet, and height of sump. This data will be utilized to identify those catch basins that are filling up more quickly and will therefore need to be cleaned more than once annually to ensure that the "50 Percent" goal is always reached. Catch basin inspections and cleaning procedures as well as an inspection form are included in Appendix E. All catch basin cleanings are brought to the Highway Department and stockpiled. The material will be disposed of in accordance with state requirements. Hopedale is currently looking for a landfill that has the capacity to accept the stockpiled catch basin cleanings.

To meet anticipated requirements of the new MS4 Permit, the Town will need to optimize catch basin inspection, cleaning and maintenance such that the following conditions are met:

- If a catch basin sump is more than 50 percent full during two consecutive routine inspections
 or cleaning events, the finding will be documented, the contributing drainage area will be
 investigated for sources of excessive sediment loading, and to the extent practicable,
 contributing sources will be addressed. If no contributing sources are found, the inspection
 and cleaning frequency will be increased.
- Catch basins located near construction activities (roadway construction, residential, commercial, or industrial development or redevelopment) will be inspected and cleaned more frequently if inspection and maintenance activities indicate excessive sediment or



debris loadings (i.e., catch basins more than 50 percent full). Priority will also be given to catch basins that discharge to impaired waters.

- The following information will be included in each annual report:
 - Any action taken in response to excessive sediment or debris loadings
 - o Total number of catch basins
 - Number of catch basins inspected
 - o Number of catch basins cleaned
 - o Total volume or mass of material removed from catch basins.

Appendix E provides Standard Operating Procedures that the Town should follow, including:

• E.1: Catch Basin Inspection and Cleaning

5.3 Street Sweeping

The town of Hopedale has approximately 102 centerline miles of public roadway within the town. All streets and parking lots under municipal jurisdiction are swept a minimum of three times per year.

The Town of Hopedale will implement the following street and parking lot sweeping procedures to reduce the discharge of pollutants from the MS4:

- All streets will be swept and/or cleaned a minimum of once per year in the spring (following winter activities such as sanding).
- More frequent sweeping will be considered for targeted areas based on pollutant load reduction potential, inspections, pollutant loads, catch basin cleaning or inspection results, land use, impaired waters, or other factors.
- More frequent sweeping will be performed on municipally-owned streets and parking lots in areas that discharge to certain nutrient-impaired waters. Sweeping must be performed in these areas a minimum of two times per year, once in the spring (following winter activities such as sanding) and at least once in the fall (Sept 1 Dec 1; following leaf fall). Since Hopedale is located within the Blackstone River Watershed and the Charles River Watershed, which are both impaired for phosphorus, all streets within MS4-regulated catchments that discharge to waters of the US must be swept twice per year.

The following information will be included in each annual report:

• Number of miles cleaned, or the volume or mass of material removed (see sweeping log in Appendix F).

All street sweepings are brought to the Highway Department Facility where they are stockpiled. Hopedale is currently looking for a landfill that has the capacity to accept the stockpiled street sweepings.



5.4 Inspection and Maintenance of Stormwater Treatment Structures

The Town of Hopedale uses in-house personnel to conduct inspections of its existing stormwater treatment structures, which include detention basins, grasses swales, and oil/water separators. When properly maintained, these structures reduce stormwater pollution and reduce stormwater facility maintenance costs.

Appendix G provides Standard Operating Procedures for stormwater treatment structures, including:

• G.1: Inspection and Maintenance of Structural Stormwater Best Management Practices (BMPs)

5.5 Winter Road Maintenance

Potential stormwater pollutants associated with winter road maintenance include chloride, sediment and various deicing materials. Pollution potential is reduced by properly storing salt and sand, minimizing the use of sodium chloride and other salts, evaluating opportunities for use of alternative materials, and ensuring that snow disposal activities do not result in disposal of snow into waters of the United States.

The Town of Hopedale uses a sand/salt mix during winter road operations. All salt is stored in a 2,500 square foot salt shed. This is where all truck loading and unloading occurs. If any sand or salt is spilled outside of the shed, it is swept up and moved back inside immediately.

Appendix H provides Standard Operating Procedures for winter road maintenance, including:

• H.1: Salt Use Optimization/ Winter Road Maintenance

There are other Standard Operating Procedures that are applicable to Winter Road Maintenance but are discussed and referenced exclusively in other sections. These include the following:

• SOPs for the operation and maintenance of vehicles and equipment, which are discussed exclusively under Section 4.0, Municipal Vehicles and Equipment



OPERATION AND MAINTENANCE PLAN

APPENDIX A

Inventory of Municipal Parks, Open Space, Buildings, and Facilities Municipal Vehicle Inventory

westonandsampson.com

Weston & Sampson

Town of Hopedale, MA Inventory of Town-Owned Parks and Open Spaces						
Park of Field Name	Location	Parcel ID	Size (Acres)			
Upton State Forest (partial)	2 Carpenter Road	3_2	2.75			
Upton State Forest (partial)	3 Carpenter Road	3_3	2.03			
Hopedale Pond and Parklands	162 Dutcher Street	5_71	279.69			
Hopedale Park	65 Dutcher Street	8_29	6.12			
General Draper Memorial Jr./Sr. School	25 Adin Street	11_84	5.40			
Hopedale Memorial School	54 Adin Steet	10_1	10.30			
Hopedale Village Cemetery	2 Fitzgerald Drive	11_172	20.55			
Hopedale Water Supply 2	208 Hopedale Street	14_140	16.03			
Hopedale Water Supply 3	208 Rear Hopedale Street	14_140-1	14.52			
Hopedale Country Club	90 Mill Street	18_34	184.95			
Water Supply Land	92 and 90A Mill Street	18_39	9.00			
Plain Street Industrial Park	1 Airport Road	22_0	12.20			
Mellen St. Playground	24 Mellen Street	20_34	15.00			
Vacant Lot	252 South Main Street	17_33	14.21			
Vacant Lot	15 rear Patrick Road	12_84	5.54			
Vacant Lot	12 ADJ Patrick Road	12_82	10.61			
Vacant Lot	11 Taft Circle	12_66-1	0.52			
Vacant Lot	6 ADJ Lapworth Circle	12_136	2.86			
Vacant Lot	6 Rear Lapworth Circle	12_136-1	8.57			
Vacant Lot	33 ADJ Hammond Road	12_164	18.93			
Vacant Lot	55 ADJ Westcott Road	9_68	2.95			
Vacant Lot	7 ADJ Moore Road	9_49	17.46			
Vacant Lot	10 ADJ Moore Road	9_92	13.52			
Vacant Lot	25 Moore Road	9_35	0.16			
Vacant Lot	28 Moore Road	9_34	0.25			
Vacant Lot	187 Freedom Street	9_103	3.75			

Town of Hopedale, MA Inventory of Municipal Buildings and Facilities							
Municipal Building	Location	Parcel ID	Size (Acres)				
General Draper High School	83 Hopedale Street	11-70-0	0.50				
Hopedale Town Hall	74 Hopedale Street	11-61-0	0.30				
Greene Street Pump Station	149 Greene Street	14-127-0	1.60				
Highway Department	7 Depot Street	11-64-0	1.90				
Hopedale Police Station	70 Hopedale Street	11-67-1	0.34				
Bancroft Memorial Library	50 Hopedale Street	11-95-1	0.40				
Little Red Shop	12 Hopedale Street	8-139-0	0.30				
Bright Beginning Center	6 Park Street	8-32-0	1.59				
Hopedale Memorial School	25 Adin Street	11-84-0	5.40				
Greene Street Water Treatment Facility	154 Mendon Street	14-146-0	61.81				

Town of Hopedale, MA								
	Inventory of Municipal Vehicle and Equipment Maintained in Hopedale							
Department	Vehicle Year	Vehicle Make	Vehicle Model					
Highway	2011	Chevrolet	3500 Dump					
Highway	1995	Ford	L8000					
Highway	2006	Ford	F350 Dump					
Highway	2002	International	7400					
Highway	2009	International	7400					
Highway	2020	Freightliner	108SD					
Highway	2005	International	7400					
Highway	2001	Ford	F350 Pick Up					
Highway	2013	Chevrolet	3500 Pick Up					
Highway	1997	Ford	L8000					
Highway	2003	John Deer	15/65					
Highway	1995	Trackless	MT					
Highway	1986	John Deer	1050					
Highway	2006	Kubota	1385					
Highway	2001	CAT	Back Hoe 420D					
Highway	2008	САМО	SIDE WALK PLOW					
Highway	1998	CAT	924F					
Highway	2007	CAT	928G					
Highway	2013	Trackless	MT					
Highway	2010	SWEEPER	ELGIN					
Highway	2013	John Deer	15/65					
Highway	2000	Woodsman	Wood chipper					
Highway	1999	Ford	E250 Van					
Highway	1985	Giant Vac	Leaf Machine					
Highway	2003	Giant Vac	Leaf Machine					
Sewer	1983	GMC	7000					
Sewer	2008	Ford	F250					
Water	1957	Sewer Rodder Trailer	-					
Water	1994	Sullivan	Compressor					
Water	2008	Ford	F650					
Water	2008	CAT	Backhoe					
Water	2009	EH	Wa TRV-1-vac					
Water	2011	Chevrolet	<u>K2500</u>					
Water	2011	Chevrolet	Silverado					
Water	2010	FUIU Rrimar	Constructi					
Water	2018	CAT	Mini Excavator					

Town of Hopedale, MA						
Inventory of Town-Owned/Operated Stormwater Treatment Structures						
BMP	Location					
Detension Basin	West of OF-134 on Condon Way					
Detension Basin	West of OF-135 on Condon Way					
Detension Basin	Near OF-2 on Harmony Trail					
Detension Basin	Near OF-7 on Haven Way					
Detension Basin	2 Larkin Lane					
Detension Basin	13 Heron Lane					
Detension Basin	5 Forest Path					
Detension Basin	90 Laurelwood Path					
Detension Basin	90 Laurelwood Path					
Detension Basin	Northeast of 12 Patrick Road					
Detension Basin	North of 4 Rockridge Road, near OF-20					
Detension Basin	7 Roberston Lane					

OPERATION AND MAINTENANCE PLAN

APPENDIX B

Standard Operating Procedures – Parks and Open Space

westonandsampson.com

Weston & Sampson

Standard Operating Procedures

Hopedale, MA Highway Department Facility

Parks and Open Space Management

Approved by:

Chris Nadeau

Highway Department Superintendent

MA Small MS4 General Permit Requirement Summary:

Part 2.3.7.a.i.

Within two (2) years from the effective date of the permit, the permittee shall develop, if not already developed, written (hardcopy or electronic) operations and maintenance procedures for parks and open space. These written procedures shall be included as part of the SWMP.

Part 2.3.7.a.ii.1.

Establish procedures to address the proper use, storage, and disposal of pesticides, herbicides, and fertilizers including minimizing the use of these products and using only in accordance with manufacturer's instruction. Evaluate lawn maintenance and landscaping activities to ensure practices are protective of water quality. Protective practices include reduced mowing frequencies, proper disposal of lawn clippings, and use of alternative landscaping materials (e.g., drought resistant planting). Establish pet waste handling collection and disposal locations at all parks and open space where pets are permitted, including the placing of proper signage concerning the proper collection and disposal of pet waste. Establish procedures to address waterfowl congregation areas where appropriate to reduce waterfowl droppings from entering the MS4. Establish procedures for management of trash containers at parks and open space (scheduled cleanings; sufficient number). Establish procedures to address erosion or poor vegetative cover when the permittee becomes aware of it; especially if the erosion is within 50 feet of a surface water.

Municipal Parks and Open Space Inventory

The following is a list of properties covered by these procedures. This inventory shall be updated annually during SWMP review.

Park	Address/Location	Lawn Mowing	Landscaping	Fertilizing	Pesticide/Herbicide	Trash mgmt.	Pet waste mgmt.	Waterfowl mgmt.	Other maintenance:
Hopedale Pond and Parklands	162 Dutcher Street	Х	Х	Х		Х	Х	Х	
Draper Fields	161 Freedom Street	Х		Х		Х			
Adin Triangle Street	2 Peace Street	Х	Х	Х					
Philips Brothers Memorial Field	24 Mellen Street	Х	Х	Х		Х			
Hopedale Village Cemetery	2 Fitzgerald Drive	Х	Х	Х		Х			

Standard Operating Procedures	Issue Date:
Hopedale, MA	lune 2021
Highway Department Facility	
Parks and Open Space Management	

Personnel

The following personnel are responsible for municipal parks and open space management. Employees performing the procedures in this SOP shall attend annual stormwater pollution prevention training.

Name	Responsibility
HWD Superintendent – Chris Nadeau	Oversee Parks and Open Space Management
Forman - Vincent Ozella	Working Foreman – Parks and Recreational Facilities

Lawn Mowing

Occurs at the following Parks:

Hopedale Parks & Parklands, Hopedale Village Cemetery, Philips Brothers Memorial Field, and Adin Ballou Park.

On the following schedule:

Once per week/ Staggered Schedule during spring/summer months. Lawns are not mowed during the fall or winter.

Responsible Personnel:

Chris Nadeau or Vincent Ozella

Standard Operating Procedures:

- \rightarrow Lawns shall be mowed to a height of 3".
- \rightarrow Mowing pattern shall vary to prevent ruts and promote even growth.
- → Grass clippings shall be mulched using a mulching mower or disposed of at the Hopedale Recycling Center

Fertilizer Use

Occurs at the following Parks:

Hopedale Pond and Parklands, Draper Fields, Adin Ballou Triangle Street, Mellen Street Playground, Hopedale Village Cemetery

On the following schedule:

Spring (weather depending); April and May Except during drought conditions or preceding heavy rainfall.

Responsible Personnel:

Chris Nadeau or Vincent Ozella

All fertilizer storage locations

- → have secondary containment and/or are located under cover;
- → contain spill response materials including Speedi dry;
- \rightarrow shall be inspected at the following frequency: monthly by Chris Nadeau or Vinny Ozella

Standard Operating Procedures	Issue Date:
Hopedale, MA	June 2021
Highway Department Facility	
Parks and Open Space Management	

Standard Operating Procedures:

- → Chemicals shall be reordered by Chris Nadeau or Vinny Ozella as needed to minimize excess storage/disposal.
- → Fertilizers shall be applied following manufacturer's instructions as well as additional municipal instructions.

Other Landscaping

- Involves the following:
 - Weeding
 - Planting/reseeding
 - Pruning
 - Leaf litter removal

Other Landscaping practices occur when necessary to keep the landscape in a healthy condition.

Responsible Personnel:

Chris Nadeau and Vincent Ozella

Standard Operating Procedures:

- → Landscaping waste including leaf litter shall be disposed of at the Hopedale Recycling Center for composting so as to avoid entering the storm drain system.
- \rightarrow Weeding shall be done manually where possible to reduce herbicide use.

Trash Management

Trash cans and/or dumpsters are located at the following parks: Hopedale Pond and Parklands, Draper Fields, Mellen Street Playground, Hopedale Village Cemetery

Emptying and replacing bags/inspecting for leaks shall take place on the following schedule: Once per week

Responsible Personnel: Chris Nadeau or Vincent Ozella

Parks shall be inspected and cleaned for litter on the following schedule: Once per week

Responsible personnel: Chris Nadeau or Vinny Ozella

Pet waste receptacles and/or bags are located at the following parks: Hopedale Pond and Parklands

Standard Operating Procedures Hopedale, MA Highway Department Facility	Issue Date: June 2021
Parks and Open Space Management	
Emptying and replacing bags/inspecting for leaks shall take place on the following schedule: Once per week Responsible Personnel: Chris Nadeau or Vincent Ozella	

OPERATION AND MAINTENANCE PLAN

APPENDIX C

Standard Operating Procedures – Municipal Building Facilities

westonandsampson.com

Weston & Sampson

C.1: Fuel and Oil Handling

Introduction

Spills, leaks, and overfilling can occur during handling of fuels and petroleum-based materials, representing a potential source of stormwater pollution, even in small volumes. The goal of this written Standard Operating Procedure (SOP) is to provide guidance to municipal employees on a variety of ways by which fuels and petroleum-based materials can be delivered, as well as steps to be taken when petroleum products (such as waste oil) are loaded onto vehicles for offsite disposal or recycling. Delivery, unloading, and loading of waste oils are hereafter referred to as "handling." Attached is a fuel delivery form checklist.

The Town of Hopedale undertakes various procedures and precautions in handling fuel and oil, as described in Section 3.0 of the Town's Operation and Maintenance Plan.

Procedures

The Town of Hopedale will implement the following fuel and oil handling procedures to help reduce the discharge of pollutants from the MS4:

General Guidelines

For all manners of fuel and oil handling described below, a member of the facility's Pollution Prevention Team (if the facility has a SWPPP) or another knowledgeable person familiar with the facility should be present during handling procedures. This person should ensure that the following are observed:

- There is no smoking while fuel handling is in process or underway.
- Sources of flame are kept away while fuel handling is being completed. This includes smoking, lighting matches, carrying any flame, or carrying a lighted cigar, pipe, or cigarette.
- The delivery vehicle's hand brake is set, and wheels are chocked while the activity is being completed.
- Catch basins and drain manholes are adequately protected.
- No tools are to be used that could damage fuel or oil containers or the delivery vehicle.
- No flammable liquid should be unloaded from any motor vehicle while the engine is operating unless the engine of the motor vehicle is required to be used for the operation of a pump.
- Ensure that local traffic does not interfere with fuel transfer operations. If it does, make appropriate accommodations.
- The attending persons should watch for any leaks or spills:
 - Any small leaks or spills should be immediately stopped, and spilled materials absorbed and disposed of properly. Follow the procedures in SOP C.3: Spill Response and Cleanup.
 - In the event of a large spill or one that discharges to surface waters or an engineered storm drain system, the facility representative should activate the facility's Stormwater Pollution Prevention Plan (SWPPP) and report the incident as specified in the document.

Delivery by Bulk (Tanker) Truck

Procedures for the delivery of bulk fuel should include the following:

• The truck driver should check in with the facility upon arrival.





- The facility representative should ensure that the appropriate spill cleanup and response equipment and personal protective equipment are readily available and easily accessible. Refer to SOP C.3: Spill Response and Cleanup for examples of spill cleanup and response materials.
- The facility representative should check to ensure that the amount of delivery does not exceed the available capacity of the tank.
 - A level gauge can be used to verify the level in the tank.
 - If a level gauge is not functioning or is not present on the tank, the tank should be stick tested prior to filling.
- The truck driver and the facility representative should both remain with the vehicle during the delivery process.
- The truck driver and the facility representative should inspect all visible lines, connections, and valves for leaks.
- When delivery is complete and the hoses are removed, buckets should be placed underneath connection points to catch drippings.
- The delivery vehicle should be inspected prior to departure to ensure that the hose is disconnected from the tank.
- The facility representative should inspect the fuel tank to verify that no leaks have occurred, or that any leaked or spilled material has been cleaned and disposed of properly.
- The facility representative should gauge tank levels to ensure that the proper amount of fuel is delivered and collect a receipt from the truck driver.

Delivery of Drummed Materials

Drummed materials may include motor oil, hydraulic fluid, transmission fluid, or waste oil from another facility (as approved). Procedures for the delivery of drummed materials should include the following:

- The truck driver should check in with the facility upon arrival.
- The facility representative should ensure that the appropriate spill cleanup and response equipment and personal protective equipment are readily available and easily accessible Refer to SOP C.3: Spill Response and Cleanup for examples of spill cleanup and response materials. The facility representative should closely examine the shipment for damaged drums.
 - If damaged drums are found, they should be closely inspected for leaks or punctures.
 - Breached drums should be removed to a dry, well-ventilated area and the contents transferred to other suitable containers.
 - Drums should be disposed of in accordance with all applicable regulations.
- Drummed materials should not be unloaded outdoors during wet weather events.
- The truck driver and the facility representative should both remain with the vehicle during the delivery process.
- Drums should be handled and unloaded carefully to prevent damage.
- Upon completion of unloading, the facility representative should inspect the unloading point and the drums to verify that no leaks have occurred, that any leaked or spilled material has been cleaned up and disposed of properly, and that the unloaded drums are not leaking.
- The facility representative should check to ensure that the proper amount of fuel or other material is delivered and collect a receipt from the truck driver.





Removal of Waste Oil from the Facility

When waste oil or similar oil products need to be removed from the premises, only haulers certified to transport waste oil should be utilized. Procedures should include the following:

- The disposal truck driver should check in with the facility upon arrival.
- The facility representative should ensure that the appropriate spill cleanup and response equipment and personal protective equipment are readily available and easily accessible. Refer to SOP C.3: Spill Response and Cleanup for examples of spill cleanup and response materials. The truck driver and the facility representative should both remain with the vehicle during the tank draining process.
- When draining is complete and the hoses are removed, buckets should be placed underneath connection points to catch drippings.
- The facility representative should inspect the loading point and the tank to verify that no leaks have occurred, or that any leaked or spilled material has been cleaned up and disposed of properly.
- The facility representative should collect a receipt from the truck driver.
- When draining bulk oil tanks:
 - The facility representative should verify that the volume of waste oil in the tank does not exceed the available capacity of the disposal hauler's vehicle.
 - The disposal hauler vehicle should be inspected prior to departure to ensure that the hose is disconnected from the tank.

Employee Training

- Employees who handle or deliver fuel and/or oil are trained once per year on proper procedures.
- Employees are also trained on stormwater pollution prevention, illicit discharge detection and elimination (IDDE) procedures, and spill and response procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.

Attachments

1. Fuel Delivery Checklist

Related Standard Operating Procedures

• C.3: Spill Response and Cleanup





C.2: Hazardous Materials Storage and Handling

Introduction

A hazardous material is any biological, chemical, or physical material with properties that make it dangerous or potentially harmful to human health or the environment. Hazardous materials can be released to the environment in a variety of ways. When hazardous materials come into contact with rain or snow, the pollutants are washed into the storm sewer system and to surface waterbodies and/or groundwater. Hazardous materials associated with municipal facilities and their operations include, but are not limited to, oil, gasoline, antifreeze, fertilizers, pesticides, and de-icing agents and additives.

Municipally owned or managed facilities where hazardous materials are commonly stores and handled include:

- Equipment storage and maintenance yards
- Hazardous waste disposal facilities •
- Hazardous waste handling and transfer facilities •
- Composting facilities •
- Materials storage yards •
- Municipal buildings and facilities (e.g., schools, libraries, police and fire departments, town offices, municipal pools, and parking garages)
- Public works yards •
- Solid waste handling and transfer facilities •
- Vehicle storage and maintenance yards •
- Water and wastewater facilities

Minimizing or eliminating contact of hazardous materials with stormwater can significantly reduce pollution of receiving waters. Proper hazardous material handling and storage also contributes to employee health, an organized workplace, and efficient operations. The goal of this written Standard Operating Procedure (SOP) is to provide guidance to municipal employees to help prevent stormwater pollution resulting from the handling and storage of hazardous materials. If services are contracted, this SOP should be provided to the contractor. The contract should also specify that the contractor is responsible for compliance with all applicable laws.

The Town of Hopedale undertakes various activities regarding handling and storing hazardous materials. These activities are outlined in Section 3.2 of the Town's Operation and Maintenance Plan.

Procedures

The Town of Hopedale will implement the following procedures for handling and storing hazardous materials to reduce the discharge of pollutants to the MS4:

Handling, Loading, and Unloading

- Avoid loading/unloading materials in the rain and/or provide cover.
- Retrace areas where materials have been transferred to identify spills. If spills are found, immediately





clean them up. Follow procedures in SOP C.3: Spill Response and Cleanup.

- Time delivery and handling of materials during favorable weather conditions whenever possible (e.g., avoid receiving loads of sand during windy weather).
- Inspect containers for material compatibility and structural integrity prior to loading/unloading any raw or waste materials.
- Use dry cleanup methods (e.g., squeegee and dust pan, sweeping, and absorbents as last step) rather than hosing down surfaces.

Material Storage

- Confine material storage indoors whenever possible. Plug or disconnect floor drains that lead to the stormwater system.
- Confine outdoor material storage to designated areas that are covered, on impervious surfaces, away from high traffic areas, and outside of drainage pathways.
- Store containers on pallets or equivalent structures to facilitate leak inspection and to prevent contact with wet floors that can cause corrosion. This technique also reduces incidences of container damage by insects and rodents.
- Store materials and waste in materially compatible containment units.
- Keep hazardous materials in their original containers.
- If materials are not in their original containers, clearly label all storage containers with the name of the chemical, the expiration date, and handling instructions.
- Maintain an inventory of all raw and waste materials to identify leakage. Order new materials only when needed.
- Provide secondary containment for storage tanks and drums with sufficient volume to store 110 percent of the volume of the material.
- Provide sufficient aisle space to allow for routine inspections and access for spill cleanup.
- Inspect storage areas for spills or leaks and containment units for corrosion or other failures.

Waste Treatment, Disposal, and Cleanup

- Adopt a regular schedule for the pick-up and disposal of waste materials.
- Recycle leftover materials whenever possible.
- Substitute nonhazardous or less-hazardous materials for hazardous materials whenever possible.
- Protect empty containers from exposure to stormwater and dispose of them regularly to avoid contamination from container residues.

Employee Training

- Employees who handle and use hazardous materials are trained once per year on these procedures.
- Employees are also trained on stormwater pollution prevention, illicit discharge detection and elimination (IDDE) procedures, and spill and response procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.




C.3: Spill Response and Cleanup

Introduction

Municipalities are responsible for any contaminant spill or release that occurs on property that they own or operate. Particular areas of concern include any facilities that use or store chemicals, fuel oil, or hazardous waste, including schools, garages, and landfills. Implementation of proper spill response and cleanup procedures can help to mitigate the effects of a contaminant release. The goal of this written Standard Operating Procedure (SOP) is to provide guidance to municipal employees to help reduce the discharge of pollutants from the MS4 as a result of spills or releases.

Procedures

The Town of Hopedale will implement the following spill response and cleanup procedures to reduce the discharge of pollutants from the MS4:

Responding to a Spill

Employees should be trained in proper spill response specific to the materials used at their site and appropriate personal protective equipment (PPE). In the event of a spill, follow these spill response and cleanup procedures:

- If the facility has a Stormwater Pollution Prevention Plan (SWPPP), notify a member of the facility's Pollution Prevention Team, the facility supervisor, and/or the facility safety officer (fill out the attached spill response contact list). If not, continue to follow the procedures outlined below.
- Assess the contaminant release site for potential safety issues and for direction of flow.
- Complete the following:
 - Stop the contaminant release.
 - Contain the contaminant release through the use of spill containment berms or absorbents.
 - Protect all drains and/or catch basins with the use of absorbents, booms, berms or drain covers.
 - o Clean up the spill.
 - Dispose of all contaminated products in accordance with applicable federal, state and local regulations.
 - Soil contaminated with petroleum should be handled and disposed of as described in MassDEP policy WCS-94-400, Interim Remediation Waste Management Policy for Petroleum Contaminated Soils
 - (https://www.mass.gov/files/documents/2016/08/mq/94-400.pdf).ii. Products saturated with petroleum products or other hazardous chemicals require
 - special handling and disposal by licensed transporters. Licensed transporters will pick up spill contaminated materials for recycling or disposal. Save the shipping records for at least three years.
 - iii. Waste oil contaminated industrial wipes and sorptive minerals:
 - Perform the "one drop" test to ensure absorbents do not contain enough oil to be considered hazardous, as described in the MassDEP Waste Oil Management Guide

(https://www.mass.gov/files/documents/2018/12/18/oilwiper.pdf).





Feb. 2020

Page 1 of 4

- 2. Wring absorbents through a paint filter. If doing so does not generate one drop of oil, the materials are not hazardous.
- 3. If absorbents pass the "one drop" test they may be discarded in the trash unless contaminated with another hazardous waste.
 - a. It is acceptable to mix the following fluids and handle them as waste oil:
 - i. Waste motor oil
 - ii. Hydraulic fluid
 - iii. Power steering fluid
 - iv. Transmission fluid
 - v. Brake fluid
 - vi. Gear oil
 - b. **Do not mix** the following materials with waste oil. Store each separately:
 - i. Gasoline
 - ii. Antifreeze
 - iii. Brake and carburetor cleaners
 - iv. Cleaning solvents
 - v. Other hazardous wastes
- 4. If absorbents do not pass the "one drop" test they should be placed in separate metal containers with tight fitting lids, labeled "Oily Waste Absorbents Only."
- If you need assistance containing and/or cleaning up the spill, or preventing it from discharging to a surface water (or an engineered storm drain system), contact your local fire department using the number listed below. In the case of an emergency call 911.
 - o Hopedale Fire Department: (508) 473-1050
- Contact the MassDEP 24-hour spill reporting notification line, toll-free at (888)-304-1133;
 - The following scenarios **are exempt** from MassDEP reporting requirements (see the MassDEP factsheet on oil and hazardous materials handling for more information: <u>https://www.mass.gov/files/documents/2016/08/xm/spillmgm.pdf</u>).
 - i. Spills that are less than 10 gallons of petroleum and do not impact a water body
 - ii. Spills that are less than one pound of hazardous chemicals and do not present an imminent health or safety hazard
 - iii. Fuel spills from passenger vehicle accidents
 - iv. Spills within a vault or building with a watertight floor and walls that completely contain all released chemicals

Reporting a Spill

When contacting emergency response personnel or a regulatory agency, or when reporting the contaminant release, be prepared to provide the following information:

- 1. Your name and the phone number you are calling from.
- 2. The exact address and location of the contaminant release.
- 3. Specifics of release, including:
 - a. What was released;
 - b. How much was released, which may include:





- i. Pounds
- ii. Gallons
- iii. Number of containers
- 4. Where was the release sent/what was contaminated, addressing:
 - a. Pavement
 - b. Soil
 - c. Drains
 - d. Catch basins
 - e. Water bodies
 - f. Public streets
 - g. Public sidewalks
- 5. The concentration of the released contaminant.
- 6. What/who caused the release.
- 7. Is the release being contained and/or cleaned up or is the response complete.
- 8. Type and amount of petroleum stored on site, if any.
- 9. Characteristics of contaminant container, including:
 - a. Tanks
 - b. Pipes
 - c. Valves

Maintenance and Prevention Guidance

Prevention of spills is preferable to even the best response and cleanup. To mitigate the effects of a contaminant release, provide proper maintenance and inspection at each facility. To protect against contaminant release adhere to the following guidance:

- Ensure all employees are properly trained to respond in the case of a spill, understand the nature and properties of the contaminant, and understand the spill control materials and personnel safety equipment. Maintain training records of current personnel on site and retain training records of former personnel for at least three years from the date last worked at the facility.
- Provide yearly maintenance and inspection at all municipal facilities, paying particular attention to underground storage tanks. Maintain maintenance and inspection records on site.
- Implement good management practices where chemicals and hazardous wastes are stored:
 - a. Ensure storage in closed containers inside a building and on an impervious surface wherever possible.
 - b. If storage cannot be provided inside, ensure secondary containment for 110 percent of the maximum volume of the storage container.
 - c. Locate storage areas near maintenance areas to decrease the distance required for transfer.
 - d. Provide accurate labels, Material Safety Data Sheets (MSDS) information, and warnings for all stored materials.
 - e. Regularly inspect storage areas for leaks.
 - f. Ensure secure storage locations, preventing access by untrained or unauthorized persons.
 - g. Maintain accurate records of stored materials.
- Replace traditional hazardous materials such as pesticides and cleansers with non-hazardous products such as bio-lubricants which can reduce response costs in the case of a spill.





Maintain appropriately stocked spill response kits at each facilities and locations where oil, chemicals, or other hazardous materials are handled and stored.

Employee Training

- Employees who perform work with potential stormwater pollutants are trained once per year on proper spill procedures.
- Employees are also trained on stormwater pollution prevention and illicit discharge detection and elimination (IDDE) procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.

Attachments

1. Spill Response and Cleanup Contact List





C.4: Operations and Maintenance of Municipal Buildings and Facilities

Introduction

Municipal buildings and facilities (schools, municipal offices, police and fire stations, municipal pools, parking garages, etc.) often house various chemicals, such as petroleum products and hazardous materials. As a result, these buildings and facilities are potential sources of pollutant discharges to the storm drainage system. The goal of this written Standard Operating Procedure (SOP) is to provide guidance to municipal employees on the use, storage, and disposal of chemicals and other stormwater pollutants to reduce the discharge of pollutants from the MS4. If services are contracted, this SOP should be provided to the contractor. The contract should specify that the contractor is responsible for compliance with all applicable laws.

The Town of Hopedale performs a variety of operations and maintenance activities at its municipally owned and operated buildings, as mentioned in the Operation and Maintenance Plan. An inventory of all municipal buildings and facilities is included in Appendix A of that plan and will be updated annually.

Procedures

The Town of Hopedale will implement the following procedures for municipally owned or operated buildings and facilities to reduce the discharge of pollutants from the MS4:

Handling, Storage, Transfer, and Disposal of Trash and Recyclables

All liquid and solid waste must be disposed of properly. Some of the most common sources of pollution at municipal facilities are a result of littering, improper collection of debris, and improper disposal of solid or liquid waste.

- All waste and recycling receptacles must be leak-tight with tight-fitting lids or covers.
- Always keep lids on dumpsters and containers closed unless adding or removing material. If using an open-top roll-off dumpster, cover it and tie it down with a tarp unless adding materials.
- Place waste or recycling receptacles indoors or under a roof or overhang whenever possible.
- Locate dumpsters on a flat, paved surface and install berms or curbs around the storage area to prevent run-on and run-off.
- Do not locate dumpsters over or adjacent to catch basins.
- Prior to transporting waste, trash, or recycling, ensure that containers are not leaking (double bag if needed) and properly secure containers to the vehicle.
- Clean and sweep up around outdoor waste containers regularly.





- Clean up any liquid leaks or spills with dry cleanup methods.
- Arrange for waste or recycling to be picked up regularly and disposed of at approved disposal facilities.
- Never place hazardous materials, liquids, or liquid-containing wastes in a dumpster or recycling or trash container (see SOP C.2: Hazardous Materials Storage and Handling).
- Do not wash trash or recycling containers outdoors or in parking lots.
- Conduct periodic inspections of solid and liquid waste storage areas to check for leaks and spills.
- Conduct periodic inspections of work areas to ensure that all wastes are being disposed of properly.
- In dumpster areas, regularly pick up surrounding trash and debris and regularly sweep the area.
- In compactor areas, regularly check the hydraulic fluid hoses and reservoir to ensure that there are no cracks or leaks. Regularly sweep the area.

Building Maintenance

- When power washing buildings and facilities, ensure that the washwater does not flow into the storm system. Containment or filtering systems should be provided.
- Paint and other chemicals should not be applied on the outside of buildings when it is raining or prior to expected rain.
- When sanding, painting, power washing, etc., ensure that sites are properly prepared (e.g., use tarps) and cleaned (e.g., use dry cleaning methods) especially if they are near storm drains. Protect catch basins when maintenance work is conducted upgradient of them.
- When painting, use a drop cloth and clean up any spills immediately.
- Do not leave open containers on the ground where they may accidentally tip over.
- Buildings should be routinely inspected for areas of potential leaks.
- Do not discharge chlorinated pool water into the stormwater system. Water must be properly dechlorinated and tested before it is discharged.
- Streets and parking lots surrounding municipal buildings and facilities should be swept and kept clean to reduce runoff of pollutants and debris to the stormwater system.
- Streets and parking lots around buildings and facilities will be swept in accordance with the procedures in SOP F.1: Streets and Parking Lots.

Storage of Petroleum Products and Potential Pollutants

- Floor drains in storage areas should be disconnected from the stormwater system.
- Routinely inspect buildings and facilities for areas of potential leaks.
- For storage and handling procedures of petroleum products and potential pollutants, refer to SOP C.2: Hazardous Materials Storage and Handling and SOP C.1: Fuel and Oil Handling Procedures.
- Should the Town begin to store and apply fertilizer, herbicides, or pesticides, a separate SOP shall be developed for all activities relevant to those potential pollutants.
- All municipal buildings and facilities should be periodically inspected to address potential pollutant sources (e.g., leaks).





Spill Prevention Plan

- Spill prevention plans such as Spill Prevention Control and Countermeasure (SPCC) Plans should be in place where applicable, based on inventories of material storage and potential pollutants. Coordinate with the local fire department if necessary.
- Spill SOPs are outlined in SOP C.3: Spill Response and Cleanup.

Employee Training

- Employees who perform maintenance or other applicable work at municipal buildings and facilities are trained once per year on these procedures and the proper operation of related equipment.
- Employees are also trained on stormwater pollution prevention, illicit discharge detection and elimination (IDDE) procedures, and spill and response procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.

Related Standard Operating Procedures

- 1. C.1: Fuel and Oil Handling
- 2. C.2: Hazardous Material Storage and Handling
- 3. C.3: Spill Response and Cleanup
- 4. F.1: Street Sweeping





OPERATION AND MAINTENANCE PLAN

APPENDIX D

Standard Operating Procedures – Vehicles and Equipment

westonandsampson.com

Weston & Sampson

D.1: Operations and Maintenance of Municipal Vehicles and Equipment

Introduction

Regular maintenance of both municipal and contracted vehicles and heavy equipment not only prolongs the life of municipal assets but also helps reduce the potential for leaking of fluids associated with normal wear and tear. Potential pollutants include fuels, oil, antifreeze, brake fluid, solvents, and battery acid. The goal of this written Standard Operating Procedure (SOP) is to provide guidance to municipal employees to help reduce the discharge of pollutants from the MS4 because of leaks from vehicles and equipment. If services are contracted with respect to vehicles and equipment, this SOP should be provided to the contractor. The contract should also specify that the contractor is responsible for compliance with all applicable laws.

The Town of Hopedale undertakes various procedures regarding its municipal vehicles and equipment, which are explained in detail in Section 4.0 of the Town's Operation and Maintenance Plan. An inventory of all municipal vehicles and equipment is included in Appendix A of that Plan and updated annually.

Procedures

The Town of Hopedale will implement the following procedures for municipally owned and operated vehicles and equipment to reduce the discharge of pollutants from the MS4:

Vehicle and Equipment Maintenance

Vehicle Storage

- Monitor vehicles and equipment for leaks and use drip pans as needed until repairs can be performed.
- When drip pans are used, avoid overtopping.
- Drain fluids from leaking or wrecked vehicles and parts as soon as possible. Dispose of fluids properly.
- Store and park vehicles on impervious surfaces and/or under cover or indoors whenever possible.

Vehicle Maintenance

- Conduct routine inspections of heavy equipment and vehicles to proactively identify maintenance needs or potential leaks.
- Perform routine preventive maintenance to ensure heavy equipment and vehicles are operating optimally.
- Recycle or dispose of waste properly and promptly.
- Sweep and pick up trash and debris as needed.
- Do not dump any liquids or other materials outside, especially near or in storm drains or ditches.





Body Repair and Painting

- Conduct all body repair and painting work indoors.
- Minimize waste from paints and thinners. Calculate paint needs based on surface area.
- Use dry cleanup methods (vacuum, sweep) to clean up metal filings and dust and paint chips from grinding, shaving and sanding. Sweep debris from wet sanding after allowing it to dry overnight on the shop floor. Dispose of waste properly; never dump waste into storm or sanitary sewers.
- Use sanding tools equipped with vacuum capability to pick up debris and dust.

Fueling

- Fueling areas owned or operated by the municipality should be covered.
- Fueling areas should be evaluated to ensure that pollutants (e.g., gasoline or oil) do not enter the MS4. Follow the procedures in SOP C.1: Fuel and Oil Handling.

Material Management

- Store materials and waste in labeled containers under cover and in secondary containment.
- Chemicals should not be combined in containers.
- Hazardous waste must be labeled and stored according to hazardous waste regulations. Follow the procedures in SOP C.2: Hazardous Materials Storage and Handling.
- Carefully transfer collected fluids from containers into designated storage areas as soon as possible.
- Store new and used batteries securely to avoid breakage. Store indoors or in secondary containment to contain potential acid leaks. Recycle used batteries.
- Conduct periodic inspections of storage areas to detect possible leaks.
- Do not wash or hose down storage areas unless there is prior approval to collect and discharge the water into the sanitary sewer. Use dry cleanup methods whenever possible.
- Keep lids on containers. Store them indoors or under cover to reduce exposure to rain.
- Inspect and maintain all pretreatment equipment, including interceptors, according to the manufacturer's maintenance schedule and at least once per year.
- Proper spill protocol should be followed to prevent chemicals from entering the stormwater system. Follow the procedures in SOP C.3: Spill Response and Cleanup.

Parts Cleaning

- Use designated areas for engine, parts, or radiator cleaning. Do not wash or rinse parts outdoors. If parts cleaning equipment is not available, then capture parts cleaning fluids.
- Recycle cleaning solution. Never discharge waste to the sanitary sewer or storm sewer.
- Use steam cleaning or pressure washing of parts instead of solvent cleaning. Cleaning equipment must be connected to an oil/water interceptor prior entering the sanitary sewer.
- When using solvents for cleaning, drain parts over the solvent tank to avoid drips to the floor. Catch excess solutions and divert them back to tank. Allow parts to dry over the hot tank.





Vehicle and Equipment Washing

Vehicle washing can result in the discharge of nutrients, sediment, petroleum products, and other contaminants to a surface water body or to a stormwater system. The MS4 Permit does not authorize the discharge of municipal vehicle washing byproducts into the MS4.

Outdoor Vehicle Washing Procedures

Outdoor washing of municipal vehicles should be avoided unless wash water is contained in a tight tank or similar structure. Where no alternative wash system is available, and full containment of wash water cannot be achieved, adhere to the following procedures:

- Avoid discharge of any wash water directly to the storm drainage system or surface water (e.g., stream, pond, or drainage swale)
- Minimize the use of water to the extent practicable.
- Where the use of detergent cannot be avoided, use products that do not contain regulated contaminants. The use of a biodegradable, phosphate-free detergent is preferred.
- Do not use solvents except in dedicated solvent parts washer systems or in areas not connected to a sanitary sewer.
- Do not power wash, steam clean, or perform engine or undercarriage cleaning.
- Grassy and pervious (porous) surfaces may be used to promote direct infiltration of wash water, providing treatment before recharging groundwater and minimizing runoff to an adjacent stormwater system. Pervious surfaces or other infiltration-based systems should not be used within wellhead protection areas or within other protected resources.
- Impervious surfaces discharging to the storm drainage system should not discharge directly to a surface water unless treatment is provided. The treatment device should be positioned such that all drainage must flow through the device, preventing bypassing or short-circuiting.
- Periodic sweeping and/or cleaning should be completed to prevent accumulation from forming on the washing area.
- Maintain absorbent pads and drip pans to capture and collect spills or noticeable leaks observed during washing activities. Follow the procedures in SOP C.3: Spill Response and Cleanup.
- Heavily soiled vehicles or vehicles dirtied from salting or snow removal efforts should follow the SOPs in the "Heavy Equipment Washing Procedures" below.

Indoor Vehicle Washing Procedures

- Vehicles and equipment should be washed inside whenever possible to reduce runoff to the stormwater system.
- Where the use of detergent cannot be avoided, use products that do not contain regulated contaminants. The use of biodegradable, phosphate-free detergent is preferred.
- Detergents should not be used in areas where oil/water separators provide pre-treatment of drainage.
- Floor drains should be connected to a sanitary sewer or tight tank. Floor drains discharging to adjacent surface water bodies or engineered storm drain systems should be permanently plugged or otherwise abandoned before any vehicle wash activities are completed.
- Designate separate areas for routine maintenance and vehicle cleaning. This helps prevent





contamination of wash water by motor oils, hydraulic lubricants, greases, or other chemicals.

- Dry cleanup methods are recommended within garage facilities. Do not wash down floors and work areas with water.
- Bring smaller vehicles to commercial washing stations.
- Maintain absorbent pads and drip pans to capture and collect spills or noticeable leaks observed during washing activities. Follow the procedures in SOP C.3: Spill Response and Cleanup.

Heavy Equipment Washing Procedures

- Mud and heavy debris removal should occur on impervious surfaces or within a retention area.
- Maintain these areas with frequent mechanical removal and proper disposal of waste.
- Impervious surfaces with engineered storm drain systems should not discharge directly to a surface water.
- Floor drains should be connected to a sanitary sewer or tight tank. Floor drains discharging to adjacent surface waterbodies or engineered storm drain systems should be permanently plugged or otherwise abandoned before any vehicle wash activities are completed.
- Where the use of detergent cannot be avoided, use products that do not contain regulated contaminants. The use of biodegradable, phosphate-free detergent is preferred.
- Detergents should not be used in areas where oil/water separators provide pre-treatment of • drainage.
- Maintain absorbent pads and drip pans to capture and collect spills or noticeable leaks observed during washing activities. Follow the procedures in SOP C.3: Spill Response and Cleanup.

Engine and Steam Washing Procedures

- Do not wash parts outdoors.
- Maintain drip pans and smaller containers to contain motor oils, hydraulic lubricants, greases, etc. and to capture and collect spills or noticeable leaks observed during washing activities, to the extent practicable. Follow the procedures in SOP C.3: Spill Response and Cleanup.
- Where use of detergent cannot be avoided, use products that do not contain regulated ٠ contaminants. The use of a biodegradable, phosphate-free detergent is preferred.
- Avoid cleaning with solvents except in dedicated solvent parts washer systems. Make use of pressure washing and steam cleaning.
- Recycle clean solutions and rinse water to the extent practicable.
- Wash water should discharge to a tight tank or a sanitary sewer via an oil/water separator. Detergents should not be used in areas where oil/water separators provide pre-treatment of drainage.

Employee Training

- Employees who perform work on/with municipal vehicles or equipment are trained once per year on these procedures and the proper operation of related equipment.
- Employees are also trained on stormwater pollution prevention, illicit discharge detection and elimination (IDDE) procedures, and spill and response procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.





OPERATION AND MAINTENANCE PLAN

APPENDIX E

Standard Operating Procedures – Catch Basin Inspection and Cleaning

westonandsampson.com

Weston & Sampson

E.1: Catch Basin Inspection and Cleaning

Introduction

Catch basins help minimize flooding and protect water quality by removing trash, sediment, decaying debris, and other solids from stormwater runoff. These materials are retained in a sump below the invert of the outlet pipe (older catch basins may not have a sump). Catch basin cleaning reduces foul odors, prevents clogs in the storm drain system, and reduces the loading of trash, suspended solids, nutrients, bacteria, and other pollutants to receiving waters. The goal of this written Standard Operating Procedure (SOP) is to provide guidance to municipal employees on catch basin inspection and cleaning to reduce the discharge of pollutants from the MS4. If services are contracted, this SOP should be provided to the contractor. The contract should specify that the contractor is responsible for compliance with all applicable laws.

This SOP can also be used for inspection of catch basins or manholes for the purpose of conducting catchment investigations as part of the municipality's Illicit Discharge Detection and Elimination program.

The Wenham Highway Department performs routine inspections, cleaning, and maintenance on over 581 catch basins that are located within the Town of Wenham. The Town of Wenham will include an optimization plan for catch basin cleaning and inspection in its annual report. A description of current Town practices for catch basin cleaning and inspection is included in Section 5.2 of the Operation and Maintenance Plan.

Wenham will implement the following catch basin inspection and cleaning procedures to reduce the discharge of pollutants from the MS4:

Procedures

Inspection and Cleaning Frequency

- Each catch basin should be cleaned and inspected at least annually.
- Catch basins near construction activities (roadway construction, residential, commercial, or industrial development or redevelopment) or high-use areas should be inspected and cleaned more frequently if inspection finds excessive sediments or debris loadings.
- Catch basins should be cleaned to ensure that they are no more than 50 percent full¹ at any time. Establish inspection and maintenance frequencies needed to meet this "50 percent" goal. If a catch basin sump is more than 50 percent full during two consecutive inspections, document the findings, investigate the contributing drainage area for sources of excessive sediment loading, and, if possible, address the contributing sources. If no contributing sources are found, increase the inspection and cleaning frequencies of the sump.
- Street sweeping performed on an appropriate schedule will reduce the amount of sediment, debris, and organic matter entering the catch basins, which will in turn reduce the frequency with which they need to be cleaned. Reference SOP 16: Streets and Parking Lots for information on appropriate street sweeping frequencies. Street sweeping schedules should also be adjusted based on catch basin inspection findings, with more frequent sweepings for areas with higher catch basin loads.

Inspection and Cleaning Procedures

Catch basin inspection and cleaning procedures should address both the grate opening and the catch basin

¹. A catch basin sump is more than 50 percent full if the contents within the sump exceed one half the distance between the bottom interior of the catch basin to the invert of the deepest outlet of the catch basin

structure, including the sump and any inlet and outlet pipes. Document any and all observations about the condition of the catch basin structure and water quality (an inspection form and log of catch basins cleaned or inspected are included in the attachments). Collect data on the condition of the physical basin structure, its frame, and the grate, as well as on the quality of stormwater conveyed by the structure. Observations like those below can indicate sources of pollution within the storm drain system:

- Oil sheen
- Discoloration
- Trash and debris

Both oil and bacteria can create a sheen on the water's surface. The source of a sheen can be differentiating by disturbing it (e.g., with a pole). A sheen caused by oil will remain intact and move in a swirl pattern, while a sheen caused by bacteria will separate and appear "blocky." The bacteria that cause this sheen are naturally occurring iron bacteria – they are not considered a pollutant but should be noted. Other types of bacteria, such as fecal bacteria, are considered pollutants and their discovery should be recorded

Observations like those below can indicate a potential connection of a sanitary sewer to the storm drain system, which is an illicit discharge:

- Indications of sanitary sewage, including fecal matter or sewage odors
- Foaming, such as from detergent
- Optical enhancers, fluorescent dye added to laundry detergent

In general, adhere to the following procedures when inspecting and cleaning catch basins. Record the findings in the log in the attachments:

- 1. Implement appropriate traffic safety procedures (e.g., traffic cones) prior to and during the catch basin inspection and cleaning process.
- 2. Work upstream to downstream in a given drainage network.
- 3. Clean sediment and trash off the grate.
- 4. Visually inspect the outside of the grate.
- 5. Remove the grate and visually inspect the inside of the catch basin to determine cleaning needs.
- 6. Inspect the catch basin for structural integrity.
- 7. Determine the most appropriate equipment and method for cleaning the basin:
 - a. Manually use a shovel to remove accumulated sediments.
 - b. Use a bucket loader to remove accumulated sediments.
 - c. Use a high pressure washer to clean any remaining material out of the catch basin while capturing the slurry with a vacuum.
 - d. If necessary, after the catch basin is cleaned, use the rodder of the vacuum truck to clean the downstream pipe and pull back sediment that might have entered it.
- 8. If contamination is suspected, chemical analysis will be required to determine if the materials comply with the Massachusetts Department of Environmental Protection (MassDEP) Hazardous Waste Regulations, 310 CMR 30.000

(https://www.mass.gov/files/documents/2016/08/xl/310cmr30_7883_54357.pdf). The chemical analysis required will depend on suspected contaminants. Note the identification number of the catch basin on the sample label and note sample collection on the Catch Basin Inspection Form.

Handling and Disposal of Catch Basin Cleanings

- Properly dispose of collected sediments and catch basin cleanings (solid material, such as leaves, sand, and twigs removed from stormwater collection systems during cleaning operations).
- Cleanings from stormwater-only drainage systems may be disposed at any landfill that is permitted by MassDEP to accept solid waste. MassDEP does not routinely require stormwater-only catch basin cleanings to be tested before disposal, unless there is evidence that they have been

contaminated by a spill or some other means.

- Screenings may need to be placed in a drying bed to allow water to evaporate before proper disposal. In this case, ensure that the screenings are managed properly to prevent pollution.
- Catch basin cleanings must be handled and disposed in accordance with compliance with the applicable MassDEP regulations, policies, and guidance (https://www.mass.gov/files/documents/2018/03/09/catch-basins.pdf).

Documentation and Reporting

The following information should be documented and included in the municipality's annual report – use the catch basin inspection log provided in the attachments to document the information to include in the report (alternatively, obtain records of volume of debris removed to include in the report):

- Metrics and other information used to reach the determination that the established plan for cleaning and maintenance is optimal for the MS4 (include in the SWMP and first annual report)
- Any action taken in response to excessive sediment or debris loadings
- Total number of catch basins
- Number of catch basins inspected
- Number of catch basins cleaned
- Total volume or mass of material removed from catch basins.

•

Employee Training

- Employees who perform catch basin cleaning and inspection are trained once per year on these procedures and the proper operation of related equipment.
- Employees are also trained on stormwater pollution prevention, illicit discharge detection and elimination (IDDE) procedures, and spill and response procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.

Attachments

- 1. Catch Basin Inspection Form and Log
- 2. Catch Basin Inventory

Town of Hopedale Highway Depa CATCH BASIN CLE	ANING FORM			
Catchbasin ID Number (from ma Map Number (if applicable):	ıp):			
Date : / / Weather Conditions (circle one): Sunny Mostly Sunny Company and Inspector's Name	Mostly Cloudy	Cloudy	Rain	Snow
Location (Closest address, pole r	umber, etc):			
Overall Structure Condition (cire	cle one): 1 is poor, 2 is fair	, 3 is average, 4 is	s above average,	5 is new
Denth from rim to top of sedime	ent before cleaning (fee	t to rim):	J feet	t
Depth from rim to bottom of the	hasin after cleaning (fe	et to rim):		feet
Depth from rim to invert of the	outlet pipe (feet to rim):		feet	_1001
Any Pollutants Present ? (circle	one or many)			
None	Trash	Pet	Waste	
Sanitary Odor Foam	Oil/Oil Sheen Other:	Alga	ae/Bacteria	
Additional Notes About Sedime	nt:			
Requires Follow-up by HWD? (d	vircle one) YES NO	If yes explain:	:	
Any there any obstructions prese	ent that prevent basin fr	om being cleane	∍d?	

OPERATION AND MAINTENANCE PLAN

APPENDIX F

Standard Operating Procedures – Street Sweeping

westonandsampson.com

Weston & Sampson

June 2021

Standard Operating Procedures

Hopedale, MA

Highway Department

Sweeping Streets and Parking Lots

Approved by:

Chris Nadeau

Highway Department Superintendent

Purpose of SOPs:

Procedures for the operation and maintenance of street sweepers, frequency of sweeping, disposal of debris, and recordkeeping to maintain clean and safe roadways all while preventing pollution from entering the stormwater sewer systems. Pollutants like sand, trash and leaves can enter the storm sewer and have a negative impact on the receiving water body.

MA Small MS4 General Permit Requirement Summary:

Part 2.3.7.a.iii.3.

The permittee shall establish and implement procedures for sweeping and/or cleaning streets, and permittee-owned parking lots. All streets with the exception high speed limited access highways shall be swept and/or cleaned a minimum of once per year. The procedures shall also include more frequent sweeping of targeted areas determined by the permittee on the basis of pollutant load reduction potential, based on inspections, pollutant loads, catch basin cleaning or inspection results, land use, water quality limited or TMDL waters or other relevant factors as determined by the permittee. The permittee shall report in each annual report the number of miles cleaned or the volume or mass of material removed.

For limited access highways, the permittee shall either meet the minimum frequencies above, or develop and implement an inspection, documentation and targeted sweeping plan with two (2) years of the effective date of the permit, and submit such plan with its year one annual report.

Part 2.3.a.iii.4.

The permittee shall ensure proper storage of catch basin cleanings and street sweepings prior to disposal or reuse such that they do not discharge to receiving waters.

Equipment Inventory:

The following is a list of street sweeping equipment:

Equipment Number	Make	Description	Sweeper Speed (or other notes)
-	2010 Elgin Pelican	Three-wheel Mechanical Sweeper	<20 MPH
			L

Sweeping Streets and Parking Lots

Operations

- 1. Operate all sweepers and equipment according to the manufacturer's recommended settings, standards, and procedures.
- 2. While sweeping, drive between the optimal sweeping speed limit, as recorded in the equipment list above.
- 3. Sweeping will not take place during moderate to heavy rainfall or during periods of extreme cold (temperatures lower than 15 degrees Fahrenheit).
- 4. If spills occur or illegal discharges are seen, report to Chris Nadeau HWD Supervisor at (508) 634-2207.

Maintenance

- 1. Sweepers will be checked for leaks after each use. If a leak is discovered, it will immediately be contained and properly cleaned up.
- 2. Regular preventative maintenance to prolong equipment use (such as greasing moving parts and minor adjustments) occur once per month.
- 3. Parts are replaced when necessary. Brushes shall be replaced in accordance with manufacturer specifications.
- 4. Equipment is washed at the Hopedale Highway Department at 7 Depot Street, Hopedale, MA 01747 to trap grease, oils and sediment

Schedule

- 1. Street sweeping will primarily take place between the months of March and October.
- 2. All streets with curbing and/or catch basins and municipal parking lots shall be swept a minimum of once per year in the spring between March and October (following winter activities such as sanding) and to meet requirements for impaired waters. Street sweeping is conducted three (3) times per ear in the downtown area. Rural uncurbed roadways are also swept a minimum of once per year.
- 3. Priority Roads and parking lots will be identified on the basis of pollutant load reduction potential, based on inspections, known pollutant loads, catch basin cleaning o inspection results, land use, proximity to impaired of TMDL waters or other relevant factors. Priority roads and parking lots will be reassessed annually. A street located within a regulated catchment that discharges directly to or is tributary to a receiving water body that is impaired for phosphorus shall be swept at a minimum twice per year. Commercial areas, high-density residential areas, and drainage areas with a large amount of impervious area are considered priorities.
- 4. Roads/Parking lots that have catch basins that are more than 50% full of sediment during two consecutive cleanings, shall be swept more to reduce sediment entering the basins.
- 5. The sweeping schedule is assessed once per year and updated as necessary.

Standard Operating Procedures	Issue Date:
Hopedale, MA	lune 2021
Highway Department	June 2021
Sweeping Streets and Parking Lots	

6. If any event/activity such as fairs, construction, firefighting activities produce an excess amount of debris on the roadway or parking lot it should be swept as soon as practicable.

Storage and Disposal

1. Solid sweeping debris is brought immediately to the Highway Department Facility for temporary storage prior to permanent disposal off-site.

Training

1. Employees are trained once per year on this procedure and the proper operation of equipment. Employees are also trained on stormwater pollution prevention, spill and response, and illicit discharge detection and elimination procedures.

Record Keeping

- 1. Records are kept at the Highway Department Facility located at 7 Depot Street. Hopedale, MA, 01747.
- 2. The number of miles swept is recorded after each sweeping. The amount of debris collected is recorded after each disposal.
- 3. The number of curb miles swept per year is calculated annually and included in the Town's Annual Report to the EPA.

Revising the SOPs

1. These procedures are reviewed once per year and updated as needed.

APPENDIX G

Standard Operating Procedures – Inspection and Maintenance of Stormwater Treatment Structures

westonandsampson.com

Weston & Sampson

G.1: Inspection and Maintenance of Structural Stormwater Best Management Practices (BMPs)

Introduction

Best Management Practices (BMPs) are policies, procedures and structures designed to reduce stormwater pollution, prevent contaminant discharges to natural water bodies, and reduce stormwater facility maintenance costs. Structural BMPs are permanent site features designed to treat stormwater before infiltrating it to the subsurface or discharging it to a surface water body. Regular inspection and maintenance of structural stormwater BMPs is critical for these engineered systems to function as designed (e.g., provide benefits to water quality, groundwater recharge, and peak flow attenuation).

This Standard Operating Procedure (SOP) provides general inspection and maintenance frequencies and procedures for eight common structural stormwater BMPs, including:

- 1. Bioretention Areas and Rain Gardens
- 2. Constructed Stormwater Wetlands
- 3. Extended Dry Detention Basins
- 4. Proprietary Media Filters
- 5. Sand and Organic Filters
- 6. Wet Basins
- 7. Dry Wells
- 8. Infiltration Basins

This SOP is based on the Massachusetts Stormwater Handbook and is not intended to replace the stormwater BMP Operation and Maintenance guidance contained in the Handbook. This SOP is also not intended to replace the Stormwater BMP Operation and Maintenance (O&M) Plan required by the Massachusetts Wetlands Protection Act, Order of Conditions.

The Hopedale Highway Department is responsible for inspection and maintenance of municipally owned structural stormwater BMPs. A list of existing structural stormwater BMPs is included in the attachments, along with inspection and maintenance checklists for each type of BMP.

Structural stormwater BMPs will be inspected annually at a minimum. Inspection checklists for each type of structural BMP are provided in the attachments.

Procedures

Bioretention Areas and Rain Gardens

Bioretention areas and rain gardens are shallow depressions filled with sandy soil, topped with a thick layer of mulch, and planted with dense native vegetation. There are two types of bioretention cells:

- 1. Filtering bioretention area: Areas that are designed solely as an organic filter.
- 2. Exfiltration bioretention area: Areas that are configured to recharge groundwater in addition to acting as a filter.





Inspection and Maintenance

Regular inspection and maintenance are important to prevent against premature failure of bioretention areas or rain gardens. Regular inspection and maintenance of pretreatment devices and bioretention cells for sediment buildup, structural damage and standing water can extend the life of the soil media.

Activity	Time of Year	Frequency
Inspect for soil erosion and repair	Year round	Monthly
Inspect for invasive species and remove if present	Year round	Monthly
Remove trash	Year round	Monthly
Mulch Void Areas	Spring	Annually
Remove dead vegetation	Fall and spring	Bi-annually
Replace dead vegetation	Spring	Annually
Prune	Spring or fall	Annually
Replace all media and vegetation	Late spring/early summer	As needed

Maintenance Schedule: Bioretention Areas and Rain Gardens

When failure is discovered, excavate the bioretention area, scarify the bottom and sides, replace the filter fabric and soil, replant vegetation, and mulch the surface.

Never store snow within a bioretention area or rain garden. This would prevent the recharge and water quality treatment of ground water.

Hopedale does not currently own or maintain any bioretention areas and rain gardens. In the event that the Town installs a bioretention area or rain garden, the operation and maintenance procedures outlined in this section shall apply.

Constructed Stormwater Wetlands

Constructed stormwater wetlands maximize pollutant removal from stormwater through the use of wetland vegetation uptake, retention, and settling. Constructed storm water wetlands must be used in conjunction with other BMPs, such as sediment forebays.

Hopedale does not currently own or maintain any constructed stormwater wetlands. In the event that the Town installs a constructed stormwater wetland, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

Regular inspection and maintenance are important for the health of constructed stormwater wetlands. They help identify the need for replacement of vegetation and media, detect potentially harmful invasive species, and ensure the overall health of the wetland.





Activity	Time of Year	Frequency
Inspect for invasive species and remove if present	Year round	Monthly
Record and Map:	Year round	Annually
Types and distribution of dominant wetland plants	Year round	Bi-annually
Presence and distribution of planted wetland species	Spring	Annually
Presence and distribution of invasive species	Fall and spring	Bi-annually
Indications other species are replacing planted wetland	Spring	Annually
species		
Percent of standing water that is not vegetated	Spring or fall	Annually
Replace all media and vegetation	Late spring/early	As needed
	summer	
Stability of original depth zones and micro-topographic		
features		
Accumulation of sediment in the forebay and micropool		
and survival rate of plants		

Maintenance Schedule, Constructed Stormwater Wetlands: Years 0-3

Maintenance Schedule, Constructed Stormwater Wetlands: Years 4-Lifetime

Activity	Time of Year	Frequency
Inspect for invasive species and remove if present	Year round	Monthly
Clean forebays	Year round	Annually
Clean sediment in basin/wetland system	Year round	Once every
		10 years
Mulch Void Areas	Spring	Annually
Remove dead vegetation	Fall and spring	Bi-annually
Replace dead vegetation	Spring	Annually
Prune	Spring or fall	Annually
Replace all media and vegetation	Late spring/early	As needed
	Summer	

Never store snow within a constructed stormwater wetland. This would prevent required water quality treatment and the recharge of groundwater.

Extended Dry Detention Basins

Extended dry detention basins are designed to control both stormwater quantity and quality. These BMPs are designed to hold stormwater for at least 24 hours, allowing solids to settle and reducing local and downstream flooding. Pretreatment is required to reduce the potential for overflow clogging. The outflow may be designed as either fixed or adjustable. Additional nutrient removal may be achieved by a micropool or shallow marsh.

Hopedale does not currently own or maintain any extended dry detention basins. In the event that the Town installs an extended dry detention basin, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

Annual inspection of extended dry detention basins is required to ensure that the basins are operating properly.





Potential problems include: erosion within the basin and banks, tree growth on the embankment, damage to the emergency spillway, and sediment accumulation around the outlet. Should any of these problems be encountered, necessary repairs should be made immediately.

Activity	Time of Year	Frequency
Inspect basins	Spring and fall	Bi-annually and during and after
		major storms
Examine outlet structure for clogging or high	Spring and fall	Bi-annually
outflow release velocities		
Mow upper stage, side slopes, embankment and	Spring through	Bi-annually
emergency spillway	fall	
Remove trash and debris	Spring	Bi-annually
Remove sediment from basin	Year round	At least once every 5 years

Maintenance	Schedule:	Extended	Drv	Detention	Basins
Mannenance	seneuule.	LAtenucu	Diy	Detention	Dasillis

Proprietary Media Filters

Media Filters are designed to reduce total suspended solids and other target pollutants, such as organics, heavy metals, or nutrients – these materials are sorbed onto the filter media, which is contained in a concrete structure. The substrate used as filter media depends on the target pollutants, and may consist of leaf compost, pleated fabric, activated charcoal, perlite, amended sand in combination with perlite, and zeolite. Two types of Media Filters are manufactured: Dry media filters, which are designed to dewater within 72 hours, and wet media filters, which maintain a permanent pool of water as part of the treatment system.

Hopedale does not currently own or maintain any proprietary media filters. In the event that the Town installs this type of BMP, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

Maintenance in accordance with the manufacturer's requirements is necessary to ensure stormwater treatment. Inspection or maintenance of the concrete structure may require OSHA confined space training. Dry media filters are required to dewater in 72 hours, thus preventing mosquito and other insect breeding. Proper maintenance is essential to prevent clogging. Wet media filters require tight fitting seals to keep mosquitoes and other insects from entering and breeding in the permanent pools. Required maintenance includes routine inspection and treatment.

Activity	Time of Year	Frequency
Inspect for standing water, trash, sediment and	Per manufacturer's	Bi-annually (minimum)
clogging	schedule	
Remove trash and debris	N/A	Each inspection
Examine to determine if system drains in 72 hours	Spring, after large storm	Annually
Inspect filtering media for clogging	Per manufacturer's	Per manufacturer's
	schedule	schedule

Maintenance Schedule: Proprietary Media Filters

Sand and Organic Filters

Sand and organic filters, also known as filtration basins, are intended for stormwater quality control rather than





quantity control. These filters improve water quality by removing pollutants through a filtering media and settling pollutants on top of the sand bed and/or in a pretreatment basin. Pretreatment is required to prevent filter media from clogging. Runoff from the filters is typically discharged to another BMP for additional treatment.

Hopedale does not currently own or maintain any sand or organic media filters. In the event that the Town installs this type of BMP, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

If properly maintained, sand and organic filters have a long life. Maintenance requirements of the filters include raking the sand and removing sediment, trash, and debris from the surface of the BMP. Over time, fine sediments will penetrate deep into the sand requiring replacement of several inches or the entire sand layer. Discolored sand is an indicator of the presence of fine sediments, suggesting that the sand should be replaced.

Maintenance Schedule: Sand and Organic Filters

Activity	Frequency
Inspect filters and remove debris	After every major storm for the first 3 months after
	construction completion. Every 6 months thereafter.

Wet Basins

Wet basins are intended to treat stormwater quality through the removal of sediments and soluble pollutants. A permanent pool of water allows sediments to settle and removes the soluble pollutants, including some metals and nutrients. Additional dry storage is required to control peak discharges during large storm events. If properly designed and maintained, wet basins can add fire protection, wildlife habitats, and aesthetic values to a property.

Hopedale does not currently own or maintain any wet basins. In the event that the Town installs this type of BMP, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

To ensure proper operation, wet basin outfalls should be inspected for evidence of clogging or excessive outfall releases. Potential problems to investigate include erosion within the basin and banks, damage to the emergency spillway, tree growth on the embankment, sediment accumulation around the outlet, and the emergence of invasive species. Should any of these problems be encountered, perform repairs immediately. An on-site sediment disposal area will reduce sediment removal costs.

Maintenance Schedule: Wet Basins

Activity	Time of Year	Frequency
Inspect wet basins	Spring and/or fall	Annually (Minimum)
Mow upper stage, side slopes, embankment and	Spring through fall	Bi-annually
emergency spillway		(Minimum)
Remove sediment, trash and debris	Spring through fall	Bi-annually
		(Minimum)
Remove sediment from basin	Year round	As required, but at
		least once every 10
		years





Dry Wells

Dry wells are used to infiltrate uncontaminated runoff. These BMPs should never be used to infiltrate stormwater or runoff that has the potential to be contaminated with sediment and other pollutants. Dry wells provide groundwater recharge and can reduce the size and cost required of downstream BMPs or storm drains. However, they are only applicable in drainage areas of less than one acre and may experience high failure rates due to clogging.

Hopedale does not currently own or maintain any dry wells. In the event that the Town installs this type of BMP, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

Proper dry well function depends on regular inspection. Clogging has the potential to cause high failure rates. The water depth in the observation well should be measured at 24 and 48 hour intervals after a storm and the clearance rate calculated. The clearance rate is calculated by dividing the drop in water level (inches) by the time elapsed (hours).

Maintenance Schedule: Dry Wells

Activity	Frequency
Inspect dry wells	After every major storm for the first 3 months after
	construction completion. Annually thereafter.

Infiltration Basins

Infiltration basins are designed to contain stormwater and provide groundwater recharge. Pollution prevention and pretreatment are required to ensure that contaminated stormwater is not infiltrated. Infiltration basins reduce local flooding and preserve the natural water balance of the site. High failure rates, however, often occur due to improper siting, inadequate pretreatment, poor design, and lack of maintenance.

Hopedale does not currently own or maintain any infiltration basins. In the event that the Town installs this type of BMP, the operation and maintenance procedures outlined in this section shall apply.

Inspection and Maintenance

Regular maintenance is required to prevent clogging, which results in infiltration basin failure. Clogging may be due to upland sediment erosion, excessive soil compaction, or low spots. Inspections should include signs of differential settlement, cracking, erosion, leakage in the embankments, tree growth on the embankments, riprap condition, sediment accumulation, and turf health.





June 2019

Activity	Time of Year	Frequency
Preventative maintenance	Spring and fall	Bi-annually
Inspection	Spring and fall	After every major storm for the first 3
		months after construction completion.
		Bi-annually thereafter and discharges
		through the high outlet orifice.
Mow/rake buffer area, side slopes and basin	Spring and fall	Bi-annually
bottom		
Remove trash, debris and organic matter	Spring and fall	Bi-annually

Maintenance Schedule: Infiltration Basins

Employee Training

- Employees who perform inspection or maintenance on structural BMPs are trained once per year on proper procedures.
- If services are contracted, the contractor should be given a copy of this and any applicable SOPs to ensure compliance with MS4 regulations.

Attachments

1. Structural BMP Inspection and Maintenance Checklist





OPERATION AND MAINTENANCE PLAN

APPENDIX H

Standard Operating Procedures – Salt Use Optimization/Winter Road Maintenance

westonandsampson.com

Weston & Sampson

STANDARD OPERATING PROCEDURE		SOP NUMBER:	ISSUE DATE:		
DEPARTMENT OF PUBLIC WORKS [OR OTHER]		H.1	June 2021		
Program:					
Snow Removal and De-Icing					
Approved By:		I			
Chris Nadeau					
Highway Department Superintendent					
MA SMALL MS4 PERMIT REQUIREMENT SUM	MARY:				
Part 2.3.7.a.iii.5. The permittee shall establish and implement procedures for winter road maintenance including the use and storage of salt and sand; minimize the use of sodium chloride and other salts, and evaluate opportunities for use of alternative materials; and ensure that snow disposal activities do not result in disposal of snow into waters of the United States. For purposes of this MS4 Permit, salt shall mean any chloride-containing material used to treat paved surfaces for deicing, including sodium chloride, calcium chloride, magnesium chloride, and brine solutions.					
Personnel The following personnel are responsible for snow and ice removal. Employees performing the procedures in this SOP shall attend yearly stormwater pollution prevention training.					
TABLE 1					
Name Chris Nadeau	Responsibility	Over see snow and ice	operations		
Gerald Lambert	Snow and ice re	moval operator			
Vincent Uzella Mark Museianaki					

Responsibility Over see snow and ice operations
Snow and ice removal operator
Snow and ice removal/ Mechanic

Equipment

The municipality owns and maintains ice control and snow removal equipment listed in Table 2. Equipment maintenance shall be conducted consistent with the Vehicles and Equipment maintenance SOP found here: 7 Depot Street, Hopedale, MA. The wash bay/ area is located at 7 Depot Street, Hopedale, MA.

Plowing

When conditions warrant, plows are installed on the nine (9) larger trucks to move snow from the traveled roadway. Average time to install a plow is approximately 5 minutes. Five (5) smaller trucks are available for plowing of residential streets and clearing public lots.

STANDARD OPERATING PROCEDURE	SOP NUMBER:	ISSUE DATE:
DEPARTMENT OF PUBLIC WORKS [OR OTHER]	H.1	June 2021
Program:		
Snow Removal and De-Icing		

Salt & Sand Spreaders

When conditions warrant, salt spreaders are installed on the 6 larger trucks to spread salt on the traveled roadway. Each salt spreader is calibrated prior to the deicing season and every 2 weeks thereafter. Salt /Sand application shall be calibrated to dispense rates of 200 pounds per lane mile. Four (4) of trucks are equipped with brine tanks which are calibrated prior to the deicing season and every 2 weeks thereafter.

TABLE 2

Equipment Number	Make	Description	Additional Equipment	Primary Use
84	International	Sander/Chem Tanks	11' Plow	Snow and Ice
				Removal
85	International	Sander	11' Plow	Snow and Ice
				Removal
86	Freightliner	Sander/ Chem Tanks	11' Plow	Snow and Ice
				Removal
87	International	Sander/Chem Tanks	11' Plow/10' Wing Plow	Snow and Ice
				Removal
88	Freightliner	Sander/Chem Tanks	11' Plow	Snow and Ice
				Removal
96	Ford	Sander	11' Plow	Snow and Ice
				Removal

Materials

The major materials are used in snow and ice control are coarse sand, coarse salt, anti-icing agent. These materials are stockpiled in advance of an event and are immediately available when needed and stocks are replenished between events.

Sand

Sand is used as an abrasive for traction on slick roadways. Approximately 500 cubic yards are anticipated to be used per year and are ordered from Kimball Sand and Gravel prior to each deicing season. Sand is stored in the covered facility located at: 7 Depot Street, Hopedale, MA. Loading areas and yards are swept as needed to prevent sand build-up and run-off.

Salt

Salt is used to expedite the melting of snow and ice from the street surface and also to keep the ice from forming a bond to the street surface. Approximately 1500 tons of coarse salt are anticipated to be used per year and are ordered from Lowest Bidder prior to each deicing season. Salt is stored in the covered facility located at: 7 Depot Street, Hopedale, MA. Loading areas and yards are swept as needed to prevent salt build-up and run-off.

Anti-icing and Pre-Wetting Chemical

Approximately 2,000 gallons of Magnesium Chloride is estimated to be needed for anti-icing application. This chemical is stored at 7 Depot Street, Hopedale, MA in 2,500 gallon storage tank equipped with appropriate spill control.

STANDARD OPERATING PROCEDURE	SOP NUMBER:	ISSUE DATE:
DEPARTMENT OF PUBLIC WORKS [OR OTHER]	H.1	June 2021
Program:		
Snow Removal and De-Icing		

Procedures

Salt & Sand Application

- 1. Whenever conditions warrant, salt is applied to the roadway prior to accumulation of snow to prevent compacted snow from bonding to the roadway surface. *The Highway Department* will instruct staff when salt application is appropriate.
- 2. Prior to salt application, equipment will be checked to ensure proper working order and ensure proper calibration of equipment. All fluid levels will be checked and filled to proper levels, all lights must be in working order. A visual walk-around inspection of the truck or equipment must be made. Any repairs must be made and reported to a supervisor or mechanic before leaving the yard.
- 3. The standard salt application speed is: 20 mph.
- 4. Before parking any truck or equipment after use, all fluid levels will be checked and filled. All minor repairs will be done by the operator. Any repairs the operator cannot perform will be written up on the proper forms and turned in to *Chris Nadeau*. *Chris Nadeau* will determine importance and will assign the repairs according to schedule. All deicing chemical will be washed from equipment at the wash bay or designated wash area.

Snow Plowing

- 1. As the storm develops and 3 inches of snow has accumulated, all of the drivers and available equipment will begin to plow their assigned routes.
- Prior to plowing operations, equipment will be checked to ensure proper working order. All fluid levels will be checked and filled to proper levels, all lights must be in working order. A visual walk-around inspection of the truck or equipment must be made. Any repairs must be made and reported to a supervisor or mechanic before leaving the yard.
- 3. Avoid plowing, pushing, blowing or storing excess snow, deicer, or other debris in or near creeks, watercourses or storm drainage systems.
- 4. Reduce plowing speed in sensitive areas (near creeks, wetlands or other water courses) to prevent snow and deicing materials from entering waterways.
- 5. The standard plowing speed is: 15-20 mph.
- 6. Follow the prioritized route or schedule.
- 7. Before parking any truck or equipment after use, all fluid levels will be checked and filled. Blades or bolts, which need replacing, will be taken care of unless told to do otherwise. Chains that need repairs will be repaired. All minor repairs will be done by the operator. Any repairs the operator cannot perform will be written up on the proper forms and turned in to Chris Nadeau. Chris Nadeau will determine importance and will assign the repairs according to schedule.

STANDARD OPERATING PROCEDURE DEPARTMENT OF PUBLIC WORKS [OR OTHER]	SOP NUMBER:	Issue Date: June 2021	
PROGRAM: Snow Removal and De-Icing	H.1		
Record Keeping and Documentation			

- 1. Maintain a master schedule of prioritized snow and sanding routes and the miles or roads plowed or sanded. HWD Superintendents Office 7 Depot Street.
- 2. Keep copies of manufacturer's recommendations for equipment calibration, plowing speed and salt/sand application rates. HWD Superintendents Office 7 Depot Street.
- 3. Keep records of the amounts of salt, sand, liquid deicer, and salt alternatives applied per season. HWD Superintendents Office 7 Depot Street.
- 4. Keep a list of all employees trained in the facility's Stormwater Pollution Prevention binder or computer file.

STORMWATER MANAGEMENT PLAN

APPENDIX J

2016 MS4 Annual Repots



Year 1 Annual Report Massachusetts Small MS4 General Permit Reporting Period: May 1, 2018-June 30, 2019

Please DO NOT attach any documents to this form. Instead, attach all requested documents to an email when submitting the form

Unless otherwise noted, all fields are required to be filled out. If a field is left blank, it will be assumed the requirement or task has not been completed.

Part I: Contact Information

Name of Municipality or Organ	nization:Town of Hopedale	
EPA NPDES Permit Number:	MAR041123	

Primary MS4 Program Manager Contact Information

Name:	Steven Sette		Title: To	own Adm	inistrato	Dr	
Street	Address Line 1: 78 Hopedale Street						
Street	Address Line 2: P.O. Box 7						
City:	Hopedale Stat	e: MA	Zip Code	: 01747			
Email:	ssette@hopedale-ma.gov		Phone	Number:	(508) 63	34-2203	
Fax Nı	umber: (508) 634-2200						

Stormwater Management Program (SWMP) Information

SWMP Location (web address):

Date SWMP was Last Updated:

If the SWMP is not available on the web please provide the physical address and an explanation of why it is not posted on the web:

The Town has recently contracted with Weston & Sampson to complete Year 1 related MS4 items. We anticipate completing the SWMP by December 31, 2019 and posting the SWMP to the Town's website.
Part II: Self Assessment

First, in the box below, select the impairment(s) and/or TMDL(s) that are applicable to your MS4.

Impairment(<u>s)</u>			
	Bacteria/Pathogens	Chloride	🗌 Nitrogen	⊠ Phosphorus
	Solids/ Oil/ Grease (Hye	drocarbons)/ Metal	S	
TMDL(s)				
In State:	Assabet River Phosphor	rus 🛛 🖾 Bacte	eria and Pathogen	Cape Cod Nitrogen
	Charles River Watershe	d Phosphorus	\Box Lake and Pond	Phosphorus
Out of State:	Bacteria/Pathogens	☐ Metals	□ Nitrogen	Phosphorus
			Cle	ear Impairments and TMDLs

Next, check off all requirements below that have been completed. **By checking each box you are certifying that you have completed that permit requirement fully.** If you have not completed a requirement leave the box unchecked. Additional information will be requested in later sections.

Year 1 Requirements

- \square Develop and begin public education and outreach program
- \boxtimes Identify and develop inventory of all known locations where SSOs have discharged to the MS4 in the last 5 years
 - The SSO inventory is attached to the email submission
 - \bigcirc The SSO inventory can be found at the following website:

Please see attached table.

- Develop written IDDE plan including a procedure for screening and sampling outfalls
- □ IDDE ordinance complete
- □ Identify each outfall and interconnection discharging from MS4, classify into the relevant category, and priority rank each catchment for investigation
 - \bigcirc The priority ranking of outfalls/interconnections is attached to the email submission
 - The priority ranking of outfalls/interconnections can be found at the following website:

Priority ranking will be completed by June 30, 2020.

- Construction/ Erosion and Sediment Control (ESC) ordinance complete
- Develop written procedures for site inspections and enforcement of sediment and erosion control measures
- Develop written procedures for site plan review
- ☐ Keep a log of catch basins cleaned or inspected
- Complete inspection of all stormwater treatment structures

Annual Requirements

- Annual opportunity for public participation in review and implementation of SWMP
- Comply with State Public Notice requirements
- Keep records relating to the permit available for 5 years and make available to the public
- Properly store and dispose of catch basin cleanings and street sweepings so they do not discharge to
- ^{__} receiving waters
- $\hfill\square$ Annual training to employees involved in IDDE program
- \boxtimes All curbed roadways have been swept a minimum of one time per year

Bacteria/ Pathogens (Combination of Impaired Waters Requirements and TMDL Requirements as Applicable)

Annual Requirements

Public Education and Outreach*

- Annual message encouraging the proper management of pet waste, including noting any existing ordinances where appropriate
- Permittee or its agents disseminate educational material to dog owners at the time of issuance or renewal of dog license, or other appropriate time
- Provide information to owners of septic systems about proper maintenance in any catchment that discharges to a water body impaired for bacteria

* Public education messages can be combined with other public education requirements as applicable (see Appendix H and F for more information)

Phosphorus (Combination of Impaired Waters Requirements and TMDL Requirements as Applicable)

Annual Requirements

Public Education and Outreach*

- Distribute an annual message in the spring (April/May) that encourages the proper use and disposal of grass clippings and encourages the proper use of slow-release and phosphorus-free fertilizers
- \boxtimes Distribute an annual message in the summer (June/July) encouraging the proper management of pet waste, including noting any existing ordinances where appropriate
- Distribute an annual message in the fall (August/September/October) encouraging the proper disposal of leaf litter

* Public education messages can be combined with other public education requirements as applicable (see Appendix H and F for more information)

Good Housekeeping and Pollution Prevention for Permittee Owned Operations

Increase street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two times per year (spring and fall)

Potential structural BMPs

Any structural BMPs listed in Attachment 3 to Appendix F already existing or installed in the regulated area by the permittee or its agents shall be tracked and the permittee shall estimate the phosphorus

☐ removal by the BMP consistent with Attachment 1 to Appendix H. Document the BMP type, total area treated by the BMP, the design storage volume of the BMP and the estimated phosphorus removed in mass per year by the BMP in each each annual report

Charles River Watershed Phosphorus TMDL

Begin Phase 1 Phosphorus Control Plan (PCP)

Use the box below to input additional details on any unchecked boxes above or any additional information you would like to share as part of your self assessment:

The Hopedale Notice of Intent (NOI) was submitted on May 3, 2019. With the reporting period being May 1, 2018 through June 30, 2019, little time was left for the Town to complete Year 1 tasks. The Town plans to complete Year 1 tasks through the end of this year and into 2020. It is important to note that although the Town does not have much this reporting period, Hopedale is committed to completing Year 1 tasks. Below is a description of all the tasks Hopedale is currently working on, along with their projected completion dates.

The Town is currently working on public education initiatives. The Town will meet the annual messages for proper disposal of grass clippings and encourage proper use of slow-release and phosphorus-free fertilizers, encouraging proper management of pet waste, and encouraging proper disposal of leaf litter. The Town currently has signs placed in residential areas adjacent to waterbodies informing dog owners to properly dispose of their pet's waste. The Town will be working with Weston & Sampson to distribute an annual message this October to encourage proper disposal of leaf litter. It is anticipated that this will be posted in the Town's local newspaper.

In September 2019, Weston & Sampson completed GPS survey work to update and modify current stormwater system mapping.

Currently, a Stormwater Management Program (SWMP) is being written and is projected to be completed by December 31, 2019. Once the SWMP is completed, an IDDE plan including a procedure for screening and sampling outfalls will be drafted. The IDDE Plan's targeted completion date is June 30, 2020. The Town plans to complete catchment delineations by June 30, 2020. Training will occur for employees once there is an IDDE plan.

The Town plans to develop regulatory mechanisms governing construction site stormwater runoff control and post-construction stormwater management with an estimated date of adoption by June 30, 2020.

The Town of Hopedale currently cleans out all catch basins each summer. The Town also sweeps streets at least 3 times a year - once in the fall and twice in the spring. Moving forward, the Town of Hopedale will maintain records of catch basin cleaning and street sweeping activities.

The legal analysis associated with Phase 1 of the Phosphorus Control Plan for the Charles River Watershed Phosphorus TMDL will be completed by Year 2.

Have you made any changes to your lists of receiving waters, outfalls, or impairments since the NOI was submitted?

Yes 🖂 🛛 1	No 🗌
-----------	------

If yes, describe below, including any relevant impairments or TMDLs:

The Town has been actively working to locate and map drainage infrastructure. Changes have been made to the list of receiving water and outfalls as additional data has been collected regarding outfall ownership, outfall drainage location, and drainage system configuration as part of a comprehensive drainage mapping effort. No new applicable impairments of TMDLs have been identified as part of this effort. The list of outfalls, receiving waters and impairments included in the Town's Stormwater Management Plan will reflect those changes.

The updated map will be incorporated into the Town's SWMP.

Part IV: Minimum Control Measures

Please fill out all of the metrics below. If applicable, include in the description who completed the task if completed by a third party.

MCM1: Public Education

Number of educational messages completed during the reporting period: 1

Below, report on the educational messages completed during the first year. For the measurable goal(s) please describe the method/measures used to assess the overall effectiveness of the educational program.

BMP:[Message name here]

Message Description and Distribution Method:

To encourage proper disposal of dog waste, signs have been placed throughout the town to inform dog owners to properly dispose of dog waste. There is also a message on the Board of Health's web page.

Targeted Audience: Residents/Dog Owners

Responsible Department/Parties: Board of Health

Measurable Goal(s):

Place signs in residential areas to inform the public on cleaning up after their dog. The signs and online information inform the public that dog waste can impact water quality.

Message Date(s): Year-Round

Message Completed for:	Appendix F Requirements 🖂	Appendix H Requirements
Was this message different	than what was proposed in your l	NOI? Yes 🗌 No 🖂
If yes, describe why the ch	ange was made:	

Add an Educational Message

MCM2: Public Participation

Describe the opportunity provided for public involvement in the development of the Stormwater Management Program (SWMP) during the reporting period:

The Town of Hopedale is currently having Weston & Sampson develop the Stormwater Management Program (SWMP). The SWMP will be completed by December 31, 2019, and posted to the Town's website for review by the public.

Was this opportunity different than what was proposed in your NOI? Yes \Box No \boxtimes

Describe any other public involvement or participation opportunities conducted during the reporting period: The Town currently holds a Household Hazardous Waste Day every year. The last Household Hazardous Waste Day was held in October 2018. This year it will be on October 26, 2019. This event allows residents to bring oil, gasoline, gasoline mixtures, auto batteries, pesticides, paint thinners, spent antifreeze, oil-based paints and stains, photo chemicals, pool chemicals, household chemicals, and aerosols to the Hopedale Recycling Center. The Town will continue to hold a Household Hazardous Waste Day.

The Town also has its own recycling center that is open on Saturdays. The recycling center accepts grass clippings, leaves, brush, dismantled oil tanks, heaters, washing machines, dryers, air conditioners, propane tanks, swing sets, television sets and stereos.

MCM3: Illicit Discharge Detection and Elimination (IDDE)

Sanitary Sewer Overflows (SSOs)

Below, report on the number of SSOs identified in the MS4 system and removed during this reporting period.

Number of SSOs identified: 0

Number of SSOs removed: 0

Below, report on the total number of SSOs identified in the MS4 system and removed to date. At a minimum, report SSOs identified since 2013.

Total number of SSOs identified: 3

Total number of SSOs removed: 3

MS4 System Mapping

Describe the status of your MS4 map, including any progress made during the reporting period:

The Town is currently working to update the drainage mapping, and will continue to update the GIS database. The updated map will be included in the Town's SWMP.

Screening of Outfalls/Interconnections

If conducted, please submit any outfall monitoring results from this reporting period. Outfall monitoring results should include the date, outfall/interconnection identifier, location, weather conditions at time of sampling, precipitation in previous 48 hours, field screening parameter results, and results from all analyses.

 \bigcirc The outfall screening data is attached to the email submission

 \bigcirc The outfall screening data can be found at the following website:

Below, report on the number of outfalls/interconnections screened during this reporting period.

Number of outfalls screened: 0

Below, report on the percent of total outfalls/ interconnections screened to date.

Percent of total outfalls screened: 0

Catchment Investigations

If conducted, please submit all data collected during this reporting period as part of the dry and wet weather investigations. Also include the presence or absence of System Vulnerability Factors for each catchment.

 \bigcirc The catchment investigation data is attached to the email submission

 \bigcirc The catchment investigation data can be found at the following website:

Below, report on the number of catchment investigations completed during this reporting period.

Number of catchment investigations completed this reporting period: 0

Below, report on the percent of catchments investigated to date.

Percent of total catchments investigated: 0%

Optional: Provide any additional information for clarity regarding the catchment investigations below:

IDDE Progress

If illicit discharges were found, please submit a document describing work conducted over this reporting period, and cumulative to date, including location source; description of the discharge; method of discovery; date of discovery; and date of elimination, mitigation, or enforcement OR planned corrective measures and schedule of removal.

 \bigcirc The illicit discharge removal report is attached to the email submission

 \bigcirc The illicit discharge removal report can be found at the following website:

Below, report on the number of illicit discharges identified and removed, along with the volume of sewage removed during this reporting period.

Number of illicit discharges identified:	0	
Number of illicit discharges removed:	0	
Estimated volume of sewage removed:	0	[UNITS]

Total number of illicit discharges identified: 0

Total number of illicit discharges removed: 0

Optional: Provide any additional information for clarity regarding illicit discharges identified, removed, or planned to be removed below:

Employee Training

Describe the frequency and type of employee training conducted during the reporting period:

Employee training is anticipated to occur in Fall 2019 and Spring 2020.

MCM4: Construction Site Stormwater Runoff Control

Below, report on the construction site plan reviews, inspections, and enforcement actions completed during this reporting period.

Number of site plan reviews completed: 0
Number of inspections completed: 0
Number of enforcement actions taken: 0

MCM5: Post-Construction Stormwater Management in New Development and Redevelopment

Ordinance Development

Describe the status of the post-construction ordinance required to be complete in year 2 of the permit term:

The Town plans to have the Post-Construction Stormwater runoff control regulation completed in Year 2 as stated in the NOI.

As-built Drawings

Describe the status of the measures the MS4 has utilized to require the submission of as-built drawings and ensure long term operation and maintenance of completed construction sites required to be complete in year 2 of the permit term:

In the Town's post-construction stormwater runoff control regulation to be completed om Permit Year 2, the Town will include requirements for the submission of as-builts and long-term operation and maintenance.

Street Design and Parking Lots Report

Describe the status of the street design and parking lots assessment due in year 4 of the permit term, including any planned or completed changes to local regulations and guidelines:

The Town plans to have this completed in Year 4 in compliance with the Permit.

Green Infrastructure Report

Describe the status of the green infrastructure report due in year 4 of the permit term, including the findings and progress towards making the practice allowable:

The Town plans to have this completed in Year 4 in compliance with the Permit.

Retrofit Properties Inventory

Describe the status of the inventory, due in year 4 of the permit term, of permittee-owned properties that could be modified or retrofitted with BMPs to mitigate impervious areas and report on any properties that have been modified or retrofitted:

The Town plans to have this completed in Year 4 in compliance with the Permit.

MCM6: Good Housekeeping

Catch Basin Cleaning

Describe the status of the catch basin cleaning optimization plan:

See additional information section below.

If complete, attach the catch basin cleaning optimization plan or the schedule to gather information to develop the optimization plan:

Town of Hopedale

- \bigcirc The catch basin cleaning optimization plan or schedule is attached to the email submission
- \bigcirc The catch basin cleaning optimization plan or schedule can be found at the following website:

Below, report on the number of catch basins inspected and cleaned, along with the total volume of material removed from the catch basins during this reporting period.

Number of catch basins inspected: 820

Number of catch basins cleaned: 820

Total volume or mass of material removed from all catch basins: 26,240 cubic feet

Below, report on the total number of catch basins in the MS4 system, if known.

Total number of catch basins: 820

If applicable:

Report on the actions taken if a catch basin sump is more than 50% full during two consecutive routine inspections/cleaning events:

Street Sweeping

Describe the status of the written procedures for sweeping streets and municipal-owned lots:

Written procedures for sweeping streets and municipal-owned parking lots will be completed in Year 2 in accordance with the Permit.

Report on street sweeping completed during the reporting period using one of the three metrics below.

• Number of miles cleaned: 101.7		
○ Volume of material removed:	[UNITS]	
○ Weight of material removed:	[UNITS]	

If applicable:

For rural uncurbed roadways with no catch basins, describe the progress of the inspection, documentation, and targeted sweeping plan:

The Town sweeps all Town roads, including rural uncurbed roadways at least 3 times per year.

Winter Road Maintenance

Describe the status of the written procedures for winter road maintenance including the storage of salt and sand:

The Town of Hopedale currently stores salt and sand at the Highway Department. A written procedure will be developed by June 30, 2020.

Inventory of Permittee-Owned Properties

Describe the status of the inventory, due in year 2 of the permit term, of permittee-owned properties, including parks and open spaces, buildings and facilities, and vehicles and equipment, and include any updates:

Inventory of Permittee-Owned Properties will be completed in Year 2 in accordance with the Permit.

O&M Procedures for Parks and Open Spaces, Buildings and Facilities, and Vehicles and Equipment

Describe the status of the operation and maintenance procedures, due in year 2 of the permit term, of permittee-owned properties (parks and open spaces, buildings and facilities, vehicles and equipment) and include maintenance activities associated with each:

The Town will complete O&M procedures for parks and open spaces, buildings and facilities, and vehicles and equipment in Year 2 in accordance with the Permit.

Stormwater Pollution Prevention Plan (SWPPP)

Describe the status of any SWPPP, due in year 2 of the permit term, for permittee-owned or operated facilities including maintenance garages, public works yards, transfer stations, and other waste handling facilities where pollutants are exposed to stormwater:

The Town will complete the required Stormwater Pollution Prevention Plans in Year 2 in accordance with the Permit.

Below, report on the number of site inspections for facilities that require a SWPPP completed during this reporting period.

Number of site inspections completed: 0

Describe any corrective actions taken at a facility with a SWPPP:

O&M Procedures for Stormwater Treatment Structures

Describe the status of the written procedure for stormwater treatment structure maintenance:

The O&M Procedure for Stormwater Treatment Structures will be completed in Year 2 in accordance with the permit.

Additional Information

Monitoring or Study Results

Results from any other stormwater or receiving water quality monitoring or studies conducted during the reporting period not otherwise mentioned above, where the data is being used to inform permit compliance or permit effectiveness must be attached.

- Not applicable
- The results from additional reports or studies are attached to the email submission
- \bigcirc The results from additional reports or studies can be found at the following website(s):

If such monitoring or studies were conducted on your behalf or if monitoring or studies conducted by other entities were reported to you, a brief description of the type of information gathered or received shall be described below:

Additional Information

Optional: Enter any additional information relevant to your stormwater management program implementation during the reporting period. Include any BMP modifications made by the MS4 if not already discussed above:

In Permit Year 2, the Town plans to begin collection requred metrics during catch basin cleaning so that a catch basin cleaning optimization plan can be developed to ensure that no sump is ever more than 50% full.

Activities Planned for Next Reporting Period

Please confirm that your SWMP has been, or will be, updated to comply with all applicable permit requirements including but not limited to the year 2 requirements summarized below. (Note: impaired waters and TMDL requirements are not listed below)

Yes, I agree 🛛

• Complete system mapping Phase I

Town of Hopedale

- Begin investigations of catchments associated with Problem Outfalls
- Develop or modify an ordinance or other regulatory mechanism for post-construction stormwater runoff from new development and redevelopment
- Establish and implement written procedures to require the submission of as-built drawings no later than two years after the completion of construction projects
- Develop, if not already developed, written operations and maintenance procedures
- Develop an inventory of all permittee owned facilities in the categories of parks and open space, buildings and facilities, and vehicles and equipment; review annually and update as necessary
- Establish a written program detailing the activities and procedures the permittee will implement so that the MS4 infrastructure is maintained in a timely manner
- Develop and implement a written SWPPP for maintenance garages, public works yards, transfer stations, and other waste handling facilities where pollutants are exposed to stormwater
- Enclose or cover storage piles of salt or piles containing salt used for deicing or other purposes
- Develop, if not already developed, written procedures for sweeping streets and municipal-owned lots
- Develop, if not already developed, written procedures for winter road maintenance including storage of salt and sand
- Develop, if not already developed, a schedule for catch basin cleaning
- Develop, if not already developed, a written procedure for stormwater treatment structure maintenance
- Develop a written catchment investigation procedure (18 months)

Annual Requirements

- Annual report submitted and available to the public
- Annual opportunity for public participation in review and implementation of SWMP
- Keep records relating to the permit available for 5 years and make available to the public
- Properly store and dispose of catch basin cleanings and street sweepings so they do not discharge to receiving waters
- Annual training to employees involved in IDDE program
- Update inventory of all known locations where SSOs have discharged to the MS4 in the last 5 years
- Continue public education and outreach program
- Update outfall and interconnection inventory and priority ranking and include data collected in connection with the dry weather screening and other relevant inspections conducted
- Implement IDDE program
- Review site plans of construction sites as part of the construction stormwater runoff control program
- Conduct site inspection of construction sites as necessary
- Inspect and maintain stormwater treatment structures
- Log catch basins cleaned or inspected
- Sweep all uncurbed streets at least annually

Provide any additional details on activities planned for permit year 2 below:

The Town will proceed on Year 2 activities once funds are allocated at the Fall 2019 Town Meeting. Hopedale will work with the goal of completing Year 1 tasks and Year 2 tasks during the Year 2 permit period.

Part V: Certification of Small MS4 Annual Report 2019

40 CFR 144.32(d) Certification

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. I certify that the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name:	Steven Sette	Title: Town Administrator
Signature:	Signatory may be a duly authorized representative	Date: 9/30/19

Year 2 Annual Report Massachusetts Small MS4 General Permit Reporting Period: July 1, 2019-June 30, 2020

Please DO NOT attach any documents to this form. Instead, attach all requested documents to an email when submitting the form

Unless otherwise noted, all fields are required to be filled out. If a field is left blank, it will be assumed the requirement or task has not been completed. Please ONLY report on activities between July 1, 2019 and June 30, 2020 unless otherwise requested.

Part I: Contact Information

Name of Municipality or Organization	on: Town of Hopedale	
EPA NPDES Permit Number: MAR	041123	

Primary MS4 Program Manager Contact Information

Name:	Christopher Nadeau			Title: H	Iighway	Departi	ment Director	
Street A	Street Address Line 1: 7 Depot Street							
Street A	Address Line 2: P.O. Box 7							
City:	Hopedale	State:	MA	Zip Code	e: 0174′	7		
Email:	cnadeau@hopedale-ma.gov			Phone	Number	r: 508-6.	34-2203 x221	

Stormwater Management Program (SWMP) Information

SWMP Location (web address):	https://www.hopedale-ma.gov/sites/g/files/vyhlif711/f/uploads/ ws_stormwater_management_plan_dec_2019_website_02192020.pdf
Date SWMP was Last Updated:	December 2019
If the SWMP is not available on	the web please provide the physical address:

Part II: Self-Assessment

First, in the box below, select the impairment(s) and/or TMDL(s) that are applicable to your MS4. Make sure you are referring to the most recent EPA approved Section 303(d) Impaired Waters List which can be found here: <u>https://www.epa.gov/tmdl/region-1-impaired-waters-and-303d-lists-state</u>

Impairment(<u>s)</u>			
	Bacteria/Pathogens	Chloride	🗌 Nitrogen	⊠ Phosphorus
	Solids/ Oil/ Grease (Hy	drocarbons)/ Metal	S	
TMDL(s)				
In State:	Assabet River Phospho	rus 🛛 🖾 Bacte	eria and Pathogen	Cape Cod Nitrogen
	\boxtimes Charles River Watershe	ed Phosphorus	Lake and Pond	Phosphorus
Out of State:	Bacteria/Pathogens	☐ Metals	🗌 Nitrogen	Phosphorus
			Cle	ar Impairments and TMDLs

Next, check off all requirements below that have been completed. **By checking each box you are certifying that you have completed that permit requirement fully.** If you have not completed a requirement leave the box unchecked. Additional information will be requested in later sections.

Year 2 Requirements

- Completed Phase I of system mapping
- Developed a written catchment investigation procedure and added the procedure to the SWMP
- Developed written procedures to require the submission of as-built drawings and ensure the long term operation and maintenance of completed construction sites and added these procedures to the SWMP
- Enclosed or covered storage piles of salt or piles containing salt used for deicing or other purposes
- Developed written operations and maintenance procedures for parks and open space, buildings and facilities, and vehicles and equipment and added these procedures to the SWMP
- Developed an inventory of all permittee owned facilities in the categories of parks and open space,
- ^{___} buildings and facilities, and vehicles and equipment and added this inventory to the SWMP
- Completed a written program for MS4 infrastructure maintenance to reduce the discharge of pollutants
 - Developed written SWPPPs, included in the SWMP, for all of the following permittee owned or
- operated facilities: maintenance garages, public works yards, transfer stations, and other waste handling facilities where pollutants are exposed to stormwater

Optional: If you would like to describe progress made on any incomplete requirements listed above, provide any additional information, and/or if any of the above year 2 requirements could not be completed due to the impacts of COVID-19, please identify the requirement that could not be completed, any actions taken to attempt to complete the requirement, and reason the requirement could not be completed below:

The Hopedale Notice of Intent (NOI) was submitted on May 3, 2019. With the reporting period for Year 1 tasks being May 1, 2018 through June 30, 2019, little time was left for the Town to complete the required Year 1 Tasks. Due to this, these Year 1 tasks have been pushed out to the Year 2 reporting period (July 1,

2019 through June 30, 2020). It is important to note that although behind, the Town of Hopedale is committed to completing Year 2 tasks.

The catchment investigation procedures were incorporated into the IDDE Plan, and are only referenced in the SWMP, as the IDDE Plan is a standalone document.

Annual Requirements

- \bowtie Provided an opportunity for public participation in review and implementation of SWMP and complied with State Public Notice requirements
- \boxtimes Kept records relating to the permit available for 5 years and made available to the public
- \Box The SSO inventory has been updated, including the status of mitigation and corrective measures implemented
 - \bigcirc This is not applicable because we do not have sanitary sewer
 - This is not applicable because we did not find any new SSOs
 - \bigcirc The updated SSO inventory is attached to the email submission
 - \bigcirc The updated SSO inventory can be found at the following website:
- Properly stored and disposed of catch basin cleanings and street sweepings so they did not discharge to receiving waters
- Provided training to employees involved in IDDE program within the reporting period
- \boxtimes All curbed roadways were swept at least once within the reporting period
- In Updated outfall and interconnection inventory and priority ranking as needed

Optional: If you would like to describe progress made on any incomplete requirements listed above, provide any additional information, and/or if any of the above annual requirements could not be completed due to the impacts of COVID-19, please identify the requirement that could not be completed, any actions taken to attempt to complete the requirement, and reason the requirement could not be completed below: Catch basin cleanings and street sweepings are properly stored at the Highway Department with hay bales enclosing the cleanings/sweepings to ensure that they do not discharge to receiving waters. The Town is exploring options on where their cleanings/sweepings can be brought and disposed of properly. By the end of the reporting period, the Town of Hopedale had completed approximately 70% of their catch basin inspections and cleanings by the end of October 2020.

Due to COVID-19, spring training for the IDDE program was not completed, as gatherings indoors were considered unsafe. The Town is committed to completing this annual task and will resume when gatherings are considered safe.

Bacteria/ **Pathogens** (Combination of Impaired Waters Requirements and TMDL Requirements as Applicable) Annual Requirements

Public Education and Outreach*

Annual message was distributed encouraging the proper management of pet waste, including noting any existing ordinances where appropriate

- Permittee or its agents disseminated educational material to dog owners at the time of issuance or renewal of dog license, or other appropriate time
- Provided information to owners of septic systems about proper maintenance in any catchment that discharges to a water body impaired for bacteria

* Public education messages can be combined with other public education requirements as applicable (see Appendix H and F for more information)

Optional: If you would like to describe progress made on any incomplete requirements listed above or provide any additional details, please use the box below:

Phosphorus (Combination of Impaired Waters Requirements and TMDL Requirements as Applicable)

Annual Requirements

Public Education and Outreach*

- Distributed an annual message in the spring (April/May) encouraging the proper use and disposal of grass clippings and encouraging the proper use of slow-release and phosphorus-free fertilizers
- Distributed an annual message in the summer (June/July) encouraging the proper management of pet waste, including noting any existing ordinances where appropriate
- Distributed an annual message in the fall (August/September/October) encouraging the proper disposal of leaf litter

* Public education messages can be combined with other public education requirements as applicable (see Appendix H and F for more information)

Good Housekeeping and Pollution Prevention for Permittee Owned Operations

Increased street sweeping frequency of all municipal owned streets and parking lots subject to Permit part 2.3.7.a.iii.(c) to a minimum of two times per year (spring and fall)

Potential structural BMPs

Any structural BMPs already existing or installed in the regulated area by the permittee or its agents α was tracked and the phosphorus removal by the BMP was estimated consistent with Attachment 3 to

- Appendix F. The BMP type, total area treated by the BMP, the design storage volume of the BMP and the estimated phosphorus removed in mass per year by the BMP were documented.
 - \bigcirc The BMP information is attached to the email submission
 - \bigcirc The BMP information can be found at the following website:

Optional: If you would like to describe progress made on any incomplete requirements listed above or provide any additional details, please use the box below:

The estimated phosphorus removal associated with existing BMPs has not yet been calculated. As the Town moves forward in developing their Phosphorus Control Plan, they will track and estimate the amount of phosphorus removed from existing BMPs, including reporting on BMP type, total area treated, design storage volume, and the estimated phosphorus removed in mass per year.

As stated above, because of group restrictions and over all concern of safety due to COVID-19, IDDE training has not been held. The Town is committed to this training and will organize a session when they are able to.

Charles River Watershed Phosphorus TMDL

Completed Legal Analysis

Optional: If you would like to describe progress made on any incomplete requirements listed above or provide any additional details, please use the box below:

The Charles River Watershed Phosphorus TMDL Legal Analysis is expected to be completed by June 30, 2021, when the Town of Hopedale focuses on Year 2 tasks.

Optional: Use the box below to provide any additional information you would like to share as part of your self-assessment:

As stated above, the Hopedale Notice of Intent (NOI) was submitted on May 3, 2019. With the reporting period for Year 1 tasks being May 1, 2018 through June 30, 2019, little time was left for the Town to complete the required Year 1 Tasks. Because of this, the Year 1 tasks were pushed out to the Year 2 reporting period (July 1, 2019 through June 30, 2020). It is important to note that although behind, the Town of Hopedale is committed to completing Year 2 tasks, as well as future years within the MS4 Permit. Below is a description of all tasks completed to date, along with what is planned for the next reporting period.

In September 2019, Weston & Sampson completed GPS survey work to update and modify current stormwater system mapping, which was included in the Town's Stormwater Management Plan (SWMP), which was completed in December of 2019. In June of 2020, Hopedale developed their IDDE Plan. The IDDE Plan includes procedures for screening and sampling outfalls and investigating catchments. Each catchment has been prioritized for future investigation. The Catchment Prioritization and Ranking is attached to the submission email.

A bylaw and accompanying rules and regulations for stormwater management have been drafted along with an IDDE Bylaw, but final drafts have not been approved. This is due to COVID-19 disrupting the finalization process. The Town is meeting October 7, 2020 to discuss next steps. Written procedures for site inspections, enforcement of sediment and erosion control measures and site plan review are included under these bylaws.

An implementation plan was created by Weston & Sampson for the Town of Hopedale to help manage the tasks and level of effort for the full MS4 permit period.

By the end of the reporting period, the Town of Hopedale had completed approximately 70% of their catch basin inspections and cleanings. The Town is expecting to complete all catch basin inspections and cleanings by the end of October 2020. Street Sweeping continues to occur at least 3 times a year - once in the fall and twice in the spring. The Town currently stockpiles the cleanings and sweepings at the Highway Department with hay bales enclosing the cleanings/sweepings to ensure that they do not discharge to receiving waters. Hopedale is currently exploring options on where they can bring their cleanings and sweepings to be properly disposed of.

The Town will continue to progress through Year 2 tasks this current reporting period.

The Town will continue public education initiatives for annual requirements for proper disposal of grass clippings and encourage proper use of slow-release and phosphorus-free fertilizers, proper management of pet

Town of Hopedale

waste, proper septic system maintenance, and proper disposal of leaf litter. The Town will be distributing their next annual message this October to encourage proper disposal of leaf litter. It is anticipated that either these will be posted on the Town's website, fliers will be distributed, or will be available in pamphlet from at Town Hall.

The Town of Hopedale will also review existing stormwater-regulatory mechanisms, and identify changes required to implement the Phosphorus Control Plan in its entirety. The Town plans to complete the legal analysis for the Phosphorus Control Plan by June 30, 2021.

Mapping updates will also be implemented to depict open channel conveyances, interconnections with neighboring MS4 communities, Town-owned stormwater treatment structures, refined catchment delineations, drainage infrastructure tributary to previously mapped outfalls, and establish connectivity of drainage structures.

Hopedale plans to develop written operation and maintenance (O&M) procedures for permitted-owned facilities and activities. This will include a complete inventory of municipal equipment, facilities and other Town-owned property. The Town plans to complete these O&M procedures by June 30, 2021. The Town will also develop a Catch Basin Optimization Plan to optimize cleaning to ensure that no catch basin sump is more than 50% full.

Stormwater pollution Prevention Plans (SWPPP) will be developed for the Highway Department Facility, the Wastewater Treatment Facility and the Water Treatment Facility by June 30, 2021.

Training for IDDE and for each SWPPP will be conducted for each at least once per reporting period.

Finally, the SWMP will be updated to reflect the status of activities completed during Year 2, such as regulatory updates implemented, good housekeeping/pollution prevention procedures developed for municipal activities and facilities, drainage mapping updates, new outfalls and/or interconnections identified along with receiving water and any associated impairments; and the legal analysis for authority to implement the Town's Phosphorus Control Plan.

Part III: Receiving Waters/Impaired Waters/TMDL

Have you made any changes to your lists of receiving waters, outfalls, or impairments since the NOI was submitted?

- Yes
- No

If yes, describe below, including any relevant impairments or TMDLs:

The Town has been actively working to locate and map drainage infrastructure. Changes will continue to be made to the list of receiving waters and outfalls as additional data is collected regarding outfall ownership, outfall drainage location, and drainage system configuration as part of a comprehensive drainage mapping effort. No new applicable impairments or TMDLs have been identified as part of this effort. The list of updated outfalls, receiving waters and impairments included in the Town's Stormwater Management Plan will reflect those changes.

The updates will continue to be incorporated into the Town's SWMP.

Part IV: Minimum Control Measures

Please fill out all of the metrics below. If applicable, include in the description who completed the task if completed by a third party.

MCM1: Public Education

Number of educational	messages comp	leted during this re	norting neriod 6
	i messages compi	totod during this re	por ung per iou.

Below, report on the educational messages completed **during this reporting period**. For the measurable goal(s) please describe the method/measures used to assess the overall effectiveness of the educational program.

BMP: Brochures/Pamphlets

Message Description and Distribution Method:

To encourage proper disposal of dog waste, signs have been placed throughout the town to inform dog owners to properly dispose of dog waste. There is also a message on the Board of Health's web page. In addition to this, two separate fliers are on the Town Website.

Targeted Audience: Residence/Dog Owners

Responsible Department/Parties: Board of Health

Measurable Goal(s):

Place signs in residential areas to inform the public on cleaning up after their dog. The signs and online information inform the public that dog waste can impact water quality.

Message Date(s): Year-Round

Message Completed for:	Appendix F Requirements 🖂	Appendix H Requirements 🖂
------------------------	---------------------------	---------------------------

Was this message different than what was propos	sed in your NOI?	Yes 🔿	No	۲
---	------------------	-------	----	---

If yes, describe why the change was made:

BMP:Brochures/Pamphlets

Message Description and Distribution Method:

To encourage proper septic system maintenance by septic system owners, a flyer was placed on the Town's web page under the stormwater tab.

Targeted Audience: Residents/Developers/Businesses/Commercial Facilities

Responsible Department/Parties: Board of Health

Measurable Goal(s):

To inform the public about septic system maintenance.

Town of Hopedale	Page 9
Message Date(s): Year-Round	
Message Completed for: Appendix F Requirements 🖂 Appendix H Requirements 🖂	
Was this message different than what was proposed in your NOI? Yes \odot No \bigcirc	
If yes, describe why the change was made:	
The NOI discusses distributing a flyer and recording the list of recipients. It was thought that Town's website, this information would be readily available to anyone wanting information o	if it was on the n septic systems.
BMP:Newspaper Articles/Press Releases/Meetings	
Information was included on the Town's website regarding Hopedale's stormwater management	ent program
specifically targeting residents and how they can impact stormwater and receiving water qual	ity.
Targeted Audience: Residents	
Responsible Department/Parties: Highway Department	
Measurable Goal(s):	
To inform the community, educational information regarding how stormwater can impact rec quality was placed on the Town's web page under the stormwater tab.	eiving water
Message Date(s): Year-Round	
Message Completed for: Appendix F Requirements 🖂 Appendix H Requirements 🗌	
Was this message different than what was proposed in your NOI? Yes • No	
If yes, describe why the change was made:	
The NOI discusses submitting an article for publication in the Town newspaper. It was thoug on the Town's website, this information would be readily available to the public at any time.	ht that if it was
PMD. Nowananan Antialas/Drass Dalaasas/Mastings	
Message Description and Distribution Method:	
Information was included on the Town's website regarding Hopedale's stormwater management	ent program
specifically targeting businesses, institutions. and commercial facilities and how they can im and receiving water quality.	pact stormwater
Targeted Audience: Businesses, institutions and commercial facilities	

Responsible Department/Parties: Highway Department

Measurable Goal(s):

To inform the community, educational information regarding how stormwater can impact receiving water quality was placed on the Town's web page under the stormwater tab.

Town of Hopedale Page 10
Message Date(s): Year Round
Message Completed for: Appendix F Requirements 🖂 Appendix H Requirements 🗌
Was this message different than what was proposed in your NOI? Yes \odot No \bigcirc
If yes, describe why the change was made:
The NOI discusses submitting an article for publication in the Town newspaper. It was thought that if it was on the Town's website, this information would be readily available to the public at any time.
BMP:Leaf Litter Flyer
Message Description and Distribution Method:
Information was provided to the community about proper disposal of leaf litter and the effects of proper disposal to help minimize contamination of stormwater runoff to protect water resources.
Targeted Audience: Residents
Responsible Department/Parties: Highway Department
Measurable Goal(s):
To inform the community, educational information regarding how improper leaf disposal can impact receiving water quality was placed on the Town's web page under the stormwater tab.
Message Date(s): October
Message Completed for: Appendix F Requirements 🖂 Appendix H Requirements 🖂
Was this message different than what was proposed in your NOI? Yes \bigcirc No \bigcirc
If yes, describe why the change was made:
BMP:Lawn and Garden Tips to Help Curb Stormwater Pollution
Message Description and Distribution Method:
Information was provided to the community on how to dispose of grass clippings as well as understanding fertilizers and the impacts to receiving waters these items can cause.
Targeted Audience: Residents
Responsible Department/Parties: Highway Department
Measurable Goal(s):

To promote awareness on grass clippings and fertilizer and the impacts to receiving waters.

I own of Hopedale	Page 11
Message Date(s): April/May	
Message Completed for: Appendix F Requirements 🖂 Appendix H Requirements 🖂	
Was this message different than what was proposed in your NOI? Yes \bigcirc No \bigcirc	
If yes, describe why the change was made:	

Add an Educational Message

MCM2: Public Participation

Describe the opportunity provided for public involvement in the development of the Stormwater Management Program (SWMP) **during this reporting period**:

The Stormwater Management Program (SWMP) was developed at the end of December of 2019 and was posted on the Town's web page for the public to read and provide comment.

Was this opportunity	y different than w	hat was proposed in	your NOI?	Yes O	No	(\bullet)
and the opportunity.		mar nue proposed m	Jem 1.01.		110	<u> </u>

Describe any other public involvement or participation opportunities conducted **during this reporting period**: The Town currently holds a Household Hazardous Waste Day every year. During this reporting period, the Household Hazardous Waste Day was held on October 26, 2019. This event allows residents to bring oil, gasoline, gasoline mixtures, auto batteries, pesticides, paint thinners, spent antifreeze, oil-based paints and stains, photo chemicals, pool chemicals, household chemicals, and aerosols to the Hopedale Recycling Center. The Town will continue to hold a Household Hazardous Waste Day. The Town works with a contracted waste hauler and the Board of Health to sponsor this program.

The Town also has its own recycling center that is open on Saturdays. The recycling center accepts grass clippings, leaves, brush, dismantled oil tanks, heaters, washing machines, dryers, air conditioners, propane tanks, swing sets, television sets and stereos.

MCM3: Illicit Discharge Detection and Elimination (IDDE)

Sanitary Sewer Overflows (SSOs)

Check off the box below if the statement is true.

 $\hfill\square$ This SSO section is NOT applicable because we DO NOT have sanitary sewer

Below, report on the number of SSOs identified in the MS4 system and removed during this reporting period.

Number of SSOs identified: 0

Number of SSOs removed: 0

MS4 System Mapping

Below, check all that apply.

The following elements of the Phase I map have been completed:

- \boxtimes Outfalls and receiving waters
- $\hfill \Box$ Open channel conveyances
- ☐ Interconnections
- Municipally-owned stormwater treatment structures
- \boxtimes Waterbodies identified by name and indication of all use impairments
- \boxtimes Initial catchment delineations

Optional: Describe any additional progress you made on your map during this reporting period or provide additional status information regarding your map:

During the reporting period, the Town developed an inventory of their outfalls, and updated their existing drainage mapping outfall locations as required in Year 1 of the Permit. The Town plans to meet the Year 2 mapping requirements this reporting period and will include the above requirements.

Screening of Outfalls/Interconnections

If conducted, please submit any outfall monitoring results from this reporting period. Outfall monitoring results should include the date, outfall/interconnection identifier, location, weather conditions at time of sampling, precipitation in previous 48 hours, field screening parameter results, and results from all analyses.

- \bigcirc The outfall screening data is attached to the email submission
- \bigcirc The outfall screening data can be found at the following website:

Below, report on the number of outfalls/interconnections screened during this reporting period.

Number of outfalls screened: 0

Catchment Investigations

If conducted, please submit all data collected during this reporting period as part of the dry and wet weather investigations. Also include the presence or absence of System Vulnerability Factors for each catchment.

- $\ensuremath{\textcircled{}}$ The catchment investigation data is attached to the email submission
- \bigcirc The catchment investigation data can be found at the following website:

Below, report on the number of catchment investigations completed during this reporting period.

Number of catchment investigations completed this reporting period: 0

Below, report on the percent of catchments investigated to date.

Optional: Provide any additional information for clarity regarding the catchment investigations below:

No catchment investigations were completed during this reporting period. The Town plans to complete catchment investigations this reporting period.

IDDE Progress

If illicit discharges were found, please submit a document describing work conducted over this reporting period, and cumulative to date, including location source; description of the discharge; method of discovery; date of discovery; and date of elimination, mitigation, or enforcement OR planned corrective measures and schedule of removal.

- \bigcirc The illicit discharge removal report is attached to the email submission
- \bigcirc The illicit discharge removal report can be found at the following website:

Below, report on the number of illicit discharges identified and removed, along with the volume of sewage removed **during this reporting period**.

Number of illicit discharges identified:	0	
Number of illicit discharges removed:	0	
Estimated volume of sewage removed:	0	gallons/day

Below, report on the total number of illicit discharges identified and removed to date. At a minimum, report on the number of illicit discharges identified and removed **since the effective date of the permit (July 1, 2018)**.

Total number of illicit discharges identified: 0

Total number of illicit discharges removed: 0

Optional: Provide any additional information for clarity regarding illicit discharges identified, removed, or planned to be removed below:

No illicit discharges were identified, removed or planned to be removed during this reporting period.

Employee Training

Describe the frequency and type of employee training conducted **during the reporting period**:

Because of COVID-19, no training has been conducted during this reporting period. Due to group restrictions and overall concerns of safety, training has not been held. The Town is committed to completing this task and will organize a session when it is safe to do so.

Below, report on the construction site plan reviews, inspections, and enforcement actions completed **during** *this reporting period*.

Number of site plan reviews completed: 0		
Number of inspections completed: 0		
Number of enforcement actions taken: 0		

Optional: Enter any additional information relevant to construction site plan reviews, inspections, and enforcement actions:

The Town developed a bylaw and accompanying rules and regulations which govern site inspections and enforcement of sediment and erosion control measures. The Bylaw has not been finalized and is in draft form. During the drafting period, the Town shut down due to COVID-19. The Town plans to revisit and finalize the Bylaw.

MCM5: Post-Construction Stormwater Management in New Development and Redevelopment

Ordinance or Regulatory Mechanism

Below, select the option that describes your ordinance or regulatory mechanism progress.

- \bigcirc Bylaw, ordinance, or regulations are updated and adopted consistent with permit requirements
- Bylaw, ordinance, or regulations are updated consistent with permit requirements but are not yet adopted
- $\bigcirc\,$ Bylaw, ordinance, or regulations have not been updated or adopted

As-built Drawings

Describe the measures the MS4 has utilized to require the submission of as-built drawings and ensure long term operation and maintenance of completed construction sites:

As shown above, Hopedale has updated their bylaws and regulations to be consistent with permit requirements, but have yet to be adopted. These bylaws and accompanying rules and regulations include the submission of as-built drawings and ensure long term operation and maintenance of completed construction sites.

Street Design and Parking Lots Report

Describe the status of the street design and parking lots assessment due in year 4 of the permit term, including any planned or completed changes to local regulations and guidelines:

The Town plans to have this completed in Year 5 in compliance with the Permit.

Green Infrastructure Report

Describe the status of the green infrastructure report due in year 4 of the permit term, including the findings and progress towards making the practice allowable:

The Town plans to have this completed in Year 5 in compliance with the Permit.

Retrofit Properties Inventory

Describe the status of the inventory, due in year 4 of the permit term, of permittee-owned properties that could be modified or retrofitted with BMPs to mitigate impervious areas and report on any properties that have been modified or retrofitted:

The Town plans to have this completed in Year 5 in compliance with the Permit.

MCM6: Good Housekeeping

Catch Basin Cleaning

Below, report on the number of catch basins inspected and cleaned, along with the total volume of material removed from the catch basins **during this reporting period**.

Number of catch basins inspected: 698

Number of catch basins cleaned: 698

Total volume or mass of material removed from all catch basins: 50 cubic yards

Below, report on the total number of catch basins in the MS4 system.

Total number of catch basins: 996

If applicable:

Report on the actions taken if a catch basin sump is more than 50% full during two consecutive routine inspections/cleaning events:

Street Sweeping

Report on street sweeping completed during this reporting period using one of the three metrics below.

[Select Units]

O&M Procedures and Inventory of Permittee-Owned Properties

Below, check all that apply.

The following permittee-owned properties have been inventoried:

Parks and open spaces

Buildings and facilities

○ Weight of material removed:

□ Vehicles and equipment

The following O&M procedures for permittee-owned properties have been completed:

Parks and open spaces

Buildings and facilities

Uvehicles and equipment

Stormwater Pollution Prevention Plan (SWPPP)

Below, report on the number of site inspections for facilities that require a SWPPP completed **during this** reporting period.

Number of site inspections completed: 0

Describe any corrective actions taken at a facility with a SWPPP:

No corrective actions were taken at facilities that require a SWPPP, as no SWPPPs were developed in Year 2. Required SWPPPs for municipal waste handling facilities will be developed in Year 3.

Additional Information

Monitoring or Study Results

Results from any other stormwater or receiving water quality monitoring or studies conducted during the reporting period not otherwise mentioned above, where the data is being used to inform permit compliance or permit effectiveness must be attached.

- Not applicable
- The results from additional reports or studies are attached to the email submission
- \bigcirc The results from additional reports or studies can be found at the following website(s):

If such monitoring or studies were conducted on your behalf or if monitoring or studies conducted by other entities were reported to you, a brief description of the type of information gathered or received shall be described below:

Additional Information

Optional: Enter any additional information relevant to your stormwater management program implementation during the reporting period. Include any BMP modifications made by the MS4 if not already discussed above:

COVID-19 Impacts

Optional: If any of the above year 2 requirements could not be completed due to the impacts of COVID-19, please identify the requirement that could not be completed, any actions taken to attempt to complete the requirement, and reason the requirement could not be completed below:

As stated in earlier sections of this annual report, the Town focused on completing all Year 1 tasks before moving on to Year 2 tasks. Unfortunately, COVID-19 has put a halt on the IDDE Training for this Reporting Period. A training session has not be able to be held due to the restrictions of gathering groups.

It should also be noted that the Town is in the process of enacting updated bylaws related to IDDE and Stormwater. COVID-19 unfortunately halted progress. The Town plans to adopt these bylaws by June 30, 2021.

Activities Planned for Next Reporting Period

Please confirm that your SWMP has been, or will be, updated to comply with all applicable permit requirements including but not limited to the year 3 requirements summarized below. (Note: impaired waters and TMDL requirements are not listed below)

Yes, I agree 🛛

- Inspect all outfalls/ interconnections (excluding Problem and Excluded outfalls) for the presence of dry weather flow
- Complete follow-up ranking as dry weather screening becomes available

Annual Requirements

- Annual report submitted and available to the public
- Annual opportunity for public participation in review and implementation of SWMP
- Keep records relating to the permit available for 5 years and make available to the public
- Properly store and dispose of catch basin cleanings and street sweepings so they do not discharge to receiving waters
- Annual training to employees involved in IDDE program
- Update inventory of all known locations where SSOs have discharged to the MS4
- Continue public education and outreach program
- Update outfall and interconnection inventory and priority ranking and include data collected in

- Implement IDDE program
- Review site plans of construction sites as part of the construction stormwater runoff control program
- Conduct site inspection of construction sites as necessary
- Inspect and maintain stormwater treatment structures
- Log catch basins cleaned or inspected
- Sweep all uncurbed streets at least annually
- Continue investigations of catchments associated with Problem Outfalls
- Review inventory of all permittee owned facilities in the categories of parks and open space, buildings and facilities, and vehicles and equipment; update if necessary

Provide any additional details on activities planned for permit year 3 below:

40 CFR 144.32(d) Certification

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, I certify that the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name:	Christopher Nadeau	Title: Highway Department Superintende
Signature	E: []////////////////////////////////////	Date: 9-29-2020
	representative]	

e.